

***PJM Generator Interconnection Request  
Queue #N35  
S. Reading-Birdsboro (Pioneer Landfill) 69kV  
Feasibility/Impact Study Report***

**September 2005  
#324667**

# **S. Reading-Birdsboro (Pioneer Landfill) 69kV (N35)**

## **Feasibility/Impact Study**

### **General**

G.A.S.-Access Pioneer Crossing Energy, LLC has proposed a project consisting of four 1600 kW Caterpillar G3520C generators (a fifth generator may be added in the future) to be installed at the Pioneer Crossing Landfill in Birdsboro, Berks County, Pennsylvania that will use landfill gas (methane) as fuel. The queue request was originally for nine – 1 MW units. This project has been assigned position N35 in the PJM Generation Interconnection Queue. The project is to be evaluated as a capacity resource. The proposed in-service date is December 31, 2005.

The intent of the feasibility / impact study is to determine system reinforcements and associated costs and construction time estimates required to facilitate the addition of the new generating plant to the transmission system. The reinforcements include the direct connection of the generator to the system and any network upgrades necessary to maintain the reliability of the transmission system.

### **Direct Connection**

The generators are to be connected to the Metropolitan Edison system by a tap to the existing 817 69 kV circuit (see Figure #1). The 817 line connects the South Reading and Birdsboro 69kV substations.

A 3-way, SCADA controlled switch and approximately 500 foot long line extension will be installed at the interconnecting point on the 817 69kV circuit and a direct transfer trip (DTT) scheme will be installed to trip the proposed generators whenever the South Reading and Birdsboro 817 69 kV substation breakers open. In addition, to accommodate the addition of the generators on the 817 69kV line the protective relays at the terminals need to be replaced.

The FE direct connection and system upgrade costs (excluding CIAC and taxes) are estimated as:

- South Reading Substation – Install DTT to Pioneer Crossing Substation: (Upgrade # n0452) **\$65,000**
- Birdsboro Substation – Install DTT to Pioneer Crossing Generation Substation: (Upgrade # n0453) **\$65,000**
- Replace relays on the Birdsboro terminal of the 817 69 kV line. (Upgrade #n0455) **\$70,000**
- 69 kV Trans. Tap – Install 3-way SCADA controlled motor operated switches (Upgrade #n0456) **\$215,000**

- 69 kV Trans. Tap – Install an estimated 500ft 69kV extension to the generation. **\$80,000**
- Pioneer Crossing Gen Sub – Substation, metering, SCADA & protection checkout: **\$15,000**

The total estimated cost for the direct connection facilities to be supplied by FirstEnergy/Jersey Central is estimated to be **\$510,000** and it is estimated that it will take 9 months to design and install the above facilities from the signing of an Interconnection or Construction Service Agreement.

## **Details of FirstEnergy Work**

### **South Reading:**

(1) RFL 9745 Teleprotection Channel. RFL Part No. “TSHK65500X”. 2 tone audio, 125 VDC, single I/O relay/solid state, test panel option. To be used for dual channel transfer trip from South Reading to Pioneer Crossing over a leased line telephone circuit.

### **Birdsboro:**

- (1) RFL 9745 Teleprotection Channel. RFL Part No. “TSHK65500X”. 2 tone audio, 125 VDC, single I/O relay/solid state, test panel option. To be used for dual channel transfer trip from Birdsboro to Pioneer Crossing over a leased line telephone circuit.
- (2) SEL 321-1 Phase, Ground Distance, and Directional Overcurrent Relay. Model # 321113256HGB3X4. To be used for primary line relay protection.
- (3) NXTPHASE Line Protection Relay. To be used for back-up line protection and reclosing. Model # 2100.
- (4) SEL 501 Overcurrent Relay. To be used for breaker failure.
- (5) Bitronics Multicom Meter. Model No. MTWIE1B-VD4A (Specify protocol compatible with SCADA).

### **The Interconnection Customer will be responsible for:**

Meeting all criteria as specified in the applicable sections of the FE “Requirements for Transmission Connected Facilities” document including and for providing the facilities listed below:

## **Pioneer Crossing**

- (2) RFL 9745 Teleprotection Channel. RFL Part No. "TSHK65500X". 2 tone audio, 125 VDC, single I/O relay/solid state, test panel option. To be used for dual channel transfer trip from South Reading and Birdsboro to Pioneer Crossing over a leased line telephone circuit. Devices to trip high side transformer breaker.
- Transformer 69 kV Terminal  
Install 3 Potential Transformers or CCVT's with dual secondary windings. Primary winding connected Grounded Wye.

Secondary winding X connected grounded wye to detect under-frequency, overfrequency, undervoltage and overvoltage conditions. Devices to trip high side transformer breaker after a time delay. A separate time delay is to be used for abnormal frequency tripping and abnormal voltage tripping.

Secondary winding Y connected Open Corner Delta for use as a ground detection scheme. Devices to trip high side transformer breaker.


- Purchase and installation of the 69 kV interconnection metering instrument transformer. FE will provide the ratio and accuracy specifications based upon the customer load and generation levels. FE will provide the meter socket for installation by the customer and will supply and install the meter.
- Supervisory control (RTU) and data acquisition (SCADA) equipment to provide information in a compatible format to the FE System Control Center.

Note: It will also be necessary to install a synchronizing relay on the generator breakers in order to parallel the generators with the FirstEnergy system.

## **Station Service**

This can be accomplished with a bi-directional meter and a separate contract with Met-Ed. If an additional interconnection is required for station service a separate Met-Ed contract subject to Reserve Capacity rate considerations would be needed.

**Figure #1**



**Network Impacts**

The #N35 project was studied as an injection of 9 MW into a tap of the Birdsboro – South Reading 69 kV circuit. Project #N35 was evaluated for compliance with reliability criteria for summer peak conditions in 2008. Potential network impacts were as follows:

**Generator Deliverability**

No identified problems

**Multiple Facility Contingency – Tower Line Outages**

No identified problems

**Contribution to Previously Identified Overloads**

None

**Short Circuit**

No identified problems

**Stability**

No analysis required

**New System Reinforcements**

None

**Contribution to Previously Identified System Reinforcements**

None

**Cost Allocation**

The N35 project is responsible for 100% of the cost of the attachment facilities estimated to be **\$95,000**. The N35 project is also responsible for 100% of the cost of the network upgrades estimated to cost **\$415,000**.