

#O11 Bustleton 11 MW
Generation Interconnection

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a Capacity Resource.

Network Impacts

The system, as planned, was evaluated for compliance with reliability criteria. **The O11 Bustleton project was studied as 7 MW Capacity interconnection to the Bustleton 13.8 kV bus.** The results are summarized below.

Normal System

No problems identified.

Generator Deliverability

Not required for an Energy Resource.

Local System Reliability Criteria

No problems identified.

Stability Analysis

Not applicable for a 7 MW generating station.

Short Circuit Analysis

No problems identified.

Network Upgrade Requirements

None.