

## #Q25 – Donegal-Iron City 138kV Generation Interconnection

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

### **Network Impacts**

The #Q25 project was studied as an 80 MW (16 MW of Capacity) resource into a tap of the Donegal-Iron City 138 kV line in the APS territory. Project #Q25 was evaluated for compliance with reliability criteria for summer peak conditions in 2011. Potential network impacts were as follows:

### **Generator Deliverability**

No problems were identified

### **Multiple Facility Contingency**

No problems were identified

### **Contribution to Previously Identified Overloads**

No problems were identified

### **New System Reinforcements**

None

### **Contribution to Previously Identified System Reinforcements**

To be determined at the System Impact Study

### **Short Circuit**

No overdutied breakers were identified.

Listed below are the positive and zero sequence source equivalent impedance at the Bullsken site with the GSU and generators OPEN.

Positive:  $(0.00897 + j0.05722)$

Zero:  $(0.05311 + j0.15955)$

### **Delivery of Energy Portion of interconnection Request**

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

As a result of the aggregate energy resources in the area, the following violations were identified:

No problems were identified.