

## **R13 Tidd-Canton Central 345kV Generation Interconnection**

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

### **Network Impacts**

#### **Option #1 Tidd-Canton Central 345kV circuit (AEP)**

The #R13 project was studied as a 350 MW of Capacity at two distinct points. The first interconnection option is a tap of the Tidd-Canton Central 345 kV line and the second option is into the Arroyo 138 kV substation. Project #R13 was evaluated for compliance with reliability criteria for summer peak conditions in 2011. Potential network impacts were as follows:

#### **Generator Deliverability**

No problems were identified

#### **Multiple Facility Contingency**

No problems were identified

#### **Short Circuit**

No problems identified.

#### **Contribution to Previously Identified Overloads**

None identified

#### **New System Reinforcements**

None

#### **Contribution to Previously Identified System Reinforcements**

None identified.

#### **Option #2 Arroyo 138kV substation (Allegheny Power)**

The #R13 project was studied as a 350 MW of Capacity at two distinct points. The first interconnection option is a tap of the Tidd-Canton Central 345 kV line and the second option is into the Arroyo 138 kV substation. Project #R13 was evaluated for compliance with reliability criteria for summer peak conditions in 2011. Potential network impacts were as follows:

#### **Generator Deliverability**

The following network impacts follow no gasification (i.e. 560 MW are delivered to the network), and interconnection into the Arroyo 138 kV substation:

1. The 138 kV line from Arroyo to Arroyo Junction loads from -6% to 151% of its normal rating (173 MVA). The R13 project contributes 272 MW to cause this thermal violation.

2. The Arroyo-Wylie Ridge 138 kV circuit loads from -39% to 122% of its normal rating (173 MVA). The R13 project contributes 278 MW to cause this thermal violation.
3. The Arroyo Junction-Wylie Ridge 138 kV circuit loads from -38% to 119% of its normal rating (173 MVA). The R13 project contributes 272 MW to cause this thermal violation.

### **Multiple Facility Contingency**

No problems were identified

### **Short Circuit**

No problems identified.

Listed below are the positive and zero sequence source equivalent impedance at Arroyo 138 kV with the GSU and generators OPEN.

Positive:  $(0.00474 + j0.02914)$

Zero:  $(0.02465 + j0.07687)$

### **Contribution to Previously Identified Overloads**

None identified

### **New System Reinforcements**

Reconductor two Wylie Ridge – Arroyo 138 kV circuits with Pecos ACSS TW or equivalent high temperature conductor. Due to the age of the circuits (50+ years), it is assumed that all structures will require replacement. The estimated cost for this work is **\$8,800,000 in 2011 dollars.**

Upgrade terminal equipment at Wylie Ridge substation to accommodate the new 138 kV circuit conductors. The estimated cost for this work is **\$1,500,000 in 2011 dollars.**

### **Contribution to Previously Identified System Reinforcements**

None identified.