

**R80 Possum Point 230-kV**  
**Generator Interconnection**

**Network Impacts**

The #R80 project proposes a 60 MW capacity uprate injecting at Possum Point in the Dominion territory. Project #R80 was evaluated for compliance with reliability criteria for summer peak conditions in 2011. Potential network impacts were as follows:

**Generator Deliverability**

No problems were identified

**Multiple Facility Contingency**

No problems were identified

**Contribution to Previously Identified Overloads**

No problems were identified

**New System Reinforcements**

None

**Contribution to Previously Identified System Reinforcements**

To be determined at the System Impact Study

**Short Circuit**

No problems were identified

**Additional Reactive Capability**

None