

**#R85 – Tanners Creek #1 138kV  
Generation Interconnection**

**This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.**

**Network Impacts**

The #R85 project was studied as a capacity increase of 5 MW at the Tanners Creek 138 kV substation. Project #R85 was evaluated for compliance with reliability criteria for summer peak conditions in 2007 to determine if Capacity Interconnection Rights can be granted. Potential network impacts were as follows:

**Generator Deliverability**

No problems identified

**Multiple Facility Contingency**

No problems identified

**Contribution to Previously Identified Overloads**

No problems were identified

**Short Circuit**

Not required, since there are no changes to the generating unit electrical characteristics.

**New System Reinforcements**

None

**Contribution to Previously Identified System Reinforcements**

None

.