

#T103 Sunbury 10 MW
Generator Interconnection

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM System as a Capacity Resource.

Network Impacts

Queue T103 was studied as a 10 MW Capacity injection at Sunbury 69 kV bus. Project T103 was evaluated for compliance with reliability criteria for summer peak conditions in 2012. Network impacts were as follows:

Generator Deliverability

No problems were identified

Multiple Facility Contingency

No problems were identified

Short Circuit

Not applicable, there is no change to generator and transformer impedance.

Stability Analysis

Not required, there are no changes to generator characteristics

Power Factor Design Requirements Compliance

Queue T102 Power Factor design capability meets or exceeds the dynamic range requirement of 0.95 lead to 0.90 lag. (or maintain grandfathered MVAR capability plus Unity to 0.90 lag power factor for new MWs if the generation request is less than 20 MW)

Contribution to Previously Identified Overloads

No problems were identified

New System Reinforcements

None

Contribution to Previously Identified System Reinforcements

None identified.