

***Revised
Generation Interconnection
Combined Feasibility/System Impact
Study Report***

For

***PJM Generation Interconnection Request
Queue Position V3-070***

J. Rinco 34.5kV

March 2010

Preface

The intent of the Combined Feasibility/System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation, if any, is included in the System Impact Study.

The Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs associated with them will be addressed when seeking an Interconnection Agreement as outlined below. Developer will also be responsible for providing and installing metering equipment in compliance with applicable PJM and Transmission Owner standards.

General

Garden Solar, LLC, the Interconnection Customer (IC), has proposed an 8.0 MW (3.04 MW capacity) solar powered generating facility. The facility will be located in Flemington, New Jersey.

Attachment facilities and local upgrades (if required) along with terms and conditions to interconnect V3-070 will be specified in a separate two party Interconnection Agreement (IA) between the Transmission Owner and the Interconnection Customer as this project is considered FERC non-jurisdictional per the PJM Open Access Transmission Tariff (OATT). From the transmission system perspective, no network impacts were identified as detailed below.

Results of PJM Analysis

Point of Interconnection

V3-070 will interconnect with the Jersey Central Power and Light distribution system as a tap of an existing 34.5 kV distribution circuit from the Buckeye substation.

Network Impacts

The queue V3-070 project was studied as an 8.0MW injection (3.04MW of which was capacity) into JCPL's system at the Buckeye 34.5kV substation. The project was studied on a combined feasibility-impact basis which utilizes an AC analysis, and incorporates all contingency types. Project V3-070 was evaluated for compliance with reliability criteria for summer peak conditions in 2014.

Potential network impacts were as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

No problems identified.

Multiple Facility Contingency

(Double Circuit Tower Line, Line with Failed Breaker and, Bus Fault contingencies for the Full energy output.

No problems identified.

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts," identified for earlier generation or transmission interconnection projects in the PJM Queue)

No problems identified.

Short Circuit

Not required.

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. "Network Impacts," initially caused by the addition of this project's generation)

None

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project.

None

Stability Analysis

Not required.

Potential Congestion due to Local Energy Deliverability

(PJM also studied the delivery of the energy portion of the surrounding generation. Any potential problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with Network Upgrades to eliminate the operational restriction at their discretion by submitting a Transmission Interconnection Request. Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full deliverability for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which analyzes all overload conditions associated with the identified overloaded element(s). As a result of the aggregate energy resources in the area, the following violations were identified:

No problems identified.

Results of First Energy Analysis

Connection Facilities

In compliance with the Regional Transmission Expansion Planning (RTEP) protocol, Garden Solar, L.L.C. has submitted a "Form of Generation Interconnection Feasibility Study Agreement" to PJM that identifies its plan to construct a Kuhl Road (V3-070) Generation Project comprised of photo-voltaic solar panels and inverters on two plots of land at 21 Kuhl Road in Flemington, New Jersey. The installed facilities will have a total capability of 8 MW with 3.04 MW of this output being recognized by PJM as capacity. The proposed in-service date for this Kuhl Road (V3-070) Project is June 1, 2011.

Based on a study performed by the Jersey Central Regional staff, it was determined that the output of the proposed Kuhl Road (V3-070) Project will be too large for a connection to the 4.8 kV Distribution Circuit #24071 that currently serves the proposed site. The output of the 8.0 MW Solar project represents 198% of the circuit egress on this line. It also exceeds the rated capacity of the Buckeye substation transformer feeding this facility by 200%. For this reason it was determined that the Kuhl Road (V3-070) Project must be connected to the 34.5 kV transmission system that crosses the project property.

The project will be studied as an 8.0 MW injection between pole numbers NJ15RTH and NJ16RTN of the East Flemington - Rocktown (Y727) 34.5 kV path. Both line and radial disconnect switches and a fuse will be needed at the point of attachment in addition to a circuit breaker and switch on the system side of the generator step-up transformer. Garden Solar, L.L.C. will be responsible for constructing all of the facilities on its side of the point of interconnection including the attachment line. A summary of the FE facilities required for the Kuhl Road (V3-070) Project Direct Connection and their cost estimate is shown on in the Attachments.

Power Flow Analysis

A Power Flow study was conducted to determine the reliability impact of the proposed Kuhl Road (V3-070) Project on the FE Transmission System. This study was completed using a 2014 summer peak load power flow that contains a detailed representation of the Jersey Central transmission networks in the area of the proposed Kuhl Road (V3-070) Project. The findings and the recommendations from this analysis are based on a contingency review that was performed to identify the facility loadings and/or voltage conditions that violate the ReliabilityFirst, PJM or FE Planning Criteria and are attributable to this project.

The results of the FE analysis show that there are no network upgrades required for the deliverability of the Kuhl Road (V3-070) Project generation to the Jersey Central transmission system. There also are no reinforcements defined for previous projects for which this project will have an impact.

Short Circuit and Dynamics Analysis

A short circuit analysis was conducted by PJM and confirmed by the FE Protection staff. This analysis showed that no FE circuit breaker will exceed its interrupting capability with the implementation of the Kuhl Road (V3-070) Project. Therefore no reinforcements will be required.

Stability studies will be conducted, if necessary, should this project proceed to the Facilities Study stage of the RTEP process.

System Protection Analysis

An analysis was conducted to assess the impact of the Kuhl Road (V3-070) Project on the system protection requirements in the area. The results of this review have identified the following:

Under the assumption that the Kuhl Road (V3-070) Project generation will not supply fault current to the Jersey Central transmission system, there will be no protection upgrades needed for the East Flemington - Rocktown (Y727) 34.5 kV line path. However, the Kuhl Road (V3-070) Project will be required to have two independent high-speed zones of protection to sense and clear faults on the interconnection transformer.

Fault current on the radial attachment line are listed below:

Three phase : 7,529 amperes
Line-to Ground: 4,601 amperes

Based on this information an S&C SMD-2C, 150E fuse, either standard or slow speed, will be required.

The cost estimate for the required FE system protection facilities is included in the Attachments.

Metering

Garden Solar, L.L.C. will be required to comply with all FE Revenue Metering Requirements for Generation Interconnection Customers. These FE requirements are detailed in the Attachments to this report.

Compliance Issues

Garden Solar, L.L.C. will be responsible for meeting all FE criteria as defined in the FE Requirements for Transmission Connected Facilities document. This includes the provision of a reactive power capability sufficient to maintain a composite power delivery for the facility at the interconnection point at a power factor between .95 leading (absorbing MVARs) and .90 lagging (producing MVARs). If this capability cannot be provided, a 3.9 MVAR capacitor must be installed at the Kuhl Road (V3-070) Project substation at Garden Solar, L.L.C. cost.

FE Facility Upgrades and Costs

The results of the FE analysis shows that no planning criteria violations are attributable to the addition of the Kuhl Road (V3-070) Project for the conditions studied. Therefore the conclusion is that no transmission or distribution reinforcements will be required to provide the requested service.

Garden Solar, L.L.C. Requirements

In addition to the FE facilities, Garden Solar, L.L.C. will also be responsible for meeting all criteria as specified in the applicable sections of the "FE Requirements for Transmission Connected Facilities" document including:

1. The purchase and installation of the minimum required FE generation interconnection relaying and control facilities. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
2. The purchase and installation of a 34.5 kV interconnection metering instrument transformer. FE will provide the ratio and accuracy specifications based on the customer load and generation levels.
3. The purchase and installation of a revenue class meter for the Kuhl Road (V3-070) interconnection to measure the power delivered in compliance with the FE standards.
4. A compliance with the FE and PJM generator power factor and voltage control requirements. However, the generators will need to supply their output at a unity power factor at the point of interconnection during normal conditions.
5. The execution of a back-up service agreement to serve the customer load supplied from the Kuhl Road 34.5 kV substation when the units are out-of-service. This assumes the intent of Garden Solar, L.L.C. is to net the generation with the station load.
6. Any complaints from other customers (e.g. flicker complaints) will have to be corrected by Garden Solar, L.L.C. Correction may include changing operation, reducing generation, disconnecting the generators from the Jersey Central system, or other measures.
7. The purchase and installation of supervisory control and data acquisition (SCADA) equipment to provide information in a compatible format to the FE Transmission System Control Center. The RTU, the communications channel and all related equipment will be furnished and maintained by the Garden Solar, L.L.C. The RTU must communicate with the FirstEnergy EMS via DNP 3.0 protocol.
8. The following status and metering points will be required:
 - a. Interconnection breaker position.
 - b. Generator real and reactive power output measured at the high-side of the generator step-up transformer.

- c. Generator voltage at the point of interconnection.
9. An installation of two independent high-speed zones of protection to sense and clear faults on the interconnection transformer.

The above requirements are in addition to any metering or other requirements imposed by PJM.

Summary

The connection of the Kuhl Road (V3-070) Project to the FE transmission system will require no network upgrades. Therefore Garden Solar, L.L.C. will only have a cost responsibility for the Direct Connection of the Kuhl Road (V3-070) Project to the Jersey Central transmission system. As shown the Attachments, the estimated cost of these facilities is \$185,000.

Based on the extent of the FE direct connection and system upgrades required to support this project, it is estimated that it will take one (1) year from the date of a fully executed Interconnection Construction Service Agreement to complete the upgrades required for the Kuhl Road (V3-070) Project. This includes the requirement for Garden Solar, L.L.C. to make a preliminary payment to FE that funds the first three months of engineering design that is related to the construction of the Direct Connection facilities. It further assumes that Garden Solar, L.L.C. will provide the property for the attachment facilities needed and any right-of-way properties needed. A further assumption is that there will be no environmental issues with any of the new properties associated with this project, that there will be no delays in acquiring the necessary permits for implementing the defined direct connection and network upgrades, and that PJM will allow all transmission system outages when requested.


Note that the FE findings were made from a conceptual review of this project. A more detailed review of the connection facilities and their cost will be identified in the Facilities Study. Further note that the cost estimate data contained in this document should be considered as only ballpark since it was produced without a detailed engineering review. The applicant will be responsible for the actual cost of construction. FE herein reserves the right to return to any issues in this document and, upon appropriate justification, request additional monies to complete any connections to the transmission system.

Attachment 1


Garden Solar LLC – Kuhl Road (V3-070) Project



Attachment 2 Local Transmission Overview



Attachment 3 Single Line



Attachment 4 Direct Connection Facilities

| Item | Connection Facilities | Cost |
|------|--|------------------|
| 1 | Construct approximately 300 feet of new 34.5kV line from a point between poles NJ15RTH and NJ16RTH on the Y727-2 34.5kV line (East Flemington-U.S. Bronze-Ringoes-Rocktown Road-Texas Eastern). | |
| 2 | Construct a new tap pole, switch pole on tap (single blade disconnects included in estimate), installation of load-break switches on poles NJ15RTH & NJ16RTN, necessary guying, etc., and a span of wire to a customer-owned meter pole beyond the switch pole | |
| 3 | Investigate environmental permitting as necessary due to wetland issues. Note that Garden Solar will be responsible for acquiring permits needed. " | |
| 4 | Install metering to be mounted on the customer owned pole. | |
| 5 | Miscellaneous Protection, Fuses, Metering, RTU, SCADA | |
| | | \$185,000 |

Attachment 5

FirstEnergy Revenue Metering Requirements for Generation Interconnection Customer

Interconnection Customer shall install, own, operate, test and maintain the necessary revenue quality Metering Equipment. This includes current transformers, voltage transformers, mounting structures, wiring, meters, communication circuits, and associated devices. The Metering Equipment must meet the specifications listed in the FirstEnergy and regional transmission organization (RTO) connection documents. The FirstEnergy “Requirements for Transmission Connected Facilities” are located at: <http://www.firstenergycorp.com/feconnect>

The Metering Equipment shall be located at the generation facility on the high voltage side of the generator step-up transformers or facility main step-up transformer and/or station service power transformers. Power flows to and from the facility shall be compensated to the Point of Interconnection.

FirstEnergy will provide revenue quality Metering Equipment for a station service power supply at a generation facility if the supply is from the local FirstEnergy distribution system.

The revenue quality Metering Equipment shall be capable of collecting and storing bidirectional billing data. The billing data shall be stored in intervals specified by FirstEnergy, typically fifteen minutes or thirty minutes. The Interconnection Customer must provide FirstEnergy with remote access to the billing data in the Metering Equipment via a dedicated voice-grade analog telephone circuit. The Interconnection Customer shall provide FirstEnergy with contact information for the person or persons responsible for meter programming and Metering Equipment maintenance.

The Interconnection Customer shall consult with FirstEnergy regarding the revenue quality metering system design and provide the following information:

- Facility one line and revenue metering installation drawings (schematics, wiring diagrams, etc.)
- Estimated power flows to and from the facility at all revenue metering points
- Current transformer and voltage transformer specifications, including manufacturer, type, nameplate drawings, and certified accuracy test reports
- Revenue meter specifications including manufacturer, type, model number, and accuracy
- Revenue meter program information including but not limited to billing data recorder channel assignments, recorder pulse weights (Ke), and read-only password for access to interval data by the FirstEnergy billing data collection system (MV-90)

- Revenue meter telephone number
- Revenue meter loss compensation data (if applicable)

The Interconnection Customer shall provide FirstEnergy with prior notification of any modifications at the facility that will affect the revenue meter measurements, including substation reconfigurations and meter program changes.

The revenue metering system at each location shall be tested for accuracy by the Interconnection Customer once every two years. The Interconnection Customer shall give reasonable notice to FirstEnergy of the time when the testing is scheduled so that FirstEnergy may have representatives present. FirstEnergy and the RTO shall have the right to audit the revenue metering equipment and/or related documents. The Interconnection Customer shall be given a reasonable period of time to comply with any requests associated with an audit.

***Generation Interconnection
Combined Feasibility/System Impact
Study Report***

For

***PJM Generation Interconnection Request
Queue Position V3-070***

J Rinco 34.5kV

January 2010

Preface

The intent of the Combined Feasibility/System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation, if any, is included in the System Impact Study.

The Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs associated with them will be addressed when seeking an Interconnection Agreement as outlined below. Developer will also be responsible for providing and installing metering equipment in compliance with applicable PJM and Transmission Owner standards.

General

Garden Solar, LLC, the Interconnection Customer (IC), has proposed an 8.0 MW (3.04 MW capacity) solar powered generating facility. The facility will be located in Flemington, New Jersey.

Attachment facilities and local upgrades (if required) along with terms and conditions to interconnect V3-070 will be specified in a separate two party Interconnection Agreement (IA) between the Transmission Owner and the Interconnection Customer as this project is considered FERC non-jurisdictional per the PJM Open Access Transmission Tariff (OATT). *From the transmission system perspective, no network impacts were identified as detailed below.*

Point of Interconnection

V3-070 will interconnect with the Jersey Central Power and Light distribution system as a tap of an existing 34.5 kV distribution circuit from the Buckeye substation.

Network Impacts

The queue V3-070 project was studied as an 8.0MW injection (3.04MW of which was capacity) into JCPL's system at the Buckeye 34.5kV substation. The project was studied on a combined feasibility-

impact basis which utilizes an AC analysis, and incorporates all contingency types. Project V3-070 was evaluated for compliance with reliability criteria for summer peak conditions in 2014.

Potential network impacts were as follows:

Generator Deliverability

*(Single or N-1 contingencies for the **Capacity** portion only of the interconnection)*

No problems identified.

Multiple Facility Contingency

*(Double Circuit Tower Line, Line with Failed Breaker and, Bus Fault contingencies for the **Full** energy output.*

No problems identified.

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. “Network Impacts”, identified for earlier generation or transmission interconnection projects in the PJM Queue)

No problems identified.

Short Circuit

Not required.

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. “Network Impacts,” initially caused by the addition of this project’s generation)

None

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project.

None

Stability Analysis

Not required.

Potential Congestion due to Local Energy Deliverability

(PJM also studied the delivery of the energy portion of the surrounding generation. Any potential problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with Network Upgrades to eliminate the operational restriction at their discretion by submitting a Transmission Interconnection Request. Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full deliverability for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which analyzes all overload conditions associated with the identified overloaded element(s). As a result of the aggregate energy resources in the area, the following violations were identified:

No problems identified.