

Generation Interconnection Feasibility Study Report Queue Position W1-021

The Interconnection Customer (IC) has proposed a 20 MWE (7.6 MWC) solar powered generating facility consisting of ground mounted fixed panel solar arrays to be located in Cumberland County, New Jersey. PJM studied W1-021 as a 20 MW injection into the Atlantic City Electric (ACE) system and evaluated the project for compliance with reliability criteria for summer peak conditions in 2014.

Point(s) of Interconnection

The IC has requested that W1-021 be evaluated as both a distribution system (Primary option) interconnection and as a transmission system (Secondary option) interconnection.

Primary Option

W1-021 will connect to the Newport and Roadstown 69/12kV substations as follows:

8.3 MWs will connect to a replacement of the T1 transformer at the Newport substation; 10 MWs will connect to a new transformer at the Newport substation; 1.7 MWs will connect to a replacement of the T1 transformer at the Roadstown substation.

Direct Connection Requirements

Transmission Owner Scope of Direct Connection Work

The scope of work and estimated costs for the direct connection facilities is as follows:

1. Newport Substation
 - a. Replace the existing T1 transformer. The estimated cost to perform this work is **\$1,509,000.**
 - b. Install a new transformer with feeder terminal. The estimated cost to perform this work is **\$2,559,000.**
 - c. Install two (2) new 12kV feeders approximately 9 miles in length from the Newport Substation to the generating site using PAC overhead cable. The estimated cost to perform this work is **\$7,200,000.**
 - d. Install a utility operated recloser with relaying and communication equipment for each feeder. The estimated cost to perform this work is **\$100,000.**
 - e. Install utility grade metering for each feeder. The estimated cost to perform this work is **\$40,000.**
 - f. Install SCADA to Control Center for each feeder. The estimated cost to perform this work is **\$20,000.**

Approximate subtotal for work at Newport substation: **\$11,428,000.**

2. Roadstown Substation

- a. Install one (1) new 12kV feeder approximately 9.9 miles in length from the Roadstown Substation to the generating site using PAC overhead cable. The estimated cost to perform this work is **\$3,960,000**.
- b. Install a new feeder terminal on T1. The estimated cost to perform this work is **\$322,000**.
- c. Install a utility operated recloser with relaying and communication equipment for the feeder. The estimated cost to perform this work is **\$50,000**.
- d. Install utility grade metering. The estimated cost to perform this work is **\$20,000**.
- e. Install SCADA to Control Center. The estimated cost to perform this work is **\$10,000**.

Approximate subtotal for work at Roadstown substation: **\$4,362,000**.

- 3. Perform Dynamic Study. The estimated cost to perform this work is **\$30,000**.
- 4. Perform system protection planning, engineering, and transfer trip work. Transfer trip to be installed in locations where a generator installation could be islandized with a minimum load that is less than 3 times the size of generator capacity. The estimated cost to perform this work is **\$20,000**.

The estimated cost to perform this work is **\$15,840,000** and will take an estimated **6 – 12 months** to complete after receipt of a fully executed Interconnection Service Agreement (ISA) and Interconnection Construction Service Agreement (CSA).

Note: the above cost does not include the Contribution in Aid of Construction (CIAC) tax.

Interconnection Customer Scope of Direct Connection Work

The Interconnection Customer (IC) assumes full responsibility for design and construction of all facilities associated with the W1-021 generating station. Site preparation including grading and an access road, as necessary, is assumed to be by the IC.

The IC will be required to install metering and telemetry equipment to provide revenue metering and real-time telemetry data to PJM. The requirements for this equipment are listed in Appendix 2, Section 8 of Attachment O to the PJM Tariff, as well as PJM Manuals 01 and 14D. Protective relaying and metering design and installation must comply with Atlantic City Electric’s Applicable Standards.

Transmission Network Impacts

Potential transmission network impacts are as follows:

Generator Deliverability

*(Single or N-1 contingencies for the **Capacity** portion only of the interconnection)*

None

Multiple Facility Contingency

(Double Circuit Tower Line, Line with Failed Breaker and, Bus Fault contingencies for the Full energy output.

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. “Network Impacts”, identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

Short Circuit

None

Stability Analysis

Not required due to project size.

Dynamic Analysis

A time based dynamic study will be completed during the System Impact Study phase of W1-021.

AC injection into the grid must follow a ramp up rate that does not negatively affect the distribution system. An inverter capable of dynamic VAR output with Droop and Time Delay settings will be required. Further study will be required to review the impact to the grid under all output scenarios and grid load profiles. The proposed project will be reviewed for protection and coordination issues and any other required upgrades will be identified in future studies.

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. “Network Impacts,” initially caused by the addition of this project’s generation)

None

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project.

None

Potential Congestion due to Local Energy Deliverability

(PJM also studied the delivery of the energy portion of the surrounding generation. Any potential problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with Network Upgrades to eliminate the operational restriction at their discretion by submitting a Transmission Interconnection Request. Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full deliverability for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which analyzes all overload conditions associated with the identified overloaded element(s). As a result of the aggregate energy resources in the area, the following violations were identified:

These are not required reliability upgrades.

1. The CRLS CR2-SHRMAN#2 69 kV line (from bus 228252 to bus 228226 ckt 1) loads from 48.86% to 65.01% (DC power flow) of its emergency rating (56 MVA) for the single line contingency ('FAIR-NEWP'). This project contributes approximately 9.0 MW to cause the thermal violation.
2. The FAIRTON-NEWPORT 69 kV line (from bus 228214 to bus 228219 ckt 1) loads from 51.72% to 69.31% (DC power flow) of its emergency rating (48 MVA) for the single line contingency ('CARLL-SHERM'). This project contributes approximately 8.44 MW to cause the thermal violation.

Secondary Option

W1-021 will connect to the Fairton 69kV substation.

Transmission Network Impacts

Potential transmission network impacts are as follows:

Generator Deliverability

*(Single or N-1 contingencies for the **Capacity** portion only of the interconnection)*

None

Multiple Facility Contingency

*(Double Circuit Tower Line, Line with Failed Breaker and, Bus Fault contingencies for the **Full** energy output.*

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

Short Circuit

None

Potential Congestion due to Local Energy Deliverability

(PJM also studied the delivery of the energy portion of the surrounding generation. Any potential problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with Network Upgrades to eliminate the operational restriction at their discretion by submitting a Transmission Interconnection Request. Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full deliverability for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which analyzes all overload conditions associated with the identified overloaded element(s). As a result of the aggregate energy resources in the area, the following violations were identified:

These are not required reliability upgrades.

1. The CRLS CR2-SHRMAN#2 69 kV line (from bus 228252 to bus 228226 ckt 1) loads from 48.86% to 65.01% (DC power flow) of its emergency rating (56 MVA) for the single line contingency ('FAIR-NEWP'). This project contributes approximately 9.0 MW to cause the thermal violation.
2. The FAIRTON-NEWPORT 69 kV line (from bus 228214 to bus 228219 ckt 1) loads from 51.72% to 69.31% (DC power flow) of its emergency rating (48 MVA) for the single line contingency ('CARLL-SHERM'). This project contributes approximately 8.44 MW to cause the thermal violation.