

This study was performed by MISO
prior to ATSI integration with PJM.

MISO Project Number	J124	County	Ashtabula
Point of Interconnection	Ashtabula 138 kV	State	OH
Summer Net Output (MW)	132	Control Area	FE
RESULTS	DPP		

Summer Off Peak

Limiting Element	Contingency	DF (%)	Rating (MVA)	Overload (%)	FCITC (MW)
N/A	N/A				

Summer Peak

Limiting Element	Contingency	DF (%)	Rating (MVA)	Overload (%)	FCITC (MW)
N/A	N/A				

*Constraints shown have a distribution factor above 5%. N/A indicates no constraints have been found based on the scope of the Feasibility Study.

MISO Project Number	J124	County	Ashtabula
Point of Interconnection	Elkem 138 kV substation	State	OH
Summer Net Output (MW)	132	Control Area	FE
RESULTS	DPP		

Summer Off Peak

Limiting Element	Contingency	DF (%)	Rating (MVA)	Overload (%)	FCITC (MW)
N/A	N/A				

Summer Peak

Limiting Element	Contingency	DF (%)	Rating (MVA)	Overload (%)	FCITC (MW)
N/A	N/A				

*Constraints shown have a distribution factor above 5%. N/A indicates no constraints have been found based on the scope of the Feasibility Study.