

***PJM Generator Interconnection  
W2-014 Richmond- 2 MW  
Feasibility/Impact Study***


**October 29, 2010**  
**Revised May 28, 2014**  
*Docs #618097*

## ***General***

Project W2-014 is an Exelon Generation Company, LLC request to increase the Capacity of Richmond Station by 2 MW (Summer net). W2-014 Capacity Interconnection Rights will increase from 96 MW to 98 MW (49 MW for each of 2 units). Richmond Station is located at 3901 N. Delaware Ave., Philadelphia, PA. W2-014 Capacity increase is currently available.

## ***Direct Connection Requirements***

Queue W2-014 is connected as shown on the one line diagram below (for clarity, not all facilities have been indicated).



### **Interconnection Customer Scope of Direct Connection Work**

Queue W2-014 Interconnection Customer is responsible for all work on the W2-014 side of the POI (Point of Interconnection).

### **PECO Energy Scope of Direct Connection work**

No PECO Energy Direct Connection work is required.

## ***Network Impacts***

Queue project W2-014 was studied as a(n) 2.0MW ( 2.0MW of which was Capacity) injection into the Richmond 230kV Substation bus. The project was studied on a combined feasibility-impact basis which utilizes an AC analysis, and incorporates all contingency types. Project W2-014 was evaluated for compliance with reliability criteria for summer peak conditions in 2014. Potential network impacts were as follows:

### **Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

No problems were identified

### **Multiple Facility Contingency**

*(Double Circuit Tower Line, Stuck breaker and Bus Fault for the full energy output)*

No problems were identified

### **Short Circuit Analysis**

Not required for the uprate, there are no changes to the Queue W2-014 generator or generator step-up transformer impedance.

### **Power Factor and Reactive Requirements**

The generator meets PJM tariff requirements for reactive power capabilities.

### **Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

None identified.

## **NETWORK UPGRADE REQUIREMENTS**

### **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. "Network Impacts", initially caused by the addition of this project generation)*

None identified.

**Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project.)*

None identified.

# **ATTACHMENT 1**

(Generator Reactive Capability Curve)

110 165 DIV. - 6 X 9 I"

GENERAL ELECTRIC COMPANY

M S T G (8-70)

ESTIMATED GENERATOR REACTIVE CAPABILITY CURVES  
ATB-2-POLE - 65889 KVA - 3600 RPM - 13800 VOLTS - .90 PF  
2757 ARM AMPS - 250 FLD VOLTS - 59 F INLET AIR - 0 FT ALT

