

This study was performed by MISO
prior to ATSI integration with PJM.

MISO Project Number	J164	County	Erie
Point of Interconnection #1	Beaver - Greenfield 138kV	State	OH
Summer Net Output	99 MW	Control Area	FE
Result	DPP		

Summer Off Peak

Monitored Element	Contingency	DF (%)	Rating (MVA)	Overload (%)	FCITC (MW)
n/a	n/a				

Summer Peak

Monitored Element	Contingency	DF (%)	Rating (MVA)	Overload (%)	FCITC (MW)
n/a	n/a				

*Constraints shown have a distribution factor above 5%. N/A indicates no constraints have been found based on the scope of the Feasibility Study.

MISO Project Number	J164	County	Erie
Point of Interconnection #2	Avery - Greenfield 138kV	State	OH
Summer Net Output	99 MW	Control Area	FE
Result	DPP		

Summer Off Peak

Monitored Element	Contingency	DF (%)	Rating (MVA)	Overload (%)	FCITC (MW)
n/a	n/a				

Summer Peak

Monitored Element	Contingency	DF (%)	Rating (MVA)	Overload (%)	FCITC (MW)
n/a	n/a				

*Constraints shown have a distribution factor above 5%. N/A indicates no constraints have been found based on the scope of the Feasibility Study.

MISO Project Number	J164	County	Erie
Point of Interconnection #3	Avery Substation 138kV	State	OH
Summer Net Output	99 MW	Control Area	FE
Result	DPP		

Summer Off Peak

Monitored Element	Contingency	DF (%)	Rating (MVA)	Overload (%)	FCITC (MW)
n/a	n/a				

Summer Peak

Monitored Element	Contingency	DF (%)	Rating (MVA)	Overload (%)	FCITC (MW)
n/a	n/a				

*Constraints shown have a distribution factor above 5%. N/A indicates no constraints have been found based on the scope of the Feasibility Study.