

***PJM Generation Interconnection
Queue W3-134
South Joliet 34.5kV
Feasibility/ System Impact Study***

640048v6
September 2011

Preface

The intent of this System Impact Study is to determine a plan, with cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

The PJM Reliability Planning Process utilizes PJM planning criteria, NERC Planning Standards, NERC Regional Council planning criteria, and the individual Transmission Owner FERC filed planning criteria. In all cases, PJM applies the most conservative of all applicable planning criteria when identifying reliability problems and determining the need for system upgrades on the PJM system. The application of the NERC Planning Standards is adapted to the specific needs of the PJM system.

In some instances an interconnection customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. All facilities required for interconnection of a generation interconnection project must be designed in compliance with the technical specifications (on PJM web site) for the appropriate Transmission Owner.

After the System Impact Study Agreement is executed and prior to execution of the Interconnection Service Agreement, an Interconnection Customer may modify its project to reduce the electrical output (MW) (in the case of a Generation Interconnection Request) of the proposed project by up to the larger of 20 percent of the capability considered in the System Impact Study or 50 MW.

The System Impact Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

General

The queue W3-134 project is proposing a hydro facility consisting of 2 – 5.4MW hydro turbines and has requested to be studied at 10.6MW Capacity injection into ComEd’s system at the South Joliet 34.5kV substation. The proposed in-service date is **December 31, 2012**.

Attachment Facilities

The proposed generation project will interconnect via a 34.5kV line 0957, fed from the TDC 409 South Joliet 34.5kV substation in Illinois (See **Figure 1** below). This interconnection would consist of a 34.5kV breaker, revenue metering, and SCADA/relaying upgrades at TDC 409 South Joliet 34.5kV substation.

The Interconnection Customer is responsible for constructing all of the facilities on the Interconnection Customer’s side of the Point of Interconnection. It will be the Interconnection Customer’s responsibility to obtain any right-of-way between the Collector Substation and the Interconnection Substation.

Revenue Metering and SCADA Requirements

For PJM: IC will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC’s generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

For ComEd: IC will be required to install equipment necessary to provide bi-directional Revenue Metering (KWH, KVARH) and real time data (KW, KVAR, circuit breaker status, and 34.5kV voltage) for IC’s generating Resource. See ComEd Applicable Standards available on the PJM website (“TO Standards”) – “Exelon Energy Delivery Interconnection Guidelines (Generators Greater than 2MVA and Less Than or Equal to 20 MVA)”.




Figure 1. Proposed Interconnection Single Line Diagram

Direct Connection Cost Estimate

The total preliminary cost estimate for Direct Connection work performed by ComEd is **\$257,500**. This estimate consists of:

Description	Direct Material	Indirect Material	Direct Labor	Indirect Labor	Total Cost
34kV transmission line tie-in (By ComEd)	\$60,000	\$2,500	\$125,000	\$70,000	\$257,500

This cost will be included in the IA between the developer and ComEd.

Non-Direct Connection Cost Estimate

The total preliminary cost estimate for Non-Direct Connection work performed by ComEd is **\$251,000**. This estimate consists of:

Description	Direct Material	Indirect Material	Direct Labor	Indirect Labor	Total Cost
Telemetry, SCADA, and Metering	\$119,000	\$7,000	\$66,000	\$59,000	\$251,000

This cost will be included in the IA between the developer and ComEd.

Loss Factor Charge

For the Brandon Road Lock and Dam, project W3-134, the Loss Factor was calculated to be 0.15% for the use of L0957. The Loss Factor is subject to periodic update as the system configuration changes in the future.

Network Impacts

Queue project W3-134 was studied as a 10.6MW Capacity injection into ComEd's system at the South Joliet 34.5kV substation. Project W3-134 was evaluated for compliance with reliability criteria for summer peak conditions in 2014. Potential network impacts were as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

No problems identified.

Multiple Facility Contingency

(Double Circuit Tower Line, Stuck breaker and Bus Fault contingencies for the full energy output)

No problems identified.

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. “Network Impacts”, identified for earlier generation or transmission interconnection projects in the PJM Queue)

No problems identified.

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. “Network Impacts”, initially caused by the addition of this project generation)

None.

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project.)

None.

Short Circuit

ComEd performed a short circuit study for this project at the distribution level and did not identify any issues. The maximum fault current at the Point of Interconnection is 8,539 Amps at 34kV with the generator in-service. However, the currently installed fuse 5749 may need replaced/ upgraded. This condition will be further evaluated by ComEd as part of the detailed engineering phase. The detailed engineering costs will be the responsibility of the Project Developer.

Potential Congestion due to Local Energy Deliverability

(PJM also studied the delivery of the energy portion of the surrounding generation. Any potential problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with Network Upgrades to eliminate the operational restriction at their discretion by submitting a Transmission Interconnection Request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full deliverability for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which analyzes all overload conditions associated with the identified overloaded element(s).

As a result of the aggregate energy resources in the area, there were no violations identified.