

This study was performed by MISO  
prior to ATSI integration with PJM.

MISO Project Number	J172	County	Mahoning
Point of Interconnection	ATSI Loweville 69kV	State	OH
Summer Net Output (MW)	3.2	Control Area	FE
Result	DPP	Fuel	Landfill Gas

Summer Off Peak

Monitored Element	Contingency	DF (%)	Rating (MVA)	Overload (%)	FCITC (MW)
N/A	N/A				

Summer Peak

Monitored Element	Contingency	DF (%)	Rating (MVA)	Overload (%)	FCITC (MW)
N/A	N/A				

\*Constraints reported in the Feasibility Study have a distribution factor above 5%. N/A indicates no constraints have been found based on the scope of the Feasibility Study.