

# ***Generation Interconnection Feasibility Study Report W4-054***

The Interconnection Customer (IC) has proposed a 12 MWE (4.6 MWC) solar powered generating facility consisting of ground mounted, fixed panel, solar photovoltaic arrays. The project is to be located in Williamstown, Gloucester County, New Jersey. PJM studied W4-054 as a 12 MW injection into the Atlantic City Electric (ACE) system at a tap of the Monroe-Winslow Alt Tap 69kV circuit. The project was evaluated for compliance with reliability criteria for summer peak conditions in 2014. The proposed in-service date, as stated in Attachment N, is May 1, 2012.

## **Point of Interconnection**

W4-054 will interconnect with the Atlantic City Electric transmission system at a new 69kV three (3)-breaker ring bus substation adjacent to the Monroe-Winslow Alt Tap 69kV circuit.

## **Direct Connection Requirements**

### **Transmission Owner Scope of Direct Connection Work**

The scope of work and estimated costs for the direct connection facilities is as follows:

#### **Substation Engineering Estimate:**

**Scope:** Construct a 69kV three-breaker ring bus substation cutting into 69kV Monroe to Winslow Alt. Tap line, inclusive of a terminal position for queue project

**Estimate:** \$3,450,000

**Construction Time:** 24 – 36 months

#### **Transmission Engineering Estimate:**

**Scope:** Install a self-supporting 69kV steel pole with a concrete foundation, motor operated disconnects and a short span to PHI substation

**Estimate:** \$125,000

**Construction Time:** 24 months.

Note: If location of generator is greater than 500 feet from substation, circuit breaker will be necessary.

Note: Additional costs upon further engineering review may result. Additionally, Contribution in Aid of Construction (CIAC) tax will be included upon further study.

### **Interconnection Customer Scope of Direct Connection Work**

The Interconnection Customer (IC) is responsible for all design and construction related activities on their side of the Point of Interconnection. Site preparation, including grading and an access road, as necessary, is assumed to be by the IC. Route selection, line design, and right-of-way acquisition of the direct connect facilities is not included in this report, and is the responsibility of the IC. The Interconnection Customer will be responsible for contributing to future O & M costs associated with the direct connect facilities.

Protective relaying and metering design and installation must comply with PHI's applicable standards. The IC is also required to provide revenue metering and real-time telemetering data to PJM in conformance with the requirements contained in PJM Manuals M-01 and M-14 and the PJM Tariff. PHI will require the capability to remotely trip the generator from its System Operations facility. The interconnected customer will grant its permission for PJM to send PHI all telemetry that the Interconnection Customer sends to PJM. The Interconnection Customer will be required to make provisions for a voice quality phone line within approximately 3 feet of each PHI metering position to facilitate remote interrogation and data collection.

### **Transmission Network Impacts**

Potential transmission network impacts are as follows:

#### **Generator Deliverability**

*(Single or N-1 contingencies for the **Capacity** portion only of the interconnection)*

None

#### **Multiple Facility Contingency**

*(Double Circuit Tower Line, Line with Failed Breaker and, Bus Fault contingencies for the **Full** energy output.*

None

#### **Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

None

#### **Short Circuit**

None

#### **Stability Analysis**

Not required due to project size.

**New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. “Network Impacts,” initially caused by the addition of this project’s generation)*

None

**Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project.*

None

**Potential Congestion due to Local Energy Deliverability**

*(PJM also studied the delivery of the energy portion of the surrounding generation. Any potential problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with Network Upgrades to eliminate the operational restriction at their discretion by submitting a Transmission Interconnection Request. Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full deliverability for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which analyzes all overload conditions associated with the identified overloaded element(s). As a result of the aggregate energy resources in the area, the following violations were identified:*

These are **not** required reliability upgrades.

None