

Generation Interconnection Feasibility Study Report W4-088

The Interconnection Customer (IC) has proposed a 10 MWE (3.8 MWC) solar powered generating facility consisting of ground mounted, fixed panel, solar photovoltaic arrays. The project is to be located in Salem County, New Jersey. PJM studied W4-088 as a 10 MW injection into the Atlantic City Electric (ACE) system at a tap of the Woodstown - Mannington Mills 69kV circuit. The project was evaluated for compliance with reliability criteria for summer peak conditions in 2014. The proposed in-service date, as stated in Attachment N, is May 1, 2012.

Point of Interconnection

W4-088 will interconnect with the Atlantic City Electric transmission system at a new 69kV three (3)-breaker ring bus substation adjacent to the Woodstown-Mannington Mills 69kV circuit.

Direct Connection Requirements

Transmission Owner Scope of Direct Connection Work

The scope of work and estimated costs for the direct connection facilities is as follows:

Substation Engineering Estimate:

Scope: Construct a 69kV three-breaker ring bus substation cutting into Woodstown – Mannington Mills 69kV line, inclusive of a terminal position for queue project

Estimate: \$3,450,000

Construction Time: 24 – 36 months

Transmission Engineering Estimate:

Scope: Install a self-supporting 69kV steel pole with a concrete foundation, motor operated disconnects and a short span to PHI substation

Estimate: \$125,000

Construction Time: 24 months.

Note: If location of generator is greater than 500 feet from substation, circuit breaker will be necessary

Additional costs upon further engineering review may result. Additionally, Contribution in Aid of Construction (CIAC) tax will be included upon further study.

Interconnection Customer Scope of Direct Connection Work

The Interconnection Customer (IC) is responsible for all design and construction related activities on their side of the Point of Interconnection. Site preparation, including grading and an access road, as necessary, is assumed to be by the IC. Route selection, line design, and right-of-way acquisition of the direct connect facilities is not included in this report, and is the responsibility of the IC. The Interconnection Customer will be responsible for contributing to future O & M costs associated with

the direct connect facilities.

Protective relaying and metering design and installation must comply with PHI's applicable standards. The IC is also required to provide revenue metering and real-time telemetering data to PJM in conformance with the requirements contained in PJM Manuals M-01 and M-14 and the PJM Tariff. PHI will require the capability to remotely trip the generator from its System Operations facility. The interconnected customer will grant its permission for PJM to send PHI all telemetry that the Interconnection Customer sends to PJM. The Interconnection Customer will be required to make provisions for a voice quality phone line within approximately 3 feet of each PHI metering position to facilitate remote interrogation and data collection.

Transmission Network Impacts

Potential transmission network impacts are as follows:

Generator Deliverability

*(Single or N-1 contingencies for the **Capacity** portion only of the interconnection)*

1. (AE) The W3-163TAP-Clayton 69 kV line (from bus 904820 to bus 228405 ckt 1) loads from 99.97% to 101.33% (DC power flow) of its emergency rating (54 MVA) for the single contingency 'MICK-BRIDG'. This project contributes approximately 0.73 MW to the thermal violation.

Multiple Facility Contingency

*(Double Circuit Tower Line, Line with Failed Breaker and, Bus Fault contingencies for the **Full** energy output.*

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

1. (AE) The W3-163TAP-Clayton 69 kV line (from bus 904820 to bus 228405 ckt 1) loads from 211.86% to 215.77% (DC power flow) of its emergency rating (54 MVA) for the tower contingency 'AE12TOWER'. This project contributes approximately 2.11 MW to the thermal violation.
2. (AE) The Woodstown #1-W3-163TAP 69 kV line (from bus 228332 to bus 904820 ckt 1) loads from 156.17% to 160.09% (DC power flow) of its emergency rating (54 MVA) for the tower contingency 'AE12TOWER'. This project contributes approximately 2.11 MW to the thermal violation.

Short Circuit

None. Any other costs determined by system protection as a result of the short circuit studies will be supplied in the near future.

Stability Analysis

Not required due to project size.

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. "Network Impacts," initially caused by the addition of this project's generation)

1. To mitigate the Woodstown-W3-163Tap-Clayton 69kV line overload will require the reconductoring of the circuit from the intersection of Route 77 and the Woodstown-Clayton 69 kV line (proposed location of connection of W3-163) to the Clayton substation, a distance of 9.5 miles, with 795 ACSR. The estimated cost to perform this work is **\$3,300,000** and will take **18 to 24 months** to complete.

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project.)

1. To mitigate the Woodstown-W3-163Tap-Clayton 69kV line overload will require the reconductoring of the circuit from the intersection of Route 77 and the Woodstown-Clayton 69 kV line (proposed location of connection of W3-163) to the Clayton substation, a distance of 9.5 miles, with 795 ACSR. The estimated cost to perform this work is **\$3,300,000** and will take **18 to 24 months** to complete.
2. See item 1 above for reinforcement.

Potential Congestion due to Local Energy Deliverability

(PJM also studied the delivery of the energy portion of the surrounding generation. Any potential problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with Network Upgrades to eliminate the operational restriction at their discretion by submitting a Transmission Interconnection Request. Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full deliverability for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which analyzes all overload conditions associated with the identified overloaded element(s). As a result of the aggregate energy resources in the area, the following violations were identified:

These are *not* required reliability upgrades.

1. (AE) The W3-163TAP-Clayton 69 kV line (from bus 904820 to bus 228405 ckt 1) loads from 181.94% to 185.52% (DC power flow) of its emergency rating (54 MVA) for the operational contingency 'MICK-BRIDG'. This project contributes approximately 1.93 MW to the thermal violation.
2. (AE) The W3-163TAP-Clayton 69 kV line (from bus 904820 to bus 228405 ckt 1) loads from 189.31% to 193.6% (DC power flow) of its normal rating (44 MVA) for non contingency condition. This project contributes approximately 1.88 MW to the thermal violation.
3. (AE) The W3-018TAP1-Deepwater 69 kV line (from bus 903370 to bus 228323 ckt 1) loads from 110.84% to 115.15% (DC power flow) of its emergency rating (72 MVA) for the operational contingency 'CLAY-WOOD_W3-163B'. This project contributes approximately 3.10 MW to the thermal violation.
4. (AE) The Woodstown #1-W3-163TAP 69 kV line (from bus 228332 to bus 904820 ckt 1) loads from 129.79% to 133.53% (DC power flow) of its emergency rating (54 MVA) for the operational contingency 'CARLL-SHERM'. This project contributes approximately 2.02 MW to the thermal violation.
5. (AE) The Woodstown #1-W3-163TAP 69 kV line (from bus 228332 to bus 904820 ckt 1) loads from 122.88% to 127.17% (DC power flow) of its normal rating (44 MVA) for non contingency condition. This project contributes approximately 1.88 MW to the thermal violation.
6. (AE) The Woodstown-Woodstown #1 69 kV line (from bus 228360 to bus 228332 ckt 1) loads from 141.14% to 147.14% (DC power flow) of its emergency rating (74 MVA) for the operational contingency 'USLC-SM_V4-036B_WITH_W1-085B'. This project contributes approximately 4.44 MW to the thermal violation.