

***Generation Interconnection
Combined Feasibility/System Impact
Study Report***

For

***PJM Generation Interconnection Request
Queue Position X1-047***

Delaware City 69kV

September 2011

Preface

The intent of the Combined Feasibility/System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the System Impact Study is performed.

Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer may be responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

General

Delaware City Refining Company LLC, the Interconnection Customer (IC), has proposed a reconfiguration of their existing generating units (TG1, TG2, TG3, TG4, G6, and G7) contained at their facility located in Delaware City, Delaware. Queue project X1-047 requests TG1 (27 MWs) and TG2 (13 MWs) be evaluated as Capacity resources. These units were previously operated as “behind the meter”. The configuration of TG3 and TG4 remains unchanged. Additionally, the IC is reducing Capacity Injection Rights CIRs for units G6 (down to 43 MWs) and G7 (down to 43 MWs). PJM evaluated the impact of the proposed changes at the Delmarva Power and Light’s (DPL) Reybold 138kV substation. The project was evaluated for compliance with reliability criteria for summer peak conditions in 2015.

Point of Interconnection

The units are interconnected with the Delmarva Power and Light Company transmission system as shown in Attachment 1.

Direct Connection Requirements

Transmission Owner Scope of Direct Connection Work

The scope of work and estimated costs for the direct connection facilities is as follows:

There are no new or additional Direct Connection requirements for project X1-047.

Interconnection Customer Scope of Direct Connection Work

The Interconnection Customer (IC) is responsible for all design and construction related activities on their side of the Point of Interconnection.

Protective relaying and metering design and installation must comply with PHI's applicable standards. The IC is also required to provide revenue metering and real-time telemetering data to PJM in conformance with the requirements contained in PJM Manuals M-01 and M-14 and the PJM Tariff.

While the project was modeled with the split designation of "behind the meter/in front of the meter" (BTM/IFM) status for units TG2, G6, and G7 as proposed; the level of metering indicated on the study data diagram does not appear to be sufficient to support such a configuration. Metering adequacy evaluations will be performed during the Facilities Study.

Special Operating Requirements

1. The Company will require the capability to remotely trip the generator from its System Operations facility. Such tripping may be facilitated by either a generator breaker, inverter (if so equipped), or a line recloser, depending upon the specific circumstances and the evaluation of the Company.
2. The Interconnection Customer will grant its permission to PJM for PJM to send the Company the following telemetry data that the Interconnection Customer sends to PJM: real time megawatts, megavars, volts, amperes and status, and interval megawatt-hours, and megavar-hours. For generation larger than 10 MW, a direct telemetry connection to PHI System Operations will be required via a radial connection to PHI's telecommunications system or a rented data circuit, at the Interconnection Customer's cost.
3. The Interconnection Customer will be required to make provisions for a voice quality phone line within approximately 3 feet of each Company metering position to facilitate remote interrogation and data collection.
4. A mutually acceptable means of interrupting and disconnecting the generator with a visible break, able to be tagged and locked out, shall be worked out with PHI Engineering.

Transmission Network Impacts

Potential transmission network impacts are as follows:

Generator Deliverability

*(Single or N-1 contingencies for the **Capacity** portion only of the interconnection)*

None

Multiple Facility Contingency

(Double Circuit Tower Line, Line with Failed Breaker and, Bus Fault contingencies for the Full energy output.

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. “Network Impacts”, identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

Short Circuit

No problems identified.

Stability Analysis

Not required.

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. “Network Impacts,” initially caused by the addition of this project’s generation)

None


Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project.

None

Attachment 1

X1-047 Reybold 138kV



7/27/2011