

***Generation Interconnection
Feasibility Study Report***

For

***PJM Generation Interconnection Request
Queue Position Y1-084***

East Newton-Blairstown 34.5kV

July 2012

Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

General

The Interconnection Customer (IC), has proposed a solar generating facility located in Fredon, New Jersey. The installed facilities will have a total capability of 1.99 MW with 0.76 MW of this output being recognized by PJM as capacity. This means that the remaining 1.23 MW will be curtailable should a system reliability constraint occur.

Point of Interconnection

Y1-084 will interconnect with the Jersey Central Power & Light system at one of two options. Option 1 is to connect at the 34.5kV line between the East Newton and Blairstown substations. Option 2 is to connect at a 4.8kV circuit from the North Newton substation

Cost Summary

The Y1-084 project will be responsible for the following costs:

Description	Total Cost
Connection facilities	\$ 500,100
Transmission upgrades	\$ 0
Total Costs	\$ 500,100

Transmission Owner Scope of Work

Primary Point of Interconnection

As defined by the Interconnection Customer and shown on Attachment 1, the proposed tapped connection point for the Y1-084 project will be located west of the East Newton substation. From this point FE will extend a radial tap approximately 1200 feet. The point of interconnection (POI) will be at the first pole installed by the Interconnection Customer, and FirstEnergy will provide one span of conductor from that POI pole. Both line and radial disconnect switches will be needed at the tap point in addition to a circuit breaker and switch on the system side of the generator step-up transformer. Attachment 2 shows a conceptual one-line diagram of the Direct Connection facilities that will be required for the Y1-084 project.

The scope of work includes:

- Construct approximately 1200 feet of new 34.5kV line M715-1 34.5kV line (Blairstown-East Newton) to the Y1-084 project.
- Includes replacing and rebuilding an existing pole, a set of disconnect switches between the tap pole and the 1st pole, the replacement of two poles and the installation of supervisory-controlled, motor-operated, load-break switches on those two poles, replacement of existing utility poles, all necessary distribution work, guying, etc., and a span of wire to a customer-owned pole.
- A review of this location in the NJDEP IMAP database shows that there is a Category 1 waterway that is within 300 feet of the proposed pole replacement and a wetland complex adjacent to the tap point. The proposed work in this area can be completed utilizing our Best Management Practices and our 5-Year Multi-Permit as long as the conditions of the permit are followed. A U.S. Fish & Wildlife Service (USFWS) Threatened and Endangered (T&E) Species Section 7 Review of this work location will need to be conducted. It would require at least a 6 month lead-time prior to construction to obtain Section 7 Review as well as arrange Federal T&E survey(s), if applicable. The widening of the ROW along the route will be required to upgrade the distribution line in the area of the Category 1 stream and wetland complex. NJDEP land use permits will be required. It is not known at this time whether mitigation would be required. The estimated cost for this review, etc., could be up to \$100,000 (Assumes no protective mats or special vehicles needed to access pole(s) in wetlands. If matting or special vehicles are required additional costs will be incurred.) The USFWS Section 7 Review could also trigger other restrictions or protective measures/precautions as being required.
- Estimate includes \$25,000 for metering to be mounted in customer substation.
- Miscellaneous Protection, Fuses, Metering, RTU, SCADA

Total cost estimate for this work is **\$500,100**. The does not include the CIAC (Contribution in Aid of Construction) Tax Gross-up charge of \$159,900.

Secondary Point of Interconnection

The sensitivity analysis performed by FirstEnergy on the Secondary Point of Interconnection found that this interconnection was not feasible. Jersey Central Power & Light limits connections to 4.8kV circuits to a 1 MW maximum.

Interconnection Customer Scope of Work

The Interconnection Customer will be responsible for constructing all of the facilities on its side of the point of interconnection including the attachment line.

Requirements

The Interconnection Customer will be responsible for the following:

- Install minimum required FE generation interconnection relaying and control facilities. This includes the installation of intertie relays at the point of interconnection that either trip the breaker at the point of interconnection or the individual generators beyond the point of interconnection. The function of the intertie relays must include over/under voltage and over/under frequency protection. Note that these intertie relays are in addition to and must be separate from the two relays that provide independent high speed zone of protection to sense and clear faults. They include the installation of an SEL-351-7 (Version 7) relay or its equivalent for power elements, a potential transformer or CCVT's on the high side of the transformer, and current transformers on the high side of the transformer.
- Install two independent high-speed zones of protection to sense and clear faults on the interconnection transformer

Fault currents at the POI are listed below.

	THREE-PHASE	SINGLE-LINE
X/R	3.2	3.8
Fault Current (Amps)	5813	2399

- Install a S&C SMD-1A 40E standard fuse on the tapped connection
- Ensure the necessary generator protection, synchronization controls, and fault detection are in place to initiate a trip to protect the Y1-084 Project equipment from faults on the Jersey Central System.
- Install standard voice grade (analog) telephone line and associated conduit between the telephone company source and the meter socket or enclosure.
- Install supervisory control and data acquisition (SCADA) equipment to provide information in a compatible format to the FE Transmission System Control Center. The RTU, the communications channel and all related equipment will be furnished and maintained by the Interconnection Customer. The RTU must communicate with the FirstEnergy EMS via DNP 3.0 protocol.

The following status, control and metering points will be required:

- Interconnection breaker position status and trip control.
 - Generator real and reactive power output measured at the high-side of the generator step-up transformer.
 - Generator voltage at the point of interconnection.
- Execute a back-up service agreement to serve the customer load supplied from the Interconnection Customer 34.5 kV substation when the units are out-of-service. This assumes the intent of the Interconnection Customer is to net the generation with the station load.
 - Meet all criteria specified in the applicable FirstEnergy standards:
 - FE Requirements for Transmission Connected Facilities
 - Technical Requirements for the Interconnection of Parallel-Operated Generation to the FirstEnergy Distribution System
 - FirstEnergy Wholesale Generation Interconnection (WGI) Manual
 - FE Approved Vendors and Contractors

These documents can be found on the FirstEnergy or PJM websites:

- <http://www.firstenergycorp.com/feconnect>
 - <http://www.pjm.com/planning/design-engineering/to-tech-standards.aspx>
- Acquiring all permits and right of way that may be needed.
 - Comply with the inverter standard UL1741 and IEEE 1547, “Standard for Interconnecting Distributed resources with Electrical Power Systems”

Notes:

- The Interconnection Customer will not excavate, construct facilities or locate solar panels under the existing FE transmission facilities or on FE right-of-ways without the express permission of FE.

Schedule

Based on the extent of the FE direct connection and system upgrades required to support this project, it is estimated that it will take eighteen (18) months from the date of a fully executed Interconnection Agreement (IA) to complete the upgrades required for the Y1-084 Project.

Revenue Metering and SCADA Requirements

PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

FirstEnergy Requirements

The Interconnection Customer will be required to comply with all FE Revenue Metering Requirements for Generation Interconnection Customers. The Revenue Metering Requirements may be found within the "FirstEnergy Requirements for Transmission Connected Facilities" document located at the following links:

<http://www.firstenergycorp.com/feconnect>

<http://www.pjm.com/planning/design-engineering/to-tech-standards.aspx>

Network Impacts

Option 1:

The Queue Project #Y1-084 was studied as a 2.0MW (Capacity 0.8MW) injection as a tap of the East Newton - Blairstown 34.5 kV line in the JCPL area. Project #Y1-084 was evaluated for compliance with reliability criteria for summer peak conditions in 2015. Potential network impacts were as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

The FE study results show that with the twenty-one solar projects at their Capacity output the Newton - Mohawk (Z702) 34.5 kV line section could load up to 123.5% of its emergency rating of 27 MVA upon loss of the Newton - Montville (N2214) 230 kV line.

Multiple Facility Contingency

(Double Circuit Tower Line contingencies were studied for the full energy output. The contingencies of Line with Failed Breaker and Bus Fault will be performed for the Impact Study.)

None.

Short Circuit

(Summary of impacted circuit breakers)

None.

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None.

Steady-State Voltage Requirements

(Summary of the VAR requirements based upon the results of the steady-state voltage studies)

None.

Stability and Reactive Power Requirement for Low Voltage Ride Through

(Summary of the VAR requirements based upon the results of the dynamic studies)

The Y1-084 will be required to maintain a composite power delivery for the facility at the interconnection point at a power factor between .95 leading (absorbing 0.65 MVAR) and .95 lagging (producing 0.65 MVAR) at the point of connection. If this capability cannot be provided by the solar units, a dynamic device such as a STATCOM or SVC must be installed at the Y1-055 Project substation at the Interconnection Customer's cost.

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

The overload on the Newton - Mohawk (Z702) 34.5 kV line section is a pre-existing violation, FirstEnergy will be responsible for the necessary upgrade. The Y1-084 project will not have any cost responsibility for the upgrade. The upgrade is expected to be completed by the summer of 2013.

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

None

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

The FE study results show that with the twenty-one solar projects at their full energy output the Newton - Mohawk (Z702) 34.5 kV line section could load up to 134.3% of its emergency rating of 27 MVA upon loss of the Newton - Montville (N2214) 230 kV line.

Option 2:

The Queue Project #Y1-084 was studied as a 2.0MW (Capacity 0.8MW) injection at the North Newton 34.5 kV substation in the JCPL area. Project #Y1-084 was evaluated for compliance with reliability criteria for summer peak conditions in 2015. Potential network impacts were as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None.

Multiple Facility Contingency

(Double Circuit Tower Line contingencies were studied for the full energy output. The contingencies of Line with Failed Breaker and Bus Fault will be performed for the Impact Study.)

None.

Short Circuit

(Summary of impacted circuit breakers)

None.

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None.

Steady-State Voltage Requirements

(Summary of the VAR requirements based upon the results of the steady-state voltage studies)

None.

Stability and Reactive Power Requirement for Low Voltage Ride Through

(Summary of the VAR requirements based upon the results of the dynamic studies)

None.

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

None.

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

None

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None.

Attachment 1. Aerial View

Attachment 2. Single Line Diagram