

***Generation Interconnection  
Combined Feasibility/System  
Impact Study Report***

***For***

***PJM Generation Interconnection Request  
Queue Position Z1-094***

***Jug St. 34.5 kV***

**July 2014**

## Preface

The intent of the Combined Feasibility/System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation, if any, is included in the System Impact Study.

The Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs associated with them will be addressed when seeking an Interconnection Agreement as outlined below. . Developer will also be responsible for providing and installing metering equipment in compliance with applicable PJM and Transmission Owner standards.

## General

RES Americas, LLC, the Interconnection Customer (IC), has proposed a battery generating facility located at Franklin County, Ohio. The installed facilities will have a total capability of 6.0 MW with 0 MW of this output being recognized by PJM as capacity. The proposed in-service date for this project is June 1, 2014. **This study does not imply an AEP commitment to this in-service date.**

Attachment facilities and local upgrades (if required) along with terms and conditions to interconnect Z1-094 will be specified in a separate two party Interconnection Agreement (IA) between AEP and the Interconnection Customer as this project is considered FERC non-jurisdictional per the PJM Open Access Transmission Tariff (OATT). From the transmission system perspective, no network impacts were identified as detailed below.

## Point of Interconnection

Z1-094 will interconnect with the AEP distribution system by connecting to the Jug St. 34.5 kV substation.

## Cost Summary

The Z1-094 project will be responsible for the costs outlined in the two-party Interconnection Agreement between AEP and Z1-094.

## **Transmission Owner Scope of Work**

The scope of AEP's work will be defined in the two-party Interconnection Agreement between AEP and Z1-094.

## **Revenue Metering and SCADA Requirements**

### **PJM Requirements**

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

### **AEP Requirements**

The Interconnection Customer will be required to comply with all AEP Revenue Metering Requirements for Generation Interconnection Customers.

## **Network Impacts**

The Queue Project #Z1-094 was studied as a 6.0 MW (Capacity 0.0 MW) injection at the Jug St. 34.5 kV substation in the AEP area. Project #Z1-094 was evaluated for compliance with reliability criteria for summer peak conditions in 2017. Potential network impacts were as follows:

## **Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

None

## **Light Load Analysis**

Light Load Studies to be conducted during later study phases (applicable to wind, coal, nuclear, and pumped storage projects).

None

## **Multiple Facility Contingency**

*(Double Circuit Tower Line, Failed Breaker and Bus Fault contingencies for the full energy output)*

None

## **Short Circuit**

*(Summary form of Cost allocation for breakers will be inserted here if any)*

None

## **Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

None

## **Steady-State Voltage Requirements**

*(Results of the steady-state voltage studies should be inserted here)*

None

**Stability and Reactive Power Requirement**

*(Results of the dynamic studies should be inserted here)*

None

**New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None

**Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

*(Summary form of Cost allocation for transmission lines and transformers will be inserted here if any)*

None

**Delivery of Energy Portion of Interconnection Request**

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.


Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

None

# Attachment 1

## System Configuration

**Jug 34.5 kV Circuit F-36533**



## Attachment 2

*Project Location*

