

**#Z1-097 – Adkins 345kV  
Generation Interconnection**

**General**

The Interconnection Customer is proposing a 30MW Capacity uprate to an existing 564MW Energy (456MW Capacity) natural gas facility for a new total of 564MW Energy (486MW Capacity) located in Mr. Sterling, OH interconnecting into the DP&L (Dayton Power & Light) area. The proposed in-service date is requested for **May 31, 2014** and is currently under review. Impacts on the MISO member transmission systems are not included in this analysis, but they will be included in the Impact Study, which may reveal upgrades needed in the MISO system not identified in this Feasibility Study.

This Generation Interconnection Feasibility Study provides analysis results to aid the Interconnection Customer in assessing the practicality and cost of incorporating the facility into the PJM system. This study was limited to load flow analyses of probable contingencies. If the interconnection customer elects to pursue a System Impact Study, a more comprehensive analysis will be performed.

**Revenue Metering and SCADA Requirements**

**For PJM:** IC will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

**Network Impacts**

Queue project Z1-097 was studied as a 30.0MW (30.0MW Capacity) injection at the Adkins 345kV substation in the Dayton area. Project Z1-097 was evaluated for compliance with reliability criteria for summer peak conditions in 2017. Potential network impacts were as follows:

**Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

No problems were identified.

**Multiple Facility Contingency**

*(Double Circuit Tower Line contingencies were studied for the full energy output. The contingencies of Line with Failed Breaker and Bus Fault will be performed for the Impact Study.)*

No problems were identified.

**Short Circuit**

*(Summary of impacted circuit breakers)*

Not required.

**Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

No problems were identified.

**Steady-State Voltage Requirements**

*(Summary of the VAR requirements based upon the results of the steady-state voltage studies)*

To be determined in the System Impact Study.

**Light Load Reliability Analysis**

*(Summary of any reinforcements required to mitigate system reliability issues during light load periods.)*

To be determined in the System Impact Study.

**Stability and Reactive Power Requirement**

*(Summary of the VAR requirements based upon the results of the dynamic studies)*

To be determined in the System Impact Study.

**New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None.

**Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

None.

### **Potential Congestion due to Local Energy Deliverability**

*PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.*

*Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.*

As a result of the aggregate energy resources in the area, there were no violations identified.