

**Generation Interconnection
Facilities Study Report
for
Queue Project AC1-101/AC1-102
Johns Creek – Excel 138 kV
Pike County, Kentucky**

March 2022

1 Facilities Study Summary

1.1 Project Description

Pike County Solar Project, LLC, proposes to install PJM Project AC1-101/AC1-102. Together, the two queue positions comprise a 100.0 MW (38.0 MW Capacity) solar generating facility in Pike County, Kentucky (see Figure 2). The Point of Interconnection (POI) for the generating facility will be via a new Rich Gap 138 kV station to be cut into AEP's Johns Creek – Excel 138 kV section of the Inez – Johns Creek 138 kV circuit, approximately 5.2 miles north of Johns Creek (see Figure 1).

1.2 Amendments/Changes to the Impact Study Report

The Interconnection Customer approached AEP and PJM to request consideration of moving the project from the original location between Excel and Johns Creek to a direct connection at Inez. The question was triggered by geo-tech conditions in the original location – a relatively recently reclaimed surface mine. AEP determined that while site preparation and foundation costs might be a bit higher than usual, the site conditions don't preclude construction of the new Rich Gap station on the proposed site. PJM subsequently determined that moving the POI would require submittal of a new interconnection request in the currently open queue. In addition, the distances between Rich Gap, Excel and Johns Creek have changed slightly, resulting from concerns about the constructability and maintainability of tap structures at the point of closest approach between the Rich Gap station site and the existing Excel-Johns Creek Right of Way. To address these concerns, the existing line is proposed to be cut several spans further north, near structure 55. See Figure 3.

1.3 Interconnection Customer Schedule

PJM and AEP understand that the Interconnection Customer originally had established the following schedule dates:

Receive back feed power from AEP: March 1, 2019.

Generation Commercial Operation Date: June 1, 2019.

Acknowledgment of the Interconnection Customer's requested back feed and commercial operation dates does not imply AEP's commitment to or guarantee of these dates.

1.4 AEP's Scope of Work to Facilitate Interconnection

- The Inez – Johns 138 kV circuit will be tapped by constructing a new three (3) circuit breaker 138 kV station, Rich Gap, physically configured and operated as a ring bus (Figure 1) approximately 5.2 miles north of Johns Creek (see Figure 1).
- Due to constraints of the local terrain, the Rich Gap station can't be located next to the existing Inez-Johns Creek 138 kV circuit. A double-circuit 138 kV line extension of approximately 0.9 miles will be constructed to reach the Rich Gap station site.
- Installation of associated protection and control equipment, 138 kV line risers, SCADA, and 138 kV revenue metering will also be required at Rich Gap 138 kV. AEP reserves the right to specify the final acceptable configuration considering design practices, future expansion, and compliance requirements.
- AEP will extend one span of 138 kV transmission line for the generation-lead going to the adjacent AC1-101/AC1-102 collector station. AEP will build and own this span. AC1-101/102 will build and own the structure in the project collector station, to which AEP's conductor will attach.
- It is understood that the Interconnection Customer is responsible for all of the connection costs associated with interconnecting the PJM project AC1-101/AC1-102 to the AEP transmission system. The cost of the customer's generating facility and the costs for the line connecting the generating facility to AEP's transmission system are not included in this report; these are assumed to be the Customer's responsibility.
- (Dual independent) fiber connection(s) are required. AEP will extend the fiber-optic cable(s) from the POI into the Rich Gap control house. The Interconnection Customer will be responsible for the fiber-optic work from their telecom equipment to the POI.

1.5 Description of Transmission Owner Facilities Included in the Facilities Study

1.5.1 Direct Connection Work

- The Inez – Johns 138 kV circuit will be tapped by constructing a new three (3) circuit breaker 138 kV station, Rich Gap, physically configured and operated as a ring bus (Figure 1) approximately 5.2 miles north of Johns Creek (see Figure 1).
- AEP will install associated line protection and control equipment, 138 kV line risers, switches, jumpers, and SCADA, at the proposed Rich Gap 138 kV station. AEP reserves the right to specify the final acceptable configuration considering design practices, future expansion, and compliance requirements.
- A double-circuit 138 kV line extension of approximately 0.9 miles will be constructed between the existing Inez-Johns Creek 138 kV circuit and the Rich Gap station site.

1.5.2 Non-Direct Connection Work

- AEP will perform final connection of the Excel - Johns Creek section of the Inez – Johns Creek 138 kV circuit to the new line extension and Rich Gap station.
- AEP will perform P&C checkout including end-to-end testing.

1.5.3 Attachment Facilities Work

- AEP will install 138 kV revenue metering at Rich Gap 138 kV substation.
- AEP will extend one span of 138 kV conductor for the generation-lead going from the Rich Gap station to the adjacent AC1-101/AC1-102 collector station. AEP will build and own this span, AC1-101/102 will build and own the structure in the project collector station, to which AEP's conductor will attach.
- (Dual independent) fiber connection(s) are required. AEP will extend the fiber-optic cable(s) from the POI into the Rich Gap control house. The customer will be responsible for the fiber work on the IPP side of the POI.

1.5.4 Network Upgrade Work

Due to system overloads found during the PJM studies, the following network reinforcements are driven by this project:

- None

1.6 Total Cost of Transmission Owner Facilities Included in the Facilities Study:

Attachment Facilities	\$488,862
Direct Connection Facilities	\$10,840,138
Non-Direct Connection Facilities	\$1,031,000
Network Upgrade Facilities	\$0
Total Cost	\$12,360,000

The estimates do not include the impact that delays in obtaining ROW, permits, or other approvals may have.

1.7 Summary of Schedule Milestones for Completion of Transmission Owner Work Included in Facilities Study:

Standard Process: Typical Schedule for this type of Scope (Actual schedule to be determined at Kick Off)

<u>Task</u>	<u>Dates(See Notes)</u>
Engineering Start	Day 1*
Material Ordered	Day 172
Construction Start (Grading & Below Grade)	Day 430
Construction Start (Above Grade)	Day 530
Outage Requests Made By	Day 230
Outage (Structure Foundations)**	Starts Day 530
Outage (Cut-in & Testing)**	Starts Day 680
Ready For Back Feed (TO In-Service Date)	Day 730

*Day 1 occurs on the first working day after the ISA/ICSA have been fully executed or a mutually agreed upon start date that is later and meets the requested back feed date. Day 1 will generally not be before the PJM project kick off meeting.

**Scheduled Outages are contingent upon outage availability. Longer duration outages are not available during peak load periods.

Notes Regarding the Schedule

- Slippage by the customer / developer in executing the ISA and ICSA agreement does not equate to a 'day for day' slippage in the scheduled back feed and in service dates. Depending on the time of year, planned outages, neighboring projects and maintenance of the grid, outage availability has the potential to shift by weeks or months depending on conditions at the time of the fully executed agreement.
- System conditions must allow scheduled outages to occur.
- All transmission outages are subject to PJM and AEP Operations outage scheduling requirements.
- Significant scope of work changes will impact the schedule.

Scope Assumptions

- The customer will obtain, at its' cost, all necessary permits and provisions for the AEP direct connection facilities.
- The final design of the line extension from the existing 138 kV ROW to the new station site will result in line length less than 1 mile.
- AEP direct connection facilities included in Customer SUP if required.
- The customer will perform station site development, structure pads and road construction, in accordance with AEP specifications.
- The customer will provide a site acceptable to AEP (for transfer to AEP in Fee Simple) and any additional easements for the Rich Gap 138 kV station and line work to include access to all facilities and structures.
- The customer will have their construction and required checkout completed prior to the start of the cut-in and testing outage.
- Estimates provided are based on a table top process without the benefit of the results of site specific engineering studies (e.g., soil borings, environmental survey, ground grid, etc.)
- Soil is considered "normal" without rock formations or "poor" soil conditions or environmental concerns, beyond the test results already provided by the customer during the study. Differing soil conditions at the location of specific foundations may affect final costs.
- The POI station and Collector station are located in close enough proximity, and have a relative orientation, to allow the generator lead between them to consist of a single span of conductors between the respective station structures.

2 Transmission Owner Facilities Study Results

2.1 Transmission Lines – New

- AEP will extend one span of 138 kV conductor for the generation lead going to the adjacent AC1-101/AC1-102 collector station from the Rich Gap 138 kV station. AEP will build and own this span. AC1-101/102 will build and own the structure in the project collector station, to which AEP's conductor will attach.
- A double-circuit 138 kV line extension consisting of approximately 0.9 miles will provide a loop feed to the Rich Gap station from the (Inez-John's Creek) 138 kV circuit.
- Johns Creek – Excel 138 kV – Perform final connection of the Inez-Johns Creek 138 kV circuit to the new line extension and Rich Gap 138 kV interconnection substation. PJM Network Upgrade Number n5595.

2.2 Transmission Lines – Upgrades

- No transmission line upgrades will be required for this project.

2.3 [Station Facilities – New](#)

- A new 138 kV station, Rich Gap Station, will be established consisting of a 3-breaker ring bus loop fed from AEP's Excel - Johns Creek section of the Inez – Johns Creek 138 kV circuit.
- Installation of a Drop In Control Module (DICM) and other associated line protection and control equipment, 138 kV line risers, switches, jumpers, and SCADA, will also be required.

2.4 [Station Facilities – Upgrades](#)

- None

2.5 [Metering & Communications](#)

Standard 138 kV metering will be installed at the Rich Gap 138 kV station. A standard station communication scheme will be used. All metering equipment shall meet the requirements as specified by AEP in the "AEP Metering and Telemetry Requirements for AEP Transmission Customers" document (SS-490011). Communication requirements are published in the "AEP SCADA RTU Requirements at Transmission Interconnection Facilities" (SS-500000).

Two (2) diverse fiber-optic paths to the AC1-101/102 collector station are required. AEP will extend two (2) fiber-optic cables from the proposed Rich Gap 138 kV Station control house to the POI. The Interconnection Customer will be responsible for the fiber work on the IPP side of the POI.

The Generation Interconnection Agreement does not in or by itself establish a requirement for American Electric Power to provide power for consumption at the developer's facilities. A separate agreement may be reached with the local utility that provides service in the area to ensure that infrastructure is in place to meet this demand, and proper metering equipment is installed. The metering work above and cost indicated below does not include any potential work or cost to address metering requirements of the local service provider. It is the responsibility of the developer to contact the local service provider to obtain a local service agreement. This is required prior to energization.

2.6 [Environmental, Real Estate, and Permitting issues](#)

The Interconnection customer is expected to obtain, at its' cost, all necessary permits and provisions for the IPP station connecting to the Rich Gap 138 kV station.

2.7 System Modeling & Operating Requirements

In addition to the IPP modeling requirements imposed by PJM as part of the Generation Interconnection process, the following system modeling parameters will need to be supplied by the Interconnection Customer to AEP:

- Modeling parameters are required as outlined in the 'Connection Requirements for the AEP Transmission System.' These requirements can be accessed at:
<https://aep.com/requiredpostings/AEPTransmissionStudies>

2.8 Summary of Results of Study

Cost Estimates for AEP


<u>Task</u>	<u>Network Upgrade Number</u>	<u>Engineering</u>	<u>Material</u>	<u>Construction</u>	<u>Other</u>	<u>TOTAL</u>
New 138kV Switching Station & Line Extension	n5599	\$235,936	\$2,806,698	\$6,401,294	\$1,412,577	\$10,856,505
Inez - Johns Creek 138kV T-Line Cut-In & checkout	n5595	\$95,000	\$106,000	\$595,000	\$235,000	\$1,031,000
138kV Revenue Metering Cost	n5596	\$22,000	\$122,000	\$143,000	\$60,000	\$347,000
Gen Lead	n5596	\$23,064	\$16,302	\$58,706	\$27,423	\$125,495
TOTAL		\$376,000	\$3,051,000	\$7,198,000	\$1,735,000	\$12,360,000

2.9 Information Required for Interconnection Service Agreement

<u>Description</u>	<u>Direct-Connect Facilities</u>	<u>Non-Direct Connect Facilities</u>	<u>Attachment Facilities</u>	<u>TOTAL</u>
<u>Direct Material</u>	\$2,806,698.00	\$106,000.00	\$138,302.00	\$3,051,000.00
<u>Direct Labor</u>	\$6,637,230.00	\$750,000.00	\$246,770.00	\$7,634,000.00
<u>Indirect Material</u>	\$561,441.66	\$44,000.00	\$21,558.34	\$627,000.00
<u>Indirect Labor</u>	\$834,768.34	\$131,000.00	\$82,231.66	\$1,048,000.00
<u>TOTAL</u>	\$10,840,138.00	\$1,031,000.00	\$488,862.00	\$12,360,000.00

Figure 1: AC1-101/102 Johns Creek – Excel 138 kV
(proposed Rich Gap 138 kV station)

Point of Interconnection One-Line Diagram



The Point of Interconnection is the first structure outside of the new 138 kV station (such structure being located in Interconnection Customer's Collector Substation) with the Interconnected Transmission Owner owning the first span of conductors, and the Interconnection Customer owning the first structure.

Figure 2: Point of Interconnection Map

[Proposed Rich Gap station at approximately 37.597041, -82.397532]



AEP CONFIDENTIAL

