

Generation Interconnection Feasibility Study Report Queue Position AB2-037

The Interconnection Customer (IC) has proposed a 250 MW (95 MWC) solar generating facility to be located in Caroline County, Maryland. PJM studied AB2-037 as a 250 MW injection into the Delmarva Power and Light Company (DPL) system at a tap of the Keeney-Steele 230 kV circuit and evaluated it for compliance with reliability criteria for summer peak conditions in 2020. The planned in-service date, as stated during the project kick-off call, is October 31, 2019.

Point of Interconnection

The Interconnection Customer requested a transmission level interconnection. As a result, AB2-037 will interconnect with the DPL system at a new three breaker 230 kV ring bus substation to be constructed adjacent to the Keeney-Steele 230 kV circuit.

Transmission Owner Scope of Work

Substation Interconnection Estimate

Scope: Build a new 230 kV substation with a 3 position ring bus. Two of the positions on the ring bus will be transmission line terminals for the tie-in of Line 23009 to the substation. The other position will be a terminal configured for the interconnection of a generator.

Estimate: \$6,491,000

Construction Time: 24 months

Major Equipment Included in Estimate:

• Control Enclosure, 20' x 15'	Qty. 1
• Power Circuit Breaker, 230 kV, 2000A, 40kA, 3 cycle	Qty. 3
• Disconnect Switch, 230 kV, 2000A, Manual Wormgear, Arcing Horns	Qty. 9
• CT/VT Combination Units, 230 kV	Qty. 3
• CVT, 230 kV	Qty. 6
• Disconnect Switch Stand, High, 230 kV, Steel	Qty. 5
• Disconnect Switch Stand, Low, 230 kV, Steel	Qty. 4
• CT/VT Stand, Single Phase, Low, 230 kV, Steel	Qty. 3
• CVT Stand, Single Phase, Low, 230 kV, Steel	Qty. 6
• SSVT, 230 kV/240-120 V	Qty. 1
• Relay Panel, Transmission Line, FL/BU (20")	Qty. 6
• Control Panel, 230 kV Circuit Breaker (10")	Qty. 3
• Take-off structure, 230 kV	Qty. 2
• Bus Support Structure, 3 phase, 230 kV, Steel	Qty. 8

Estimate Assumptions:

- Land purchase for the substation is not included.
- A 3.5 acre, relatively square lot is available for use.
- Site clearing and grading performed by Developer.
- Lightning protection (lightning masts) are not required.

Required Relaying and Communications

New protection relays are required for the new terminals.

An SEL-487 will be required for primary protection and an SEL-387 will be required for back-up protection. Two 20" relay panels for each generator terminal will be required for front line and back-up protection (2 total).

New protection relays are required for the new line terminals. An SEL-421 will be required for primary protection and an SEL-311C will be required for back-up protection. Two 20" relay panels will be required for each transmission line terminal (4 total).

An SEL-451 relay on a 20" breaker control panel will be required for the control and operation of each new 230 kV circuit breaker.

The project will require re-wiring and adjustment of existing relay schemes to accommodate the new 230 kV substation.

The cost of the required relay and communications is included in the Substation Interconnection Estimate.

Metering

Three phase 230 kV revenue metering points will need to be established. DPL will purchase and install all metering instrument transformers as well as construct a metering structure. The secondary wiring connections at the instrument transformers will be completed by DPL's metering technicians. The metering control cable and meter cabinets will be supplied and installed by DPL. DPL will install conduit for the control cable between the instrument transformers and the metering enclosure. The location of the metering enclosure will be determined in the construction phase. DPL will provide both the Primary and the Backup meters. DPL's meter technicians will program and install the Primary & Backup solid state multi-function meters for each new metering position. Each meter will be equipped with load profile, telemetry, and DNP outputs. The IC will be provided with one meter DNP output for each meter. DPL will own the metering equipment for the interconnection point, unless the IC asserts its right to install, own, and operate the metering system.

The Interconnection Customer will be required to make provisions for a voice quality phone line within approximately 3 feet of each Company metering position to facilitate remote interrogation and data collection.

It is the IC's responsibility to send the data that PJM and DPL requires directly to PJM. The IC will grant permission for PJM to send DPL the following telemetry that the IC sends to PJM: real time MW, MVAR, volts, amperes, generator status, and interval MWH and MVARH. The estimate for

DPL to design, purchase, and install metering as specified in the aforementioned scope for metering is included in the Substation Interconnection Estimate.

Interconnection Customer Scope of Work

The Interconnection Customer is responsible for all design and construction related to activities on their side of the Point of Interconnection. Site preparation, including grading and an access road, as necessary, is assumed to be by the IC. Route selection, line design, and right-of-way acquisition of the direct connect facilities is not included in this report, and is the responsibility of the IC. Protective relaying and metering design and installation must comply with DPL's applicable standards. The IC is also required to provide revenue metering and real-time telemetering data to PJM in conformance with the requirements contained in PJM Manuals M-01 and M-14 and the PJM Tariff.

DPL Interconnection Customer Scope of Direct Connection Work Requirements:

- DPL requires that an IC circuit breaker is located within 500 feet of the new 230 kV substation to facilitate the relay protection scheme between DPL and the IC at the Point of Interconnection (POI).

Special Operating Requirements

1. DPL will require the capability to remotely disconnect the generator from the grid by communication from its System Operations facility. Such disconnection may be facilitated by a generator breaker, or other method depending upon the specific circumstances and the evaluation by DPL.
2. DPL reserves the right to charge the Interconnection Customer operation and maintenance expenses to maintain the Interconnection Customer attachment facilities, including metering and telecommunications facilities, owned by DPL.

Additional Interconnection Customer Responsibilities:

1. An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

Summer Peak Analysis - 2020

Transmission Network Impacts

Potential transmission network impacts are as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

1. (PECO - AE) The DELCOTAP-MCKLTON 230 kV line (from bus 213559 to bus 228401 ckt 1) loads from 97.56% to 98.94% (DC power flow) of its emergency rating (796 MVA) for the bus fault outage of 'CHI230B1/* \$ DELCO \$ CHI230B1 \$ B'. This project contributes approximately 24.47 MW to the thermal violation.

CONTINGENCY 'CHI230B1/* \$ DELCO \$ CHI230B1 \$ B'
DISCONNECT BUS 213489 /* CHICHST1 230.00 \$ DELCO \$
CHI230B1 \$ B
END/* \$ DELCO \$ CHI230B1 \$ B

Please refer to Appendix 1 for a table containing the generators having contribution to this flowgate.

2. (PECO - AE) The DELCOTAP-MCKLTON 230 kV line (from bus 213559 to bus 228401 ckt 1) loads from 97.56% to 98.94% (DC power flow) of its emergency rating (796 MVA) for the line fault with failed breaker contingency outage of 'CHICH045/* \$ DELCO \$ CHICH045 \$ STBK'. This project contributes approximately 24.47 MW to the thermal violation.

CONTINGENCY 'CHICH045/* \$ DELCO \$ CHICH045 \$ STBK'
DISCONNECT BUS 213489 /* CHICHST1 230.00 \$ DELCO \$
CHICH045 \$ STBK
DISCONNECT BUS 213627 /* FOULK8 230.00 \$ DELCO \$
CHICH045 \$ STBK
END/* \$ DELCO \$ CHICH045 \$ STBK

3. (DP&L - DP&L) The TOWNSEND-MIDLTNTP 138 kV line (from bus 232107 to bus 232106 ckt 1) loads from 38.26% to 43.36% (DC power flow) of its emergency rating (348 MVA) for the tower line contingency outage of 'DBL_4NC'. This project contributes approximately 39.44 MW to the thermal violation.

CONTINGENCY 'DBL_4NC' /* RED LION-CEDAR CREEK
230;RED LION-CARTANZA 230
OPEN LINE FROM BUS 231004 TO BUS 232002 CKT 1
OPEN LINE FROM BUS 231004 TO BUS 232003 CKT 1
END

Please refer to Appendix 2 for a table containing the generators having contribution to this flowgate.

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

Summer Peak Load Flow Analysis Reinforcements

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

- 1&2. To mitigate the (PECO - AE) DELCOTAP-MCKLTON 230 kV line (from bus 213559 to bus 228401 ckt 1) overloads will require reinforcements to increase the emergency rating of the Delco Tap to Mickleton 230 kV line. Reinforcements include the replacement of substation equipment and substation bus at Mickleton Substation. The estimate to perform this work is **\$905,000** and will take **18 months** to complete.
3. To mitigate the (DP&L) TOWNSEND-MIDLTNTP 138 kV line (from bus 232107 to bus 232106 ckt 1) over load will require reinforcements to increase the emergency rating of the Townsend to Middletown Tap 138 kV line. Reinforcements include rebuilding a short section of the circuit and installation of new poles and re-mounting of 138 kV disconnect switches. The estimate to perform this work is **\$800,000** and will take **18 months** to complete.

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

(Summary form of Cost allocation for transmission lines and transformers will be inserted here if any)

None

Steady-State Voltage Requirements

(Results of the steady-state voltage studies should be inserted here)

To be performed during later study phases.

Short Circuit

(Summary of impacted circuit breakers)

No issues identified.

(Results of the dynamic studies should be inserted here)

Light Load Analysis - 2020

Facilities Study Estimate

7 months; \$100,000

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

1. (PECO - PECO) The LINWOOD-CHICHST1 230 kV line (from bus 213750 to bus 213489 ckt 1) loads from 102.07% to 103.42% (DC power flow) of its emergency rating (1593 MVA) for the single line contingency outage of '220-39'. This project contributes approximately 47.62 MW to the thermal violation.

```
CONTINGENCY '220-39'                                /* $ DELCO $ 220-39 $ L
TRIP BRANCH FROM BUS 213490 TO BUS 213750 CKT 1      /*
END
```

2. (PECO - PECO) The LINWOOD-CHICHST2 230 kV line (from bus 213750 to bus 213490 ckt 1) loads from 101.92% to 103.26% (DC power flow) of its emergency rating (1593 MVA) for the single line contingency outage of '220-43/* \$ DELCO \$ 220-43 \$ L'. This project contributes approximately 47.55 MW to the thermal violation.

CONTINGENCY '220-43/* \$ DELCO \$ 220-43 \$ L'
TRIP BRANCH FROM BUS 213489 TO BUS 213750 CKT 1 /*
END/* \$ DELCO \$ 220-43 \$ L

Cost estimates will further be refined as a part of the Impact Study and Facilities Study for this project. The Interconnection Customer will be responsible for all costs incurred by DPL in

connection with the AB2-037 project. Such costs may include, but are not limited to, any transmission system assets currently in DPL's rate base that are prematurely retired due to the AB2-037 project. PJM shall work with DPL to identify these retirement costs and any additional expenses. DPL reserves the right to reassess issues presented in this document and, upon appropriate justification, submit additional costs related to the AB2-037 project.

Appendices

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact.

It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Appendix 1

(PECO - AE) The DELCOTAP-MCKLTON 230 kV line (from bus 213559 to bus 228401 ckt 1) loads from 97.56% to 98.94% (DC power flow) of its emergency rating (796 MVA) for the bus fault outage of 'CHI230B1/* \$ DELCO \$ CHI230B1 \$ B'. This project contributes approximately 24.47 MW to the thermal violation.

CONTINGENCY 'CHI230B1/* \$ DELCO \$ CHI230B1 \$ B'

DISCONNECT BUS 213489 /* CHICHST1 230.00 \$ DELCO \$
CHI230B1 \$ B
END/* \$ DELCO \$ CHI230B1 \$ B

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
213400	COVANTA DELA	10.48
231916	EM3	3.48
231901	EM4	7.09
231900	EM5	26.32
231908	HR1	5.1
231909	HR2	5.05
231910	HR3	5.1
231505	HR4	10.82
232923	MR1	1.45
232924	MR2	1.45
213888	PHLISCT1	12.48

213889	<i>PHLISCT2</i>	12.48
213890	<i>PHLISCT3</i>	12.48
213893	<i>PHLISST1</i>	11.37
297077	<i>V2-028 E</i>	0.35
904212	<i>V4-022E</i>	0.29
901004	<i>W1-003 E</i>	0.42
901014	<i>W1-004 E</i>	0.42
901024	<i>W1-005 E</i>	0.42
901034	<i>W1-006 E</i>	0.42
905132	<i>W4-015 E</i>	-8.99
907052	<i>X1-032 E</i>	0.37
907324	<i>X1-096 E</i>	8.61
910572	<i>X3-008 E</i>	1.18
910592	<i>X3-015 E</i>	1.14
910822	<i>X3-066 E</i>	0.37
920352	<i>X4-027</i>	0.84
913362	<i>Y1-079 E</i>	0.61
913412	<i>Y1-080 E</i>	0.2
920543	<i>Y3-054 E</i>	1.08
915542	<i>Y3-058 E</i>	0.86
920582	<i>Z1-076 C</i>	0.49
920583	<i>Z1-076 E</i>	0.8
920592	<i>Z1-077 C</i>	0.35
920593	<i>Z1-077 E</i>	0.57
916282	<i>Z1-081 E</i>	0.37
917082	<i>Z2-012 E</i>	1.15
920763	<i>Z2-076 E</i>	0.18
920773	<i>Z2-077 E</i>	0.18
920812	<i>Z2-097 C</i>	0.36
920813	<i>Z2-097 E</i>	0.15
921122	<i>AA1-059 C</i>	0.4
921123	<i>AA1-059 E</i>	0.16
921142	<i>AA1-061 C</i>	1.27
921143	<i>AA1-061 E</i>	0.62
921442	<i>AA1-110 C</i>	0.4
921443	<i>AA1-110 E</i>	0.2
921592	<i>AA1-140 C</i>	0.69
921593	<i>AA1-140 E</i>	1.13
921602	<i>AA1-141 C</i>	0.53
921603	<i>AA1-141 E</i>	0.86
921872	<i>AA2-069</i>	45.33
922213	<i>AA2-129 E</i>	1.85
922222	<i>AA2-130</i>	0.19
922752	<i>AB1-056 C OP</i>	5.86
922753	<i>AB1-056 E OP</i>	16.68

922762	<i>AB1-057 C</i>	5.95
922763	<i>AB1-057 E</i>	16.95
923282	<i>AB1-137 C</i>	1.28
923283	<i>AB1-137 E</i>	0.55
923322	<i>AB1-141 C OP</i>	1.35
923323	<i>AB1-141 E OP</i>	0.63
923332	<i>AB1-142 C OP</i>	1.35
923333	<i>AB1-142 E OP</i>	0.63
923452	<i>AB1-162 C OP</i>	0.63
923453	<i>AB1-162 E OP</i>	1.03
923602	<i>AB1-176 C</i>	0.34
923603	<i>AB1-176 E</i>	0.56
923902	<i>AB2-030 E</i>	0.37
923921	<i>AB2-032 C</i>	1.36
923922	<i>AB2-032 E</i>	0.64
923931	<i>AB2-033 C</i>	0.66
923932	<i>AB2-033 E</i>	0.26
923951	<i>AB2-036 C</i>	4.51
923952	<i>AB2-036 E</i>	7.35
923961	<i>AB2-037 C</i>	9.3
923962	<i>AB2-037 E</i>	15.17
924191	<i>AB2-063 C</i>	0.76
924192	<i>AB2-063 E</i>	1.23
924361	<i>AB2-084 C</i>	0.35
924362	<i>AB2-084 E</i>	0.57
924461	<i>AB2-095 C</i>	1.04
924462	<i>AB2-095 E</i>	1.7
924562	<i>AB2-105 E</i>	0.02
924681	<i>AB2-120 C OP</i>	3.51
924682	<i>AB2-120 E OP</i>	5.72
924781	<i>AB2-130 C OP</i>	3.49
924782	<i>AB2-130 E OP</i>	5.7
924801	<i>AB2-133 C OP</i>	3.21
924802	<i>AB2-133 E OP</i>	4.31
924821	<i>AB2-135 C</i>	2.93
924822	<i>AB2-135 E</i>	4.43
924831	<i>AB2-136 C OP</i>	2.34
924832	<i>AB2-136 E OP</i>	3.32
924881	<i>AB2-142 C</i>	0.5
924882	<i>AB2-142 E</i>	0.81
924891	<i>AB2-143 C OP</i>	0.76
924892	<i>AB2-143 E OP</i>	1.24
924971	<i>AB2-153 C</i>	0.76
924972	<i>AB2-153 E</i>	1.24
925071	<i>AB2-164 C OP</i>	0.7

925072	AB2-164 E OP	1.15
925081	AB2-165 C OP	0.7
925082	AB2-165 E OP	1.15
925091	AB2-166 C	0.18
925092	AB2-166 E	0.32
925101	AB2-167 C	0.49
925102	AB2-167 E	0.8
925111	AB2-168 C	0.43
925112	AB2-168 E	0.7
925151	AB2-172 C OP	1.8
925152	AB2-172 E OP	2.94
925231	AB2-177 C	0.23
925232	AB2-177 E	0.38
925251	AB2-179 C OP	3.99
925252	AB2-179 E OP	1.32
925261	AB2-180 C	1.3
925262	AB2-180 E	0.56
925271	AB2-185 C OP	1.38
925272	AB2-185 E OP	0.59
925311	AB2-192 C OP	0.7
925312	AB2-192 E OP	1.15

Appendix 2

(DP&L - DP&L) The TOWNSEND-MIDLTNTP 138 kV line (from bus 232107 to bus 232106 ckt 1) loads from 38.26% to 43.36% (DC power flow) of its emergency rating (348 MVA) for the tower line contingency outage of 'DBL_4NC'. This project contributes approximately 39.44 MW to the thermal violation.

CONTINGENCY 'DBL_4NC'

/* RED LION-CEDAR CREEK

230;RED LION-CARTANZA 230

OPEN LINE FROM BUS 231004 TO BUS 232002 CKT 1

OPEN LINE FROM BUS 231004 TO BUS 232003 CKT 1

END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
232900	DEMECSMY	2.15
232851	DUP-SFR1	0.41
232902	EASTMUNI	3.4
232923	MR1	3.36
232924	MR2	3.36
232910	NRG_G1	2.43
232911	NRG_G2	2.43

292089	<i>T-011</i>	<i>0.17</i>
297076	<i>V2-028 C</i>	<i>0.09</i>
297077	<i>V2-028 E</i>	<i>0.75</i>
904212	<i>V4-022E</i>	<i>0.61</i>
232813	<i>VAUGHN</i>	<i>0.15</i>
232919	<i>VN10</i>	<i>0.57</i>
901004	<i>W1-003 E</i>	<i>0.89</i>
901014	<i>W1-004 E</i>	<i>0.89</i>
901024	<i>W1-005 E</i>	<i>0.89</i>
901034	<i>W1-006 E</i>	<i>0.89</i>
901411	<i>W1-062</i>	<i>2.28</i>
907052	<i>X1-032 E</i>	<i>0.79</i>
907324	<i>X1-096 E</i>	<i>18.27</i>
910571	<i>X3-008 C</i>	<i>0.32</i>
910572	<i>X3-008 E</i>	<i>2.68</i>
910591	<i>X3-015 C</i>	<i>0.3</i>
910592	<i>X3-015 E</i>	<i>2.51</i>
910821	<i>X3-066 C</i>	<i>0.17</i>
910822	<i>X3-066 E</i>	<i>1.41</i>
913361	<i>Y1-079 C</i>	<i>0.24</i>
913362	<i>Y1-079 E</i>	<i>1.96</i>
913411	<i>Y1-080 C</i>	<i>0.05</i>
913412	<i>Y1-080 E</i>	<i>0.43</i>
915751	<i>Y3-033</i>	<i>1.46</i>
915752	<i>Y3-033</i>	<i>9.76</i>
920543	<i>Y3-054 E</i>	<i>2.48</i>
915541	<i>Y3-058 C</i>	<i>0.22</i>
915542	<i>Y3-058 E</i>	<i>1.86</i>
920582	<i>Z1-076 C</i>	<i>1.05</i>
920583	<i>Z1-076 E</i>	<i>1.71</i>
920592	<i>Z1-077 C</i>	<i>0.75</i>
920593	<i>Z1-077 E</i>	<i>1.22</i>
916281	<i>Z1-081 C</i>	<i>0.2</i>
916282	<i>Z1-081 E</i>	<i>1.65</i>
917082	<i>Z2-012 E</i>	<i>2.44</i>
920763	<i>Z2-076 E</i>	<i>0.4</i>
920773	<i>Z2-077 E</i>	<i>0.4</i>
920812	<i>Z2-097 C</i>	<i>1.57</i>
920813	<i>Z2-097 E</i>	<i>0.65</i>
921122	<i>AA1-059 C</i>	<i>0.84</i>
921123	<i>AA1-059 E</i>	<i>0.33</i>
921142	<i>AA1-061 C</i>	<i>2.87</i>
921143	<i>AA1-061 E</i>	<i>1.41</i>
921442	<i>AA1-110 C</i>	<i>1.78</i>
921443	<i>AA1-110 E</i>	<i>0.89</i>

921592	AA1-140 C	1.51
921593	AA1-140 E	2.47
921602	AA1-141 C	1.13
921603	AA1-141 E	1.84
921872	AA2-069	104.81
922213	AA2-129 E	3.94
922222	AA2-130	0.39
922752	AB1-056 C OP	12.79
922753	AB1-056 E OP	36.43
922762	AB1-057 C	12.99
922763	AB1-057 E	37.03
923282	AB1-137 C	2.79
923283	AB1-137 E	1.2
923322	AB1-141 C OP	5.3
923323	AB1-141 E OP	2.47
923332	AB1-142 C OP	5.3
923333	AB1-142 E OP	2.47
923452	AB1-162 C OP	2.4
923453	AB1-162 E OP	3.92
923602	AB1-176 C	1.29
923603	AB1-176 E	2.12
923902	AB2-030 E	0.79
923921	AB2-032 C	5.34
923922	AB2-032 E	2.51
923931	AB2-033 C	1.41
923932	AB2-033 E	0.56
923951	AB2-036 C	13.81
923952	AB2-036 E	22.54
923961	AB2-037 C	14.99
923962	AB2-037 E	24.45
924191	AB2-063 C	2.87
924192	AB2-063 E	4.69
924361	AB2-084 C	0.75
924362	AB2-084 E	1.22
924461	AB2-095 C	2.27
924462	AB2-095 E	3.7
924681	AB2-120 C OP	7.49
924682	AB2-120 E OP	12.21
924781	AB2-130 C OP	7.73
924782	AB2-130 E OP	12.62
924801	AB2-133 C OP	14.2
924802	AB2-133 E OP	19.08
924821	AB2-135 C	12.06
924822	AB2-135 E	18.18
924831	AB2-136 C OP	5.19

924832	<i>AB2-136 E OP</i>	7.37
924881	<i>AB2-142 C</i>	1.14
924882	<i>AB2-142 E</i>	1.85
924891	<i>AB2-143 C OP</i>	3.37
924892	<i>AB2-143 E OP</i>	5.5
924971	<i>AB2-153 C</i>	2.98
924972	<i>AB2-153 E</i>	4.87
925071	<i>AB2-164 C OP</i>	1.5
925072	<i>AB2-164 E OP</i>	2.44
925081	<i>AB2-165 C OP</i>	1.5
925082	<i>AB2-165 E OP</i>	2.44
925091	<i>AB2-166 C</i>	0.4
925092	<i>AB2-166 E</i>	0.7
925101	<i>AB2-167 C</i>	1.05
925102	<i>AB2-167 E</i>	1.72
925151	<i>AB2-172 C OP</i>	4.11
925152	<i>AB2-172 E OP</i>	6.7
925231	<i>AB2-177 C</i>	0.49
925232	<i>AB2-177 E</i>	0.81
925251	<i>AB2-179 C OP</i>	26.29
925252	<i>AB2-179 E OP</i>	8.67
925261	<i>AB2-180 C</i>	2.8
925262	<i>AB2-180 E</i>	1.2
925271	<i>AB2-185 C OP</i>	4.42
925272	<i>AB2-185 E OP</i>	1.89
925311	<i>AB2-192 C OP</i>	1.5
925312	<i>AB2-192 E OP</i>	2.44