

***Generation Interconnection  
Feasibility Study Report***

***For***

***PJM Generation Interconnection Request  
Queue Position AC1-175***

***Losantville 345 kV***

**April 2017**

## Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

## General

The Interconnection Customer proposes to install PJM Project #AC1-175, a 100.0 MW (38.0 MW Capacity) solar generating facility in Losantville, IN (see Figure 2). The point of interconnection will be a direct connection to AEP's Losantville 345 kV substation utilizing the Generator Lead that will be constructed for PJM Project #AC1-174 (see Figure 1).

The requested in service date is November 30, 2019.

## Attachment Facilities

### Point of Interconnection (Losantville 345 kV Substation)

It is assumed that PJM Project AC1-174 will pay for the necessary direct connection work required to connect to the Losantville 345 kV substation (see Figure 1). In the event that AC1-175 proceeds without AC1-174, the Attachment Facilities estimates provided in the AC1-174 report would apply for AC1-175.

It is understood that The Interconnection Customer is responsible for all costs associated with this interconnection. The cost of The Interconnection Customer's generating plant and the costs for the line connecting the generating plant to The Interconnection Customer's switching station are not included in this report; these are assumed to be The Interconnection Customer's responsibility.

The Generation Interconnection Agreement does not in or by itself establish a requirement for American Electric Power to provide power for consumption at the developer's facilities. A separate agreement may be reached with the local utility that provides service in the area to ensure that infrastructure is in place to meet this demand and proper metering equipment is installed. It is the responsibility of the developer to contact the local service provider to determine if a local service agreement is required.

## Interconnection Customer Requirements

Requirement from the PJM Open Access Transmission Tariff:

1. An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.
2. The Interconnection Customer may be required to install and/or pay for metering as necessary to properly track real time output of the facility as well as installing metering which shall be used for billing purposes. See Section 8 of Appendix 2 to the Interconnection Service Agreement as well as Section 4 of PJM Manual 14D for additional information.

# Revenue Metering and SCADA Requirements

## PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

## AEP Requirements

The Interconnection Customer will be required to comply with all AEP Revenue Metering Requirements for Generation Interconnection Customers. The Revenue Metering Requirements may be found within the "Requirements for Connection of New Facilities or Changes to Existing Facilities Connected to the AEP Transmission System" document located at the following link:

<http://www.pjm.com/~media/planning/plan-standards/private-aep/aep-interconnection-requirements.ashx>

## Network Impacts

The Queue Project AC1-175 was evaluated as a 100.0 MW (Capacity 38.0 MW) injection at the Losantville 345kV substation in the AEP area. Project AC1-175 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AC1-175 was studied with a commercial probability of 53%. Potential network impacts were as follows:

## Base Case Used

Summer Peak Analysis – 2020 Case

## Contingency Descriptions

The following contingencies resulted in overloads:

Option 1	
Contingency Name	Description
8823	CONTINGENCY '8823'
	OPEN BRANCH FROM BUS 243218 TO BUS 243232 CKT 2 / 243218 05DESOTO 345 243232 05SORENS 345 2
	OPEN BRANCH FROM BUS 243225 TO BUS 243232 CKT 1 / 243225 05KEYSTN 345 243232 05SORENS 345 1
	END
3027_C2	CONTINGENCY '3027_C2'
	OPEN BRANCH FROM BUS 243233 TO BUS 249567 CKT 1 / 243233 05TANNER 345 249567 08M.FTHS 345 1
	OPEN BRANCH FROM BUS 243233 TO BUS 254524 CKT 1 / 243233 05TANNER 345 254524 16HANNA 345 1

Option 1	
Contingency Name	Description
	OPEN BRANCH FROM BUS 243233 TO BUS 243382 CKT 5 / 243233 05TANNER 345 243382 05TANNER 138 5 END
678_B3_05TANNER 345-5	CONTINGENCY '678_B3_05TANNER 345-5' OPEN BRANCH FROM BUS 243233 TO BUS 249567 CKT 1 / 243233 05TANNER 345 249567 08M.FTHS 345 1 OPEN BRANCH FROM BUS 243233 TO BUS 243382 CKT 5 / 243233 05TANNER 345 243382 05TANNER 138 5 END
8702_B2_TOR2543	CONTINGENCY '8702_B2_TOR2543' OPEN BRANCH FROM BUS 243218 TO BUS 243232 CKT 2 / 243218 05DESOTO 345 243232 05SORENS 345 2 END
P1-#.B2 TERMINAL- EAST BEND 4516	CONTINGENCY 'P1-#.B2 TERMINAL-EAST BEND 4516' OPEN BRANCH FROM BUS 249575 TO BUS 249565 CKT 1 END

**Table 1**

### **Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

None

### **Multiple Facility Contingency**

*(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)*

AC1-175 Multiple Facility Contingency														
Contingency					Bus		Loading		Rating		MW	FG		
#	Type	Name	Affected Area	Facility Description	From	To	Cir.	PF	Initial	Final	Type	MVA	Con.	App.
1	LFFB	3027_C2	AEP - AEP	05LOSANTVILL-05DESOTO 345 kV line	243792	243218	2	DC	96.08	102.61	ER	1166	76.13	2

**Table 2**

## **Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

*Note: Please see Appendices for projects providing impacts to flowgate violations. The values in the Reference column correspond to the proper table in the Appendix.*

AC1-175 Contributions to Previously Identified Overloads														
Contingency		Bus			Loading		Rating		MW		FG			
#	Type	Name	Affected Area	Facility Description	From	To	Cir.	PF	Initial	Final	Type	MVA	Con.	App.
1	DCTL	8823	AEP - AEP	05DESOTO-05JAY 138 kV line	243278	243319	1	DC	100.6	101.45	ER	393	7.43	1

**Table 3**

## **Steady-State Voltage Requirements**

None

## **Short Circuit**

*(Summary of impacted circuit breakers)*

New circuit breakers found to be over-duty:

None

## **Delivery of Energy Portion of Interconnection Request**

*PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.*

*Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.*

AC1-175 Delivery of Energy Portion of Interconnection Request														
Contingency		Bus			Loading		Rating		MW		FG			
#	Type	Name	Affected Area	Facility Description	From	To	Cir.	PF	Initial	Final	Type	MVA	Con.	App.
1	N-1	8702_B2_TOR2543	AEP - AEP	05KEYSTN-05SORENS 345	243225	243232	1	DC	109.49	111.9	NR	897	21.59	

				kV line										
2	N-1	P1-#.B2 TERMINAL-EAST BEND 4516	AEP - DEO&K	05TANNER- 08M.FORT 345 kV line	243233	249567	1	DC	140.91	141.51	NR	1409	19.96	
3	N-1	678_B3_05TANNER 345-5	AEP - AEP	05LOSANTVILL- 05DESOTO 345 kV line	243792	243218	2	DC	97.13	104.61	NR	1016	76	

**Table 4**

## **Affected System Analysis & Mitigation**

### **LGEE Impacts:**

LGEE Impacts to be determined during later study phases (as applicable).

### **MISO Impacts:**

MISO Impacts to be determined during later study phases (as applicable).

### **Duke, Progress & TVA Impacts:**

Duke Carolina, Progress, & TVA Impacts to be determined during later study phases (as applicable).

### **OVEC Impacts:**

OVEC Impacts to be determined during later study phases (as applicable).

## **New System Reinforcements**

#	Overloaded Facility	Upgrade Description	Schedule	Estimated Cost
#1	05DESOTO-05JAY 138 kV line	Replace the Jay breaker G (1200A) Replace the Jay Switch (1200A) Replace Jay Riser (1590 AAC 61 Str.) Replace the Jay Bus (1590 AAC 61 Str.) Replace the Desoto Switch (1200A)  The Jay Area Improvements project will replace the limiting elements identified above.	Work to be completed May 2017	N/A
	05LOSANTVILL-05DESOTO	A sag check will be required for the ACAR ~ 2303.5 ~ 54/7 ~ Conductor Section 1 to determine if the line section can be operated	Sag Study: 6 to 12 months.	\$56,000

#	Overloaded Facility	Upgrade Description	Schedule	Estimated Cost
#2	345 kV line	above its emergency rating of 1166 MVA. The result could prove that no additional upgrades are necessary, that some upgrades on the circuit are necessary, or that the entire 14 mile section of line would need to be rebuilt.	Rebuild/Reconductor: The standard time required for construction differs from state to state. An approximate construction time would be 36 to 48 months after signing an interconnection agreement.	
Total New Network Upgrades				\$56,000

**Table 5**

## **Schedule**

It is anticipated that the time between receipt of executed agreements and Commercial Operation may range from 12 to 18 months if no line work is required. If line work is required, construction time would be between 24 to 36 months after signing an interconnection agreement.

**Note:** The time provided between anticipated normal completion of System Impact, Facilities Studies, subsequent execution of ISA and ICSA documents, and the proposed Backfeed Date is shorter than usual and may be difficult to achieve.

## **Conclusion**

Based upon the results of this Feasibility Study, the construction of the 100.0 MW (38.0 MW Capacity) solar generating facility of The Interconnection Customer (PJM Project #AC1-175) will require the following additional interconnection charges. This plan of service will interconnect the proposed solar generating facility in a manner that will provide operational reliability and flexibility to both the AEP system and the The Interconnection Customer generating facility.

<b>Cost Breakdown for Point of Interconnection (Losantville 345 kV Substation)</b>		
<b>Attachment Cost</b>	PJM Project AC1-174 is expected to pay for the necessary direct connection work required to connect to the Losantville 345 kV substation (see Figure 1).	<b>N/A</b>
<b>Non-Direct Connection Cost Estimate</b>	345 kV Revenue Metering to be installed by PJM Project AC1-174.	<b>N/A</b>
	A sag check will be required for the ACAR ~ 2303.5 ~ 54/7 ~ Conductor Section 1 to determine if the line section can be operated above its emergency rating of 1166 MVA. The result could prove that no additional upgrades are necessary, that some upgrades on the circuit are necessary, or that the entire 14 mile section of line would need to be rebuilt.	<b>\$56,000</b>
	<b>Total Estimated Cost for Project AC1-175</b>	<b>\$56,000</b>

**Table 6**

The estimates are preliminary in nature, as they were determined without the benefit of detailed engineering studies. The cost of remediation for sag limited conductors is not included in this estimate. Final estimates will require an on-site review and coordination to determine final construction requirements.