

Feasibility Study Report

For

***PJM Generation Interconnection Request
Queue Position AD2-066***

Mazon-Crescent Ridge

July 31, 2018

Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement.

For Local and Network Upgrades which are required due to overloads associated with the System Impact Studies of an individual New Services Queue, and have a cost less than \$5,000,000, the cost of the Local and Network Upgrades will be shared by all proposed projects which have been assigned a Queue Position in the New Services Queue in which the need for the Local and Network Upgrades was identified. The Load Flow Cost Allocation methods discussed in this manual, including cutoffs, still apply to the individual projects.

For Local and Network Upgrades which are required due to the overloads associated with the System Impact Studies of an individual New Services Queue, and have a cost of \$5,000,000 or greater, the cost of the Local and Network Upgrades will be allocated according to the order of the New Service Requests in the New Services Queue and the MW contribution of each individual Interconnection Request for those projects which cause or contribute to the need for the Local or Network Upgrades. The Load Flow Cost Allocation methods discussed in this manual, including cutoffs, still apply to the individual projects.

Cost allocation rules can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment G-2 of Manual 14A. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new

models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See Section 2.2.2. of Manual 14A for starting dates) for the Interconnection Request which shall specify the use of the new model. The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment G-1 of Manual 14A) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

General

The Interconnection Customer (“IC”) for Queue **AD2-066 Mazon-Crescent Ridge** project is a proposal to connect a 116 MW Energy (69.6 MW Capacity) solar PV facility to be located in Grundy County, IL.

The IC has proposed a service date for this project of September 1, 2020.

Impacts on the MISO member transmission systems are not included in this analysis, but will be included in the System Impact Study Phase. Winter peak analysis will be performed in the System Impact Study phase.

This Generation Interconnection Feasibility Study provides analysis results to aid the IC in assessing the practicality and cost of incorporating the facility into the PJM system. This study was limited to load flow analyses of probable contingencies. If the IC elects to pursue a System Impact Study, a more comprehensive analysis will be performed.

Primary Point of Interconnection (Option-1)

The Interconnection Customer (IC) AD2-066, a 116 MW solar facility, proposes to interconnect with the ComEd transmission system by tying into the Crescent Ridge-Oglesby (Ameren)-Mazon 138kV Line 7713, approximately 6 miles from Mazon.

Attachment Facilities

The IC AD2-066 generator lead would interconnect to a new 138kV Interconnection Substation. This interconnection would require one 138kV line MOD, a dead-end structure and revenue metering as shown in the one line diagram.

The cost for the attachment facilities is estimated at \$1M.

Scope of Work	Cost Estimate
Installation of one 138kV line MOD, one dead-end structure and one set of revenue metering (see notes below on cost estimate)	\$1,000,000

Direct Connection Network Upgrades

In order to accommodate interconnection of AD2-066, a new 138kV Interconnection Substation would need to be built close to the Crescent Ridge-Oglesby (Ameren)-Mazon 138kV Line 7713 approximately 6 miles from the Mazon TSS 77.

The scope of work includes the installation of three 138kV circuit breakers in a “breaker-and-a-half” bus configuration and cutting in the Interconnection Substation to Crescent Ridge-Oglesby (Ameren)-Mazon 138kV Line 7713, as shown in the one-line diagram below.

The IC is responsible for constructing all of the facilities on the IC side of the point of interconnection outside of the substation. It is assumed for the purposes of this report that the IC will obtain the site for the Interconnection Substation and right-of-way between the Interconnection Substation and the 138kV transmission line.

In the event that the IC exercises the option to build the interconnecting substation, the IC will be required to construct all interconnection facilities that will be turned over to ComEd in accordance with ComEd published standards and the PJM Tariff.

ComEd would design, engineer and construct the tie in of the Interconnection Substation to the Crescent Ridge-Oglesby (Ameren)-Mazon 138kV Line 7713.

The preliminary cost estimate for Direct Connection Network Upgrade is given in the following tables.

For Option to Build Direct Connection cost estimates:

Scope of Work	Cost Estimate
Installation of a new 138kV substation as described above	N/A
Transmission line tie in work (foundations, structures, conductors)	\$ 2,000,000
ComEd oversight and testing	\$ 1,000,000
Total Cost Estimate (see notes below on cost estimate)	\$ 3,000,000

For ComEd building the interconnecting substation cost estimates:

Scope of Work	Cost Estimate
Installation of a new 138kV substation as described above	\$15,000,000
Transmission line tie in work (foundations, structures, conductors)	\$ 2,000,000
Total Cost Estimate (see notes below on cost estimate)	\$ 17,000,000

ComEd would take approximately 24-months to construct the substation and transmission line work after the ISA / ICSA are signed.


Non-Direct Connection Network Upgrades

The integration of the new 138kV Interconnection Substation would require relay/communications/SCADA upgrades at the Mazon TSS 77, Crescent Ridge TSS 981, and AMEREN's Oglesby substation. The ComEd cost is given below:

Scope of Work	Cost Estimate
Relay/communications/SCADA upgrades at Mazon TSS 77 substation	\$ 750,000
Relay/communications/SCADA upgrades at Crescent Ridge TSS 981 substation	\$ 750,000
Relay/communications/SCADA upgrades at Oglesby substation (Ameren to provide cost-estimate)	\$ 0
Total Cost Estimate (see notes below on cost estimate)	\$ 1,500,000

Notes on Cost Estimate:

- 1) These estimates are Order-of-Magnitude estimates of the costs that ComEd would bill to the customer for this interconnection. These estimates are based on a one-line electrical diagram of the project and the information provided by the IC.
- 2) There were no site visits performed for these estimates. There may be costs related to specific site related issues that are not identified in these estimates. The site reviews will be performed during the Facilities Study or during detailed engineering.
- 3) These estimates are not a guarantee of the maximum amount payable by the IC and the actual costs of ComEd's work may differ significantly from these estimates. Per the PJM Tariff, IC will be responsible for paying all actual costs of ComEd's work.
- 4) The IC is responsible for all engineering, procurement, testing and construction of all equipment on the IC's side of the Point of Interconnection (POI).
- 5) These cost estimates do not include cost of acquiring right-of-way for the transmission line and purchasing any additional land, if needed, for the line terminations. The need and cost of acquiring property and associated legal costs will be investigated during Facilities Study for this project



Network Impacts for Primary POI

The Queue Project AD2-066 was evaluated as a 116.0 MW (Capacity 69.6 MW) injection at the tap of the Mazon to Oglesby Tap 138 kV line in the ComEd area. Project AD2-066 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AD2-066 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Analysis - 2021

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

1. (CE - MISO AMIL) The OGLESBY ; T-4OGLESBY MN 138 kV line (from bus 272189 to bus 348935 ckt 1) loads from 86.6% to 133.71% (**DC power flow**) of its emergency rating (202 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_012-38-L1206__'. This project contributes approximately 95.16 MW to the thermal violation.

CONTINGENCY 'COMED_P4_012-38-L1206__'

TRIP BRANCH FROM BUS 271187 TO BUS 271987 CKT 1	/ CHANNAHON; R 138 MAZON ; R 138
TRIP BRANCH FROM BUS 271337 TO BUS 272125 CKT 1	/ DRESDEN ; R 138 ESS J339 ; R 138
TRIP BRANCH FROM BUS 271987 TO BUS 936510 CKT 1	/ MAZON ; R 138 AD2-066 TAP 138
TRIP BRANCH FROM BUS 272319 TO BUS 271187 CKT 1	/ ESS J375 ; R 138 CHANNAHON; R 138
TRIP BRANCH FROM BUS 272319 TO BUS 272125 CKT 1	/ ESS J375 ; R 138 ESS J339 ; R 138
MOVE 50 PERCENT LOAD FROM BUS 271187 TO BUS 271566	/ CHANNAHON; R 138 GOOSE LK ; B 138
MOVE 50 PERCENT LOAD FROM BUS 271187 TO BUS 271567	/ CHANNAHON; R 138 GOOSE LK ; R 138
MOVE 100 PERCENT LOAD FROM BUS 272125 TO BUS 272124	/ ESS J339 ; R 138 ESS J339 ; B 138
CLOSE LINE FROM BUS 271986 TO BUS 271987 CKT 1	/ MAZON ; B 138 MAZON ; R 138
DISCONNECT BUS 274836	/ EQUISTAR ; R 13.8
TRIP BRANCH FROM BUS 271337 TO BUS 271336 CKT 1	/ DRESDEN ; R 138 DRESDEN ; B 138
TRIP BRANCH FROM BUS 271337 TO BUS 271567 CKT 1	/ DRESDEN ; R 138 GOOSE LK ; R 138

END

2. (CE - MISO AMIL) The OGLESBY ; T-4OGLESBY MN 138 kV line (from bus 272189 to bus 348935 ckt 1) loads from 86.59% to 133.7% (**DC power flow**) of its emergency rating (202 MVA) for the tower line contingency outage of 'COMED_P7_138-L0903__R-S+_138-L1206__R-S_A'. This project contributes approximately 95.16 MW to the thermal violation.

CONTINGENCY 'COMED_P7_138-L0903__R-S+_138-L1206__R-S_A'

TRIP BRANCH FROM BUS 271567 TO BUS 271337 CKT 1	/ GOOSE LK ; R 138 DRESDEN ; R 138
TRIP BRANCH FROM BUS 271567 TO BUS 274190 CKT 7	/ GOOSE LK ; R 138 GOOSE LK ; 34.5
TRIP BRANCH FROM BUS 271725 TO BUS 271723 CKT 1	/ ESS J370 ; RT 138 ESS J370 ; R 138
MOVE 100 PERCENT LOAD FROM BUS 271181 TO BUS 271180	/ ESS J326 ; R 138 ESS J326 ; B 138
MOVE 100 PERCENT LOAD FROM BUS 272019 TO BUS 272018	/ MINOOKA ; R 138 MINOOKA ; B 138
CLOSE LINE FROM BUS 271470 TO BUS 271471 CKT 1	/ ESS J305 ; 2B 138 ESS J305 ; 2R 138
CLOSE LINE FROM BUS 271722 TO BUS 271723 CKT 1	/ ESS J370 ; B 138 ESS J370 ; R 138
DISCONNECT BUS 271185	/ ESS J326 ; RT 138

DISCONNECT BUS 271417 / ESS J390 ; R 138
DISCONNECT BUS 271473 / ESS J305 ;RT 138
TRIP BRANCH FROM BUS 271187 TO BUS 271987 CKT 1 / CHANNAHON; R 138 MAZON ; R 138
TRIP BRANCH FROM BUS 271337 TO BUS 272125 CKT 1 / DRESDEN ; R 138 ESS J339 ; R 138
TRIP BRANCH FROM BUS 271987 TO BUS 936510 CKT 1 / MAZON ; R 138 AD2-066 TAP 138
TRIP BRANCH FROM BUS 272319 TO BUS 271187 CKT 1 / ESS J375 ; R 138 CHANNAHON; R 138
TRIP BRANCH FROM BUS 272319 TO BUS 272125 CKT 1 / ESS J375 ; R 138 ESS J339 ; R 138
MOVE 50 PERCENT LOAD FROM BUS 271187 TO BUS 271566 / CHANNAHON; R 138 GOOSE LK ; B 138
MOVE 50 PERCENT LOAD FROM BUS 271187 TO BUS 271567 / CHANNAHON; R 138 GOOSE LK ; R 138
MOVE 100 PERCENT LOAD FROM BUS 272125 TO BUS 272124 / ESS J339 ; R 138 ESS J339 ; B 138
CLOSE LINE FROM BUS 271986 TO BUS 271987 CKT 1 / MAZON ; B 138 MAZON ; R 138
DISCONNECT BUS 274836 / EQUISTAR ; R 13.8
END

3. (CE - MISO AMIL) The OGLESBY ; T-4OGLESBY MN 138 kV line (from bus 272189 to bus 348935 ckt 1) loads from 86.54% to 133.65% (**DC power flow**) of its emergency rating (202 MVA) for the tower line contingency outage of 'COMED_P7_138-L0903__R-S+_138-L1206__R-S_B'. This project contributes approximately 95.16 MW to the thermal violation.

CONTINGENCY 'COMED_P7_138-L0903__R-S+_138-L1206__R-S_B'
TRIP BRANCH FROM BUS 271567 TO BUS 271337 CKT 1 / GOOSE LK ; R 138 DRESDEN ; R 138
TRIP BRANCH FROM BUS 271567 TO BUS 274190 CKT 7 / GOOSE LK ; R 138 GOOSE LK ; 34.5
TRIP BRANCH FROM BUS 271725 TO BUS 271723 CKT 1 / ESS J370 ;RT 138 ESS J370 ; R 138
MOVE 100 PERCENT LOAD FROM BUS 271181 TO BUS 271180 / ESS J326 ; R 138 ESS J326 ; B 138
MOVE 100 PERCENT LOAD FROM BUS 271187 TO BUS 271566 / CHANNAHON; R 138 GOOSE LK ; B 138
MOVE 100 PERCENT LOAD FROM BUS 271783 TO BUS 271416 / JOLIET374; R 138 ESS J390 ; B 138
MOVE 100 PERCENT LOAD FROM BUS 272019 TO BUS 272018 / MINOOKA ; R 138 MINOOKA ; B 138
MOVE 100 PERCENT LOAD FROM BUS 272125 TO BUS 272124 / ESS J339 ; R 138 ESS J339 ; B 138
MOVE 100 PERCENT LOAD FROM BUS 272318 TO BUS 272319 / ESS J375 ; B 138 ESS J375 ; R 138
CLOSE LINE FROM BUS 271986 TO BUS 271987 CKT 1 / MAZON ; B 138 MAZON ; R 138
DISCONNECT BUS 271185 / ESS J326 ;RT 138
DISCONNECT BUS 271417 / ESS J390 ; R 138
DISCONNECT BUS 271473 / ESS J305 ;RT 138
TRIP BRANCH FROM BUS 271187 TO BUS 271987 CKT 1 / CHANNAHON; R 138 MAZON ; R 138
TRIP BRANCH FROM BUS 271337 TO BUS 272125 CKT 1 / DRESDEN ; R 138 ESS J339 ; R 138
TRIP BRANCH FROM BUS 271987 TO BUS 936510 CKT 1 / MAZON ; R 138 AD2-066 TAP 138
TRIP BRANCH FROM BUS 272319 TO BUS 271187 CKT 1 / ESS J375 ; R 138 CHANNAHON; R 138
TRIP BRANCH FROM BUS 272319 TO BUS 272125 CKT 1 / ESS J375 ; R 138 ESS J339 ; R 138
CLOSE LINE FROM BUS 271986 TO BUS 271987 CKT 1 / MAZON ; B 138 MAZON ; R 138
DISCONNECT BUS 274836
END

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

1. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 163.84% to 163.94% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 16.34 MW to the thermal violation.

CONTINGENCY 'AEP_P4_#2978_05DUMONT 765'
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 X1-020
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1
END

2. (CE - MISO NIPS) The BURNHAM ;0R-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 129.46% to 129.57% (**DC power flow**) of its emergency rating (1195 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 13.69 MW to the thermal violation.

CONTINGENCY 'AEP_P4_#2978_05DUMONT 765'
 OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 X1-020
 OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1
 END

3. (CE - CE) The DRESDEN ; B-WOLFS ; B 345 kV line (from bus 270716 to bus 270928 ckt 1) loads from 114.9% to 116.7% (**DC power flow**) of its load dump rating (1479 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_012-45-BT5-6__'. This project contributes approximately 26.44 MW to the thermal violation.

CONTINGENCY 'COMED_P4_012-45-BT5-6__'
 TRIP BRANCH FROM BUS 270716 TO BUS 270736 CKT 1 / DRESD; B 345 ELWOO; B 345
 TRIP BRANCH FROM BUS 270736 TO BUS 270737 CKT 1 / ELWOO; B 345 ELWOO; R 345
 TRIP BRANCH FROM BUS 274702 TO BUS 270716 CKT 1 / KENDA; B 345 DRESD; B 345
 END

4. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.85% to 108.91% (**DC power flow**) of its load dump rating (1399 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 14.65 MW to the thermal violation.

CONTINGENCY 'AEP_P4_#2978_05DUMONT 765'
 OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 X1-020
 OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1
 END

5. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.35% to 108.41% (**DC power flow**) of its load dump rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT2-3__'. This project contributes approximately 14.74 MW to the thermal violation.

CONTINGENCY 'COMED_P4_023-65-BT2-3__'
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
 TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765
 END

6. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.31% to 108.36% (**DC power flow**) of its load dump rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT4-5__'. This project contributes approximately 14.73 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT4-5__'
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765
 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345
 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33
 END

7. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.3% to 108.35% (**DC power flow**) of its load dump rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT3-4__'. This project contributes approximately 14.73 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT3-4__'

TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1	/ WILTO; 765 05DUMONT 765
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1	/ WILTO;3M 345 WILTO; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1	/ WILTO;3M 345 WILTO; B 345
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1	/ WILTO;3M 345 WILTO;3C 33

END

8. (CE - CE) The WILTON ; B-WILTON ;3M 345 kV line (from bus 270926 to bus 275232 ckt 1) loads from 145.12% to 145.32% (**DC power flow**) of its load dump rating (1379 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT5-6__'. This project contributes approximately 17.29 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT5-6__'

TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1	/ WILTO; 765 COLLI; 765
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1	/ WILTO;4M 345 WILTO; 765
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1	/ WILTO;4M 345 WILTO; R 345
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1	/ WILTO;4M 345 WILTO;4C 33

END

9. (CE - CE) The WILTON ; R-WILTON ;4M 345 kV line (from bus 270927 to bus 275233 ckt 1) loads from 148.09% to 148.27% (**DC power flow**) of its load dump rating (1379 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT2-3__'. This project contributes approximately 17.65 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT2-3__'

TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1	/ WILTO; 765 COLLI; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1	/ WILTO;3M 345 WILTO; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1	/ WILTO;3M 345 WILTO; B 345
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1	/ WILTO;3M 345 WILTO;3C 33

END

10. (CE - CE) The KENDALL ;BU-LOCKPORT ; B 345 kV line (from bus 274702 to bus 270810 ckt 1) loads from 118.58% to 119.61% (**DC power flow**) of its load dump rating (1479 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_111-45-L16704T'. This project contributes approximately 15.04 MW to the thermal violation.

CONTINGENCY 'COMED_P4_111-45-L16704T'

TRIP BRANCH FROM BUS 270846 TO BUS 270730 CKT 1	/ PLANO ; B 345 ELEC JUNC; B 345
TRIP BRANCH FROM BUS 272250 TO BUS 272278 CKT 1	/ PLANO ; B 138 PLANO;1I 138
TRIP BRANCH FROM BUS 272250 TO BUS 272278 CKT 2	/ PLANO ; B 138 PLANO;1I 138
TRIP BRANCH FROM BUS 270846 TO BUS 272278 TO BUS 275354 CKT 1	/ PLANO ; B 345 PLANO;1I 138 PLANO;1C 34.5
TRIP BRANCH FROM BUS 270730 TO BUS 270916 CKT 1	/ ELEC JUNC; B 345 WAYNE ; B 345
TRIP BRANCH FROM BUS 270730 TO BUS 270928 CKT 1	/ ELEC JUNC; B 345 WOLFS ; B 345
TRIP BRANCH FROM BUS 270928 TO BUS 272794 TO BUS 275334 CKT 1	/ WOLFS ; B 345 WOLFS ; B 138 WOLFS ;1C 34.5
DISCONNECT BUS 275239	/ ELEC JUNC;2M 138

END

11. (CE - CE) The KENDALL ;BU-LOCKPORT ; B 345 kV line (from bus 274702 to bus 270810 ckt 1) loads from 118.28% to 119.3% (**DC power flow**) of its load dump rating (1479

MVA) for the bus fault outage of 'COMED_P2-2_111_EJ-345B__2'. This project contributes approximately 15.06 MW to the thermal violation.

```

CONTINGENCY 'COMED_P2-2_111_EJ-345B__2'
TRIP BRANCH FROM BUS 270730 TO BUS 270846 CKT 1      / ELECT; B 345 PLANO; B 345
TRIP BRANCH FROM BUS 270730 TO BUS 270916 CKT 1      / ELECT; B 345 WAYNE; B 345
TRIP BRANCH FROM BUS 270730 TO BUS 270928 CKT 1      / ELECT; B 345 WOLFS; B 345
TRIP BRANCH FROM BUS 270928 TO BUS 272794 TO BUS 275334 CKT 1 / WOLFS; B 345 WOLFS; B 138 WOLFS;1C 34.5
DISCONNECT BUS 275239                                / ELECT;2M 138
END

```

12. (CE - CE) The KENDALL ;BU-LOCKPORT ; B 345 kV line (from bus 274702 to bus 270810 ckt 1) loads from 118.28% to 119.3% (**DC power flow**) of its load dump rating (1479 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_111-45-L11126_'. This project contributes approximately 15.06 MW to the thermal violation.

```

CONTINGENCY 'COMED_P4_111-45-L11126_'
TRIP BRANCH FROM BUS 270730 TO BUS 270916 CKT 1      / ELECT; B 345 WAYNE; B 345
TRIP BRANCH FROM BUS 270730 TO BUS 270846 CKT 1      / ELECT; B 345 PLANO; B 345
TRIP BRANCH FROM BUS 270730 TO BUS 270928 CKT 1      / ELECT; B 345 WOLFS; B 345
TRIP BRANCH FROM BUS 270928 TO BUS 272794 TO BUS 275334 CKT 1 / WOLFS; B 345 WOLFS; B 138 WOLFS;1C 34.5
DISCONNECT BUS 275239                                / ELECT;2M 138
END

```

13. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 126.42% to 126.47% (**DC power flow**) of its emergency rating (1399 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 14.47 MW to the thermal violation.

```

CONTINGENCY 'AEP_P4_#2978_05DUMONT 765'
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1      / 243206 05DUMONT 765 X1-020
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1      / 243206 05DUMONT 765 270644 WILTON ; 765 1
END

```

14. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 125.93% to 125.99% (**DC power flow**) of its emergency rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT2-3__'. This project contributes approximately 14.56 MW to the thermal violation.

```

CONTINGENCY 'COMED_P4_023-65-BT2-3__'
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1      / WILTO; 765 05DUMONT 765
TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1      / COLLI; 765 PLANO; 765
END

```

15. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 125.89% to 125.94% (**DC power flow**) of its emergency rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT4-5__'. This project contributes approximately 14.54 MW to the thermal violation.

```

CONTINGENCY 'COMED_P4_112-65-BT4-5__'
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1      / WILTO; 765 05DUMONT 765
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1      / WILTO;4M 345 WILTO; 765
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1      / WILTO;4M 345 WILTO; R 345
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1      / WILTO;4M 345 WILTO;4C 33
END

```

16. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 125.88% to 125.93% (**DC power flow**) of its emergency rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT3-4__'. This project contributes approximately 14.54 MW to the thermal violation.

```
CONTINGENCY 'COMED_P4_112-65-BT3-4__'
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33
END
```

17. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 133.06% to 133.16% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 11.49 MW to the thermal violation.

```
CONTINGENCY 'AEP_P4_#2978_05DUMONT 765'
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 X1-020
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1
END
```

18. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.92% to 132.01% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT4-5__'. This project contributes approximately 11.57 MW to the thermal violation.

```
CONTINGENCY 'COMED_P4_023-65-BT4-5__'
TRIP BRANCH FROM BUS 275168 TO BUS 270607 CKT 1 / COLLI;2M 345 COLLI; 765
TRIP BRANCH FROM BUS 275168 TO BUS 270697 CKT 1 / COLLI;2M 345 COLLI; R 345
TRIP BRANCH FROM BUS 275168 TO BUS 275268 CKT 1 / COLLI;2M 345 COLLI;2C 33
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
END
```

19. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.92% to 132.01% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT4-5__'. This project contributes approximately 11.57 MW to the thermal violation.

```
CONTINGENCY 'COMED_P4_112-65-BT4-5__'
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33
END
```

20. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.92% to 132.01% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT3-4__'. This project contributes approximately 11.57 MW to the thermal violation.

```
CONTINGENCY 'COMED_P4_112-65-BT3-4__'
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765
```

TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345
 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33
 END

21. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.91% to 132.0% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT2-3__'. This project contributes approximately 11.58 MW to the thermal violation.

CONTINGENCY 'COMED_P4_023-65-BT2-3__'
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
 TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765
 END

22. (CE - CE) The WILTON ; 765/345 kV transformer (from bus 275232 to bus 270644 ckt 1) loads from 145.12% to 145.32% (**DC power flow**) of its load dump rating (1379 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT5-6__'. This project contributes approximately 17.29 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT5-6__'
 TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765
 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765
 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345
 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33
 END

23. (CE - CE) The WILTON ; 765/345 kV transformer (from bus 275233 to bus 270644 ckt 1) loads from 148.08% to 148.26% (**DC power flow**) of its load dump rating (1379 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT2-3__'. This project contributes approximately 17.65 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT2-3__'
 TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765
 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765
 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345
 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33
 END

Steady-State Voltage Requirements

(Results of the steady-state voltage studies should be inserted here)

To be determined

Short Circuit

(Summary of impacted circuit breakers)

None identified

Affected System Analysis & Mitigation

MISO Impacts:

MISO Impacts to be determined during later study phases (as applicable).

Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request. Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

1. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 160.47% to 160.58% (**DC power flow**) of its normal rating (1409 MVA) for the single line contingency outage of 'COMED_P1-2_695_B2'. This project contributes approximately 16.73 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_695_B2'
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1
END

2. (CE - MISO NIPS) The BURNHAM ;OR-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 128.5% to 128.62% (**DC power flow**) of its emergency rating (1195 MVA) for the single line contingency outage of 'COMED_P1-2_695_B2'. This project contributes approximately 13.77 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_695_B2'
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1
END

3. (CE - CE) The DRESDEN ; B-KENDALL ;BU 345 kV line (from bus 270716 to bus 274702 ckt 1) loads from 103.54% to 104.84% (**DC power flow**) of its emergency rating (1195 MVA) for the single line contingency outage of 'COMED_P1-2_345-L1221__B-S'. This project contributes approximately 15.53 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_345-L1221__B-S'
TRIP BRANCH FROM BUS 270716 TO BUS 270928 CKT 1 / DRESD; B 345 WOLFS; B 345
END

4. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.2% to 108.26% (**DC power flow**) of its emergency rating (1399 MVA) for the single line contingency outage of 'COMED_P1-2_695_B2'. This project contributes approximately 14.72 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_695_B2'
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1
END

5. (CE - CE) The ELWOOD ; B-GOODINGS ;4B 345 kV line (from bus 270736 to bus 270770 ckt 1) loads from 99.86% to 100.13% (**DC power flow**) of its emergency rating (1479 MVA) for

the single line contingency outage of 'COMED_P1-2_345-L93505_B-S'. This project contributes approximately 9.1 MW to the thermal violation.

```
CONTINGENCY 'COMED_P1-2_345-L93505_B-S'  
TRIP BRANCH FROM BUS 274702 TO BUS 270716 CKT 1      / KENDA;BU 345 DRESDEN ; B  
TRIP BRANCH FROM BUS 274702 TO BUS 274703 CKT 1      / KENDA;BU 345 KENDA;RU 345  
END
```

6. (CE - CE) The KICKAPOO ; B-LASCO STA; B 138 kV line (from bus 271844 to bus 271908 ckt 1) loads from 99.33% to 104.6% (**DC power flow**) of its emergency rating (442 MVA) for the single line contingency outage of 'COMED_P1-2_138-L1206__R-S-A'. This project contributes approximately 23.32 MW to the thermal violation.

```
CONTINGENCY 'COMED_P1-2_138-L1206__R-S-A'  
TRIP BRANCH FROM BUS 271187 TO BUS 271987 CKT 1      / CHANNAHON; R 138 MAZON ; R 138  
TRIP BRANCH FROM BUS 271337 TO BUS 272125 CKT 1      / DRESDEN ; R 138 ESS J339 ; R 138  
TRIP BRANCH FROM BUS 271987 TO BUS 936510 CKT 1      / MAZON ; R 138 AD2-066 TAP 138  
TRIP BRANCH FROM BUS 272319 TO BUS 271187 CKT 1      / ESS J375 ; R 138 CHANNAHON; R 138  
TRIP BRANCH FROM BUS 272319 TO BUS 272125 CKT 1      / ESS J375 ; R 138 ESS J339 ; R 138  
MOVE 50 PERCENT LOAD FROM BUS 271187 TO BUS 271566   / CHANNAHON; R 138 GOOSE LK ; B 138  
MOVE 50 PERCENT LOAD FROM BUS 271187 TO BUS 271567   / CHANNAHON; R 138 GOOSE LK ; R 138  
MOVE 100 PERCENT LOAD FROM BUS 272125 TO BUS 272124  / ESS J339 ; R 138 ESS J339 ; B 138  
CLOSE LINE FROM BUS 271986 TO BUS 271987 CKT 1      / MAZON ; B 138 MAZON ; R 138  
DISCONNECT BUS 274836                               / EQUISTAR ; R 13.8  
END
```

7. (CE - CE) The MAZON ; R-CHANNAHON; R 138 kV line (from bus 271987 to bus 271187 ckt 1) loads from 91.08% to 120.6% (**DC power flow**) of its emergency rating (223 MVA) for the single line contingency outage of 'COMED_P1-2_138-L0112__B-S'. This project contributes approximately 65.83 MW to the thermal violation.

```
CONTINGENCY 'COMED_P1-2_138-L0112__B-S'  
TRIP BRANCH FROM BUS 271844 TO BUS 271908 CKT 1      / KICKA; B 138 LASCO; B 138  
END
```

8. (CE - CE) The MAZON ; R-CHANNAHON; R 138 kV line (from bus 271987 to bus 271187 ckt 1) loads from 80.09% to 117.46% (**DC power flow**) of its normal rating (173 MVA) for non-contingency condition. This project contributes approximately 64.66 MW to the thermal violation.

9. (CE - CE) The ESS J339 ; R-DRESDEN ; R 138 kV line (from bus 272125 to bus 271337 ckt 1) loads from 77.24% to 101.79% (**DC power flow**) of its emergency rating (268 MVA) for the single line contingency outage of 'COMED_P1-2_138-L0112__B-S'. This project contributes approximately 65.78 MW to the thermal violation.

```
CONTINGENCY 'COMED_P1-2_138-L0112__B-S'  
TRIP BRANCH FROM BUS 271844 TO BUS 271908 CKT 1      / KICKA; B 138 LASCO; B 138  
END
```

10. (CE - MISO AMIL) The OGLESBY ; T-4OGLESBY MN 138 kV line (from bus 272189 to bus 348935 ckt 1) loads from 86.49% to 133.6% (**DC power flow**) of its emergency rating (202 MVA) for the single line contingency outage of 'COMED_P1-2_138-L1206__R-S-A'. This project contributes approximately 95.16 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_138-L1206__R-S-A'
 TRIP BRANCH FROM BUS 271187 TO BUS 271987 CKT 1 / CHANNAHON; R 138 MAZON ; R 138
 TRIP BRANCH FROM BUS 271337 TO BUS 272125 CKT 1 / DRESDEN ; R 138 ESS J339 ; R 138
 TRIP BRANCH FROM BUS 271987 TO BUS 936510 CKT 1 / MAZON ; R 138 AD2-066 TAP 138
 TRIP BRANCH FROM BUS 272319 TO BUS 271187 CKT 1 / ESS J375 ; R 138 CHANNAHON; R 138
 TRIP BRANCH FROM BUS 272319 TO BUS 272125 CKT 1 / ESS J375 ; R 138 ESS J339 ; R 138
 MOVE 50 PERCENT LOAD FROM BUS 271187 TO BUS 271566 / CHANNAHON; R 138 GOOSE LK ; B 138
 MOVE 50 PERCENT LOAD FROM BUS 271187 TO BUS 271567 / CHANNAHON; R 138 GOOSE LK ; R 138
 MOVE 100 PERCENT LOAD FROM BUS 272125 TO BUS 272124 / ESS J339 ; R 138 ESS J339 ; B 138
 CLOSE LINE FROM BUS 271986 TO BUS 271987 CKT 1 / MAZON ; B 138 MAZON ; R 138
 DISCONNECT BUS 274836 / EQUISTAR ; R 13.8
 END

11. (CE - CE) The KENDALL ;BU-LOCKPORT ; B 345 kV line (from bus 274702 to bus 270810 ckt 1) loads from 117.47% to 118.5% (**DC power flow**) of its emergency rating (1479 MVA) for the single line contingency outage of 'COMED_P1-2_345-L1221__B-S'. This project contributes approximately 15.16 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_345-L1221__B-S'
 TRIP BRANCH FROM BUS 270716 TO BUS 270928 CKT 1 / DRESD; B 345 WOLFS; B 345
 END

12. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 125.78% to 125.84% (**DC power flow**) of its emergency rating (1399 MVA) for the single line contingency outage of 'COMED_P1-2_695_B2'. This project contributes approximately 14.53 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_695_B2'
 OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1
 END

13. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.88% to 131.98% (**DC power flow**) of its normal rating (971 MVA) for the single line contingency outage of 'COMED_P1-2_695_B2'. This project contributes approximately 11.57 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_695_B2'
 OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1
 END

14. (CE - CE) The AD2-066 TAP-MAZON ; R 138 kV line (from bus 936510 to bus 271987 ckt 1) loads from 109.52% to 143.04% (**DC power flow**) of its emergency rating (223 MVA) for the single line contingency outage of 'COMED_P1-2_138-L0112__B-S'. This project contributes approximately 74.74 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_138-L0112__B-S'
 TRIP BRANCH FROM BUS 271844 TO BUS 271908 CKT 1 / KICKA; B 138 LASCO; B 138
 END

15. (CE - CE) The AD2-066 TAP-MAZON ; R 138 kV line (from bus 936510 to bus 271987 ckt 1) loads from 95.41% to 137.75% (**DC power flow**) of its normal rating (173 MVA) for non-contingency condition. This project contributes approximately 73.24 MW to the thermal violation.

Light Load Analysis - 2021

Light Load Studies to be conducted during later study phases (as required by PJM Manual 14B).

System Reinforcements

Short Circuit

(Summary form of Cost allocation for breakers will be inserted here if any)

To be determined

Stability and Reactive Power Requirement

(Results of the dynamic studies should be inserted here)

To be determined

Summer Peak Load Flow Analysis Reinforcements

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

Multiple Facility Contingency

1. (CE - MISO AMIL) The OGLESBY ; T-4OGLESBY MN 138 kV line (from bus 272189 to bus 348935 ckt 1) loads from 86.6% to 133.71% (**DC power flow**) of its emergency rating (202 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_012-38-L1206__'. This project contributes approximately 95.16 MW to the thermal violation.

COMED:

Not a ComEd owned facility.

MISO:

The external (i.e. Non-PJM) Transmission Owner, MISO, will not evaluate this violation until the impact study phase.

2. (CE - MISO AMIL) The OGLESBY ; T-4OGLESBY MN 138 kV line (from bus 272189 to bus 348935 ckt 1) loads from 86.59% to 133.7% (**DC power flow**) of its emergency rating (202 MVA) for the tower line contingency outage of 'COMED_P7_138-L0903__R-S+_138-L1206__R-S_A'. This project contributes approximately 95.16 MW to the thermal violation.

Same as Multiple Facility Contingency #1

3. (CE - MISO AMIL) The OGLESBY ; T-4OGLESBY MN 138 kV line (from bus 272189 to bus 348935 ckt 1) loads from 86.54% to 133.65% (**DC power flow**) of its emergency rating (202 MVA) for the tower line contingency outage of 'COMED_P7_138-L0903__R-S+_138-L1206__R-S_B'. This project contributes approximately 95.16 MW to the thermal violation.

Same as Multiple Facility Contingency #1

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

(Summary form of Cost allocation for transmission lines and transformers will be inserted here if any)

1. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 163.84% to 163.94% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 16.34 MW to the thermal violation.

AEP / MISO:

- 1) (N4058) Sag study results: Stillwell - Dumont 345 kV line work will include the replacement of tower 20 with a custom steel pole, replacement of tower 24 with a custom H-frame and the removal of swing angle brackets on 2 structures. Cost estimate is \$1.613 million. New SE rating will be 1718 MVA limited by a Dumont wavetrapp and possibly the conductor. This upgrade is driven by a prior queue. Per PJM cost allocation rules, AC1-002 LTF presently does not receive cost allocation for this upgrade. Note: as changes to the interconnection process occur, such as prior queued projects withdrawing from the queue, AC1-002 LTF could receive cost allocation.
- 2) Additional AEP-end upgrade: Rebuild 8.6 miles of the AEP owned line and upgrade necessary Dumont terminal equipment (wavetrapp) at a cost of \$20 million. PJM Network Upgrade N4790. New AEP-end ratings to be 1409/2045 MVA (SN/SE). Limited by Dumont risers.
- 3) Additional AEP-end upgrade: In addition to upgrading the Dumont risers, a different conductor (compared to the prior upgrade) will need to be selected to achieve the desired rating. The new conductor would be 1272 dual ACSR conductor. The additional cost for this work scope is \$2 million. The new AEP-end ratings to be 1690/2278 MVA SN/SE (limited by the conductor). PJM Network Upgrade N5064.
- 4) Additional AEP-end upgrade: AEP said it would cost \$4.8 million to string a second Stillwell- Dumont 345 kV line on the existing tower. The \$4.8 million is for 8.5 miles of the AEP portion. Would need a NIPSCO portion (2.87 miles) cost estimate.

- 5) **MISO end – ratings are 1409/1779 MVA. MISO end upgrade: Rebuild NIPSCO portion of line (2.87 miles) at a cost of \$6.5 million and upgrade Stillwell substation equipment at a cost of \$1.5 million. Total cost is \$8.0 million. New expected MISO end ratings will be 1582/1898 MVA SN/SE.**
- 6) **Additional MISO-end upgrade: Reconductor 2.87 miles of transmission conductor to bundled 954 ACSS, replace substation conductor to bundled 2500 AL, and replace wavetrap. \$12 million. New MISO-end ratings to be 2550/2923 MVA SN/SE.**

2. (CE - MISO NIPS) The BURNHAM ;OR-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 129.46% to 129.57% (**DC power flow**) of its emergency rating (1195 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 13.69 MW to the thermal violation.

COMED:

ComEd L17703 SSTE rating is 1251 MVA. The post contingency flow exceeds the rating therefore an upgrade is required. Upgrades include line reconductoring and station conductor work at Burnham. A preliminary estimate for the upgrades is \$8.1 million with a preliminary construction timeline of 30 months. Upon completion the new ratings will be 1248/1441/1667/1982 MVA (SN/SLTE/SSTE/SLD)

3. (CE - CE) The DRESDEN ; B-WOLFS ; B 345 kV line (from bus 270716 to bus 270928 ckt 1) loads from 114.9% to 116.7% (**DC power flow**) of its load dump rating (1479 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_012-45-BT5-6__'. This project contributes approximately 26.44 MW to the thermal violation.

COMED:

ComEd 345kV L1221 SSTE rating is 1568 MVA. The post contingency flow for this event exceeds the rating therefore an upgrade is required. The upgrade will be to mitigate sag on sections of the line along with re-conductoring the line. A preliminary estimate for this upgrade is \$14.8 million with a construction timeline of 30 - 36 months. Upon completion of the upgrade the ratings will be 1334/1726/1837/2084 MVA (SN/SLTE/SSTE/SLD)

4. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.85% to 108.91% (**DC power flow**) of its load dump rating (1399 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 14.65 MW to the thermal violation.

COMED:

ComEd 345kV L6607 SSTE rating is 1483 MVA. The post contingency flow for this event exceeds the rating therefore an upgrade is required. The upgrade will be to reconductor the line. A preliminary estimate for this upgrade is \$11.2 million with a

preliminary construction timeline of 30-36 months. Upon completion of this upgrade the new ratings will be 1334/1726/1837/2084 MVA (SN/SLTE/SSTE/SLD)

5. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.35% to 108.41% (**DC power flow**) of its load dump rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT2-3__'. This project contributes approximately 14.74 MW to the thermal violation.

Same as Contribution to Previously Identified #4

6. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.31% to 108.36% (**DC power flow**) of its load dump rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT4-5__'. This project contributes approximately 14.73 MW to the thermal violation.

Same as Contribution to Previously Identified #4

7. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.3% to 108.35% (**DC power flow**) of its load dump rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT3-4__'. This project contributes approximately 14.73 MW to the thermal violation.

Same as Contribution to Previously Identified #4

8. (CE - CE) The WILTON ; B-WILTON ;3M 345 kV line (from bus 270926 to bus 275232 ckt 1) loads from 145.12% to 145.32% (**DC power flow**) of its load dump rating (1379 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT5-6__'. This project contributes approximately 17.29 MW to the thermal violation.

COMED:

ComEd post contingency facility overloaded by this event is Tr. 93 @ Station 112 Wilton Center. The upgrade will be to build out the 765kV ring bus at Wilton Center, installation of two 765 kV Bus Tie Circuit Breakers (BT 6-8 & 8-2) along with a relocation of 765kV L11216 from bus 6 to bus 8. Preliminary estimate for upgrade is \$12 million with an estimated construction time line of 30 months. Note, the rating for Tr. 93 at Wilton Center will remain current however with this upgrade the 112-65-BT5-6 contingency file will no longer include the Wilton Center Tr. 94 and will allow both transformers to remain in service eliminating the overload.

9. (CE - CE) The WILTON ; R-WILTON ;4M 345 kV line (from bus 270927 to bus 275233 ckt 1) loads from 148.09% to 148.27% (**DC power flow**) of its load dump rating (1379 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT2-3__'. This project contributes approximately 17.65 MW to the thermal violation.

Same as Contribution to Previously Identified #8

10. (CE - CE) The KENDALL ;BU-LOCKPORT ; B 345 kV line (from bus 274702 to bus 270810 ckt 1) loads from 118.58% to 119.61% (**DC power flow**) of its load dump rating (1479 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_111-45-L16704T'. This project contributes approximately 15.04 MW to the thermal violation.

COMED:

ComEd 345kV L10805 SSTE rating is 1568 MVA. The post contingency flow for this event exceeds the rating therefore an upgrade is required. The upgrade will be to mitigate sag on the line along with re-conductoring of the line. Station conductor work at the Lockport is also required. A preliminary estimate for this upgrade is \$10.1 million with a preliminary construction timeline of 30-36 months. Upon completion of the upgrade the ratings will be 1334/1726/1837/2084 MVA (SN/SLTE/SSTE/SLD).

11. (CE - CE) The KENDALL ;BU-LOCKPORT ; B 345 kV line (from bus 274702 to bus 270810 ckt 1) loads from 118.28% to 119.3% (**DC power flow**) of its load dump rating (1479 MVA) for the bus fault outage of 'COMED_P2-2_111_EJ-345B__2'. This project contributes approximately 15.06 MW to the thermal violation.

Same as Contribution to Previously Identified #10

12. (CE - CE) The KENDALL ;BU-LOCKPORT ; B 345 kV line (from bus 274702 to bus 270810 ckt 1) loads from 118.28% to 119.3% (**DC power flow**) of its load dump rating (1479 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_111-45-L11126_'. This project contributes approximately 15.06 MW to the thermal violation.

Same as Contribution to Previously Identified #10

13. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 126.42% to 126.47% (**DC power flow**) of its emergency rating (1399 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 14.47 MW to the thermal violation.

Same as Contribution to Previously Identified #4

14. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 125.93% to 125.99% (**DC power flow**) of its emergency rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT2-3__'. This project contributes approximately 14.56 MW to the thermal violation.

Same as Contribution to Previously Identified #4

15. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 125.89% to 125.94% (**DC power flow**) of its emergency rating (1399

MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT4-5__'. This project contributes approximately 14.54 MW to the thermal violation.

Same as Contribution to Previously Identified #4

16. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 125.88% to 125.93% (**DC power flow**) of its emergency rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT3-4__'. This project contributes approximately 14.54 MW to the thermal violation.

Same as Contribution to Previously Identified #4

17. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 133.06% to 133.16% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 11.49 MW to the thermal violation.

COMED:

ComEd 345kV L97008 SSTE rating is 1134 MVA. The post contingency flow exceeds the rating therefore an upgrade is required. The upgrade will be to mitigate the sag on the line. A preliminary estimate for this upgrade is \$ 22.6 million with a construction timeline of 30 months. Upon completion of the upgrade the ratings will be 1334/1334/1391/1523 MVA (SN/SLTE/SSTE/SLD).

18. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.92% to 132.01% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT4-5__'. This project contributes approximately 11.57 MW to the thermal violation.

Same as Contribution to Previously Identified #17

19. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.92% to 132.01% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT4-5__'. This project contributes approximately 11.57 MW to the thermal violation.

Same as Contribution to Previously Identified #17

20. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.92% to 132.01% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT3-4__'. This project contributes approximately 11.57 MW to the thermal violation.

Same as Contribution to Previously Identified #17

21. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.91% to 132.0% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT2-3__'. This project contributes approximately 11.58 MW to the thermal violation.

Same as Contribution to Previously Identified #17

22. (CE - CE) The WILTON ; 765/345 kV transformer (from bus 275232 to bus 270644 ckt 1) loads from 145.12% to 145.32% (**DC power flow**) of its load dump rating (1379 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT5-6__'. This project contributes approximately 17.29 MW to the thermal violation.

Same as Contribution to Previously Identified #8

23. (CE - CE) The WILTON ; 765/345 kV transformer (from bus 275233 to bus 270644 ckt 1) loads from 148.08% to 148.26% (**DC power flow**) of its load dump rating (1379 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT2-3__'. This project contributes approximately 17.65 MW to the thermal violation.

Same as Contribution to Previously Identified #8

Secondary Point of Interconnection (Option-2)

Under this option, the IC AD2-066, a 116 MW solar facility, proposes to interconnect with the ComEd transmission system by tying into the Lasalle-Mazon 138kV Line 0108.

Attachment Facilities

The IC AD2-066 generator lead would interconnect to a new 138kV Interconnection Substation. This interconnection would require one 138kV line MOD, a dead-end structure and revenue metering as shown in the one-line diagram.

The cost for the attachment facilities is estimated at \$1M.

Scope of Work	Cost Estimate
Installation of one 138kV line MOD, one dead-end structure and one set of revenue metering (see notes below on cost estimate)	\$1,000,000

Direct Connection Network Upgrades

In order to accommodate interconnection of AD2-066, a new 138kV Interconnection Substation would need to be built close to the Lasalle-Mazon 138kV Line 0108 approximately 8.4 miles from the Mazon TSS 77.

The scope of work includes the installation of three 138kV circuit breakers in a “breaker-and-a-half” bus configuration and cutting in the Interconnection Substation Lasalle-Mazon 138kV Line 0108, as shown in the one-line diagram below.

The IC is responsible for constructing all of the facilities on the IC side of the point of interconnection outside of the substation. It is assumed for the purposes of this report that the IC will obtain the site for the Interconnection Substation and right-of-way between the Interconnection Substation and the 138kV transmission line.

In the event that the IC exercises the option to build the interconnecting substation, the IC will be required to construct all interconnection facilities that will be turned over to ComEd in accordance with ComEd published standards and the PJM Tariff.

ComEd would design, engineer and construct the tie in of the Interconnection Substation to the Lasalle-Mazon 138kV Line 0108.

The preliminary cost estimate for Direct Connection Network Upgrade is given in the following tables.

For Option to Build Direct Connection cost estimates:

Scope of Work	Cost Estimate
Installation of a new 138kV substation as described above	N/A

Transmission line tie in work (foundations, structures, conductors)	\$ 2,000,000
ComEd oversight and testing	\$ 1,000,000
Total Cost Estimate (see notes below on cost estimate)	\$ 3,000,000

For ComEd building the interconnecting substation cost estimates:

Scope of Work	Cost Estimate
Installation of a new 138kV substation as described above	\$15,000,000
Transmission line tie in work (foundations, structures, conductors)	\$ 2,000,000
Total Cost Estimate (see notes below on cost estimate)	\$ 17,000,000

ComEd would take approximately 24-months to construct the substation and transmission line work after the ISA / ICSA are signed.

Non-Direct Connection Network Upgrades


The integration of the new 138kV Interconnection Substation would require relay/communications/SCADA upgrades at the Mazon TSS 77 and Lasalle Sta. 1 substations. The ComEd cost is given below:

Scope of Work	Cost Estimate
Relay/communications/SCADA upgrades at Mazon TSS 77 substation	\$ 750,000
Relay/communications/SCADA upgrades at Lasalle Sta. 1 substation	\$ 750,000
Total Cost Estimate (see notes below on cost estimate)	\$ 1,500,000

Notes on Cost Estimate:

- 1) These estimates are Order-of-Magnitude estimates of the costs that ComEd would bill to the customer for this interconnection. These estimates are based on a one-line electrical diagram of the project and the information provided by the IC.
- 2) There were no site visits performed for these estimates. There may be costs related to specific site related issues that are not identified in these estimates. The site reviews will be performed during the Facilities Study or during detailed engineering.

- AD2-066
-
- SECONDARY POI



Network Impacts for Secondary POI

The Queue Project AD2-066 was evaluated as a 116.0 MW (Capacity 69.6 MW) injection tapping the Mazon; B to Lasco Sta; B 138kV line in the ComEd area. Project AD2-066 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AD2-066 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Analysis - 2021

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

1. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 109.36% to 109.42% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 11.19 MW to the thermal violation.

CONTINGENCY 'AEP_P4_#2978_05DUMONT 765'
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 X1-020
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1
END

2. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 108.57% to 108.63% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT2-3__'. This project contributes approximately 11.31 MW to the thermal violation.

CONTINGENCY 'COMED_P4_023-65-BT2-3__'
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765
END

3. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 108.53% to 108.59% (**DC power flow**) of its emergency rating (1091

MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT4-5__'. This project contributes approximately 11.28 MW to the thermal violation.

```
CONTINGENCY 'COMED_P4_112-65-BT4-5__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345  
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33  
END
```

4. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 108.53% to 108.59% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT3-4__'. This project contributes approximately 11.28 MW to the thermal violation.

```
CONTINGENCY 'COMED_P4_112-65-BT3-4__'  
TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765  
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345  
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33  
END
```

5. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 163.84% to 163.95% (**DC power flow**) of its emergency rating (1409 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 17.23 MW to the thermal violation.

```
CONTINGENCY 'AEP_P4_#2978_05DUMONT 765'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 X1-020  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

6. (CE - MISO NIPS) The BURNHAM ;OR-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 129.36% to 129.47% (**DC power flow**) of its emergency rating (1195 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 14.52 MW to the thermal violation.

```
CONTINGENCY 'AEP_P4_#2978_05DUMONT 765'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 X1-020  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

7. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.77% to 108.83% (**DC power flow**) of its load dump rating (1399 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 15.94 MW to the thermal violation.

```
CONTINGENCY 'AEP_P4_#2978_05DUMONT 765'  
OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 X1-020  
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1  
END
```

8. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.27% to 108.33% (**DC power flow**) of its load dump rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT2-3__'. This project contributes approximately 16.1 MW to the thermal violation.

CONTINGENCY 'COMED_P4_023-65-BT2-3__'
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
 TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765
 END

9. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.23% to 108.29% (**DC power flow**) of its load dump rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT4-5__'. This project contributes approximately 16.04 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT4-5__'
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765
 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345
 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33
 END

10. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.21% to 108.28% (**DC power flow**) of its load dump rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT3-4__'. This project contributes approximately 16.04 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT3-4__'
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765
 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345
 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33
 END

11. (CE - MISO NIPS) The ST JOHN ; T-17GREEN_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 109.35% to 109.41% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 11.19 MW to the thermal violation.

CONTINGENCY 'AEP_P4_#2978_05DUMONT 765'
 OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 X1-020
 OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1
 END

12. (CE - MISO NIPS) The ST JOHN ; T-17GREEN_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 108.57% to 108.63% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT2-3__'. This project contributes approximately 11.31 MW to the thermal violation.

CONTINGENCY 'COMED_P4_023-65-BT2-3__'
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
 TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765
 END

13. (CE - MISO NIPS) The ST JOHN ; T-17GREEN_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 108.53% to 108.59% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT4-5__'. This project contributes approximately 11.28 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT4-5__'

TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1	/ WILTO; 765 05DUMONT 765
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1	/ WILTO;4M 345 WILTO; 765
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1	/ WILTO;4M 345 WILTO; R 345
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1	/ WILTO;4M 345 WILTO;4C 33

END

14. (CE - MISO NIPS) The ST JOHN ; T-17GREEN_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 108.53% to 108.59% (**DC power flow**) of its emergency rating (1091 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT3-4__'. This project contributes approximately 11.28 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT3-4__'

TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1	/ WILTO; 765 05DUMONT 765
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1	/ WILTO;3M 345 WILTO; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1	/ WILTO;3M 345 WILTO; B 345
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1	/ WILTO;3M 345 WILTO;3C 33

END

15. (CE - CE) The WILTON ; B-WILTON ;3M 345 kV line (from bus 270926 to bus 275232 ckt 1) loads from 144.99% to 145.17% (**DC power flow**) of its load dump rating (1379 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT5-6__'. This project contributes approximately 18.52 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT5-6__'

TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1	/ WILTO; 765 COLLI; 765
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1	/ WILTO;4M 345 WILTO; 765
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1	/ WILTO;4M 345 WILTO; R 345
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1	/ WILTO;4M 345 WILTO;4C 33

END

16. (CE - CE) The WILTON ; R-WILTON ;4M 345 kV line (from bus 270927 to bus 275233 ckt 1) loads from 148.03% to 148.2% (**DC power flow**) of its load dump rating (1379 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT2-3__'. This project contributes approximately 18.91 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT2-3__'

TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1	/ WILTO; 765 COLLI; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1	/ WILTO;3M 345 WILTO; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1	/ WILTO;3M 345 WILTO; B 345
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1	/ WILTO;3M 345 WILTO;3C 33

END

17. (CE - MISO AMIL) The HENNEEPIN; T-4HENNEPIN S 138 kV line (from bus 271655 to bus 348918 ckt 1) loads from 110.96% to 112.72% (**DC power flow**) of its emergency rating (160 MVA) for the tower line contingency outage of 'COMED_P7_138-L0108__B-S+_138-L7713__R-S_A'. This project contributes approximately 6.25 MW to the thermal violation.

CONTINGENCY 'COMED_P7_138-L0108__B-S+_138-L7713__R-S_A'

TRIP BRANCH FROM BUS 936510 TO BUS 271986 CKT 1	/ AD2-066 TAP 138 MAZON ; B 138
---	---------------------------------

TRIP BRANCH FROM BUS 271241 TO BUS 272189 CKT 1	/ CRESCENT OGLES; T 138
TRIP BRANCH FROM BUS 271241 TO BUS 271836 CKT 1	/ CRESCENT KEWANEE 138
TRIP BRANCH FROM BUS 272189 TO BUS 271987 CKT 1	/ OGLES; T 138 MAZON; R 138
TRIP BRANCH FROM BUS 272189 TO BUS 348935 CKT 1	/ OGLES; T 138 4OGLESBY MN 138

END

18. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 126.33% to 126.39% (**DC power flow**) of its emergency rating (1399 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 15.76 MW to the thermal violation.

CONTINGENCY 'AEP_P4_#2978_05DUMONT 765'

OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1	/ 243206 05DUMONT 765 X1-020
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1	/ 243206 05DUMONT 765 270644 WILTON ; 765 1

END

19. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 125.84% to 125.91% (**DC power flow**) of its emergency rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT2-3__'. This project contributes approximately 15.92 MW to the thermal violation.

CONTINGENCY 'COMED_P4_023-65-BT2-3__'

TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1	/ WILTO; 765 05DUMONT 765
TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1	/ COLLI; 765 PLANO; 765

END

20. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 125.8% to 125.86% (**DC power flow**) of its emergency rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT4-5__'. This project contributes approximately 15.86 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT4-5__'

TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1	/ WILTO; 765 05DUMONT 765
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1	/ WILTO;4M 345 WILTO; 765
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1	/ WILTO;4M 345 WILTO; R 345
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1	/ WILTO;4M 345 WILTO;4C 33

END

21. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 125.79% to 125.85% (**DC power flow**) of its emergency rating (1399 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT3-4__'. This project contributes approximately 15.85 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT3-4__'

TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1	/ WILTO; 765 05DUMONT 765
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1	/ WILTO;3M 345 WILTO; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1	/ WILTO;3M 345 WILTO; B 345
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1	/ WILTO;3M 345 WILTO;3C 33

END

22. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 133.02% to 133.12% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'AEP_P4_#2978_05DUMONT 765'. This project contributes approximately 12.37 MW to the thermal violation.

CONTINGENCY 'AEP_P4_#2978_05DUMONT 765'
 OPEN BRANCH FROM BUS 243206 TO BUS 907040 CKT 1 / 243206 05DUMONT 765 X1-020
 OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1
 END

23. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.88% to 131.98% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT4-5__'. This project contributes approximately 12.47 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT4-5__'
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765
 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345
 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33
 END

24. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.88% to 131.97% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT4-5__'. This project contributes approximately 12.47 MW to the thermal violation.

CONTINGENCY 'COMED_P4_023-65-BT4-5__'
 TRIP BRANCH FROM BUS 275168 TO BUS 270607 CKT 1 / COLLI;2M 345 COLLI; 765
 TRIP BRANCH FROM BUS 275168 TO BUS 270697 CKT 1 / COLLI;2M 345 COLLI; R 345
 TRIP BRANCH FROM BUS 275168 TO BUS 275268 CKT 1 / COLLI;2M 345 COLLI;2C 33
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
 END

25. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.88% to 131.97% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT3-4__'. This project contributes approximately 12.47 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT3-4__'
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765
 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345
 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33
 END

26. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.85% to 131.95% (**DC power flow**) of its emergency rating (971 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_023-65-BT2-3__'. This project contributes approximately 12.49 MW to the thermal violation.

CONTINGENCY 'COMED_P4_023-65-BT2-3__'
 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765
 TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765
 END

27. (CE - CE) The WILTON ; 765/345 kV transformer (from bus 275232 to bus 270644 ckt 1) loads from 144.99% to 145.17% (**DC power flow**) of its load dump rating (1379 MVA) for the

line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT5-6__'. This project contributes approximately 18.52 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT5-6__'

TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1	/ WILTO; 765 COLLI; 765
TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1	/ WILTO;4M 345 WILTO; 765
TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1	/ WILTO;4M 345 WILTO; R 345
TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1	/ WILTO;4M 345 WILTO;4C 33

END

28. (CE - CE) The WILTON ; 765/345 kV transformer (from bus 275233 to bus 270644 ckt 1) loads from 148.03% to 148.2% (**DC power flow**) of its load dump rating (1379 MVA) for the line fault with failed breaker contingency outage of 'COMED_P4_112-65-BT2-3__'. This project contributes approximately 18.91 MW to the thermal violation.

CONTINGENCY 'COMED_P4_112-65-BT2-3__'

TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1	/ WILTO; 765 COLLI; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1	/ WILTO;3M 345 WILTO; 765
TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1	/ WILTO;3M 345 WILTO; B 345
TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1	/ WILTO;3M 345 WILTO;3C 33

END

Steady-State Voltage Requirements

(Results of the steady-state voltage studies should be inserted here)

To be determined

Short Circuit

(Summary of impacted circuit breakers)

None

Affected System Analysis & Mitigation

MISO Impacts:

MISO Impacts to be determined during later study phases (as applicable).

Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request. Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

1. (MISO NIPS - CE) The 17STJOHN-ST JOHN ; T 345 kV line (from bus 255112 to bus 270886 ckt 1) loads from 108.5% to 108.56% (**DC power flow**) of its emergency rating (1091

MVA) for the single line contingency outage of 'COMED_P1-2_695_B2'. This project contributes approximately 11.28 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_695_B2'
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1
END

2. (MISO NIPS - AEP) The 17STILLWELL-05DUMONT 345 kV line (from bus 255113 to bus 243219 ckt 1) loads from 160.47% to 160.58% (**DC power flow**) of its normal rating (1409 MVA) for the single line contingency outage of 'COMED_P1-2_695_B2'. This project contributes approximately 17.72 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_695_B2'
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1
END

3. (CE - MISO NIPS) The BURNHAM ;0R-17MUNSTER 345 kV line (from bus 270677 to bus 255109 ckt 1) loads from 128.4% to 128.51% (**DC power flow**) of its emergency rating (1195 MVA) for the single line contingency outage of 'COMED_P1-2_695_B2'. This project contributes approximately 14.62 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_695_B2'
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1
END

4. (CE - CE) The E FRANKFO; B-CRETE EC ;BP 345 kV line (from bus 270728 to bus 274750 ckt 1) loads from 108.12% to 108.18% (**DC power flow**) of its emergency rating (1399 MVA) for the single line contingency outage of 'COMED_P1-2_695_B2'. This project contributes approximately 16.02 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_695_B2'
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1
END

5. (CE - AEP) The GREENACRE; T-05OLIVE 345 kV line (from bus 270771 to bus 243229 ckt 1) loads from 110.54% to 110.62% (**DC power flow**) of its normal rating (971 MVA) for the single line contingency outage of 'COMED_P1-2_695_B2'. This project contributes approximately 10.14 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_695_B2'
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1
END

6. (CE - MISO NIPS) The ST JOHN ; T-17GREEN_ACRE 345 kV line (from bus 270886 to bus 255104 ckt 1) loads from 108.49% to 108.55% (**DC power flow**) of its emergency rating (1091 MVA) for the single line contingency outage of 'COMED_P1-2_695_B2'. This project contributes approximately 11.28 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_695_B2'
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206
05DUMONT 765 270644 WILTO; 765 1
END

7. (CE - CE) The LASCO STA; B 345/138 kV transformer (from bus 271908 to bus 270802 ckt 1) loads from 82.3% to 103.56% (**DC power flow**) of its emergency rating (449 MVA) for the single line contingency outage of 'COMED_P1-2_138-L0108__B-S_B'. This project contributes approximately 102.08 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_138-L0108__B-S_B'
TRIP BRANCH FROM BUS 936510 TO BUS 271986 CKT 1 / AD2-066 TAP 138 MAZON; B 138
END

8. (CE - CE) The ESS J339 ; B-DRESDEN ; B 138 kV line (from bus 272124 to bus 271336 ckt 1) loads from 88.04% to 115.24% (**DC power flow**) of its emergency rating (268 MVA) for the single line contingency outage of 'COMED_P1-3_TR81_LASCO_B-S'. This project contributes approximately 72.87 MW to the thermal violation.

CONTINGENCY 'COMED_P1-3_TR81_LASCO_B-S'
TRIP BRANCH FROM BUS 270802 TO BUS 270803 CKT 1 / LASCO STA; B 345 LASCO STA; R 345
TRIP BRANCH FROM BUS 270802 TO BUS 271908 CKT 1 / LASCO STA; B 345 LASCO STA; B 138
END

9. (CE - MISO NIPS) The CRETE EC ;BP-17STJOHN 345 kV line (from bus 274750 to bus 255112 ckt 1) loads from 125.69% to 125.76% (**DC power flow**) of its emergency rating (1399 MVA) for the single line contingency outage of 'COMED_P1-2_695_B2'. This project contributes approximately 15.84 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_695_B2'
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1
END

10. (CE - AEP) The UNIV PK N;RP-05OLIVE 345 kV line (from bus 274804 to bus 243229 ckt 1) loads from 131.83% to 131.93% (**DC power flow**) of its normal rating (971 MVA) for the single line contingency outage of 'COMED_P1-2_695_B2'. This project contributes approximately 12.47 MW to the thermal violation.

CONTINGENCY 'COMED_P1-2_695_B2'
OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTO; 765 1
END

11. (CE - CE) The AD2-066 TAP-MAZON ; B 138 kV line (from bus 936510 to bus 271986 ckt 1) loads from 125.65% to 157.92% (**DC power flow**) of its emergency rating (223 MVA) for the single line contingency outage of 'COMED_P1-3_TR81_LASCO_B-S'. This project contributes approximately 81.58 MW to the thermal violation.

CONTINGENCY 'COMED_P1-3_TR81_LASCO_B-S'
TRIP BRANCH FROM BUS 270802 TO BUS 270803 CKT 1 / LASCO STA; B 345 LASCO STA; R 345
TRIP BRANCH FROM BUS 270802 TO BUS 271908 CKT 1 / LASCO STA; B 345 LASCO STA; B 138
END

12. (CE - CE) The AD2-066 TAP-MAZON ; B 138 kV line (from bus 936510 to bus 271986 ckt 1) loads from 80.6% to 104.65% (**DC power flow**) of its normal rating (173 MVA) for non-contingency condition. This project contributes approximately 41.6 MW to the thermal violation.

Light Load Analysis - 2021

Light Load Studies to be conducted during later study phases (as required by PJM Manual 14B).