

# ***Generation Interconnection Feasibility Study Report Queue Position AD2-116***

Interconnection Customer has proposed a new solar generation facility of 20 MW net capability output. PJM recognizes 13 MW as Capacity Interconnection Rights for this project. The facility is located in Berks County, Pennsylvania. The proposed in-service date is October 31, 2020.

**This study does not imply a Mid-Atlantic Interstate Transmission (MAIT or Met-Ed) commitment to this in-service date.**

## **Point of Interconnection (“POI”)**

The AD2-116 will interconnect with the Met-Ed subtransmission system through one of the following two options:

- Option 1 POI (or Primary POI) will be tapping the Hokes-Grantley subtransmission 69 kV line at a point located less than a mile from Hokes substation and approximately 3 miles from Grantley substation. The Point of Interconnection will be located close to transmission line. The POI will be modeled at Grantley segment bus #204722 and Hokes bus #204723.
- Option 2 POI (or Secondary POI) will be direct injection into the Lyons substation. Met-Ed will construct a new 69 kV line terminal at the substation. The dead-end structure will be the location of the POI. A full scope of work or estimated cost is not provided for the Secondary POI.

## **Network Impacts**

### **AD2-116 Option 1 POI - Summer Peak Analysis – 2021**

The Queue Project AD2-116 was evaluated as a 20.0 MW (Capacity 13.0 MW) injection tapping the Hokes to Grantley 69kV line in the METED area. Project AD2-116 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AD2-116 was studied with a commercial probability of 53%. Potential network impacts were as follows:

**Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

None

**Multiple Facility Contingency**

*(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)*

None

**Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

None

**Steady-State Voltage Requirements**

To be determined at system impact study stage.

**Short Circuit**

None

**Affected System Analysis & Mitigation****Delivery of Energy Portion of Interconnection Request**

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

None

**Light Load Analysis - 2021**

Light Load Studies to be conducted during later study phases (as required by PJM Manual 14B).

**System Reinforcements****Short Circuit**

None

### **Stability and Reactive Power Requirement**

To be determined at system impact study stage.

### **Summer Peak Load Flow Analysis Reinforcements**

#### **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None

#### **Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

None

### **Light Load Load Flow Analysis Reinforcements**

#### **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None

#### **Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

None

## **Option 2 - Summer Peak Analysis - 2021**

The Queue Project AD2-116 was evaluated as a 20.0 MW (Capacity 13.0 MW) injection at the Hokes 69kV substation in the METED area. Project AD2-116 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AD2-116 was studied with a commercial probability of 53%. Potential network impacts were as follows:

### **Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

None

**Multiple Facility Contingency**

*(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)*

None

**Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

None

**Steady-State Voltage Requirements**

To be determined at system impact study stage.

**Short Circuit**

None

**Affected System Analysis & Mitigation**

**Delivery of Energy Portion of Interconnection Request**

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

None

**Light Load Analysis - 2021**

Light Load Studies to be conducted during later study phases (as required by PJM Manual 14B).

**System Reinforcements**

**Short Circuit**

None

## **Stability and Reactive Power Requirement**

To be determined at system impact study stage.

## **Summer Peak Load Flow Analysis Reinforcements**

### **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None

### **Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

None

## **Light Load Load Flow Analysis Reinforcements**

### **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None

### **Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

None