

# ***Generation Interconnection Feasibility Study Report Queue Position AD2-158***

Interconnection Customer has proposed a 77.5 MW solar generating facility to be located in Charles Town city, Jefferson County, West Virginia. PJM recognizes 46.5 MW as Capacity Interconnection Rights for this project. The proposed in-service date is September 1, 2020. **This study does not imply a Potomac Edison (“Transmission Owner”) commitment to this in-service date.**

## **Point of Interconnection (POI)**

The AD2-158 solar project will interconnect with the Potomac Edison transmission system by tapping the Old Chapel – Millville 138 kV line at a point located approximately 9 miles from Old Chapel substation and 5 miles from Millville substation. A new three breaker ring bus station will be built to tap the line. The project will be modeled at bus #235486 (Millville) and 235498 (Old Chapel). The POI will be located outside the substation at the exist side to solar plant.

## **Network Impacts**

The Queue Project AD2-158 was evaluated as a 77.5 MW (Capacity 46.5 MW) injection tapping the Old Chapel to Millville 138kV line in the APS area. Project AD2-158 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AD2-158 was studied with a commercial probability of 53%. Potential network impacts were as follows:

## **Summer Peak Analysis - 2021**

### **Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

None

**Multiple Facility Contingency**

*(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)*

None

**Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

None

**Steady-State Voltage Requirements**

To be determined at the system impact study stage.

**Short Circuit**

None

**Delivery of Energy Portion of Interconnection Request**

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

None

**Light Load Analysis - 2021**

Light Load Studies to be conducted during later study phases (as required by PJM Manual 14B).

**System Reinforcements**

**Short Circuit**

None

**Stability and Reactive Power Requirement**

To be determined at the system impact study stage.

## **Summer Peak Load Flow Analysis Reinforcements**

### **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None

### **Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

None

## **Light Load Load Flow Analysis Reinforcements**

### **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None

### **Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

None