

***Generation Interconnection  
Feasibility Study Report***

***For***

***PJM Generation Interconnection Request  
Queue Position AD2-192***

***“Glen Falls 138 kV”***

***20 MW Capacity / 45 MW Energy Uprate***

**August 2018**

Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network users, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

General

The Interconnection Customer (IC), has proposed an increase in output of their planned future Glen Falls combined cycle natural gas facility to be located in Harrison County, Clarksburg, West Virginia. The uprate will increase the maximum facility output (MFO) of the combined cycle facility by 45 MWE for a total plant MFO of 625 MW. The uprate will also increase the Capacity value by 20 MW for a total of 600 MW being recognized by PJM as Capacity. (See the summary table below.) The installed facilities will have a total capability of **625 MW** with **600 MW** of this output being recognized by PJM as Capacity. The proposed in-service date for this project is **June 1, 2021**. **This study does not imply an Allegheny Power Systems (APS) commitment to this in-service date.**

Uprate to AA2-119 and AC1-055 Glen Falls Facility (no new equipment):

Queue No.	MFO (MW)	Capacity (MW)
AA2-119	550	550
AC1-055	30	30
AD2-192	+45	+20
Total	625	600

Point of Interconnection

**AD2-192 “Glen Falls 138 kV”** uprate project will be at increase to the planned future Glen Falls combined cycle natural gas generation plant which will interconnect to the APS transmission system at the Glen Falls 138 kV substation bus.

Attachment 1 shows the one line diagram of the project and the point of interconnection with the Glen Falls 138 kV substation.

Cost Summary

The **AD2-192 “Glen Falls 138 kV”** project will be responsible for the following costs. These costs do not include CIAC Tax Gross-up:

Description	Total Cost
Attachment Facilities	\$ 0
Direct Connection Network Upgrades	\$ 0
Non Direct Connection Network Upgrades (APS)	\$ 6,200
<b>Total Costs</b>	<b>\$ 6,200</b>

In addition, the AD2-192 project may be responsible for a contribution to the following costs:

Description	Total Cost
New System Upgrades	\$ 0
Previously Identified Upgrades	\$ 2,665,000
<b>Total Costs</b>	<b>\$ 2,665,000</b>

The transmission and substation costs given above exclude any applicable state or federal taxes. If at a future date Federal CIAC (contribution in aid of construction) taxes are deemed necessary by the IRS for this project, APS shall be reimbursed by the Interconnection Customer for such taxes. APS estimates the tax, if applicable, would be approximately **\$363,400** (\$900 for Non-Direct Connection Network Upgrades and \$362,500 for Previously Identified Upgrades).

The required Attachment Facilities, Direct Connection, and Non-Direct Connection work for the interconnection of the AD2-192 generation project to the JCPL Transmission System is detailed in the following sections. The associated one-line with the generation project is shown in Attachment 1.

Note that all cost estimates contained in this document were produced without a detailed engineering review and are therefore subject to change. IC will be responsible for the actual cost of the work that is implemented. APS herein reserves the right to return to any issues in this document and, upon appropriate justification, request additional monies to complete any reinforcements to the transmission or subtransmission systems.

**Attachment Facilities**

There is no Attachment Facilities work required for this project.

**Direct Connection Cost Estimate**

There is no Direct Connection scope of work required for this project.

**Non-Direct Connection Cost Estimate**

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Glen Falls 138 kV SS. Adjust Remote Relay and Metering Settings at the Glen Falls 138 kV substation (APS)	\$ 6,200
<b>Total Non-Direct Connection Facility Costs</b>	<b>\$ 6,200</b>

The total Non-Direct Connection cost estimate for the AD2-192 project is approximately **\$6,200**. This work is to review the protection system settings at APS’s Glen Falls Substation and to implement any necessary changes.

## Schedule

Based on the extent of the APS Non-Direct Connection work required to support the AD2-192 generation project, it is expected to take a minimum of **8 months** from the date of a fully executed Interconnection Construction Service Agreement to complete the installation. This includes the requirement for the Interconnection Customer to make a preliminary payment to APS which funds the construction of the Non-Direct Connection facilities and Network Upgrade work (*AD2-192 may have some cost allocation for the network upgrade identified in this report under the “Network Impacts” section. Cost allocation will be determined in the System Impact Study phase. Customer will be required to pay full Security for their allocation of the network upgrade if they sign an ISA*). It assumes that there will be no environmental or permitting issues to implement the upgrades required for this uprate project and that all system outages will be allowed when requested. The time required to complete the required network upgrades is identified in the “**Network Impacts**” section below.

## Revenue Metering and SCADA Requirements

### PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC’s generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

### JPCL Requirements

The IC will be required to comply with all FE revenue metering requirements for generation interconnection customers which can be found in FE’s “Requirements for Transmission Connected Facilities” document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>.

## Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with FE’s “Requirements for Transmission Connected Facilities” document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated 138 kV circuit breaker to protect the AD2-192 generator lead line. A single circuit breaker must be used to protect this line; if the project has several GSU transformers, the individual GSU transformer breakers cannot be used to protect this line.
2. The purchase and installation of the minimum required FE generation interconnection relaying and control facilities. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition (“SCADA”) equipment to provide information in a compatible format to the FE Transmission System Control Center.
4. Compliance with the FE and PJM generator power factor and voltage control requirements.
5. The execution of a back-up service agreement to serve the customer load supplied from the AD2-192 generation project metering point when the units are out-of-service. This assumes the intent of the IC is to net the generation with the load.

The IC will also be required to meet all PJM, ReliabilityFirst, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and ReliabilityFirst audits. Failure to comply with these requirements may result

in a disconnection of service if the violation is found to compromise the reliability of the FE system.

## **Power Factor Requirements**

The 580 MW portion of the Customer Facility (installed by December 31, 2020 under AA2-119 and AC1-055) shall maintain a power factor of at least 0.95 leading to 0.90 lagging measured at the generator's terminals.

The increase of 45 MW to the Customer Facility associated with this AD2-192 project (by June 1, 2021) shall be designed with the ability to maintain a power factor of at least 1.0 (unity) to 0.90 lagging (supplying vars) measured at the generator's terminals.

## **JCPL Analysis:**

### **Power Flow Analysis**

PJM performed a power flow analysis of the transmission system using a 2021 summer peak load flow model and the results were verified by FE. Additionally, FE performed an analysis of its underlying transmission <100 kV system. At the Primary POI, the AD2-192 project contributes to overloads on the FE transmission system as shown in the Network Impact section of this report. The estimated cost of system reinforcements necessary to mitigate these overloads are also provided.

### **Short Circuit Analysis**

No short circuit analysis was required for this project since it is an uprate project and the original electrical characteristics of the machines and GSUs did not change.

### **Stability Analysis**

PJM will be responsible for completing a dynamic stability analysis, if necessary, as part of the System Impact Study. The results of this analysis will be reviewed by FE. Should stability concerns be identified in PJM's study, FE will develop the appropriate system reinforcement(s) and included the estimated cost of any reinforcement(s) in FE's System Impact Study report.

### **System Protection**

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

## Network Impacts

The Queue Project AD2-192 was evaluated as a 20.0 MW (Capacity 20.0 MW) uprate to AA2-119 / AC1-055 which is an injection at Glenn Falls 138kV substation in the APS area. Project AD2-192 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AD2-192 was studied with a commercial probability of 53%. Potential network impacts were as follows:

### Contingency Descriptions

The following contingencies resulted in overloads:

Contingency Name	Description
AP-P1-2-MP-138-013A	CONTINGENCY 'AP-P1-2-MP-138-013A' /* 53 DISCONNECT BRANCH FROM BUS 235334 TO BUS 235375 CKT 1 /* 01GLENFL 138 01NATLCN 138 DISCONNECT BRANCH FROM BUS 235375 TO BUS 235415 CKT 1 /* 01NATLCN 138 01RIDER 138 END
AP-P1-2-MP-138-023	CONTINGENCY 'AP-P1-2-MP-138-023' /* 235417 01VARNER 138 235432 01WALDORN 138 1 DISCONNECT BRANCH FROM BUS 235334 TO BUS 235812 CKT 1 /* 01GLENFL 138 01CHIEFTON 138 DISCONNECT BRANCH FROM BUS 235417 TO BUS 235812 CKT 1 /* 01VARNER 138 01CHIEFTON 138 DISCONNECT BRANCH FROM BUS 235417 TO BUS 235432 CKT 1 /* 01VARNER 138 01WALDORN 138 END
AP-P2-2-MP-138-013	CONTINGENCY 'AP-P2-2-MP-138-013' /* GLEN-FALLS-138-EAST DISCONNECT BRANCH FROM BUS 235334 TO BUS 235375 CKT 1 /* 01GLENFL 138 01NATLCN 138 DISCONNECT BRANCH FROM BUS 235334 TO BUS 235349 CKT 1 /* 01GLENFL 138 01HARR T 138 DISCONNECT BRANCH FROM BUS 235334 TO BUS 235442 CKT 1 /* 01GLENFL 138 01MCALPN 138 END

Contingency Name	Description
AP-P2-3-MP-138-023	<p>CONTINGENCY 'AP-P2-3-MP-138-023' /* GLEN FALLS-MCALPIN STK BKR AT GLEN FALLS</p> <p>DISCONNECT BRANCH FROM BUS 235334 TO BUS 235349 CKT 1 /* 01GLENFL 138 01HARR T 138</p> <p>DISCONNECT BRANCH FROM BUS 235334 TO BUS 235375 CKT 1 /* 01GLENFL 138 01NATLCN 138</p> <p>DISCONNECT BRANCH FROM BUS 235334 TO BUS 235442 CKT 1 /* 01GLENFL 138 01MCALPN 138</p> <p>END</p>
AP-P2-3-MP-138-024	<p>CONTINGENCY 'AP-P2-3-MP-138-024' /* GLEN FALLS-HARRISON TAP STK BKR AT GLEN FALLS</p> <p>DISCONNECT BRANCH FROM BUS 235334 TO BUS 235349 CKT 1 /* 01GLENFL 138 01HARR T 138</p> <p>DISCONNECT BRANCH FROM BUS 235347 TO BUS 235349 CKT 1 /* 01HARSNR 138 01HARR T 138</p> <p>DISCONNECT BRANCH FROM BUS 235349 TO BUS 235367 CKT 1 /* 01HARR T 138 01MARGAR 138</p> <p>DISCONNECT BRANCH FROM BUS 235347 TO BUS 235396 CKT 1 /* 01HARSNR 138 01ROBERT 138</p> <p>DISCONNECT BRANCH FROM BUS 235334 TO BUS 235442 CKT 1 /* 01GLENFL 138 01MCALPN 138</p> <p>DISCONNECT BRANCH FROM BUS 235334 TO BUS 235375 CKT 1 /* 01GLENFL 138 01NATLCN 138</p> <p>END</p>
AP-P7-1-MP-138-015	<p>CONTINGENCY 'AP-P7-1-MP-138-015' /* GLF-WUN-GLF-MRG</p> <p>DISCONNECT BRANCH FROM BUS 235334 TO BUS 235349 CKT 1 /* 01GLENFL 138 01HARR T 138</p> <p>DISCONNECT BRANCH FROM BUS 235347 TO BUS 235349 CKT 1 /* 01HARSNR 138 01HARR T 138</p> <p>DISCONNECT BRANCH FROM BUS 235349 TO BUS 235367 CKT 1 /* 01HARR T 138 01MARGAR 138</p> <p>DISCONNECT BRANCH FROM BUS 235417 TO BUS 235432 CKT 1 /* 01VARNER 138 01WALDORN 138</p> <p>DISCONNECT BRANCH FROM BUS 235417 TO BUS 235812 CKT 1 /* 01VARNER 138 01CHIEFTON 138</p> <p>DISCONNECT BRANCH FROM BUS 235347 TO BUS 235396 CKT 1 /* 01HARSNR 138 01ROBERT 138</p> <p>DISCONNECT BRANCH FROM BUS 235334 TO BUS 235812 CKT 1 /* 01GLENFL 138 01CHIEFTON 138</p> <p>END</p>

# Summer Peak Analysis - 2021

## Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

## Multiple Facility Contingency

(Double Circuit Tower Line contingencies were studied for the full energy output. The contingencies of Line with Failed Breaker and Bus Fault will be performed for the Impact Study.)

None

## Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

Overload Number	Type	Contingency Name	Affected Area	Facility Description	Bus From	Bus To	Circuit	Power Flow	Loading % Initial	Loading % Final	Rating Type	Rating MVA	MW Contribution	Flowgate Appendix
1	LFFB	AP-P2-3-MP-138-024	AP - AP	01GLENFL-01OAKMND 138 kV line	235334	235380	1	DC	143.51	148.01	ER	192	8.65	1
2	BUS	AP-P2-2-MP-138-013	AP - AP	01GLENFL-01OAKMND 138 kV line	235334	235380	1	DC	143.46	147.96	ER	192	8.65	
3	LFFB	AP-P2-3-MP-138-023	AP - AP	01GLENFL-01OAKMND 138 kV line	235334	235380	1	DC	143.46	147.96	ER	192	8.65	
4	DCTL	AP-P7-1-MP-138-015	AP - AP	01GLENFL-01OAKMND 138 kV line	235334	235380	1	DC	132.84	135.76	ER	192	5.61	



Overload Number	Contingency Type	Contingency Name	Affected Area	Facility Description	Bus From	Bus To	Circuit	Power Flow	Loading % Initial	Loading % Final	Rating Type	Rating MVA	MW Contribution	Flowgate Appendix
5	N-1	AP-P1-2-MP-138-023	AP - AP	01GLENFL-01OAKMND 138 kV line	235334	235380	1	DC	117.95	120.5	ER	192	4.9	
6	N-1	AP-P1-2-MP-138-013A	AP - AP	01GLENFL-01OAKMND 138 kV line	235334	235380	1	DC	102.84	105.56	ER	192	5.22	

## **Steady-State Voltage Requirements**

*(Summary of the VAR requirements based upon the results of the steady-state voltage studies)*

To be determined in the Impact Study Phase.

## **Short Circuit**

*(Summary of impacted circuit breakers)*

None.

## **Affected System Analysis & Mitigation**

*(Summary of impacts on systems external to PJM)*

### **NYISO Impacts:**

NYISO Impacts to be determined during later study phases (as applicable).

## **Delivery of Energy Portion of Interconnection Request**

*PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.*

*Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.*

None

### **Light Load Analysis**

*Light Load Studies to be conducted during later study phases (as required by PJM Manual 14B).*

### **Stability and Reactive Power Requirement for Low Voltage Ride Through**

*(Summary of the VAR requirements based upon the results of the dynamic studies)*

To be determined in the Impact Study phase.

### **Summer Peak Load Flow Analysis Reinforcements**

#### **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None

**Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

Violation #	Overloaded Facility	Upgrade Description	Network Upgrade Number	Upgrade Cost
1, 2, 3, 4, 5, 6	01GLENFL- 01OAKMND 138 kV line	(APS) Glenn Falls- Oak Mound 138 kV: Reconductor from Glen Falls Sub to structure #13, approx. 2.5 miles, replacing existing 336 ACSR with 954 ACSR.	N4855	<b>\$2,665,000</b>
<b>Total</b>				<b>\$2,665,000</b>

**Attachment 1. AD2-192 ‘Glen Falls 138 kV’  
One Line Diagram**

**Attachment 2. AD2-192 ‘Glen Falls 138 kV’  
Project Location**

## **Appendices**

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact.

It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

## Appendix 1

(AP - AP) The 01GLENFL-01OAKMND 138 kV line (from bus 235334 to bus 235380 ckt 1) loads from 143.51% to 148.01% (**DC power flow**) of its emergency rating (192 MVA) for the line fault with failed breaker contingency outage of 'AP-P2-3-MP-138-024'. This project contributes approximately 8.65 MW to the thermal violation.

```

CONTINGENCY 'AP-P2-3-MP-138-024'                                /* GLEN FALLS-HARRISON
TAP STK BKR AT GLEN FALLS
  DISCONNECT BRANCH FROM BUS 235334 TO BUS 235349 CKT 1        /* 01GLENFL
138 01HARR T 138
  DISCONNECT BRANCH FROM BUS 235347 TO BUS 235349 CKT 1        /* 01HARSNR
138 01HARR T 138
  DISCONNECT BRANCH FROM BUS 235349 TO BUS 235367 CKT 1        /* 01HARR T
138 01MARGAR 138
  DISCONNECT BRANCH FROM BUS 235347 TO BUS 235396 CKT 1        /* 01HARSNR
138 01ROBERT 138
  DISCONNECT BRANCH FROM BUS 235334 TO BUS 235442 CKT 1        /* 01GLENFL
138 01MCALPN 138
  DISCONNECT BRANCH FROM BUS 235334 TO BUS 235375 CKT 1        /* 01GLENFL
138 01NATLCN 138
END
  
```

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
<i>937391</i>	<i>AD2-192</i>	<i>8.65</i>
<i>LTF</i>	<i>AMIL</i>	<i>0.05</i>
<i>LTF</i>	<i>BAYOU</i>	<i>0.18</i>
<i>LTF</i>	<i>BIG_CAJUN1</i>	<i>0.28</i>
<i>LTF</i>	<i>BIG_CAJUN2</i>	<i>0.56</i>
<i>LTF</i>	<i>BLUEG</i>	<i>0.34</i>
<i>LTF</i>	<i>CALDERWOOD</i>	<i>0.09</i>
<i>LTF</i>	<i>CANNELTON</i>	<i>0.06</i>
<i>LTF</i>	<i>CATAWBA</i>	<i>0.05</i>
<i>LTF</i>	<i>CBM-N</i>	<i>0.02</i>
<i>LTF</i>	<i>CELEVELAND</i>	<i>0.14</i>
<i>LTF</i>	<i>CHEOAH</i>	<i>0.09</i>

<i>LTF</i>	<i>CHILHOWEE</i>	<i>0.03</i>
<i>LTF</i>	<i>CHOCTAW</i>	<i>0.18</i>
<i>LTF</i>	<i>CLIFTY</i>	<i>1.56</i>
<i>LTF</i>	<i>COTTONWOOD</i>	<i>0.72</i>
<i>LTF</i>	<i>DEARBORN</i>	<i>0.11</i>
<i>LTF</i>	<i>EDWARDS</i>	<i>0.09</i>
<i>LTF</i>	<i>ELMERSMITH</i>	<i>0.17</i>
<i>LTF</i>	<i>FARMERCITY</i>	<i>0.06</i>
<i>LTF</i>	<i>G-007A</i>	<i>0.3</i>
<i>LTF</i>	<i>GIBSON</i>	<i>0.11</i>
<i>LTF</i>	<i>HAMLET</i>	<i>0.12</i>
<i>LTF</i>	<i>MORGAN</i>	<i>0.3</i>
<i>LTF</i>	<i>NEWTON</i>	<i>0.24</i>
<i>LTF</i>	<i>NYISO</i>	<i>0.32</i>
<i>LTF</i>	<i>PRAIRIE</i>	<i>0.46</i>
<i>LTF</i>	<i>ROWAN</i>	<i>0.09</i>
<i>LTF</i>	<i>SANTEETLA</i>	<i>0.03</i>
<i>LTF</i>	<i>SMITHLAND</i>	<i>0.04</i>
<i>LTF</i>	<i>TATANKA</i>	<i>0.11</i>
<i>LTF</i>	<i>TILTON</i>	<i>0.11</i>
<i>LTF</i>	<i>TRIMBLE</i>	<i>0.07</i>
<i>LTF</i>	<i>TVA</i>	<i>0.14</i>
<i>LTF</i>	<i>UNIONPOWER</i>	<i>0.12</i>
<i>LTF</i>	<i>VFT</i>	<i>0.81</i>
<i>920231</i>	<i>AA2-119</i>	<i>237.74</i>
<i>925791</i>	<i>AC1-055</i>	<i>12.97</i>