



**Generation Interconnection
Feasibility Study Report
for
Queue Project AE1-008
COLLEGE CORNER 138 KV
7.6 MW Capacity / 20 MW Energy**

June, 2019

Table Of Contents

Introduction..... 3

Preface 4

General..... 5

Point of Interconnection..... 6

Cost Summary..... 6

Transmission Owner Scope of Work..... 8

Attachment Facilities 8

Direct Connection Cost Estimate 8

Non-Direct Connection Cost Estimate 9

Incremental Capacity Transfer Rights (ICTRs)..... 10

Schedule 11

Interconnection Customer Requirements 12

Revenue Metering and SCADA Requirements..... 13

PJM Requirements 13

AEP Requirements 13

Network Impacts 14

Summer Peak Load Flow..... 15

Generation Deliverability..... 16

Multiple Facility Contingency..... 16

Contribution to Previously Identified Overloads..... 16

Potential Congestion due to Local Energy Deliverability 16

System Reinforcements..... 17

Flow Gate Details..... 18

Affected Systems..... 20

Short Circuit..... 23

Figure 1: AE1-008 Point of Interconnection (College Corner 138 kV) **Error! Bookmark not defined.**

Single-Line Diagram **Error! Bookmark not defined.**

Figure 2: AE1-008 Point of Interconnection (College Corner 138 kV) **Error! Bookmark not defined.**

Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between, the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is American Electric Power Company (AEP).

Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model. The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

General

The IC has proposed an update to its previous PJM project # AC2-111, a solar generating facility located in Preble County, Camden, Ohio (See Figure 2) by 20 MW with 7.6 MW of this output being recognized by PJM as capacity. The installed facilities will have a total capability of 100MW with 38 MW of this output being recognized by PJM as capacity. Note that this project is an increase to the Interconnection Customer's AC2-111 project, which will share the same property and connection point (See Figure 1).

The objective of this Feasibility Study is to determine budgetary cost estimates and approximate construction timelines for identified transmission facilities required to connect the proposed generating facilities to the AEP transmission system. These reinforcements include the Attachment Facilities, Local Upgrades, and Network Upgrades required for maintaining the reliability of the AEP transmission system.

The Feasibility Study includes Short Circuit and Peak Load steady state power flow analyses. The conduct of power flow studies at other load levels, stability analysis, and coordination with non-PJM Transmission Planners, as required under the PJM planning process, is not performed during the Generation Interconnection Feasibility Study phase of the PJM study process. Additional reinforcement requirements for this Interconnection Request may be defined during the conduct of these additional analyses which shall be performed following execution of the System Impact Study agreement.

Queue Number	AE1-008
Project Name	COLLEGE CORNER 138 KV
State	Ohio
County	Preble
Transmission Owner	AEP
MFO	100
MWE	20
MWC	7.6
Fuel	Solar
Basecase Study Year	2022

The IC has requested a July 1, 2019 in service date. This study does not imply AEP's commitment to this in-service date.

Point of Interconnection

AE1-008 is an uprate to the AC2-111 project and will interconnect with the AEP transmission system at the College Corner 138 kV substation.

Note: It is assumed that the 138kV revenue metering system, gen lead and Protection & Control Equipment that will be installed for #AC2-111 will be adequate for the additional generation requested in AE1-008. Depending on the timing of the completion of the AC2-111 interconnection construction relative to the AE1-008 completion, there may (or may not) be a need to review and revise relay settings for the increased generation of AE1-008.

Cost Summary

The AE1-008 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$0
Direct Connection Network Upgrade	\$0
Non Direct Connection Network Upgrades	\$0
Total Costs	\$0

In addition, the AE1-008 project may be responsible for a contribution to the following costs

(Reference System Reinforcements in the Network Impacts section for details):

Description	Total Cost
System Upgrades	\$24,183,861

Cost allocations for these upgrades will be provided in the System Impact Study Report.

Note: PJM Open Access Transmission Tariff (OATT) section 217.3A outline cost allocation rules. The rules are further clarified in PJM Manual 14A Attachment B. The allocation of costs for a network upgrade will start with the first Queue project to cause the need for the upgrade. Later queue projects will receive cost allocation contingent on their contribution to the violation and are allocated to the queues that have not closed less than 5 years following the execution of the first Interconnection Service Agreement which identifies the need for this upgrade.

The Feasibility Study is used to make a preliminary determination of the type and scope of Attachment Facilities, Local Upgrades, and Network Upgrades that will be necessary to accommodate the Interconnection

Request and to provide the Interconnection Customer a preliminary estimate of the time that will be required to construct any necessary facilities and upgrades and the Interconnection Customer's cost responsibility. The System Impact Study provides refined and comprehensive estimates of cost responsibility and construction lead times for new facilities and system upgrades. Facilities Studies will include, commensurate with the degree of engineering specificity as provided in the Facilities Study Agreement, good faith estimates of the cost, determined in accordance with Section 217 of the Tariff,

- (a) to be charged to each affected New Service Customer for the Facilities and System Upgrades that are necessary to accommodate this queue project;
- (b) the time required to complete detailed design and construction of the facilities and upgrades; and
- (c) a description of any site-specific environmental issues or requirements that could reasonably be anticipated to affect the cost or time required to complete construction of such facilities and upgrades.

Transmission Owner Scope of Work

Attachment Facilities

The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
	\$0
Total Attachment Facility Costs	\$0

Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
	\$0
Total Direct Connection Facility Costs	\$0

Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
	\$0
Total Non-Direct Connection Facility Costs	\$0

Remote Terminal Work: During the Facilities Study, ITO's System Protection Engineering Department will review transmission line protection as well as anti-islanding required to accommodate the new generation and interconnection substation. System Protection Engineering will determine the minimal acceptable protection requirements to reliably interconnect the proposed generating facility with the transmission system. The review is based on maintaining system reliability by reviewing ITO's protection requirements with the known transmission system configuration which includes generating facilities in the area. This review may determine that transmission line protection and communication upgrades are required at remote substations.

Incremental Capacity Transfer Rights (ICTRs)

Will be determined at a later study phase

Schedule

It is anticipated that the time between receipt of executed Agreements and Commercial Operation may range from 12 to 18 months if no line work is required. If line work is required, construction time would generally be between 24 to 36 months after signing Agreement execution.

Interconnection Customer Requirements

American Electric Power's facility Connection Requirements as posted on PJM's website at <https://www.pjm.com/-/media/planning/plan-standards/private-aep/aep-interconnection-requirements.ashx>.

The Interconnection Customer (IC) is responsible for all Direct and Non-Direct Network Upgrade costs associated with this interconnection request. The AE1-008 project's attachment costs should be covered by the AC2-111 because this is an uprate to the existing AC2-111 project. The costs contained in this Feasibility Study Report are reimbursable to AEP.

The Generation Interconnection Agreement does not in or by itself establish a requirement for American Electric Power to provide power for consumption at the developer's facilities. A separate agreement may be reached with the local utility that provides service in the area to ensure that infrastructure is in place to meet this demand and proper metering equipment is installed. It is the responsibility of the developer to contact the local service provider to determine if a local service agreement is required.

Voltage Ride Through Requirements - The Customer Facility shall be designed to remain in service (not trip) for voltages and times as specified for the Eastern Interconnection in Attachment 1 of NERC Reliability Standard PRC-024-1, and successor Reliability Standards, for both high and low voltage conditions, irrespective of generator size, subject to the permissive trip exceptions established in PRC-024-1 (and successor Reliability Standards).

Frequency Ride Through Requirements - The Customer Facility shall be designed to remain in service (not trip) for frequencies and times as specified in Attachment 2 of NERC Reliability Standard PRC-024-1, and successor Reliability Standards, for both high and low frequency condition, irrespective of generator size, subject to the permissive trip exceptions established in PRC-024-1 (and successor Reliability Standards).

Reactive Power - The Generation Interconnection Customer shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading to 0.95 lagging measured at the generator's terminals.

Revenue Metering and SCADA Requirements

PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

Meteorological Data Reporting Requirement

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Temperature (degrees Fahrenheit)
- Atmospheric pressure (hectopascals)
- Irradiance
- Forced outage data

AEP Requirements

The Interconnection Customer will be required to comply with all AEP Revenue Metering Requirements for Generation Interconnection Customers. The Revenue Metering Requirements may be found within the "Requirements for Connection of New Facilities or Changes to Existing Facilities Connected to the AEP Transmission System" document located at the following link:

<http://www.pjm.com/~media/planning/plan-standards/private-aep/aep-interconnection-requirements.ashx>

Network Impacts

The Queue Project AE1-008 was evaluated as a 20 MW (Capacity 7.6 MW) uprate to the AC2-111 project which is an injection at the College Corner 138 kV substation in the AEP area. Project AE1-008 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE1-008 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Load Flow

Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC/DC	MW IMPACT
15630	243262	05COLLCO	AEP	250001	08COLINV	DEO&K	1	AEP_P4_#10527_05BLUFFP138_E2	breaker	167.0	111.84	114.8	DC	4.94
15631	243262	05COLLCO	AEP	250001	08COLINV	DEO&K	1	.345.DEO&K.C21403_MIAMIFORT	breaker	167.0	109.52	112.28	DC	4.61
16186	243262	05COLLCO	AEP	250001	08COLINV	DEO&K	1	.345.DEO&K-AEP.C54504MFTANNERS4512EBTANNERS	tower	167.0	116.04	118.82	DC	4.65

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC/DC	MW IMPACT
16036	243262	05COLLCO	AEP	250001	08COLINV	DEO&K	1	.138.DEO&K-AEP-DAY.B2TODHUNTER JCT 138	operation	167.0	107.12	110.34	DC	5.38
16037	243262	05COLLCO	AEP	250001	08COLINV	DEO&K	1	AEP_P1-	operation	167.0	107.12	110.34	DC	5.38

								2_#6372A					
--	--	--	--	--	--	--	--	----------	--	--	--	--	--

System Reinforcements

ID	Index	Facility	Upgrade Description	Cost
16186, 15630, 15631	1	05COLLCO 138.0 kV - 08COLINV 138.0 kV Ckt 1	<p><u>DEO&K</u> Description: Rebuild and reconductor 11.87 miles of 138 kV line from Collinsville to College Corner. This will require new poles as well. Time Estimate : 36.0 Months Cost : \$24,163,861</p> <p><u>AEP</u> Description: A Sag Study will be required on the 0.15 mile section of the ACSR 397.5 30/7 LARK Conductor line to mitigate the overload. New Rating after the Sag Study: S/N: 167 MVA S/E: 245 MVA. Depending on the sag study results, the cost for this upgrade is expected to be between \$20,000 (no remediation required just sag study) and \$0.3 million (complete line reconductor/rebuild). Time Estimate: a) Sag Study: 6-12 months b) Rebuild: The standard time required for construction differs from state to state. An approximate construction time would be 24 to 36 months after signing an interconnection agreement. Cost : \$20,000</p>	\$24,183,861
			TOTAL COST	\$24,183,861

Flow Gate Details

The following appendices contain additional information about each flow gate presented in the body of the report. For each appendix, a description of the flow gate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flow gate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gauge other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPAC T
16186	243262	05COLLC O	AEP	250001	08COLIN V	DEO&K	1	.345.DEO&K-AEP.C5 4504MFTANNERS4512EBTANNER S	tower	167.0	116.04	118.82	DC	4.65

Bus #	Bus	MW Impact
243415	05WWVSTA	2.7
247288	05RICHG1	0.9
247289	05RICHG2	0.9
247929	S-071 E	6.98
932841	AC2-111 C O1	7.07
932842	AC2-111 E O1	11.53
934961	AD1-128 C O1	5.89
934962	AD1-128 E O1	9.62
936681	AD2-087 C O1	3.81
936682	AD2-087 E O1	17.84
938061	AE1-008 C	1.77
938062	AE1-008 E	2.88
CARR	CARR	0.03
CATAWBA	CATAWBA	0.01
CBM-S1	CBM-S1	0.45
CBM-W1	CBM-W1	3.27
CBM-W2	CBM-W2	10.92
CIN	CIN	2.06
G-007	G-007	0.09
HAMLET	HAMLET	0.04
IPL	IPL	1.77
LGEE	LGEE	0.01
MEC	MEC	2.73
MECS	MECS	1.59
O-066	O-066	0.31
RENSSELAER	RENSSELAER	0.02
WEC	WEC	0.46

Affected Systems

LG&E

LG&E Impacts to be determined during later study phases (as applicable).

MISO

MISO Impacts to be determined during later study phases (as applicable).

TVA

TVA Impacts to be determined during later study phases (as applicable).

Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

NYISO

NYISO Impacts to be determined during later study phases (as applicable).

Contingency Name	Contingency Definition
AEP_P1-2_#6372A	CONTINGENCY 'AEP_P1-2_#6372A' OPEN BRANCH FROM BUS 243262 TO BUS 250106 CKT 1 / 243262 05COLLCO 138 250106 08TODHJT 138 1 END
AEP_P4_#10527_05BLUFFP 138_E2	CONTINGENCY 'AEP_P4_#10527_05BLUFFP 138_E2' OPEN BRANCH FROM BUS 243253 TO BUS 243319 CKT 1 / 243253 05BLUFFP 138 243319 05JAY 138 1 OPEN BRANCH FROM BUS 243253 TO BUS 246014 CKT 1 / 243253 05BLUFFP 138 246014 05BLUFFPNT 69.0 1 END
.345.DEO&K.C2 1403_MIAMIFORT	CONTINGENCY '.345.DEO&K.C2 1403_MIAMIFORT' OPEN BRANCH FROM BUS 249567 TO BUS 243233 CKT 1 OPEN BUS 251950 END
.345.DEO&K-AEP.C5 4504MFTANNERS4512EBTANNERS	CONTINGENCY '.345.DEO&K-AEP.C5 4504MFTANNERS4512EBTANNERS' OPEN BRANCH FROM BUS 243233 TO BUS 249567 CKT 1 OPEN BRANCH FROM BUS 243233 TO BUS 249565 CKT 1 END
.138.DEO&K-AEP-DAY.B2 TODHUNTER JCT 138	CONTINGENCY '.138.DEO&K-AEP-DAY.B2 TODHUNTER JCT 138' OPEN BUS 250106 END

Short Circuit

Short Circuit

The following Breakers are overduty

None