



**Generation Interconnection
Combined Feasibility / Impact Study Report
for
Queue Project AE1-039
WEST STREET (ORCHARD HILLS) 12.47 KV
0.8 MW Capacity / 0.8 MW Energy**

August, 2019

General

The Interconnection Customer (IC), has proposed a 0.8 MW (0.8 MW Capacity) uprate to the existing Methane generating facility located in Berrien, Watervliet, Michigan. The installed facilities will have a capability of 4.0 MW (3.8 MW Capacity). Note that this project is an increase to the Interconnection Customer's X1-042 project, which will share the same property and connection point. Please refer to Figure 1 for a SLD of AE1-039

Queue Number	AE1-039
Project Name	WEST STREET (ORCHARD HILLS) 12.47 KV
Interconnection Customer	Energy Developments Watervliet, LLC
State	Michigan
County	Berrien
Transmission Owner	AEP
MFO	4.0
MWE	0.8
MWC	0.8
Fuel	Methane
Basecase Study Year	2022

Point of Interconnection

AE1-039 is an update to the X1-042 queue position.

Cost Summary

The AE1-039 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$0
Direct Connection Network Upgrade	\$0
Non Direct Connection Network Upgrades	\$0
Total Costs	\$0

In addition, the AE1-039 project may be responsible for a contribution to the following costs

Description	Total Cost
System Upgrades	\$0

Cost allocations for these upgrades will be provided in the System Impact Study Report.

Transmission Owner Scope of Work

Attachment Facilities

The AE1-039 project will utilize the existing facilities constructed for the X1-042 project, however American Electric Power Distribution Planning has completed a Distribution Impact Study (DIS) for the EDL Energy “Watervliet” Interconnection Request associated with PJM project AE1-039 connecting an additional 800 kW (A.C.) generator, for a total system capacity of 4,000 kW AC to Watervliet Substation in Watervliet, MI.

Below is listed a summary of the requirements and cost estimates identified by distribution planning as associated with the details of this interconnection.

- The generating facility must install power factor and current limiting equipment and operate within parameters outlined in the “Electrical Description and Operations Manual - Energy Developments, Orchard Hill landfill, Watervliet, MI Original plant construction: 2010, Generator #3 addition: 2019. Issued June 6, 2019”
- There is no cost to improve AEP facilities if the above stated equipment and operating conditions are enacted.
- If the above equipment and operating conditions cannot be enacted and maintained, a high speed transfer trip scheme would need to be constructed, including installation of a three phase 139 kV bus potential transformer, a transfer trip relay, and a fiber option line for communication.
- In the event of the need for AEP to construct a high speed transfer trip scheme, the estimated cost to upgrade would be \$600,000

A copy of the “AE1-039 Watervliet Electrical System Operations Guide, issued June 26, 2019, and Distribution Impact Study are included in this Combined Study Report as Appendix 1 and 2 respectively.

Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
	\$0
	\$0
	\$0
Total Direct Connection Facility Costs	\$0

Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
	\$0
	\$0
	\$0
Total Non-Direct Connection Facility Costs	\$0

Revenue Metering and SCADA Requirements

PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

AEP Requirements

The existing metering is sufficient.

Network Impacts

The Queue Project AE1-039 was evaluated as a 0.8 MW (Capacity 0.8 MW) uprate to the X1-042 queue position which is injection at the West St. 138kV substation in the AEP area. Project AE1-039 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE1-039 was studied with a commercial probability of 100%. Potential network impacts were as follows:

Summer Peak Load Flow

Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

System Reinforcements

None


Short Circuit

Short Circuit

The following Breakers are overduty

None

Single line Diagram



The point of interconnection is at AEP's distribution primary meter facility on the Interconnection Customer's premise.

Figure 1

Appendix 1 - Distribution System Impact Study

Request

Energy Developments Watervliet LLC (EDL) has requested an interconnection application for a synchronous methane gas generator capable of 800 kW total maximum power output. This is an addition to the existing 2-1600kW synchronous methane gas generators operating since 2012 at the site near the Orchard Hills Sanitary Landfill in Watervliet, Michigan. Energy Developments Watervliet LLC will install an 800kW/1000kVA generator with the intention of starting operations in July, 2019. These generators are planned to export power to the Indiana and Michigan Power Co. (I&M) 12kV utility grid.

The DG system will generate electricity by burning methane gas from the landfill. Energy Developments Watervliet LLC has indicated they will not serve any of the Orchard Hills Landfill site load from the DG system. Therefore, the maximum output of the DG system to the utility grid is 4.0MW/5000kVA.

Energy Developments Watervliet LLC intends to operate the generators 24 hours a day, seven days per week. The only anticipated down time for generation is planned maintenance of a couple days per year.

Disclaimer

The results of this Distribution System Impact Study apply only to the system described in the attached Distributed Generation Interconnection Request. All Modeling is based on a DG system location at 3563 Hennessey Rd, Watervliet MI 49098, interconnection pole BE0146000518.

This review is limited to equipment affecting the AEP system operations. The customer must take all necessary steps to assure compliance with all laws, ordinances, and building codes and other applicable regulations. AEP granting approval of the requested connection is not an endorsement of a particular design nor does it assure fitness of the DG to accomplish an intended function.

The customer is expected to understand and comply with IEEE 1547 concerning the DG installation and its requirements for interconnection with the utility grid.

Modeling and Assumptions

It is assumed the customer has received a copy of the Customer Guide To The Interconnection of Distributed Resources To The American Electric Power (AEP) Distribution System document to guide them through the application.

The DG system is assumed to be equipped with appropriate voltage regulation. As previously stated, the DG system will be operated in parallel with the AEP distribution System and Energy Developments Watervliet LLC intends to export power to the utility grid.

Energy Developments Watervliet LLC is currently served from the 138/12kV West St Station through the Ryno Rd feeder. The Ryno Rd feeder is a radial configuration; three phase multi-grounded four wire, wye system. The primary voltage is nominally 12.47kV line to line, and 7.2kV line to ground.

The DG system will add a single Caterpillar 3516 generator rated 4160 Volts, 800kW/1000kVA, 80% power factor to the existing two Caterpillar 3520 generators each rated 4160 volts, 1600kW/2000kVA, 80% power factor, 277.6 full load amps, driven by a methane gas burning engine. The DG system will contribute up to a maximum of 4.0kW/5000kVA at 80% power factor when operating. The Caterpillar output voltage of 4160 volts will be stepped up to 12.47kV through a 5000 kVA, 12.47/4.16 kV pad mount transformer. The Energy Developments Watervliet LLC facilities will be protected by a 1200 amp, 4160 Volt breaker with a Schweitzer SEL351 control. The AEP service will connect to Energy Developments Watervliet LLC DG system through the existing 12 kV primary metered point of common coupling (PCC) to a 3 phase, 600 amp, pole mounted disconnect switch.

The Energy Developments Watervliet LLC owned 5000 kVA, 12.47/4.16kV step up transformer will be configured Gnd Wye-Gnd Wye and has an impedance of $Z=6.0\%$. This transformer will be connected to the PCC by no more than 100 feet of two conductors per phase of 500MCM Cu.

Analysis

The system conditions of concern are:

1. Generator location.
2. Generator fault contribution.
3. Generator effect on system steady state voltage at peak load.
4. Generator effect on system steady state voltage at light load.
5. Generator effect on power flow for the West St Transformer during light load conditions.

DG Location

The Energy Developments Watervliet LLC facility is modeled near AEP pole BE0146000518 on the West St-Ryno Rd distribution circuit. This is approximately 9350 feet east of the West St station.

DG Fault Contribution

1. Analysis of DG system effects during bolted fault conditions (Available fault current in amps).

Base case. West Street-Ryno Rd circuit; No DG system connected.

Case 1. West Street-Ryno Rd circuit; DG system connected steady state analysis.

Case 2. West Street-Ryno Rd circuit; DG system connected subtransient analysis.

Location: West Street station

Case	LLL fault current	LG fault current
Base case	5942 A	6016 A
Case 1	5954 A	6690 A
Case 2	5942A	6016A

The circuit analysis indicates a steady state 11.2% increase in LG fault current the West Street station.

Location: Energy Developments Watervliet LLC (PCC)

Case	LLL fault current	LG fault current
Base case	3225 A	2448 A
Case 1	3148 A	3876 A
Case 2	4228 A	4328 A

The circuit analysis shows a 31% increase in LLL fault current, and a 58% increase in steady state and 77% increase in subtransient LG fault current at I&M facilities at the PCC.

Location: Ryno Rd down line of circuit tap to DG connection.

Case	LLL fault current	LG fault current
Base case	3492 A	2705 A
Case 1	3504 A	4035 A
Case 2	4561 A	4429 A

The circuit analysis shows a 30% increase in LLL fault current and a 63% increase in LG subtransient fault current at I&M facilities at the PCC.

Bolted fault current analysis does show an increase in available fault currents but not to a level that exceeds interrupting ratings on system protection devices.

Analysis of DG system effects during single phase fault conditions (Available fault current in amps). All faults are on A phase and have a 10 ohm resistance applied.

Base case: West Street-Ryno Rd circuit; No DG system connected.

Case 1. West Street-Ryno Rd circuit; DG system connected subtransient analysis.

LG 10 Ohm fault current, fault location on Hennessey Rd between Ryno Rd and Granger PCC:

Case	West Street Station	Hennessey Rd tap	Granger PCC
Base Case	711 A	689 A	685 A
Case 1.	711 A	685 A	677 A
Result	No change	-4 A (-0.5%)	-8 A (-1%)

LG 10 Ohm fault current, fault location on Hennessey Rd north of Ryno Rd:

Case	West Street Station	Hennessey Rd tap	Ryno Rd upline of tap to Granger PCC

Base Case	711 A	658 A	660 A
Case 1.	711 A	685 A	686 A
Result	No change	27 A (4%)	26 A (4%)

Shunt fault current analysis does show a slight decrease in available fault current at the three phase tap to the Energy Developments Watervliet LLC .

There is no required change to the sectionalizing settings or equipment on the West Street- Ryno Rd circuit due to the additional 800kW generation from Energy Developments Watervliet LLC.

Voltage Regulation

Generator effect on system steady state voltage at peak load

The generator output has negligible effect on utility voltage at peak demand load when operated at unity power factor. When the generator power factor gets to +98% lagging or -92% leading it causes the AEP distribution system to exceed voltage limits.

- Therefore, it is recommended to the customer to operate within these power factor limits. Energy Developments Watervliet LLC has agreed to this condition and sent an attachment with the operating procedure to achieve this power factor limit.

Generator effect on system steady state voltage at light load

Light load conditions are assumed to be one third of peak demand. The generator output has negligible effect on utility voltage at light demand load when operated at unity power factor. When the generator power factor gets to +90% lagging or -95% leading, it causes the AEP distribution system to exceed voltage limits. As in the peak load condition, the operating procedure to limit the power factor range will address this condition.

Generator effect on power flow for the West Street Transformer during light load

During fall and spring months, the transformer at West Street Station is lightly loaded.

The generated power of the Energy Developments Watervliet LLC DG system could be more than the load on the 12 kV bus, thus resulting in a back flow of power through the 12 kV bus regulators and the transformer.

- No additional system work will be required from this additional generation application. In 2012, the CL-5A controls on the 3-833 KVA West St station bus regulators were reprogrammed for Co-generation regulation.

- The addition of the 800kW generator will cause conductor overload over 195 amps on the 4-2AA conductor from the customer interconnection point back to Hennessey Rd. This condition occurs when the generator power factor gets to -91% leading.
- Therefore, it is recommended to the customer to operate within these power factor limits. The voltage regulation power factor limit will achieve this power factor limit.

System Protection

The customer responsibilities include providing adequate protection to AEP facilities due to events arising from the operation of the DG under all AEP distribution system operating conditions. The customer is responsible for protecting their own facility under all AEP distribution system operating conditions whether the DG is connected to AEP facilities or not, including but not limited to:

1. Abnormal voltage or frequency
2. Loss of a single phase of supply
3. Equipment failure
4. Distribution system faults
5. Lightning
6. Excessive harmonic voltages
7. Excessive negative sequence voltages
8. Separation from supply
9. Loss of synchronization

Ground Current Sources – Protective relays must be utilized to detect line-to-ground faults. Energy Developments Watervliet LLC shall provide adequate protection to comply with IEEE 1547 to clear generation source for all types of faults on the AEP system including any breaker failure events. Adequate protection requires that all fault types are cleared before equipment damage occurs to AEP facilities. If Energy Developments Watervliet LLC fails to provide adequate protection for faults on the AEP system, then Energy Developments Watervliet LLC will pay all costs associated with AEP facility damage.

Automatic Reclosing – Automatic high speed reclosing is applied to the transmission circuit serving West Street Station (18 cycles or .3 seconds). When the AEP source breakers trip and isolate Energy Developments Watervliet LLC's facilities, Energy Developments Watervliet LLC shall ensure that their generation equipment is disconnected from AEP facilities in accordance with requirements established in IEEE 1547 prior to automatic reclosure by AEP. Automatic reclosing out-of-phase with Energy Developments Watervliet LLC's generation equipment may cause damage to Energy Developments Watervliet LLC's equipment. Energy Developments Watervliet LLC is solely responsible for the protection of their equipment from automatic reclosing by AEP.

- AEP will continue to require communication to the customer site in order to monitor connection status, real power output, reactive power output and voltage as stated in section 4.1.6 of IEEE-1547.
- If the customer is unable to detect AEP's automatic high speed reclosing a transfer trip signal can be sent to their protection system. This will require installation of a three phase 138kV bus potential transformer, a transfer trip relay, and a fiber optic line for communication path.

Summary

Facilities

The proposed interconnection will not require any improvements to AEP facilities with the attached customer operating procedure limiting power factor and current levels.

Additional system improvement options:


- If the customer selects the high speed transfer trip option the cost estimate is \$600,000.

System improvements required on the Energy Developments Watervliet LLC DG system:

- Energy Developments Watervliet LLC to install power factor and current limit settings as detail in the attached operation procedure addition.


Attachment 1

Energy Developments Watervliet LLC DG system one line:



Energy Developments Watervliet LLC DG system Location plan:

NO.	DATE	DESCRIPTION	BY	CHKD
1	10/12/18	100' corner of point building	WJ	WJ
2	10/12/18	100' corner of point building	WJ	WJ
3	10/12/18	100' corner of point building	WJ	WJ
4	10/12/18	100' corner of point building	WJ	WJ
5	10/12/18	100' corner of point building	WJ	WJ
6	10/12/18	100' corner of point building	WJ	WJ
7	10/12/18	100' corner of point building	WJ	WJ
8	10/12/18	100' corner of point building	WJ	WJ
9	10/12/18	100' corner of point building	WJ	WJ
10	10/12/18	100' corner of point building	WJ	WJ
11	10/12/18	100' corner of point building	WJ	WJ
12	10/12/18	100' corner of point building	WJ	WJ
13	10/12/18	100' corner of point building	WJ	WJ
14	10/12/18	100' corner of point building	WJ	WJ
15	10/12/18	100' corner of point building	WJ	WJ
16	10/12/18	100' corner of point building	WJ	WJ
17	10/12/18	100' corner of point building	WJ	WJ
18	10/12/18	100' corner of point building	WJ	WJ
19	10/12/18	100' corner of point building	WJ	WJ
20	10/12/18	100' corner of point building	WJ	WJ



NOTES:
 1. CERTAIN LOCATIONS HAVE SMALL
 CIRCUMFERENCE. PLEASE BE AWARE THAT
 THE COORDINATES COULD BE A FEW FEET
 AWAY FROM CORRECT LOCATION OF
 UNDERGROUND UTILITY/CONDUIT. APPLY
 CORRECT PROCEDURES BEFORE DIGGING.


SCALE: 1" = 20'

THIS DRAWING IS THE PROPERTY OF THE CLIENT. IT IS TO BE USED ONLY FOR THE PROJECT AND NOT FOR ANY OTHER PURPOSE. ANY REUSE OR MODIFICATION OF THIS DRAWING WITHOUT THE WRITTEN CONSENT OF THE CLIENT IS PROHIBITED.

INDIANA MICHIGAN POWER PRIMARY POLE EASEMENT CLIENT: ENERGY DEVELOPMENTS LOCATION: WATERVLIET, MICHIGAN SITE: ORCHARD HILL GENERATING STATION	
1" = 20'	18-30712
6002	1/2"

Attachment 2:

AEP system diagram:



Appendix 2

Electrical Description and Operations Manual

Energy Developments, Orchard Hill landfill, Watervliet, MI Original plant construction: 2010,

Generator #3 addition: 2019

Issued June 6, 2019

System description:

A 12,470V distribution feeder supplies service to this generation facility via overhead line at the northern property line at 3563 Hennessy Road, Watervliet, MI. The AEP ownership changes at the first pole that contains metering transformers. The site visible disconnect is the next pole with load breaking three pole gang disconnect, ground level operated. The last pole contains a G&W Viper recloser controlled by a SEL-351R controller that communicates to AEP via DNP protocol and inside the generation facility via SEL mirrored bits via fiber optic connection.

The G&W recloser protects a sub-surface 15kV rated cable connected to a 5000kVA @ 55deg C rated transformer (5600kVA @ 65 deg C). The 12,470V wye to 4,160V wye transformer feeds indoor switchgear protected by a SEL-351 relay. The 5kV switchgear has a fused house power disconnect feeding a 500kVA @ 55deg C transformer that powers a 480V motor control center. The 500kVA transformer is 4160V delta : 480V delta connected.

The 5kV switchgear has one 1200A main breaker (protected by SEL-351), one fused house power disconnect, and three 1200A generator circuit breakers each protected by a SEL-300G relay. Generator #1 and #2 are CAT 3520, 1600kW, 0.8pf, 4160V, 277amp. Generator #3 currently is a CAT 3516, 800kW, 0.8pf, 4160V, 139amp. Generator 3 is designed to be replaced with a CAT 3520 in the future as landfill gas supply increases.

Protection description:

The SEL-351R provides primary system protection from voltage and frequency issues on the AEP system as well as over current protection of the main generator step-up transformer.

The SEL-351 located in the 5kV switchgear provides similar voltage and frequency protection as the SEL-351R and over current protection of the 5kV switchgear bus. Additional protection was required with the addition of Generator #3 in 2019.

The addition of Generator #3 is pushing the limits of the current AEP distribution system construction. The line conductors are limited in capacity as well as the possible reactive power capability of the facility would cause overvoltage issues on the nearby system. EDL agreed to more strict parameters of operation that would take Generator #3 offline (only) by using the SEL- 351 relay in the switchgear. Line overloading was addressed by limiting current out of the Watervliet facility to 195 amps at 12,470V for 30 seconds. These settings were converted to 4160V and applied to the SEL-351 relay. System voltage management was addressed by limiting reactive power (VARs) of the facility to 500kVAR exported from the plant to 2000kVAR imported to the plant for 30 seconds. Both considerations for operation were accepted by AEP.

Each generator is protected by a SEL-300G generator relay. These relays protect the individual generator with volts/hz, sync check, under voltage, over voltage, loss of excitation, reverse power, voltage restraint overcurrent, frequency, and current differential elements. Each generator relay trips that individual generator from the system.

SEL-351R

Location: outdoor, pole mounted CT

ratio: 500:1

PT ratio: 60:1

Element Number	Description	Setting/delay	Primary pickup value
81D1P	Under Frequency level 1	59.0Hz @ 60cy	59.0Hz
81D2P	Under Frequency level 2	57.0Hz @ 9.5cy	57.0Hz
81D3P	Over Frequency	60.5Hz @ 9.5cy	60.5Hz
27P1P	Under Voltage level 1	105.6V @ 120cy (SV1)	6336V
27P2P	Under Voltage level 2	60.0V @ 9.5cy (SV2)	3600V
59P1P	Over Voltage level 1	132.0V @ 60cy (SV3)	7920V
59P2P	Over Voltage level 2	144V @ 9.5cy (SV4)	8640V
50P1P	Phase Instant Overcurrent	3.70A @ 0 sec	1850A
50G1P	Residual Instant Overcurrent	0.10A @ 0 sec	50A
51P1P	Phase Time Overcurrent	0.58A / U4 curve / 5.0 dial / EM reset	250A
51G1P	Residual Time Overcurrent	0.10A / U4 curve / 3.50 dial / EM reset	50A

Trip function: Open recloser

Trip elements: all in above table + local push button + remote trip bit via mirrored bits

Close function: local pushbutton + remote pushbutton provided remote control is not disabled

Communication via mirrored bits to SEL-351 in plant, DNP-3 to AEP for metering/status

SEL-351R Mirrored Bits transmit equations		
Bit	Function	Description
TMB1A	52A- recloser position	Used to indicate recloser open/close inside plant
TMB2A	LT1- remote close block	Used to block closing recloser from plant, used in logic and display in plant
TMB3A	Frequency and Voltage elements not tripped	Used for indication in plant that utility voltage is restored and recloser may be closed to re-energize facility
TMB4A	Alarm	Used for indication in the plant of a SEL-351R relay problem.

SEL-351R Display points on LCD at relay		
Display	Function	Description
Point 1	recloser open or closed	IN101 logic, displays position in conjunction with lamp near open/close button
Point 2	Utility voltage OK / not OK	Voltage/Freq logic detection used to determine if OK to close recloser- also used as a lamp indicator in plant
Point 3	Under Volt trip	Reset with breaker close
Point 4	Over Volt trip	Reset with breaker close
Point 5	Over Freq trip	Reset with breaker close
Point 6	Under Freq trip	Reset with breaker close
Point 7	Over Current trip	Reset with breaker close

SEL-351

Location: indoor, 5kV switchgear, utility breaker door

CT ratio: 240:1

PT ratio: 35:1

Element Number	Description	Setting/delay	Primary pickup value
81D1P	Under Frequency	58.0Hz @ 60cy	58.0Hz
81D2P	Over Frequency	61.0Hz @ 60cy	61.0Hz
27P1P	Under Voltage	59.0V @ 90cy (SV1)	2065V
59P1P	Over Voltage	75.0V @ 90cy (SV2)	2625V
50P1P	Phase Instant Overcurrent	30.0A @ 0 sec	7200A
*50P2P	Phase Overcurrent w/delay	2.438A @ 30 sec	585 A (195A @12.47kV)
51PP	Phase Time Overcurrent	3.5A / U4 curve / 10.0 dial / EM reset	840A
51G1P	Residual Time Overcurrent	0.5A / U4 curve / 3.0 dial / EM reset	120A
*3PWR1P	Reactive element leading	59.53 VA @ 30 sec	-500kVAR
*3PWR2P	Reactive element lagging	238.09 VA @ 30 sec	+2000kVAR

*Elements used to trip Gen #3 only per modified AEP operations agreement.

SEL-351 Input / Output assignment		
I/O	Function	Description
IN101	Main 5kV breaker position	Used in protection logic
IN102	Isolated mode	Allows operation of plant isolated from utility
IN103	Close recloser- remote	Recloser close via com to SEL-351R
IN104	Open recloser- remote	Recloser open via com to SEL-351R
IN105	Generator #1 breaker position	Transmit breaker status to AEP
IN106	Generator #2 breaker position	Transmit breaker status to AEP
IN201	Generator #3 breaker position	Transmit breaker status to AEP
IN202	Generator #4 breaker position	Future
ALARM	SEL-351 relay trouble	PLC indication of SEL-351 relay trouble
OUT101	Trip main 5kV breaker	Protection logic trip local breaker
OUT102	Trip 86U lockout relay	Protection logic trip local lockout relay
OUT103	Main 5kV breaker close permissive	Logic to allow main 5kV breaker close (sync, utility volts OK, dead bus, etc)
OUT104	Recloser closed	Panel lamp lit if recloser closed and com OK
OUT105	Recloser open	Panel lamp lit if recloser open and com OK
OUT106	Remote recloser close blocked	Panel lamp lit if remote close ability is blocked for recloser and com OK
OUT107	Utility voltage OK indicator	Panel lamp lit if utility voltage present and com OK
OUT201	DC voltage trouble	PLC indication of 48Vdc system trouble
OUT202	Mirrored Bits com trouble	PLC indication of SEL-351/351R com trouble
OUT203	SEL-351R trouble	PLC indication of SEL-351R relay trouble
OUT204	Trip Generator #3 only	AEP system parameters exceeded per interconnect agreement/system limitations

SEL-351 Mirrored Bits transmit equations		
Bit	Function	Description
TMB1A	Main 5kV breaker position	Transmit breaker status to AEP
TMB2A	Generator #1 breaker position	Transmit breaker status to AEP
TMB3A	Generator #2 breaker position	Transmit breaker status to AEP
TMB4A	Generator #3 breaker position	Transmit breaker status to AEP
TMB5A	Generator #4 breaker position	Future
TMB6A	Close recloser- remote	Transmit recloser close command
TMB7A	Open recloser- remote	Transmit recloser open command

SEL-351 Display points on LCD at relay		
Display	Function	Description
Point 1	Under Volt Trip	Reset with target reset button
Point 2	Over Volt Trip	Reset with target reset button
Point 3	Under Freq Trip	Reset with target reset button
Point 4	Over Freq Trip	Reset with target reset button
Point 5	Over Curr Trip	Reset with target reset button
Point 6	Ground Curr Trip	Reset with target reset button
Point 7	Fiber com OK/Fail	Mirrored Bits communication status
Point 8	Recloser closed	Status of line recloser via Mirrored Bits
Point 9	Recloser open	Status of line recloser via Mirrored Bits
Point 10	VAR trip Gen #3	Line parameters exceeded
Point 11	OC trip Gen #3	Line parameters exceeded

SEL-300G (Gen 1,2,3)

Location: indoor, engine control panels
CT ratio, phase: 60:1 (3520) 30:1 (3516)
CT ratio, neutral: 10:1 (3520)
PT ratio: 35:1

Element Number	Description	Setting/delay (3520)	Primary pickup value
24D1P	Volts/Hz level 1	105% @ 60.0 sec	
24D2P1	Volts/Hz level 2 PU one	110% @ 60.0 sec	
24D2P2	Volts/Hz level 2, PU two	115% @ 10.0 sec	
25	Sync check	63.5 V low, 73.9 V high, 2.0 V delta, -0.1 slip min, 0.15 slip max	2222.5V to 2586.5V sync range 48V delta
27P1P	Under Voltage phase-neutral	54.0V @ cy	1890V
27PP1	Under Voltage phase-phase	108V @ 1.0 sec (SV5)	3780V
27PP2	Under Voltage phase-phase	105V @ 1.0 sec (SV6)	
59P1P	Over Voltage phase-neutral	74.0V @ cy	2590V
59PP1	Over Voltage phase-phase	126V @ 1.0sec (SV1)	4410V
32P1P	Reverse power- level 1	-0.0800W @ 10 sec	168kW
32P2P	Reverse power- level 2	-0.20 @ 2.0 sec	420kW
40	Loss of excitation, zone 1	14.9 ohm diameter, -1.0 ohm offset, 0.05 sec delay	

40	Loss of excitation, zone 2	15.7 ohm diameter, -1.0 ohm offset, 0.50 sec delay	
50P1P	Phase Instant Overcurrent	50.0A @ 0.05 sec	3000A
50H1P	Differential instant Overcurrent	50.0A @ 0.05 sec	3000A
51NP	Neutral Time Overcurrent	0.50A / U4 curve / 3.0 dial / EM reset	5A
51VP	Voltage Restraint Time Overcurrent	5.0A / U4 curve / 6.0 dial / EM reset	300A
81D1P	Under Frequency	59.0Hz @ 1 sec (SV7)	59.0Hz
81D2P	Over Frequency	61.0Hz @ 1 sec (SV7)	61.0Hz
87U	Differential, unrestrained	10.0 x tap	
87R	Differential, restrained	0.30 x tap @ 25% slope	
SEL-300G Input / Output assignment			
I/O	Function	Description	
IN101	Generator breaker position	Used in protection logic	
OUT101	Trip generator breaker	Protection logic trip local breaker	
OUT102	Trip 86G lockout relay	Protection logic trip local lockout relay	
OUT103	PLC trip indication	Protection/indication to PLC	
OUT104	PLC 48V battery alarm	Indication to PLC of high/low 48V DC battery system	
OUT105	Sync check breaker close	Supervise DSLC controller for backup sync check of generator breaker	

SEL-300G Display points on LCD at relay		
Display	Function	Description
Point 1		Not used at this time
Point 2	EM Reset Timing	Displays when any element is reset timing. Used when calibrating relays
Point 3	Over Volt Trip	Reset with target reset button or 20 seconds after breaker closes
Point 4	Under Volt Trip	Reset with target reset button or 20 seconds after breaker closes
Point 5	Reverse Power	Reset with target reset button or 20 seconds after breaker closes
Point 6	Volt per Hertz Trip	Reset with target reset button or 20 seconds after breaker closes
Point 7	Excitation Loss	Reset with target reset button or after breaker closes
Point 8	Overcurrent Trip	Reset with target reset button or after breaker closes
Point 9	Gen Differential	Reset with target reset button or after breaker closes

Electrical system data obtained from AEP on 3/12/13 for use in arc flash study: LLL= 3682
amps, LG= 2832 amps
X/R ratio = 5.49
X Thevenin = 2.0200 ohms R
Thevenin = 0.3681 ohms