



Generation Interconnection
Queue Project AE1-129
Zions View – Middletown 115 KV
Feasibility Study Report
Capacity : 47 MW / Energy : 79.6 MW
(Revised)

February, 2019

General

Interconnection Customer has proposed a Solar generating facility located in York County, Pennsylvania. The installed facilities will have a total capability of 79.6 MW with 47 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is September 30, 2021. This study does not imply a **Mid-Atlantic Interstate Transmission, LLC (Transmission Owner or MAIT)** commitment to this in-service date.

Point of Interconnection (POI)

The AE1-129 solar facility will interconnect with the MAIT transmission system by either one of the following two options:

1. Option 1 POI: tapping the Zions View – Middletown 115 kV transmission line at a point located approximately 2.8 miles from Zions View.
2. Option 2 POI: tapping the Cly – ES3 115 kV transmission line, circuit #978, at a point located approximately 1.8 miles from Cly substation. A three breaker ring bus station is required to tap the line.

Network Impacts

Option 1 POI: Summer Peak Analysis - 2022

The Queue Project AE1-129 was evaluated as a 79.6 MW (Capacity 47 MW) injection at ZION VIEW - MIDDLETOWN 115 KV substation in the Meted area. Project AE1-129 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE1-129 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

Short Circuit

None. (No overdutied circuit breakers identified)

Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

None

System Reinforcements**Short Circuit**

None.

Stability and Reactive Power Requirement

Will be determined at a later study stages.

Summer Peak Load Flow Analysis Reinforcements**New System Reinforcements**

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

None

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

None.

Option 2 POI: Summer Peak Analysis - 2022

The Queue Project AE1-129 was evaluated as a 79.6 MW (Capacity 47 MW) injection tapping the Cly to ES3 115 kV line in the ME area. Project AE1-129 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE1-129 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

Short Circuit

None. (No overdutied circuit breakers identified)

Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

None