



**Generation Interconnection
Feasibility Study Report
for**

Queue Project AE1-166

LORETTO-WILTON & BRAIDWOOD-DAVIS CREEK

78 MW Capacity / 150 MW Energy

June, 2019

Revised February 2020

Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model.

The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

The conduct of light load analysis as well as Affected Systems as required under the PJM planning process is not performed during the Generation Interconnection Feasibility Study phase of the PJM study process. Additional reinforcement requirements for this Interconnection Request may be defined during the conduct of the System Impact Study.

General

The Interconnection Customer (IC) has proposed a Solar generating facility located in Kankakee County, Illinois. The installed facilities will have a total capability of 150 MW with 78 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is 09/30/2020. This study does not imply a TO commitment to this in-service date.

Queue Number	AE1-166
Project Name	LORETTO-WILTON & BRAIDWOOD-DAVIS CREEK
State	None
County	Kankakee
Transmission Owner	ComEd
MFO	150
MWE	150
MWC	78
Fuel	Solar
Basecase Study Year	2022

Primary Point of Interconnection

Queue Position AE1-166, a 150 MW solar facility, proposes to interconnect with the ComEd transmission system by utilizing the same attachment facilities as AD1-100.

Cost Summary

The AE1-166 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$ 200,000
Direct Connection Network Upgrade	\$0
Non Direct Connection Network Upgrades	\$0
Total Costs	\$ 200,000

In addition, the AE1-166 project may be responsible for a contribution to the following costs (see later sections of this report).

Description	Total Cost
System Upgrades	\$93,410,120

Cost allocations for these upgrades will be provided in the System Impact Study Report.

Interconnected Transmission Owner Scope of Work

Attachment Facilities

Queue Position AE1-166, a 150 MW solar facility, proposes to interconnect with the ComEd transmission system by utilizing the same attachment facilities as AD1-100. Addition of a 150 MW solar facility behind the meter will require review and possible upgrade of SCADA, Communication, relays and metering. The estimated cost is \$200,000.

Direct Connection Cost Estimate

None

Non-Direct Connection Cost Estimate

None

Schedule

ComEd would take approximately 18-months to review and possibly upgrade SCADA, Communication, relays and metering after the ISA / ICSA are signed.

Interconnection Customer Requirements

Exelon Utilities Transmission Bus Configuration Design Philosophy, ComEd Interconnection Guidelines, and Exelon Utilities Transmission Facility Interconnection Requirements shall apply. They are available on the PJM website. To the extent that these Applicable Technical Requirements and Standards conflict with the terms and conditions of the Tariff, the Tariff shall control.

Revenue Metering and SCADA Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

Network Impacts

The Queue Project AE1-166 was evaluated as a 150 MW (Capacity 78 MW) injection tapping the Braidwood; B to Davis Creek; B 345 kV line in the ComEd area. Project AE1-166 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE1-166 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Load Flow

Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
161919	270644	WILTON	CE	243206	05DUMONT	AEP	1	AEP_P4_#8805_05OLIVE 345_D	breaker	4105.0	96.9	97.23	DC	46.6
768083	270644	WILTON	CE	243206	05DUMONT	AEP	1	AEP_P4_#8805_05OLIVE 345_D	breaker	4105.0	96.9	97.23	DC	46.6

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
161808	255104	17GREEN_ACRE	NIPS	270771	GREENACRE; T	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	102.9	103.27	DC	13.15
161637	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	108.51	109.01	DC	14.51
161638	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	COMED_P4_023-65-BT2-3	breaker	1091.0	110.86	111.32	DC	14.62
161639	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	COMED_P4_112-65-BT4-5	breaker	1091.0	108.72	109.21	DC	14.62
161640	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	COMED_P4_112-65-BT3-4	breaker	1091.0	108.72	109.21	DC	14.62
767455	255113	17STILLWELL	NIPS	243219	05DUMONT	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	173.35	173.76	DC	22.68
163004	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L94507_B-S+_345-L97008_R-S	tower	4105.0	103.54	103.83	DC	50.52

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC/D C	MW IMPACT
163005	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L6607__B-S_+_345-L97008_R-S	tower	4105.0	102.74	103.06	DC	50.58
769308	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L94507_B-S_+_345-L97008_R-S	tower	4105.0	103.54	103.83	DC	50.52
769309	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L6607__B-S_+_345-L97008_R-S	tower	4105.0	102.74	103.06	DC	50.58
161813	270677	BURNHAM ;OR	CE	255109	17MUNSTER	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1441.0	112.67	113.05	DC	19.68
161796	270728	E FRANKFO; B	CE	274750	CRETE EC;BP	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	110.61	111.15	DC	20.51
161797	270728	E FRANKFO; B	CE	274750	CRETE EC;BP	CE	1	COMED_P4_023-65-BT2-3__	breaker	1399.0	110.26	110.8	DC	20.61
161798	270728	E FRANKFO; B	CE	274750	CRETE EC;BP	CE	1	COMED_P4_112-65-BT4-5__	breaker	1399.0	110.19	110.72	DC	20.61
161799	270728	E FRANKFO; B	CE	274750	CRETE EC;BP	CE	1	COMED_P4_112-65-BT3-4__	breaker	1399.0	110.18	110.72	DC	20.61
161679	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	115.6	116.01	DC	13.15
767719	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	115.6	116.01	DC	13.15
161642	270886	ST JOHN ;T	CE	255104	17GREEN_ACR E	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	108.51	109.01	DC	14.51
161643	270886	ST JOHN ;T	CE	255104	17GREEN_ACR E	NIPS	1	COMED_P4_023-65-BT2-3__	breaker	1091.0	110.86	111.32	DC	14.62
161644	270886	ST JOHN ;T	CE	255104	17GREEN_ACR E	NIPS	1	COMED_P4_112-65-BT4-5__	breaker	1091.0	108.72	109.21	DC	14.62
161645	270886	ST JOHN ;T	CE	255104	17GREEN_ACR E	NIPS	1	COMED_P4_112-65-BT3-4__	breaker	1091.0	108.72	109.21	DC	14.62
161503	270926	WILTON ;B	CE	275232	WILTON ;3M	CE	1	COMED_P4_112-65-BT5-6__	breaker	1379.0	165.81	166.14	DC	27.93
161505	270927	WILTON ;R	CE	275233	WILTON ;4M	CE	1	COMED_P4_112-65-BT2-3__	breaker	1379.0	163.55	164.04	DC	28.49
161535	274750	CRETE EC;BP	CE	255112	17STJOHN	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	123.84	124.43	DC	20.28
161536	274750	CRETE EC;BP	CE	255112	17STJOHN	NIPS	1	COMED_P4_023-65-BT2-3__	breaker	1399.0	123.25	123.84	DC	20.37
161537	274750	CRETE EC;BP	CE	255112	17STJOHN	NIPS	1	COMED_P4_112-65-BT4-5__	breaker	1399.0	123.19	123.78	DC	20.37
161538	274750	CRETE EC;BP	CE	255112	17STJOHN	NIPS	1	COMED_P4_112-65-BT3-4__	breaker	1399.0	123.18	123.78	DC	20.37
161592	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	134.44	134.98	DC	15.92
161593	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT2-3__	breaker	971.0	132.35	132.95	DC	16.06
161594	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT4-5__	breaker	971.0	133.2	133.75	DC	16.06
161595	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT3-4__	breaker	971.0	133.2	133.75	DC	16.06
161596	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT4-5__	breaker	971.0	133.19	133.74	DC	16.06
767588	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	134.44	134.98	DC	15.92
767589	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT2-3__	breaker	971.0	132.35	132.95	DC	16.06
767590	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT4-5__	breaker	971.0	133.2	133.75	DC	16.06
767591	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT3-4__	breaker	971.0	133.2	133.75	DC	16.06
767592	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT4-5__	breaker	971.0	133.19	133.74	DC	16.06
161502	275232	WILTON ;3M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT5-6__	breaker	1379.0	165.81	166.14	DC	27.93
161507	275233	WILTON ;4M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT2-3__	breaker	1379.0	163.55	164.04	DC	28.49

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC/DC	MW IMPACT
162841	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	COMED_P7_345-L17704AR-S+_345-L17907TB-S-A	tower	1846.0	136.21	138.35	DC	39.47
162842	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	COMED_P7_345-L2001_B-S+_345-L2003_R-S	tower	1846.0	133.2	135.55	DC	43.48
162815	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	COMED_P7_345-L17704AR-S+_345-L17907TB-S-A	tower	1846.0	143.4	145.54	DC	39.47
162816	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	COMED_P7_345-L2001_B-S+_345-L2003_R-S	tower	1846.0	140.73	143.09	DC	43.48

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC/DC	MW IMPACT
162539	255104	17GREEN_ACRE	NIPS	270771	GREENACRE; T	CE	1	AEP_P1-2_#695A	operation	1091.0	101.61	101.99	DC	13.31
162345	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	AEP_P1-2_#695A	operation	1091.0	108.71	109.2	DC	14.62
768279	255113	17STILLWELL	NIPS	243219	05DUMONT	AEP	1	AEP_P1-2_#695A	operation	1409.0	169.83	170.25	DC	23.36
162595	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	Base Case	operation	3555.0	105.6	105.87	DC	43.08
162596	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P1-2_#697A	operation	4105.0	96.86	97.2	DC	46.63
768808	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	Base Case	operation	3555.0	105.6	105.87	DC	43.08
768809	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P1-2_#697A	operation	4105.0	96.86	97.2	DC	46.63
162538	270677	BURNHAM ;OR	CE	255109	17MUNSTER	NIPS	1	AEP_P1-2_#695A	operation	1441.0	111.84	112.22	DC	19.82
162506	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	AEP_P1-2_#695A	operation	1399.0	110.14	110.68	DC	20.62
162394	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	114.15	114.57	DC	13.31
768524	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	114.15	114.57	DC	13.31
162341	270886	ST JOHN ; T	CE	255104	17GREEN_ACRE	NIPS	1	AEP_P1-2_#695A	operation	1091.0	108.71	109.2	DC	14.62
162620	270926	WILTON ; B	CE	275232	WILTON ;3M	CE	1	COMED_P1-2_765-L11216_-S	operation	1379.0	104.09	104.3	DC	17.55

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
162594	270927	WILTON ; R	CE	275233	WILTON ;4M	CE	1	COMED_P1-2_765-L11216__-S	operation	1379.0	105.47	105.79	DC	18.36
162263	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	AEP_P1-2_#695A	operation	1399.0	123.15	123.74	DC	20.38
162264	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	Base Case	operation	1091.0	80.07	80.62	DC	13.24
162327	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	133.19	133.74	DC	16.06
768449	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	133.19	133.74	DC	16.06
162258	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	COMED_P1-2_345-L8014__-S-B	operation	1528.0	150.15	152.43	DC	34.77
162262	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	Base Case	operation	1364.0	132.68	135.19	DC	34.32
162640	934730	AD1-100 TAP	CE	270670	BRAIDWOOD; B	CE	1	COMED_P1-2_345-L11212_B-S-A	operation	1528.0	84.12	89.65	DC	84.56
162221	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	COMED_P1-2_345-L8014__-S-B	operation	1528.0	156.85	159.13	DC	34.77
162225	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	Base Case	operation	1364.0	142.58	145.09	DC	34.32

System Reinforcements

ID	Index	Facility	Upgrade Description	Cost
161640,161637,161638,161639	3	17STJOHN 345.0 kV - ST JOHN ; T 345.0 kV Ckt 1	<u>CE</u> Description : The upgrade will be to mitigate the sag on the line. Note, the estimate provided does not include potential transmission tower pole upgrades. This cost will be determined during the Facilities Studies. Time Estimate : 24-30 Months Cost : \$2,600,000	\$2,600,000
161642,161643,161644,161645	8	ST JOHN ; T 345.0 kV - 17GREEN_ACRE 345.0 kV Ckt 1	<u>NIPS</u> Description : The external (i.e. Non-PJM) Transmission Owner, NIPS, will not evaluate this violation until the impact study phase.	
161507	14	WILTON ;4M 345.0 kV - WILTON ; 765.0 kV Ckt 1	<u>CE</u> Description : PJM network upgrade n5145: Reconfigure Wilton 765kV bus thereby allowing for 765kV L11216 (currently on Bus 6) to be relocated to Bus 8. Along with this line relocation, installation of 2-765kV BT CB's (6-8 & 8-2). The baseline project has an projected in-service date of 06/30/2019. Time Estimate : 36.0 Months Cost : \$ 11,000,000	\$11,000,000
161503	9	WILTON ; B 345.0 kV - WILTON ;3M 345.0 kV Ckt 1		
161502	13	WILTON ;3M 345.0 kV - WILTON ; 765.0 kV Ckt 1		
161505	10	WILTON ; R 345.0 kV - WILTON ;4M 345.0 kV Ckt 1		
161813	5	BURNHAM ;0R 345.0 kV - 17MUNSTER 345.0 kV Ckt 1	<u>CE</u> Description : Line conductor & station conductor upgrades. (Note that there may be additional 345kV line tower costs as a result of this upgrade. This estimate does not include potential tower work. The tower costs will be determined during the Facility Study). Time Estimate : 36.0 Months Cost : \$9,200,000 <u>NIPS</u> Description : The external (i.e. Non-PJM) Transmission Owner, NIPS, will not evaluate this violation until the impact study phase.	\$9,200,000
162816,162815	16	AD2-137 TAP 345.0 kV - WILTON ; B 345.0 kV Ckt 1	<u>CE</u> Description : Replace 2x345kV circuit breakers and station conductor @ Wilton Center, Reconductor 5 miles.Additional tower work may be required. The estimate for the tower work will not be determined until the Facility Study is performed. Time Estimate : 30.0 Months Cost : \$11,600,000	\$11,600,000

ID	Index	Facility	Upgrade Description	Cost
767455	4	17STILLWELL 345.0 kV - 05DUMONT 345.0 kV Ckt 1	<u>AEP</u> Description : 1) Rebuild / reconductor 8.58 miles of conductor (ACSR ~ 954 ~ 45/7 ~ RAIL - Conductor section 1), Estimated Cost : \$17.16 million . 2) Replace Dumont Wavetrap , Estimated Cost : \$200k. 3) An Engineering study will need to be conducted to determine if the CT Thermal Limits can be adjusted to mitigate the overload. Estimated Cost: \$25,000. 4) Replace two Dumont Breakers , Estimated Cost: \$2.4 million 5) Replace 11 Dumont risers (11 Sub cond 2-1700 kcm AAC 61 Str.- Dumont) , Estimated Cost : \$ 175,000 6) Replace four 3000 A Dumont Switches , Estimated Cost : \$2,000,000 7) An Engineering study will need to be conducted to determine if the CT Thermal Limit settings can be adjusted to mitigate the overload. Estimated Cost: \$25,000. New relay package will be required if the settings cannot be adjusted, Estimated Cost: \$600,000. Time Estimate : 24-36 Months Cost : \$21,985,000 <u>NIPS</u> Description : The external (i.e. Non-PJM) Transmission Owner, NIPS, will not evaluate this violation until the impact study phase.	\$21,985,000
767719,161679	7	GREENACRE; T 345.0 kV - 05OLIVE 345.0 kV Ckt 1	<u>CE</u> Description : No Violation. ComEd 345kV L6615 SSTE rating is 1134 MVA. <u>AEP</u> Description : Replace ACSR/PE 1414 62/19 - Conductor Section 1. A Sag Study will be required on the 40.64 miles of conductor to mitigate the overload. The new ratings after sag study will be: S/N: 971 MVA, S/E: 1419 MVA, Depending on the sag study results, the cost for this upgrade is expected to be between \$162,560 (no remediation required, just sag study) and \$81.28 million (complete line Reconductor/rebuild). Time Estimate: a) Sag Study: 6-12 months b) Rebuild: The standard time required for construction differs from state to state. An approximate construction time would be 24 to 36 months after signing an interconnection agreement. Time Estimate : 6-12 Months Cost : \$162,560	\$162,560
162841,162842	15	AD1-100 TAP 345.0 kV - AD2-137 TAP 345.0 kV Ckt 1	<u>CE</u> Description : No Violation. The ALDR rating is 2554 MVA.	\$0

ID	Index	Facility	Upgrade Description	Cost
767588,767589,767590,767591,767592,161592,161593,161594,161595,161596	12	UNIV PK N;RP 345.0 kV - 05OLIVE 345.0 kV Ckt 1	CE Description : Line sag mitigation. Note that there may be additional 345kV line tower costs as a result of this upgrade. This estimate does not include potential tower work. The tower costs will be determined during the Facility Study Time Estimate : 24-30 Months Cost : \$13,800,000 AEP Description : 1) A Sag Study will be required on the 40.64 miles of ACSR/PE 1414 62/19 conductor to mitigate the overload. The new ratings after sag study will be: S/N: 971 MVA, S/E: 1419 MVA, Depending on the sag study results, the cost for this upgrade is expected to be between \$162,560 (no remediation required, just sag study) and \$81.28 million (complete line Reconductor/rebuild). Time Estimate: a) Sag Study: 6-12 months b) Rebuild: The standard time required for construction differs from state to state. An approximate construction time would be 24 to 36 months after signing an interconnection agreement. Time Estimate : 6-12 Months Cost : \$162,560	\$ 13,962,560
161808	2	17GREEN_ACRE 345.0 kV - GREENACRE; T 345.0 kV Ckt 1	CE Description : No Violation. The SSTE rating is 1134 MVA. NIPS Description : The external (i.e. Non-PJM) Transmission Owner, NIPS, will not evaluate this violation until the impact study phase.	\$0
161536,161537,161538,161535	11	CRETE EC ;BP 345.0 kV - 17STJOHN 345.0 kV Ckt 1	CE Description : The upgrade will be to re-conductor the line and upgrade station conductor. Time Estimate : 24-30 Months Cost : \$5,500,000 NIPS Description : The external (i.e. Non-PJM) Transmission Owner, NIPS, will not evaluate this violation until the impact study phase.	\$5,500,000
163004,163005,768083,769308,769309,161919	1	WILTON ; 765.0 kV - 05DUMONT 765.0 kV Ckt 1	CE Description : No Violation. The SLD rating is 4802 MVA. AEP Description : 1) Replace Dumont Circuit Breaker [Breaker (3000A) Non oil - Dumont] Time Estimate : 24-36 Months Cost : \$3,000,000	\$3,000,000

ID	Index	Facility	Upgrade Description	Cost
161796,161797,161798,161799	6	E FRANKFO; B 345.0 kV - CRETE EC ;BP 345.0 kV Ckt 1	<u>CE</u> Description : Line conductoring upgrade. Note that there may be additional 345kV line tower costs as a result of this upgrade. This estimate does not include potential tower work. The tower costs will be determined during the Facility Study. Time Estimate : 30.0 Months Cost : \$14,400,000	\$14,400,000
			TOTAL COST	\$93,410,120

Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gauge other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
769309	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L6607__B-S+_345-L97008_R-S	tower	4105.0	102.74	103.06	DC	50.58

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	32.21
274722	S-055 E	29.58
274772	LINCOLN ;3U	4.7
274773	LINCOLN ;4U	4.7
274774	LINCOLN ;5U	4.7
274775	LINCOLN ;6U	4.7
274776	LINCOLN ;7U	4.7
274777	LINCOLN ;8U	4.7
274832	U4-027	28.1
274859	EASYR;U1 E	29.17
274860	EASYR;U2 E	29.17
274888	PILOT HIL;1E	44.36
274890	CAYUG;1U E	36.12
274891	CAYUG;2U E	36.12
275149	KEMPTON ;1E	44.36
290021	O50 E	49.31
290051	GSG-6; E	28.12
290108	LEEDK;1U E	65.65
293061	N-015 E	41.27
293516	O-009 E1	23.83
293517	O-009 E2	12.1
293518	O-009 E3	13.33
293644	O22 E1	25.34
293645	O22 E2	49.19
293715	O-029 E	25.82
293716	O-029 E	14.15
293717	O-029 E	13.01
293771	O-035 E	16.52
294392	P-010 E	52.41
294401	BSHIL;1U E	22.13
294410	BSHIL;2U E	22.13
294763	P-046 E	24.91
295109	WESTBROOK E	15.05
295111	SUBLETTE E	6.88
296125	R-030 C3	9.32
296128	R-030 E3	37.3
296271	R-030 C2	9.21
296272	R-030 E2	36.85
296308	R-030 C1	9.21
296309	R-030 E1	36.85

Bus #	Bus	MW Impact
910542	X3-005 E	1.58
914641	Y2-103	118.34
915011	Y3-013 1	9.86
915021	Y3-013 2	9.86
915031	Y3-013 3	9.86
916211	Z1-072 E	12.5
916221	Z1-073 E	14.51
916502	Z1-106 E1	3.41
916504	Z1-106 E2	3.41
916512	Z1-107 E	6.53
916522	Z1-108 E	6.63
917502	Z2-087 E	48.2
918052	AA1-018 E	40.46
919221	AA1-146	46.56
919581	AA2-030	46.56
919621	AA2-039 C	5.39
919622	AA2-039 E	36.1
920272	AA2-123 E	6.51
924041	AB2-047 C O1	8.89
924042	AB2-047 E O1	59.51
924471	AB2-096	112.75
925161	AB2-173	8.3
925302	AB2-191 E	3.72
925581	AC1-033 C	3.62
925582	AC1-033 E	24.26
926311	AC1-109 1	5.22
926321	AC1-109 2	5.22
926331	AC1-110 1	5.13
926341	AC1-110 2	5.13
926351	AC1-111 1	2.07
926361	AC1-111 2	2.07
926371	AC1-111 3	2.07
926381	AC1-111 4	2.07
926391	AC1-111 5	2.07
926401	AC1-111 6	2.07
926431	AC1-114	6.33
926821	AC1-168 C O1	2.99
926822	AC1-168 E O1	20.04
927091	AC1-204 1	184.51
927101	AC1-204 2	184.55
927201	AC1-214 C O1	5.3
927202	AC1-214 E O1	16.85
927451	AC1-142A 1	10.62
927461	AC1-142A 2	10.62
927511	AC1-113 1	3.17
927521	AC1-113 2	3.17
927531	AC1-185 1	1.82
927541	AC1-185 2	1.82
927551	AC1-185 3	1.82
927561	AC1-185 4	1.82
927571	AC1-185 5	1.82
927581	AC1-185 6	1.82

Bus #	Bus	MW Impact
927591	AC1-185 7	1.82
927601	AC1-185 8	1.82
930481	AB1-089	175.38
930501	AB1-091 O1	174.2
930741	AB1-122 1O1	195.19
930751	AB1-122 2O1	188.91
932881	AC2-115 1	6.33
932891	AC2-115 2	6.33
932921	AC2-116	2.22
932931	AC2-117	14.97
933341	AC2-147 C	2.31
933342	AC2-147 E	3.78
933411	AC2-154 C	6.02
933412	AC2-154 E	9.82
933431	AC2-156 C O1	2.64
933432	AC2-156 E O1	4.3
933911	AD1-013 C	4.95
933912	AD1-013 E	7.91
933931	AD1-016 C	2.48
933932	AD1-016 E	4.04
934051	AD1-031 C O1	7.36
934052	AD1-031 E O1	12.0
934101	AD1-039 1	19.13
934111	AD1-039 2	18.51
934401	AD1-064 C O1	8.57
934402	AD1-064 E O1	40.14
934431	AD1-067 C	0.35
934432	AD1-067 E	1.48
934651	AD1-096 C	2.37
934652	AD1-096 E	3.87
934701	AD1-098 C O1	18.49
934702	AD1-098 E O1	13.5
934721	AD1-100 C	51.1
934722	AD1-100 E	238.47
934871	AD1-116 C	2.36
934872	AD1-116 E	3.84
934881	AD1-117 C	14.25
934882	AD1-117 E	9.5
934971	AD1-129 C	2.41
934972	AD1-129 E	1.61
935001	AD1-133 C O1	56.03
935002	AD1-133 E O1	37.35
936291	AD2-038 C O1	5.87
936292	AD2-038 E O1	39.26
936371	AD2-047 C O1	5.39
936372	AD2-047 E O1	57.98
936461	AD2-060	6.34
936511	AD2-066 C O1	21.5
936512	AD2-066 E O1	14.33
936781	AD2-101 C	10.69
936782	AD2-101 E	50.05
936791	AD2-102 C	31.93

Bus #	Bus	MW Impact
936792	AD2-102 E	30.68
936961	AD2-130	1.41
937001	AD2-134 C	7.35
937002	AD2-134 E	30.37
937031	AD2-137 C O1	10.27
937032	AD2-137 E O1	48.06
937051	AD2-140 C O1	10.51
937052	AD2-140 E O1	49.22
937061	AD2-141 C O1	10.45
937062	AD2-141 E O1	49.28
937071	AD2-142 C O1	21.03
937072	AD2-142 E O1	98.44
937121	AD2-148 C O1	8.36
937122	AD2-148 E O1	39.16
937131	AD2-149 C O1	8.36
937132	AD2-149 E O1	39.16
937141	AD2-150 C O1	8.36
937142	AD2-150 E O1	39.16
937181	AD2-155 C O1	8.36
937182	AD2-155 E O1	39.16
937311	AD2-172 C	6.54
937312	AD2-172 E	9.03
937321	AD2-175 C	38.97
937322	AD2-175 E	25.98
937331	AD2-176 C O1	19.55
937332	AD2-176 E O1	13.03
937401	AD2-194 1	19.84
937411	AD2-194 2	19.85
937531	AD2-214 C	11.62
937532	AD2-214 E	5.47
938012	AE1-002 E O1	20.61
938511	AE1-070 1	23.31
938521	AE1-070 2	21.33
938851	AE1-113 C O1	22.31
938852	AE1-113 E O1	70.14
938861	AE1-114 C O1	9.55
938862	AE1-114 E O1	36.5
939051	AE1-134 1	3.62
939061	AE1-134 2	3.62
939321	AE1-163 C O1	14.74
939322	AE1-163 E O1	90.54
939351	AE1-166 C O1	26.3
939352	AE1-166 E O1	24.28
939401	AE1-172 C O1	16.59
939402	AE1-172 E O1	77.68
939631	AE1-193 C O1	17.98
939632	AE1-193 E O1	120.33
939681	AE1-198 C O1	53.39
939682	AE1-198 E O1	45.36
939691	AE1-199	6.43
939701	AE1-201 C	5.34
939702	AE1-201 E	1.17

Bus #	Bus	MW Impact
939732	AE1-204 E	0.77
939741	AE1-205 C O1	23.32
939742	AE1-205 E O1	32.21
939861	AE1-222 1	215.56
939871	AE1-222 2	208.62
939921	AE1-228 C O1	27.06
939922	AE1-228 E O1	18.04
939961	AE1-233 C O1	6.29
939962	AE1-233 E O1	26.0
940101	AE1-252 C O1	28.28
940102	AE1-252 E O1	18.85
990901	L-005 E	20.34
AB2-013	AB2-013	41.13
AE1-033	AE1-033	47.76
BLUEG	BLUEG	16.6
CALDERWOOD	CALDERWOOD	0.21
CANNELTON	CANNELTON	0.24
CARR	CARR	1.95
CATAWBA	CATAWBA	0.78
CBM-S1	CBM-S1	3.58
CBM-W1	CBM-W1	77.21
CBM-W2	CBM-W2	141.69
CHEOAH	CHEOAH	0.22
CHILHOWEE	CHILHOWEE	0.06
DEARBORN	DEARBORN	6.39
ELMERSMITH	ELMERSMITH	0.25
G-007	G-007	5.48
GIBSON	GIBSON	0.07
HAMLET	HAMLET	2.97
MEC	MEC	98.4
O-066	O-066	18.45
RENSSELAER	RENSSELAER	1.54
SANTEETLA	SANTEETLA	0.07
TRIMBLE	TRIMBLE	1.97
WEC	WEC	20.97
Z1-043	Z1-043	73.98

Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
161808	255104	17GREEN_ACR E	NIPS	270771	GREENACR E; T	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	102.9	103.27	DC	13.15

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	8.06
274722	S-055 E	7.52
274751	CRETE EC ;1U	1.93
274752	CRETE EC ;2U	1.93
274753	CRETE EC ;3U	1.93
274754	CRETE EC ;4U	1.93
274832	U4-027	7.11
274859	EASYR;U1 E	7.3
274860	EASYR;U2 E	7.3
274888	PILOT HIL;1E	12.4
274890	CAYUG;1U E	8.92
274891	CAYUG;2U E	8.92
275149	KEMPTON ;1E	12.4
290021	O50 E	12.98
290051	GSG-6; E	6.94
290108	LEEDK;1U E	16.14
293061	N-015 E	10.24
293516	O-009 E1	5.99
293517	O-009 E2	3.04
293518	O-009 E3	3.35
293644	O22 E1	7.24
293645	O22 E2	14.06
293715	O-029 E	6.47
293716	O-029 E	3.55
293717	O-029 E	3.26
294392	P-010 E	13.0
294763	P-046 E	6.23
295109	WESTBROOK E	3.72
295111	SUBLETTE E	1.72
910542	X3-005 E	0.52
914641	Y2-103	30.09
915011	Y3-013 1	2.51
915021	Y3-013 2	2.51
915031	Y3-013 3	2.51
916221	Z1-073 E	3.58
916502	Z1-106 E1	0.84
916504	Z1-106 E2	0.84
916512	Z1-107 E	1.71
916522	Z1-108 E	1.66
918052	AA1-018 E	10.62
919221	AA1-146	11.67

Bus #	Bus	MW Impact
919581	AA2-030	11.67
920272	AA2-123 E	1.63
924471	AB2-096	28.21
925161	AB2-173	2.08
925302	AB2-191 E	0.92
925881	AC1-067 O1	102.57
926311	AC1-109 1	1.27
926321	AC1-109 2	1.27
926331	AC1-110 1	1.27
926341	AC1-110 2	1.27
926351	AC1-111 1	0.51
926361	AC1-111 2	0.51
926371	AC1-111 3	0.51
926381	AC1-111 4	0.51
926391	AC1-111 5	0.51
926401	AC1-111 6	0.51
926431	AC1-114	1.58
926821	AC1-168 C O1	0.76
926822	AC1-168 E O1	5.08
927091	AC1-204 1	48.76
927101	AC1-204 2	48.73
927201	AC1-214 C O1	0.74
927202	AC1-214 E O1	2.34
927451	AC1-142A 1	2.83
927461	AC1-142A 2	2.83
927511	AC1-113 1	0.79
927521	AC1-113 2	0.79
927531	AC1-185 1	0.46
927541	AC1-185 2	0.46
927551	AC1-185 3	0.46
927561	AC1-185 4	0.46
927571	AC1-185 5	0.46
927581	AC1-185 6	0.46
927591	AC1-185 7	0.46
927601	AC1-185 8	0.46
930481	AB1-089	43.76
930501	AB1-091 O1	49.15
930741	AB1-122 1O1	47.58
930751	AB1-122 2O1	49.75
932881	AC2-115 1	1.58
932891	AC2-115 2	1.58
932921	AC2-116	0.55
933341	AC2-147 C	0.58
933342	AC2-147 E	0.94
933411	AC2-154 C	1.68
933412	AC2-154 E	2.75
933431	AC2-156 C O1	0.64
933432	AC2-156 E O1	1.04
933911	AD1-013 C	1.22
933912	AD1-013 E	1.95
933931	AD1-016 C	0.62
933932	AD1-016 E	1.01

Bus #	Bus	MW Impact
934101	AD1-039 1	4.66
934111	AD1-039 2	4.88
934401	AD1-064 C O1	2.13
934402	AD1-064 E O1	9.99
934431	AD1-067 C	0.09
934432	AD1-067 E	0.37
934651	AD1-096 C	0.59
934652	AD1-096 E	0.97
934701	AD1-098 C O1	4.57
934702	AD1-098 E O1	3.34
934721	AD1-100 C	12.94
934722	AD1-100 E	60.39
934871	AD1-116 C	0.62
934872	AD1-116 E	1.01
934881	AD1-117 C	3.57
934882	AD1-117 E	2.38
934971	AD1-129 C	0.6
934972	AD1-129 E	0.4
935001	AD1-133 C O1	13.73
935002	AD1-133 E O1	9.15
936291	AD2-038 C O1	1.54
936292	AD2-038 E O1	10.32
936371	AD2-047 C O1	1.51
936372	AD2-047 E O1	16.21
936461	AD2-060	1.77
936511	AD2-066 C O1	5.56
936512	AD2-066 E O1	3.71
936781	AD2-101 C	3.17
936782	AD2-101 E	14.84
936791	AD2-102 C	8.0
936792	AD2-102 E	7.69
936961	AD2-130	0.38
937001	AD2-134 C	1.82
937002	AD2-134 E	7.5
937031	AD2-137 C O1	2.31
937032	AD2-137 E O1	10.8
937051	AD2-140 C O1	2.32
937052	AD2-140 E O1	10.87
937061	AD2-141 C O1	2.31
937062	AD2-141 E O1	10.88
937071	AD2-142 C O1	4.64
937072	AD2-142 E O1	21.73
937121	AD2-148 C O1	2.36
937122	AD2-148 E O1	11.04
937131	AD2-149 C O1	2.36
937132	AD2-149 E O1	11.04
937141	AD2-150 C O1	2.36
937142	AD2-150 E O1	11.04
937181	AD2-155 C O1	2.36
937182	AD2-155 E O1	11.04
937311	AD2-172 C	1.64
937312	AD2-172 E	2.26

Bus #	Bus	MW Impact
937321	AD2-175 C	10.99
937322	AD2-175 E	7.33
937331	AD2-176 C O1	4.89
937332	AD2-176 E O1	3.26
937401	AD2-194 1	5.24
937411	AD2-194 2	5.24
937531	AD2-214 C	2.92
937532	AD2-214 E	1.37
938012	AE1-002 E O1	4.63
938511	AE1-070 1	6.16
938521	AE1-070 2	5.63
938851	AE1-113 C O1	5.88
938852	AE1-113 E O1	18.47
938861	AE1-114 C O1	2.39
938862	AE1-114 E O1	9.13
939051	AE1-134 1	0.91
939061	AE1-134 2	0.91
939321	AE1-163 C O1	3.87
939322	AE1-163 E O1	23.79
939351	AE1-166 C O1	6.84
939352	AE1-166 E O1	6.31
939401	AE1-172 C O1	4.1
939402	AE1-172 E O1	19.18
939641	AE1-194 C	10.88
939642	AE1-194 E	72.84
939651	AE1-195 C	10.88
939652	AE1-195 E	72.84
939691	AE1-199	1.59
939701	AE1-201 C	1.34
939702	AE1-201 E	0.29
939732	AE1-204 E	0.2
939861	AE1-222 1	52.55
939871	AE1-222 2	54.95
939921	AE1-228 C O1	6.68
939922	AE1-228 E O1	4.45
939961	AE1-233 C O1	1.55
939962	AE1-233 E O1	6.39
940101	AE1-252 C O1	6.98
940102	AE1-252 E O1	4.65
951721	J643	15.51
952581	J740 C	3.4
952582	J740 E	18.42
953871	J847	8.38
AB2-013	AB2-013	10.64
AE1-033	AE1-033	12.03
BLUEG	BLUEG	2.86
CANNELTON	CANNELTON	0.0
CARR	CARR	0.5
CATAWBA	CATAWBA	0.16
CBM-S1	CBM-S1	1.36
CBM-W1	CBM-W1	19.98
CBM-W2	CBM-W2	38.44

Bus #	Bus	MW Impact
CIN	CIN	0.12
DEARBORN	DEARBORN	2.29
G-007	G-007	1.38
HAMLET	HAMLET	0.65
MEC	MEC	25.05
O-066	O-066	4.65
RENSSELAER	RENSSELAER	0.39
SANTEETLA	SANTEETLA	0.0
TRIMBLE	TRIMBLE	0.34
WEC	WEC	5.32
Z1-043	Z1-043	18.82

Index 3

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
161638	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	COMED_P4_023-65-BT2-3__	breaker	1091.0	110.86	111.32	DC	14.62

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	9.04
274654	BRAIDWOOD;1U	19.05
274655	BRAIDWOOD;2U	18.24
274661	LASCO STA;2U	17.6
274687	WILL CNTY;4U	8.03
274704	KENDALL ;1C	2.81
274705	KENDALL ;1S	1.88
274706	KENDALL ;2C	2.81
274707	KENDALL ;2S	1.88
274722	S-055 E	8.45
274751	CRETE EC ;1U	3.36
274752	CRETE EC ;2U	3.36
274753	CRETE EC ;3U	3.36
274754	CRETE EC ;4U	3.36
274859	EASYR;U1 E	8.17
274860	EASYR;U2 E	8.17
274861	TOP CROP ;1U	0.33
274862	TOP CROP ;2U	0.63
274888	PILOT HIL;1E	12.81
274890	CAYUG;1U E	9.74
274891	CAYUG;2U E	9.74
275149	KEMPTON ;1E	12.81
290021	O50 E	14.65
290051	GSG-6; E	7.78
290108	LEEDK;1U E	18.09
293061	N-015 E	11.61
293516	O-009 E1	6.69
293517	O-009 E2	3.4
293518	O-009 E3	3.74
293644	O22 E1	8.5
293645	O22 E2	16.51
293715	O-029 E	7.24
293716	O-029 E	3.97
293717	O-029 E	3.65
294392	P-010 E	14.75
294763	P-046 E	6.98
295109	WESTBROOK E	4.16
295111	SUBLETTE E	1.92
914641	Y2-103	33.8
915011	Y3-013 1	2.82

Bus #	Bus	MW Impact
915021	Y3-013 2	2.82
915031	Y3-013 3	2.82
916221	Z1-073 E	4.01
916502	Z1-106 E1	0.94
916504	Z1-106 E2	0.94
916512	Z1-107 E	1.85
916522	Z1-108 E	1.86
918052	AA1-018 E	11.64
919221	AA1-146	13.04
919581	AA2-030	13.04
920272	AA2-123 E	1.83
924471	AB2-096	31.63
925161	AB2-173	2.33
925302	AB2-191 E	1.03
926311	AC1-109 1	1.42
926321	AC1-109 2	1.42
926331	AC1-110 1	1.42
926341	AC1-110 2	1.42
926351	AC1-111 1	0.57
926361	AC1-111 2	0.57
926371	AC1-111 3	0.57
926381	AC1-111 4	0.57
926391	AC1-111 5	0.57
926401	AC1-111 6	0.57
926431	AC1-114	1.77
926821	AC1-168 C O1	0.85
926822	AC1-168 E O1	5.68
927091	AC1-204 1	55.19
927101	AC1-204 2	55.12
927451	AC1-142A 1	3.2
927461	AC1-142A 2	3.2
927511	AC1-113 1	0.89
927521	AC1-113 2	0.89
927531	AC1-185 1	0.51
927541	AC1-185 2	0.51
927551	AC1-185 3	0.51
927561	AC1-185 4	0.51
927571	AC1-185 5	0.51
927581	AC1-185 6	0.51
927591	AC1-185 7	0.51
927601	AC1-185 8	0.51
930481	AB1-089	49.05
930501	AB1-091 O1	50.61
930741	AB1-122 1O1	52.99
930751	AB1-122 2O1	56.33
932881	AC2-115 1	1.77
932891	AC2-115 2	1.77
932921	AC2-116	0.62
933341	AC2-147 C	0.65
933342	AC2-147 E	1.06
933411	AC2-154 C	1.74
933412	AC2-154 E	2.84

Bus #	Bus	MW Impact
933431	AC2-156 C O1	0.71
933432	AC2-156 E O1	1.16
933911	AD1-013 C	1.37
933912	AD1-013 E	2.19
933931	AD1-016 C	0.69
933932	AD1-016 E	1.13
934101	AD1-039 1	5.19
934111	AD1-039 2	5.52
934401	AD1-064 C O1	2.39
934402	AD1-064 E O1	11.2
934431	AD1-067 C	0.1
934432	AD1-067 E	0.41
934651	AD1-096 C	0.66
934652	AD1-096 E	1.08
934701	AD1-098 C O1	5.12
934702	AD1-098 E O1	3.74
934721	AD1-100 C	14.27
934722	AD1-100 E	66.6
934871	AD1-116 C	0.68
934872	AD1-116 E	1.11
934881	AD1-117 C	3.99
934882	AD1-117 E	2.66
934971	AD1-129 C	0.67
934972	AD1-129 E	0.45
935001	AD1-133 C O1	15.16
935002	AD1-133 E O1	10.11
936291	AD2-038 C O1	1.71
936292	AD2-038 E O1	11.45
936371	AD2-047 C O1	1.56
936372	AD2-047 E O1	16.75
936461	AD2-060	1.83
936511	AD2-066 C O1	6.19
936512	AD2-066 E O1	4.13
936781	AD2-101 C	3.09
936782	AD2-101 E	14.46
936791	AD2-102 C	8.96
936792	AD2-102 E	8.61
936961	AD2-130	0.42
937001	AD2-134 C	2.03
937002	AD2-134 E	8.4
937031	AD2-137 C O1	2.44
937032	AD2-137 E O1	11.43
937051	AD2-140 C O1	2.44
937052	AD2-140 E O1	11.42
937061	AD2-141 C O1	2.43
937062	AD2-141 E O1	11.44
937071	AD2-142 C O1	4.88
937072	AD2-142 E O1	22.85
937121	AD2-148 C O1	2.43
937122	AD2-148 E O1	11.37
937131	AD2-149 C O1	2.43
937132	AD2-149 E O1	11.37

Bus #	Bus	MW Impact
937141	AD2-150 C O1	2.43
937142	AD2-150 E O1	11.37
937181	AD2-155 C O1	2.43
937182	AD2-155 E O1	11.37
937311	AD2-172 C	1.83
937312	AD2-172 E	2.53
937321	AD2-175 C	11.32
937322	AD2-175 E	7.55
937331	AD2-176 C O1	5.48
937332	AD2-176 E O1	3.65
937401	AD2-194 1	5.94
937411	AD2-194 2	5.93
937531	AD2-214 C	0.8
937532	AD2-214 E	0.38
938012	AE1-002 E O1	4.9
938511	AE1-070 1	6.97
938521	AE1-070 2	6.37
938851	AE1-113 C O1	6.63
938852	AE1-113 E O1	20.84
938861	AE1-114 C O1	2.67
938862	AE1-114 E O1	10.22
939051	AE1-134 1	1.01
939061	AE1-134 2	1.01
939321	AE1-163 C O1	4.3
939322	AE1-163 E O1	26.41
939351	AE1-166 C O1	7.6
939352	AE1-166 E O1	7.02
939401	AE1-172 C O1	4.47
939402	AE1-172 E O1	20.95
939641	AE1-194 C	18.96
939642	AE1-194 E	126.86
939651	AE1-195 C	18.96
939652	AE1-195 E	126.86
939691	AE1-199	1.78
939701	AE1-201 C	1.5
939702	AE1-201 E	0.33
939732	AE1-204 E	0.22
939861	AE1-222 1	58.52
939871	AE1-222 2	62.2
939921	AE1-228 C O1	7.48
939922	AE1-228 E O1	4.99
939961	AE1-233 C O1	1.73
939962	AE1-233 E O1	7.16
940101	AE1-252 C O1	7.63
940102	AE1-252 E O1	5.08
AB2-013	AB2-013	11.87
AE1-033	AE1-033	13.47
BLUEG	BLUEG	5.05
CALDERWOOD	CALDERWOOD	0.09
CANNELTON	CANNELTON	0.11
CARR	CARR	0.56
CATAWBA	CATAWBA	0.23

Bus #	Bus	MW Impact
CBM-S1	CBM-S1	0.77
CBM-W1	CBM-W1	20.04
CBM-W2	CBM-W2	37.14
CHEOAH	CHEOAH	0.09
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.24
ELMERSMITH	ELMERSMITH	0.14
G-007	G-007	1.57
GIBSON	GIBSON	0.06
HAMLET	HAMLET	0.87
MEC	MEC	27.58
O-066	O-066	5.3
RENSSELAER	RENSSELAER	0.45
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.59
WEC	WEC	5.97
Z1-043	Z1-043	20.98

Index 4

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
767455	255113	17STILLWEL	NIPS	243219	05DUMONT	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	173.35	173.76	DC	22.68

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	13.92
274722	S-055 E	12.95
274724	RIVER EC ;11	4.75
274788	SE CHICAG;5U	1.14
274789	SE CHICAG;6U	1.14
274790	SE CHICAG;7U	1.14
274791	SE CHICAG;8U	1.14
274795	SE CHICAG;2U	1.12
274832	U4-027	12.45
274859	EASYR;U1 E	12.67
274860	EASYR;U2 E	12.67
274888	PILOT HIL;1E	22.3
274890	CAYUG;1U E	15.76
274891	CAYUG;2U E	15.76
275149	KEMPTON ;1E	22.3
290021	O50 E	22.31
290051	GSG-6; E	12.02
290108	LEEDK;1U E	27.92
293061	N-015 E	17.54
293516	O-009 E1	10.45
293517	O-009 E2	5.31
293518	O-009 E3	5.85
293644	O22 E1	11.95
293645	O22 E2	23.2
293715	O-029 E	11.27
293716	O-029 E	6.18
293717	O-029 E	5.68
293771	O-035 E	7.36
294392	P-010 E	22.27
294763	P-046 E	10.8
295109	WESTBROOK E	6.44
295111	SUBLETTE E	2.99
910542	X3-005 E	1.0
914641	Y2-103	51.8
915011	Y3-013 1	4.32
915021	Y3-013 2	4.32
915031	Y3-013 3	4.32
916211	Z1-072 E	5.57
916221	Z1-073 E	6.2
916502	Z1-106 E1	1.45
916504	Z1-106 E2	1.45

Bus #	Bus	MW Impact
916512	Z1-107 E	3.03
916522	Z1-108 E	2.86
918052	AA1-018 E	18.74
919221	AA1-146	20.28
919581	AA2-030	20.28
920272	AA2-123 E	2.81
924471	AB2-096	48.73
925161	AB2-173	3.62
925302	AB2-191 E	1.59
925581	AC1-033 C	1.61
925582	AC1-033 E	10.81
925881	AC1-067 O1	198.49
926311	AC1-109 1	2.19
926321	AC1-109 2	2.19
926331	AC1-110 1	2.18
926341	AC1-110 2	2.18
926351	AC1-111 1	0.88
926361	AC1-111 2	0.88
926371	AC1-111 3	0.88
926381	AC1-111 4	0.88
926391	AC1-111 5	0.88
926401	AC1-111 6	0.88
926431	AC1-114	2.74
926821	AC1-168 C O1	1.32
926822	AC1-168 E O1	8.85
927091	AC1-204 1	83.26
927101	AC1-204 2	83.23
927201	AC1-214 C O1	2.36
927202	AC1-214 E O1	7.51
927451	AC1-142A 1	4.83
927461	AC1-142A 2	4.84
927511	AC1-113 1	1.37
927521	AC1-113 2	1.37
927531	AC1-185 1	0.79
927541	AC1-185 2	0.79
927551	AC1-185 3	0.79
927561	AC1-185 4	0.79
927571	AC1-185 5	0.79
927581	AC1-185 6	0.79
927591	AC1-185 7	0.79
927601	AC1-185 8	0.79
930481	AB1-089	75.67
930501	AB1-091 O1	88.22
930741	AB1-122 1O1	82.42
930751	AB1-122 2O1	84.95
932881	AC2-115 1	2.74
932891	AC2-115 2	2.74
932921	AC2-116	0.96
932931	AC2-117	5.81
933341	AC2-147 C	1.0
933342	AC2-147 E	1.64
933411	AC2-154 C	3.03

Bus #	Bus	MW Impact
933412	AC2-154 E	4.94
933431	AC2-156 C O1	1.1
933432	AC2-156 E O1	1.79
933911	AD1-013 C	2.12
933912	AD1-013 E	3.38
933931	AD1-016 C	1.07
933932	AD1-016 E	1.74
934101	AD1-039 1	8.08
934111	AD1-039 2	8.33
934401	AD1-064 C O1	3.69
934402	AD1-064 E O1	17.25
934431	AD1-067 C	0.15
934432	AD1-067 E	0.63
934651	AD1-096 C	1.03
934652	AD1-096 E	1.67
934701	AD1-098 C O1	7.91
934702	AD1-098 E O1	5.78
934721	AD1-100 C	22.45
934722	AD1-100 E	104.76
934871	AD1-116 C	1.09
934872	AD1-116 E	1.78
934881	AD1-117 C	6.19
934882	AD1-117 E	4.13
934971	AD1-129 C	1.04
934972	AD1-129 E	0.69
935001	AD1-133 C O1	24.06
935002	AD1-133 E O1	16.04
936291	AD2-038 C O1	2.69
936292	AD2-038 E O1	18.02
936371	AD2-047 C O1	2.71
936372	AD2-047 E O1	29.15
936461	AD2-060	3.19
936511	AD2-066 C O1	9.67
936512	AD2-066 E O1	6.45
936781	AD2-101 C	5.9
936782	AD2-101 E	27.62
936791	AD2-102 C	13.85
936792	AD2-102 E	13.3
936961	AD2-130	0.66
937001	AD2-134 C	3.14
937002	AD2-134 E	12.98
937031	AD2-137 C O1	4.08
937032	AD2-137 E O1	19.09
937051	AD2-140 C O1	4.11
937052	AD2-140 E O1	19.25
937061	AD2-141 C O1	4.09
937062	AD2-141 E O1	19.27
937071	AD2-142 C O1	8.22
937072	AD2-142 E O1	38.5
937121	AD2-148 C O1	4.23
937122	AD2-148 E O1	19.82
937131	AD2-149 C O1	4.23

Bus #	Bus	MW Impact
937132	AD2-149 E O1	19.82
937141	AD2-150 C O1	4.23
937142	AD2-150 E O1	19.82
937181	AD2-155 C O1	4.23
937182	AD2-155 E O1	19.82
937311	AD2-172 C	2.83
937312	AD2-172 E	3.91
937321	AD2-175 C	19.73
937322	AD2-175 E	13.15
937331	AD2-176 C O1	8.43
937332	AD2-176 E O1	5.62
937401	AD2-194 1	8.95
937411	AD2-194 2	8.95
937531	AD2-214 C	5.1
937532	AD2-214 E	2.4
938012	AE1-002 E O1	8.18
938511	AE1-070 1	10.52
938521	AE1-070 2	9.62
938851	AE1-113 C O1	10.1
938852	AE1-113 E O1	31.74
938861	AE1-114 C O1	4.14
938862	AE1-114 E O1	15.83
939051	AE1-134 1	1.58
939061	AE1-134 2	1.58
939321	AE1-163 C O1	6.77
939322	AE1-163 E O1	41.57
939351	AE1-166 C O1	11.8
939352	AE1-166 E O1	10.89
939401	AE1-172 C O1	7.21
939402	AE1-172 E O1	33.74
939631	AE1-193 C O1	4.73
939632	AE1-193 E O1	31.63
939641	AE1-194 C	10.24
939642	AE1-194 E	68.55
939651	AE1-195 C	10.24
939652	AE1-195 E	68.55
939681	AE1-198 C O1	23.78
939682	AE1-198 E O1	20.2
939691	AE1-199	2.75
939701	AE1-201 C	2.31
939702	AE1-201 E	0.51
939732	AE1-204 E	0.34
939861	AE1-222 1	91.02
939871	AE1-222 2	93.81
939921	AE1-228 C O1	11.56
939922	AE1-228 E O1	7.71
939961	AE1-233 C O1	2.67
939962	AE1-233 E O1	11.05
940101	AE1-252 C O1	12.28
940102	AE1-252 E O1	8.19
951721	J643	25.73
952581	J740 C	4.3

Bus #	Bus	MW Impact
952582	J740 E	23.28
953871	J847	13.1
954751	J351	434.54
AB2-013	AB2-013	18.6
AE1-033	AE1-033	20.85
BLUEG	BLUEG	1.07
CARR	CARR	0.9
CATAWBA	CATAWBA	0.22
CBM-S1	CBM-S1	3.95
CBM-W1	CBM-W1	35.83
CBM-W2	CBM-W2	81.92
CIN	CIN	3.3
DEARBORN	DEARBORN	4.0
G-007	G-007	2.51
HAMLET	HAMLET	0.96
IPL	IPL	1.12
MEC	MEC	44.69
O-066	O-066	8.44
RENSSELAER	RENSSELAER	0.71
TRIMBLE	TRIMBLE	0.16
WEC	WEC	9.2
Z1-043	Z1-043	32.93

Index 5

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
161813	270677	BURNHAM ;OR	CE	255109	17MUNSTER	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1441.0	112.67	113.05	DC	19.68

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	11.75
274722	S-055 E	10.96
274723	RIVER EC ;12	4.32
274792	SE CHICAG;9U	0.96
274793	SE CHICAG;0U	0.96
274794	SE CHICAG;1U	0.96
274795	SE CHICAG;2U	0.96
274832	U4-027	10.31
274859	EASYR;U1 E	10.61
274860	EASYR;U2 E	10.61
274888	PILOT HIL;1E	20.48
274890	CAYUG;1U E	13.4
274891	CAYUG;2U E	13.4
275149	KEMPTON ;1E	20.48
290021	O50 E	18.57
290051	GSG-6; E	10.13
290108	LEEDK;1U E	23.57
293061	N-015 E	14.82
293516	O-009 E1	8.7
293517	O-009 E2	4.42
293518	O-009 E3	4.87
293644	O22 E1	9.26
293645	O22 E2	17.98
293715	O-029 E	9.4
293716	O-029 E	5.15
293717	O-029 E	4.74
293771	O-035 E	6.09
294392	P-010 E	18.82
294763	P-046 E	9.07
295109	WESTBROOK E	5.42
295111	SUBLETTE E	2.5
296125	R-030 C3	3.43
296128	R-030 E3	13.71
296271	R-030 C2	3.39
296272	R-030 E2	13.54
296308	R-030 C1	3.39
296309	R-030 E1	13.54
910541	X3-005 C	0.08
910542	X3-005 E	0.91
914641	Y2-103	43.82
915011	Y3-013 1	3.65

Bus #	Bus	MW Impact
915021	Y3-013 2	3.65
915031	Y3-013 3	3.65
916211	Z1-072 E	4.61
916221	Z1-073 E	5.23
916502	Z1-106 E1	1.23
916504	Z1-106 E2	1.23
916512	Z1-107 E	2.58
916522	Z1-108 E	2.42
917502	Z2-087 E	8.96
918052	AA1-018 E	16.81
919221	AA1-146	16.93
919581	AA2-030	16.93
920272	AA2-123 E	2.37
924471	AB2-096	41.11
925161	AB2-173	3.02
925302	AB2-191 E	1.34
925881	AC1-067 O1	301.08
926311	AC1-109 1	1.86
926321	AC1-109 2	1.86
926331	AC1-110 1	1.85
926341	AC1-110 2	1.85
926351	AC1-111 1	0.75
926361	AC1-111 2	0.75
926371	AC1-111 3	0.75
926381	AC1-111 4	0.75
926391	AC1-111 5	0.75
926401	AC1-111 6	0.75
926431	AC1-114	2.31
926821	AC1-168 C O1	1.1
926822	AC1-168 E O1	7.36
927091	AC1-204 1	70.09
927101	AC1-204 2	70.14
927201	AC1-214 C O1	1.95
927202	AC1-214 E O1	6.21
927451	AC1-142A 1	4.09
927461	AC1-142A 2	4.09
927511	AC1-113 1	1.15
927521	AC1-113 2	1.15
927531	AC1-185 1	0.66
927541	AC1-185 2	0.66
927551	AC1-185 3	0.66
927561	AC1-185 4	0.66
927571	AC1-185 5	0.66
927581	AC1-185 6	0.66
927591	AC1-185 7	0.66
927601	AC1-185 8	0.66
930481	AB1-089	63.73
930501	AB1-091 O1	82.27
930741	AB1-122 1O1	70.02
930751	AB1-122 2O1	70.99
932881	AC2-115 1	2.31
932891	AC2-115 2	2.31

Bus #	Bus	MW Impact
932921	AC2-116	0.81
932931	AC2-117	5.3
933341	AC2-147 C	0.84
933342	AC2-147 E	1.37
933411	AC2-154 C	2.78
933412	AC2-154 E	4.53
933431	AC2-156 C O1	0.93
933432	AC2-156 E O1	1.52
933911	AD1-013 C	1.78
933912	AD1-013 E	2.85
933931	AD1-016 C	0.9
933932	AD1-016 E	1.47
934101	AD1-039 1	6.86
934111	AD1-039 2	6.96
934401	AD1-064 C O1	3.11
934402	AD1-064 E O1	14.56
934431	AD1-067 C	0.13
934432	AD1-067 E	0.53
934651	AD1-096 C	0.86
934652	AD1-096 E	1.41
934701	AD1-098 C O1	6.66
934702	AD1-098 E O1	4.86
934721	AD1-100 C	19.54
934722	AD1-100 E	91.19
934871	AD1-116 C	0.98
934872	AD1-116 E	1.6
934881	AD1-117 C	5.18
934882	AD1-117 E	3.46
934971	AD1-129 C	0.88
934972	AD1-129 E	0.58
935001	AD1-133 C O1	20.3
935002	AD1-133 E O1	13.53
936291	AD2-038 C O1	2.33
936292	AD2-038 E O1	15.58
936371	AD2-047 C O1	2.49
936372	AD2-047 E O1	26.77
936461	AD2-060	2.93
936511	AD2-066 C O1	8.14
936512	AD2-066 E O1	5.43
936781	AD2-101 C	4.75
936782	AD2-101 E	22.22
936791	AD2-102 C	11.64
936792	AD2-102 E	11.19
936961	AD2-130	0.56
937001	AD2-134 C	2.65
937002	AD2-134 E	10.94
937031	AD2-137 C O1	3.67
937032	AD2-137 E O1	17.17
937051	AD2-140 C O1	3.72
937052	AD2-140 E O1	17.42
937061	AD2-141 C O1	3.7
937062	AD2-141 E O1	17.44

Bus #	Bus	MW Impact
937071	AD2-142 C O1	7.44
937072	AD2-142 E O1	34.83
937121	AD2-148 C O1	3.94
937122	AD2-148 E O1	18.43
937131	AD2-149 C O1	3.94
937132	AD2-149 E O1	18.43
937141	AD2-150 C O1	3.94
937142	AD2-150 E O1	18.43
937181	AD2-155 C O1	3.94
937182	AD2-155 E O1	18.43
937311	AD2-172 C	2.38
937312	AD2-172 E	3.29
937321	AD2-175 C	18.34
937322	AD2-175 E	12.23
937331	AD2-176 C O1	7.12
937332	AD2-176 E O1	4.75
937401	AD2-194 1	7.54
937411	AD2-194 2	7.54
937531	AD2-214 C	4.24
937532	AD2-214 E	1.99
938012	AE1-002 E O1	7.36
938511	AE1-070 1	8.86
938521	AE1-070 2	8.11
938851	AE1-113 C O1	8.4
938852	AE1-113 E O1	26.41
938861	AE1-114 C O1	3.47
938862	AE1-114 E O1	13.28
939051	AE1-134 1	1.32
939061	AE1-134 2	1.32
939321	AE1-163 C O1	5.85
939322	AE1-163 E O1	35.94
939351	AE1-166 C O1	10.23
939352	AE1-166 E O1	9.45
939401	AE1-172 C O1	6.18
939402	AE1-172 E O1	28.94
939691	AE1-199	2.32
939701	AE1-201 C	1.95
939702	AE1-201 E	0.43
939732	AE1-204 E	0.28
939741	AE1-205 C O1	8.57
939742	AE1-205 E O1	11.84
939861	AE1-222 1	77.33
939871	AE1-222 2	78.4
939921	AE1-228 C O1	9.74
939922	AE1-228 E O1	6.49
939961	AE1-233 C O1	2.26
939962	AE1-233 E O1	9.34
940101	AE1-252 C O1	10.54
940102	AE1-252 E O1	7.02
AB2-013	AB2-013	15.32
AE1-033	AE1-033	17.49
BLUEG	BLUEG	5.47

Bus #	Bus	MW Impact
CALDERWOOD	CALDERWOOD	0.06
CANNELTON	CANNELTON	0.08
CARR	CARR	0.73
CATAWBA	CATAWBA	0.27
CBM-S1	CBM-S1	1.44
CBM-W1	CBM-W1	23.88
CBM-W2	CBM-W2	51.81
CHEOAH	CHEOAH	0.06
CHILHOWEE	CHILHOWEE	0.02
DEARBORN	DEARBORN	2.93
ELMERSMITH	ELMERSMITH	0.08
G-007	G-007	2.03
GIBSON	GIBSON	0.04
HAMLET	HAMLET	1.05
MEC	MEC	36.09
O-066	O-066	6.84
RENSSELAER	RENSSELAER	0.58
SANTEETLA	SANTEETLA	0.02
TRIMBLE	TRIMBLE	0.65
WEC	WEC	7.74
Z1-043	Z1-043	27.27

Index 6

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
161796	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	110.61	111.15	DC	20.51

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	12.73
274654	BRAIDWOOD;1U	27.26
274655	BRAIDWOOD;2U	26.09
274660	LASCO STA;1U	24.9
274661	LASCO STA;2U	24.94
274675	JOLIET 29;7U	11.25
274676	JOLIET 29;8U	11.26
274687	WILL CNTY;4U	11.37
274704	KENDALL ;1C	4.0
274705	KENDALL ;1S	2.67
274706	KENDALL ;2C	4.0
274707	KENDALL ;2S	2.67
274722	S-055 E	11.91
274736	ELWOOD EC;9P	3.23
274832	U4-027	11.21
274859	EASYR;U1 E	11.52
274860	EASYR;U2 E	11.52
274861	TOP CROP ;1U	0.47
274862	TOP CROP ;2U	0.92
274888	PILOT HIL;1E	17.1
274890	CAYUG;1U E	13.64
274891	CAYUG;2U E	13.64
275149	KEMPTON ;1E	17.1
290021	O50 E	20.79
290051	GSG-6; E	10.94
290108	LEEDK;1U E	25.43
293061	N-015 E	16.43
293516	O-009 E1	9.45
293517	O-009 E2	4.8
293518	O-009 E3	5.29
293644	O22 E1	12.34
293645	O22 E2	23.96
293715	O-029 E	10.21
293716	O-029 E	5.6
293717	O-029 E	5.15
293771	O-035 E	6.61
294392	P-010 E	20.87
294763	P-046 E	9.84
295109	WESTBROOK E	5.86
295111	SUBLETTE E	2.71

Bus #	Bus	MW Impact
914641	Y2-103	47.64
915011	Y3-013 1	3.97
915021	Y3-013 2	3.97
915031	Y3-013 3	3.97
916211	Z1-072 E	5.0
916221	Z1-073 E	5.65
916502	Z1-106 E1	1.33
916504	Z1-106 E2	1.33
916512	Z1-107 E	2.55
916522	Z1-108 E	2.62
918052	AA1-018 E	16.2
919221	AA1-146	18.41
919581	AA2-030	18.41
920272	AA2-123 E	2.57
924471	AB2-096	44.55
925161	AB2-173	3.28
925302	AB2-191 E	1.45
925581	AC1-033 C	1.45
925582	AC1-033 E	9.71
926311	AC1-109 1	2.0
926321	AC1-109 2	2.0
926331	AC1-110 1	2.0
926341	AC1-110 2	2.0
926351	AC1-111 1	0.8
926361	AC1-111 2	0.8
926371	AC1-111 3	0.8
926381	AC1-111 4	0.8
926391	AC1-111 5	0.8
926401	AC1-111 6	0.8
926431	AC1-114	2.5
926821	AC1-168 C O1	1.2
926822	AC1-168 E O1	8.03
927091	AC1-204 1	78.31
927101	AC1-204 2	78.18
927201	AC1-214 C O1	2.12
927202	AC1-214 E O1	6.75
927451	AC1-142A 1	4.53
927461	AC1-142A 2	4.53
927511	AC1-113 1	1.25
927521	AC1-113 2	1.25
927531	AC1-185 1	0.72
927541	AC1-185 2	0.72
927551	AC1-185 3	0.72
927561	AC1-185 4	0.72
927571	AC1-185 5	0.72
927581	AC1-185 6	0.72
927591	AC1-185 7	0.72
927601	AC1-185 8	0.72
930481	AB1-089	69.1
930501	AB1-091 O1	67.39
930741	AB1-122 1O1	74.68
930751	AB1-122 2O1	79.86

Bus #	Bus	MW Impact
932881	AC2-115 1	2.5
932891	AC2-115 2	2.5
932921	AC2-116	0.88
933341	AC2-147 C	0.91
933342	AC2-147 E	1.49
933411	AC2-154 C	2.32
933412	AC2-154 E	3.79
933431	AC2-156 C O1	1.0
933432	AC2-156 E O1	1.63
933911	AD1-013 C	1.93
933912	AD1-013 E	3.08
933931	AD1-016 C	0.98
933932	AD1-016 E	1.6
934101	AD1-039 1	7.32
934111	AD1-039 2	7.83
934401	AD1-064 C O1	3.37
934402	AD1-064 E O1	15.78
934431	AD1-067 C	0.14
934432	AD1-067 E	0.58
934651	AD1-096 C	0.94
934652	AD1-096 E	1.53
934701	AD1-098 C O1	7.2
934702	AD1-098 E O1	5.26
934721	AD1-100 C	19.95
934722	AD1-100 E	93.11
934871	AD1-116 C	0.94
934872	AD1-116 E	1.54
934881	AD1-117 C	5.63
934882	AD1-117 E	3.75
934971	AD1-129 C	0.95
934972	AD1-129 E	0.63
935001	AD1-133 C O1	21.34
935002	AD1-133 E O1	14.23
936291	AD2-038 C O1	2.41
936292	AD2-038 E O1	16.1
936371	AD2-047 C O1	2.08
936372	AD2-047 E O1	22.36
936461	AD2-060	2.44
936511	AD2-066 C O1	8.72
936512	AD2-066 E O1	5.81
936781	AD2-101 C	3.97
936782	AD2-101 E	18.57
936791	AD2-102 C	12.63
936792	AD2-102 E	12.14
936961	AD2-130	0.59
937001	AD2-134 C	2.86
937002	AD2-134 E	11.82
937031	AD2-137 C O1	3.34
937032	AD2-137 E O1	15.64
937051	AD2-140 C O1	3.33
937052	AD2-140 E O1	15.57
937061	AD2-141 C O1	3.31

Bus #	Bus	MW Impact
937062	AD2-141 E O1	15.59
937071	AD2-142 C O1	6.65
937072	AD2-142 E O1	31.14
937121	AD2-148 C O1	3.24
937122	AD2-148 E O1	15.15
937131	AD2-149 C O1	3.24
937132	AD2-149 E O1	15.15
937141	AD2-150 C O1	3.24
937142	AD2-150 E O1	15.15
937181	AD2-155 C O1	3.24
937182	AD2-155 E O1	15.15
937311	AD2-172 C	2.58
937312	AD2-172 E	3.57
937321	AD2-175 C	15.07
937322	AD2-175 E	10.05
937331	AD2-176 C O1	7.72
937332	AD2-176 E O1	5.15
937401	AD2-194 1	8.42
937411	AD2-194 2	8.41
937531	AD2-214 C	4.61
937532	AD2-214 E	2.17
938012	AE1-002 E O1	6.71
938511	AE1-070 1	9.9
938521	AE1-070 2	9.04
938851	AE1-113 C O1	9.41
938852	AE1-113 E O1	29.58
938861	AE1-114 C O1	3.77
938862	AE1-114 E O1	14.41
939051	AE1-134 1	1.43
939061	AE1-134 2	1.43
939321	AE1-163 C O1	6.04
939322	AE1-163 E O1	37.13
939351	AE1-166 C O1	10.67
939352	AE1-166 E O1	9.85
939401	AE1-172 C O1	6.26
939402	AE1-172 E O1	29.29
939631	AE1-193 C O1	1.03
939632	AE1-193 E O1	6.9
939681	AE1-198 C O1	21.36
939682	AE1-198 E O1	18.15
939691	AE1-199	2.5
939701	AE1-201 C	2.11
939702	AE1-201 E	0.46
939732	AE1-204 E	0.31
939861	AE1-222 1	82.47
939871	AE1-222 2	88.2
939921	AE1-228 C O1	10.52
939922	AE1-228 E O1	7.01
939961	AE1-233 C O1	2.44
939962	AE1-233 E O1	10.07
940101	AE1-252 C O1	10.66
940102	AE1-252 E O1	7.11

Bus #	Bus	MW Impact
AB2-013	AB2-013	16.84
AE1-033	AE1-033	19.0
BLUEG	BLUEG	5.85
CALDERWOOD	CALDERWOOD	0.03
CANNELTON	CANNELTON	0.09
CARR	CARR	0.74
CATAWBA	CATAWBA	0.27
CBM-S1	CBM-S1	1.66
CBM-W1	CBM-W1	26.48
CBM-W2	CBM-W2	55.79
CHEOAH	CHEOAH	0.04
CHILHOWEE	CHILHOWEE	0.01
DEARBORN	DEARBORN	3.02
ELMERSMITH	ELMERSMITH	0.09
G-007	G-007	2.06
GIBSON	GIBSON	0.05
HAMLET	HAMLET	1.03
MEC	MEC	39.2
O-066	O-066	6.93
RENSSELAER	RENSSELAER	0.58
SANTEETLA	SANTEETLA	0.01
TRIMBLE	TRIMBLE	0.69
WEC	WEC	8.42
Z1-043	Z1-043	29.68

Index 7

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
767719	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	115.6	116.01	DC	13.15

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	8.06
274722	S-055 E	7.52
274751	CRETE EC ;1U	1.93
274752	CRETE EC ;2U	1.93
274753	CRETE EC ;3U	1.93
274754	CRETE EC ;4U	1.93
274832	U4-027	7.11
274859	EASYR;U1 E	7.3
274860	EASYR;U2 E	7.3
274888	PILOT HIL;1E	12.4
274890	CAYUG;1U E	8.92
274891	CAYUG;2U E	8.92
275149	KEMPTON ;1E	12.4
290021	O50 E	12.98
290051	GSG-6; E	6.94
290108	LEEDK;1U E	16.14
293061	N-015 E	10.24
293516	O-009 E1	5.99
293517	O-009 E2	3.04
293518	O-009 E3	3.35
293644	O22 E1	7.24
293645	O22 E2	14.06
293715	O-029 E	6.47
293716	O-029 E	3.55
293717	O-029 E	3.26
294392	P-010 E	13.0
294763	P-046 E	6.23
295109	WESTBROOK E	3.72
295111	SUBLETTE E	1.72
910542	X3-005 E	0.52
914641	Y2-103	30.09
915011	Y3-013 1	2.51
915021	Y3-013 2	2.51
915031	Y3-013 3	2.51
916221	Z1-073 E	3.58
916502	Z1-106 E1	0.84
916504	Z1-106 E2	0.84
916512	Z1-107 E	1.71
916522	Z1-108 E	1.66
918052	AA1-018 E	10.62
919221	AA1-146	11.67

Bus #	Bus	MW Impact
919581	AA2-030	11.67
920272	AA2-123 E	1.63
924471	AB2-096	28.21
925161	AB2-173	2.08
925302	AB2-191 E	0.92
925881	AC1-067 O1	102.57
926311	AC1-109 1	1.27
926321	AC1-109 2	1.27
926331	AC1-110 1	1.27
926341	AC1-110 2	1.27
926351	AC1-111 1	0.51
926361	AC1-111 2	0.51
926371	AC1-111 3	0.51
926381	AC1-111 4	0.51
926391	AC1-111 5	0.51
926401	AC1-111 6	0.51
926431	AC1-114	1.58
926821	AC1-168 C O1	0.76
926822	AC1-168 E O1	5.08
927091	AC1-204 1	48.76
927101	AC1-204 2	48.73
927201	AC1-214 C O1	0.74
927202	AC1-214 E O1	2.34
927451	AC1-142A 1	2.83
927461	AC1-142A 2	2.83
927511	AC1-113 1	0.79
927521	AC1-113 2	0.79
927531	AC1-185 1	0.46
927541	AC1-185 2	0.46
927551	AC1-185 3	0.46
927561	AC1-185 4	0.46
927571	AC1-185 5	0.46
927581	AC1-185 6	0.46
927591	AC1-185 7	0.46
927601	AC1-185 8	0.46
930481	AB1-089	43.76
930501	AB1-091 O1	49.15
930741	AB1-122 1O1	47.58
930751	AB1-122 2O1	49.75
932881	AC2-115 1	1.58
932891	AC2-115 2	1.58
932921	AC2-116	0.55
933341	AC2-147 C	0.58
933342	AC2-147 E	0.94
933411	AC2-154 C	1.68
933412	AC2-154 E	2.75
933431	AC2-156 C O1	0.64
933432	AC2-156 E O1	1.04
933911	AD1-013 C	1.22
933912	AD1-013 E	1.95
933931	AD1-016 C	0.62
933932	AD1-016 E	1.01

Bus #	Bus	MW Impact
934101	AD1-039 1	4.66
934111	AD1-039 2	4.88
934401	AD1-064 C O1	2.13
934402	AD1-064 E O1	9.99
934431	AD1-067 C	0.09
934432	AD1-067 E	0.37
934651	AD1-096 C	0.59
934652	AD1-096 E	0.97
934701	AD1-098 C O1	4.57
934702	AD1-098 E O1	3.34
934721	AD1-100 C	12.94
934722	AD1-100 E	60.39
934871	AD1-116 C	0.62
934872	AD1-116 E	1.01
934881	AD1-117 C	3.57
934882	AD1-117 E	2.38
934971	AD1-129 C	0.6
934972	AD1-129 E	0.4
935001	AD1-133 C O1	13.73
935002	AD1-133 E O1	9.15
936291	AD2-038 C O1	1.54
936292	AD2-038 E O1	10.32
936371	AD2-047 C O1	1.51
936372	AD2-047 E O1	16.21
936461	AD2-060	1.77
936511	AD2-066 C O1	5.56
936512	AD2-066 E O1	3.71
936781	AD2-101 C	3.17
936782	AD2-101 E	14.84
936791	AD2-102 C	8.0
936792	AD2-102 E	7.69
936961	AD2-130	0.38
937001	AD2-134 C	1.82
937002	AD2-134 E	7.5
937031	AD2-137 C O1	2.31
937032	AD2-137 E O1	10.8
937051	AD2-140 C O1	2.32
937052	AD2-140 E O1	10.87
937061	AD2-141 C O1	2.31
937062	AD2-141 E O1	10.88
937071	AD2-142 C O1	4.64
937072	AD2-142 E O1	21.73
937121	AD2-148 C O1	2.36
937122	AD2-148 E O1	11.04
937131	AD2-149 C O1	2.36
937132	AD2-149 E O1	11.04
937141	AD2-150 C O1	2.36
937142	AD2-150 E O1	11.04
937181	AD2-155 C O1	2.36
937182	AD2-155 E O1	11.04
937311	AD2-172 C	1.64
937312	AD2-172 E	2.26

Bus #	Bus	MW Impact
937321	AD2-175 C	10.99
937322	AD2-175 E	7.33
937331	AD2-176 C O1	4.89
937332	AD2-176 E O1	3.26
937401	AD2-194 1	5.24
937411	AD2-194 2	5.24
937531	AD2-214 C	2.92
937532	AD2-214 E	1.37
938012	AE1-002 E O1	4.63
938511	AE1-070 1	6.16
938521	AE1-070 2	5.63
938851	AE1-113 C O1	5.88
938852	AE1-113 E O1	18.47
938861	AE1-114 C O1	2.39
938862	AE1-114 E O1	9.13
939051	AE1-134 1	0.91
939061	AE1-134 2	0.91
939321	AE1-163 C O1	3.87
939322	AE1-163 E O1	23.79
939351	AE1-166 C O1	6.84
939352	AE1-166 E O1	6.31
939401	AE1-172 C O1	4.1
939402	AE1-172 E O1	19.18
939641	AE1-194 C	10.88
939642	AE1-194 E	72.84
939651	AE1-195 C	10.88
939652	AE1-195 E	72.84
939691	AE1-199	1.59
939701	AE1-201 C	1.34
939702	AE1-201 E	0.29
939732	AE1-204 E	0.2
939861	AE1-222 1	52.55
939871	AE1-222 2	54.95
939921	AE1-228 C O1	6.68
939922	AE1-228 E O1	4.45
939961	AE1-233 C O1	1.55
939962	AE1-233 E O1	6.39
940101	AE1-252 C O1	6.98
940102	AE1-252 E O1	4.65
951721	J643	15.51
952581	J740 C	3.4
952582	J740 E	18.42
953871	J847	8.38
AB2-013	AB2-013	10.64
AE1-033	AE1-033	12.03
BLUEG	BLUEG	2.86
CANNELTON	CANNELTON	0.0
CARR	CARR	0.5
CATAWBA	CATAWBA	0.16
CBM-S1	CBM-S1	1.36
CBM-W1	CBM-W1	19.98
CBM-W2	CBM-W2	38.44

Bus #	Bus	MW Impact
CIN	CIN	0.12
DEARBORN	DEARBORN	2.29
G-007	G-007	1.38
HAMLET	HAMLET	0.65
MEC	MEC	25.05
O-066	O-066	4.65
RENSSELAER	RENSSELAER	0.39
SANTEETLA	SANTEETLA	0.0
TRIMBLE	TRIMBLE	0.34
WEC	WEC	5.32
Z1-043	Z1-043	18.82

Index 8

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
161643	270886	ST JOHN ; T	CE	255104	17GREEN_ACRE	NIPS	1	COMED_P4_023-65-BT2-3__	breaker	1091.0	110.86	111.32	DC	14.62

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	9.04
274654	BRAIDWOOD;1U	19.05
274655	BRAIDWOOD;2U	18.24
274661	LASCO STA;2U	17.6
274687	WILL CNTY;4U	8.03
274704	KENDALL ;1C	2.81
274705	KENDALL ;1S	1.88
274706	KENDALL ;2C	2.81
274707	KENDALL ;2S	1.88
274722	S-055 E	8.45
274751	CRETE EC ;1U	3.36
274752	CRETE EC ;2U	3.36
274753	CRETE EC ;3U	3.36
274754	CRETE EC ;4U	3.36
274859	EASYR;U1 E	8.17
274860	EASYR;U2 E	8.17
274861	TOP CROP ;1U	0.33
274862	TOP CROP ;2U	0.63
274888	PILOT HIL;1E	12.81
274890	CAYUG;1U E	9.74
274891	CAYUG;2U E	9.74
275149	KEMPTON ;1E	12.81
290021	O50 E	14.65
290051	GSG-6; E	7.78
290108	LEEDK;1U E	18.09
293061	N-015 E	11.61
293516	O-009 E1	6.69
293517	O-009 E2	3.4
293518	O-009 E3	3.74
293644	O22 E1	8.5
293645	O22 E2	16.51
293715	O-029 E	7.24
293716	O-029 E	3.97
293717	O-029 E	3.65
294392	P-010 E	14.75
294763	P-046 E	6.98
295109	WESTBROOK E	4.16
295111	SUBLETTE E	1.92
914641	Y2-103	33.8
915011	Y3-013 1	2.82

Bus #	Bus	MW Impact
915021	Y3-013 2	2.82
915031	Y3-013 3	2.82
916221	Z1-073 E	4.01
916502	Z1-106 E1	0.94
916504	Z1-106 E2	0.94
916512	Z1-107 E	1.85
916522	Z1-108 E	1.86
918052	AA1-018 E	11.64
919221	AA1-146	13.04
919581	AA2-030	13.04
920272	AA2-123 E	1.83
924471	AB2-096	31.63
925161	AB2-173	2.33
925302	AB2-191 E	1.03
926311	AC1-109 1	1.42
926321	AC1-109 2	1.42
926331	AC1-110 1	1.42
926341	AC1-110 2	1.42
926351	AC1-111 1	0.57
926361	AC1-111 2	0.57
926371	AC1-111 3	0.57
926381	AC1-111 4	0.57
926391	AC1-111 5	0.57
926401	AC1-111 6	0.57
926431	AC1-114	1.77
926821	AC1-168 C O1	0.85
926822	AC1-168 E O1	5.68
927091	AC1-204 1	55.19
927101	AC1-204 2	55.12
927451	AC1-142A 1	3.2
927461	AC1-142A 2	3.2
927511	AC1-113 1	0.89
927521	AC1-113 2	0.89
927531	AC1-185 1	0.51
927541	AC1-185 2	0.51
927551	AC1-185 3	0.51
927561	AC1-185 4	0.51
927571	AC1-185 5	0.51
927581	AC1-185 6	0.51
927591	AC1-185 7	0.51
927601	AC1-185 8	0.51
930481	AB1-089	49.05
930501	AB1-091 O1	50.61
930741	AB1-122 1O1	52.99
930751	AB1-122 2O1	56.33
932881	AC2-115 1	1.77
932891	AC2-115 2	1.77
932921	AC2-116	0.62
933341	AC2-147 C	0.65
933342	AC2-147 E	1.06
933411	AC2-154 C	1.74
933412	AC2-154 E	2.84

Bus #	Bus	MW Impact
933431	AC2-156 C O1	0.71
933432	AC2-156 E O1	1.16
933911	AD1-013 C	1.37
933912	AD1-013 E	2.19
933931	AD1-016 C	0.69
933932	AD1-016 E	1.13
934101	AD1-039 1	5.19
934111	AD1-039 2	5.52
934401	AD1-064 C O1	2.39
934402	AD1-064 E O1	11.2
934431	AD1-067 C	0.1
934432	AD1-067 E	0.41
934651	AD1-096 C	0.66
934652	AD1-096 E	1.08
934701	AD1-098 C O1	5.12
934702	AD1-098 E O1	3.74
934721	AD1-100 C	14.27
934722	AD1-100 E	66.6
934871	AD1-116 C	0.68
934872	AD1-116 E	1.11
934881	AD1-117 C	3.99
934882	AD1-117 E	2.66
934971	AD1-129 C	0.67
934972	AD1-129 E	0.45
935001	AD1-133 C O1	15.16
935002	AD1-133 E O1	10.11
936291	AD2-038 C O1	1.71
936292	AD2-038 E O1	11.45
936371	AD2-047 C O1	1.56
936372	AD2-047 E O1	16.75
936461	AD2-060	1.83
936511	AD2-066 C O1	6.19
936512	AD2-066 E O1	4.13
936781	AD2-101 C	3.09
936782	AD2-101 E	14.46
936791	AD2-102 C	8.96
936792	AD2-102 E	8.61
936961	AD2-130	0.42
937001	AD2-134 C	2.03
937002	AD2-134 E	8.4
937031	AD2-137 C O1	2.44
937032	AD2-137 E O1	11.43
937051	AD2-140 C O1	2.44
937052	AD2-140 E O1	11.42
937061	AD2-141 C O1	2.43
937062	AD2-141 E O1	11.44
937071	AD2-142 C O1	4.88
937072	AD2-142 E O1	22.85
937121	AD2-148 C O1	2.43
937122	AD2-148 E O1	11.37
937131	AD2-149 C O1	2.43
937132	AD2-149 E O1	11.37

Bus #	Bus	MW Impact
937141	AD2-150 C O1	2.43
937142	AD2-150 E O1	11.37
937181	AD2-155 C O1	2.43
937182	AD2-155 E O1	11.37
937311	AD2-172 C	1.83
937312	AD2-172 E	2.53
937321	AD2-175 C	11.32
937322	AD2-175 E	7.55
937331	AD2-176 C O1	5.48
937332	AD2-176 E O1	3.65
937401	AD2-194 1	5.94
937411	AD2-194 2	5.93
937531	AD2-214 C	0.8
937532	AD2-214 E	0.38
938012	AE1-002 E O1	4.9
938511	AE1-070 1	6.97
938521	AE1-070 2	6.37
938851	AE1-113 C O1	6.63
938852	AE1-113 E O1	20.84
938861	AE1-114 C O1	2.67
938862	AE1-114 E O1	10.22
939051	AE1-134 1	1.01
939061	AE1-134 2	1.01
939321	AE1-163 C O1	4.3
939322	AE1-163 E O1	26.41
939351	AE1-166 C O1	7.6
939352	AE1-166 E O1	7.02
939401	AE1-172 C O1	4.47
939402	AE1-172 E O1	20.95
939641	AE1-194 C	18.96
939642	AE1-194 E	126.86
939651	AE1-195 C	18.96
939652	AE1-195 E	126.86
939691	AE1-199	1.78
939701	AE1-201 C	1.5
939702	AE1-201 E	0.33
939732	AE1-204 E	0.22
939861	AE1-222 1	58.52
939871	AE1-222 2	62.2
939921	AE1-228 C O1	7.48
939922	AE1-228 E O1	4.99
939961	AE1-233 C O1	1.73
939962	AE1-233 E O1	7.16
940101	AE1-252 C O1	7.63
940102	AE1-252 E O1	5.08
AB2-013	AB2-013	11.87
AE1-033	AE1-033	13.47
BLUEG	BLUEG	5.05
CALDERWOOD	CALDERWOOD	0.09
CANNELTON	CANNELTON	0.11
CARR	CARR	0.56
CATAWBA	CATAWBA	0.23

Bus #	Bus	MW Impact
CBM-S1	CBM-S1	0.77
CBM-W1	CBM-W1	20.04
CBM-W2	CBM-W2	37.14
CHEOAH	CHEOAH	0.09
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.24
ELMERSMITH	ELMERSMITH	0.14
G-007	G-007	1.57
GIBSON	GIBSON	0.06
HAMLET	HAMLET	0.87
MEC	MEC	27.58
O-066	O-066	5.3
RENSSELAER	RENSSELAER	0.45
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.59
WEC	WEC	5.97
Z1-043	Z1-043	20.98

Index 9

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
161503	270926	WILTON ; B	CE	275232	WILTON ;3M	CE	1	COMED_P4_112-65-BT5-6__	breaker	1379.0	165.81	166.14	DC	27.93

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	14.81
274722	S-055 E	13.75
274772	LINCOLN ;3U	3.36
274773	LINCOLN ;4U	3.36
274774	LINCOLN ;5U	3.36
274775	LINCOLN ;6U	3.36
274776	LINCOLN ;7U	3.36
274777	LINCOLN ;8U	3.36
274859	EASYR;U1 E	13.46
274860	EASYR;U2 E	13.46
274888	PILOT HIL;1E	23.62
274890	CAYUG;1U E	20.25
274891	CAYUG;2U E	20.25
275149	KEMPTON ;1E	23.62
290021	O50 E	23.75
290051	GSG-6; E	12.8
290108	LEEDK;1U E	29.74
293061	N-015 E	19.44
293516	O-009 E1	1.0
293517	O-009 E2	0.51
293518	O-009 E3	0.56
293644	O22 E1	12.55
293645	O22 E2	24.37
293715	O-029 E	11.98
293716	O-029 E	6.57
293717	O-029 E	6.04
294392	P-010 E	24.69
294763	P-046 E	11.48
295109	WESTBROOK E	6.85
295111	SUBLETTE E	3.18
296125	R-030 C3	4.98
296128	R-030 E3	19.93
296271	R-030 C2	4.92
296272	R-030 E2	19.7
296308	R-030 C1	4.92
296309	R-030 E1	19.7
910542	X3-005 E	0.9
914641	Y2-103	55.02
915011	Y3-013 1	4.58
915021	Y3-013 2	4.58
915031	Y3-013 3	4.58

Bus #	Bus	MW Impact
916221	Z1-073 E	6.61
916502	Z1-106 E1	1.55
916504	Z1-106 E2	1.55
916512	Z1-107 E	3.17
916522	Z1-108 E	3.04
917502	Z2-087 E	25.76
918052	AA1-018 E	20.13
919221	AA1-146	21.54
919581	AA2-030	21.54
920272	AA2-123 E	2.99
924041	AB2-047 C O1	4.75
924042	AB2-047 E O1	31.79
924471	AB2-096	51.84
925161	AB2-173	3.84
925302	AB2-191 E	1.7
925881	AC1-067 O1	168.51
926311	AC1-109 1	2.34
926321	AC1-109 2	2.34
926331	AC1-110 1	2.33
926341	AC1-110 2	2.33
926351	AC1-111 1	0.94
926361	AC1-111 2	0.94
926371	AC1-111 3	0.94
926381	AC1-111 4	0.94
926391	AC1-111 5	0.94
926401	AC1-111 6	0.94
926431	AC1-114	2.91
926821	AC1-168 C O1	1.43
926822	AC1-168 E O1	9.59
927091	AC1-204 1	88.93
927101	AC1-204 2	88.93
927451	AC1-142A 1	5.12
927461	AC1-142A 2	5.12
927511	AC1-113 1	1.46
927521	AC1-113 2	1.46
927531	AC1-185 1	0.84
927541	AC1-185 2	0.84
927551	AC1-185 3	0.84
927561	AC1-185 4	0.84
927571	AC1-185 5	0.84
927581	AC1-185 6	0.84
927591	AC1-185 7	0.84
927601	AC1-185 8	0.84
930481	AB1-089	80.5
930501	AB1-091 O1	93.97
930741	AB1-122 1O1	89.35
930751	AB1-122 2O1	90.31
932881	AC2-115 1	2.91
932891	AC2-115 2	2.91
932921	AC2-116	1.02
932931	AC2-117	6.52
933341	AC2-147 C	1.07

Bus #	Bus	MW Impact
933342	AC2-147 E	1.74
933411	AC2-154 C	3.21
933412	AC2-154 E	5.23
933431	AC2-156 C O1	1.17
933432	AC2-156 E O1	1.91
933911	AD1-013 C	2.25
933912	AD1-013 E	3.6
933931	AD1-016 C	1.14
933932	AD1-016 E	1.85
934101	AD1-039 1	8.76
934111	AD1-039 2	8.85
934401	AD1-064 C O1	3.92
934402	AD1-064 E O1	18.37
934431	AD1-067 C	0.16
934432	AD1-067 E	0.68
934651	AD1-096 C	1.09
934652	AD1-096 E	1.78
934701	AD1-098 C O1	8.43
934702	AD1-098 E O1	6.15
934721	AD1-100 C	29.44
934722	AD1-100 E	137.37
934871	AD1-116 C	1.17
934872	AD1-116 E	1.91
934881	AD1-117 C	6.58
934882	AD1-117 E	4.39
934971	AD1-129 C	1.11
934972	AD1-129 E	0.74
935001	AD1-133 C O1	27.42
935002	AD1-133 E O1	18.28
936291	AD2-038 C O1	2.88
936292	AD2-038 E O1	19.29
936371	AD2-047 C O1	2.87
936372	AD2-047 E O1	30.87
936461	AD2-060	3.37
936511	AD2-066 C O1	10.36
936512	AD2-066 E O1	6.91
936781	AD2-101 C	5.83
936782	AD2-101 E	27.31
936791	AD2-102 C	14.71
936792	AD2-102 E	14.14
936961	AD2-130	0.69
937001	AD2-134 C	3.35
937002	AD2-134 E	13.82
937031	AD2-137 C O1	7.17
937032	AD2-137 E O1	33.59
937051	AD2-140 C O1	7.53
937052	AD2-140 E O1	35.28
937061	AD2-141 C O1	7.49
937062	AD2-141 E O1	35.32
937071	AD2-142 C O1	15.07
937072	AD2-142 E O1	70.55
937121	AD2-148 C O1	4.51

Bus #	Bus	MW Impact
937122	AD2-148 E O1	21.13
937131	AD2-149 C O1	4.51
937132	AD2-149 E O1	21.13
937141	AD2-150 C O1	4.51
937142	AD2-150 E O1	21.13
937181	AD2-155 C O1	4.51
937182	AD2-155 E O1	21.13
937311	AD2-172 C	3.01
937312	AD2-172 E	4.16
937321	AD2-175 C	21.03
937322	AD2-175 E	14.02
937331	AD2-176 C O1	8.97
937332	AD2-176 E O1	5.98
937401	AD2-194 1	9.56
937411	AD2-194 2	9.56
938012	AE1-002 E O1	14.4
938511	AE1-070 1	11.24
938521	AE1-070 2	10.28
938851	AE1-113 C O1	10.75
938852	AE1-113 E O1	33.78
938861	AE1-114 C O1	4.4
938862	AE1-114 E O1	16.84
939051	AE1-134 1	1.67
939061	AE1-134 2	1.67
939321	AE1-163 C O1	7.24
939322	AE1-163 E O1	44.49
939351	AE1-166 C O1	14.52
939352	AE1-166 E O1	13.41
939401	AE1-172 C O1	9.52
939402	AE1-172 E O1	44.57
939691	AE1-199	2.93
939701	AE1-201 C	2.45
939702	AE1-201 E	0.54
939732	AE1-204 E	0.36
939741	AE1-205 C O1	12.48
939742	AE1-205 E O1	17.23
939861	AE1-222 1	98.68
939871	AE1-222 2	99.73
939921	AE1-228 C O1	12.31
939922	AE1-228 E O1	8.21
939961	AE1-233 C O1	2.85
939962	AE1-233 E O1	11.77
940101	AE1-252 C O1	16.23
940102	AE1-252 E O1	10.82
AB2-013	AB2-013	19.85
AE1-033	AE1-033	22.1
BLUEG	BLUEG	7.86
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.96
CATAWBA	CATAWBA	0.38
CBM-S1	CBM-S1	1.85

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	37.32
CBM-W2	CBM-W2	71.02
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.9
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.69
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.46
MEC	MEC	46.58
O-066	O-066	9.06
RENSSELAER	RENSSELAER	0.76
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.94
WEC	WEC	9.75
Z1-043	Z1-043	35.51

Index 10

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
161505	270927	WILTON	CE	275233	WILTON	CE	1	COMED_P4_112-65-BT2-3__	breaker	1379.0	163.55	164.04	DC	28.49

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	15.13
274722	S-055 E	14.05
274772	LINCOLN ;3U	3.45
274773	LINCOLN ;4U	3.45
274774	LINCOLN ;5U	3.45
274775	LINCOLN ;6U	3.45
274776	LINCOLN ;7U	3.45
274777	LINCOLN ;8U	3.45
274832	U4-027	6.82
274859	EASYR;U1 E	13.75
274860	EASYR;U2 E	13.75
274888	PILOT HIL;1E	24.11
274890	CAYUG;1U E	20.66
274891	CAYUG;2U E	20.66
275149	KEMPTON ;1E	24.11
290021	O50 E	24.25
290051	GSG-6; E	13.07
290108	LEEDK;1U E	30.37
293061	N-015 E	19.85
293516	O-009 E1	11.37
293517	O-009 E2	5.78
293518	O-009 E3	6.36
293644	O22 E1	12.82
293645	O22 E2	24.89
293715	O-029 E	12.24
293716	O-029 E	6.71
293717	O-029 E	6.17
293771	O-035 E	8.08
294392	P-010 E	25.21
294763	P-046 E	11.72
295109	WESTBROOK E	7.0
295111	SUBLETTE E	3.24
296125	R-030 C3	5.08
296128	R-030 E3	20.34
296271	R-030 C2	5.02
296272	R-030 E2	20.09
296308	R-030 C1	5.02
296309	R-030 E1	20.09
910542	X3-005 E	0.91
914641	Y2-103	56.19
915011	Y3-013 1	4.68

Bus #	Bus	MW Impact
915021	Y3-013 2	4.68
915031	Y3-013 3	4.68
916211	Z1-072 E	6.11
916221	Z1-073 E	6.75
916502	Z1-106 E1	1.58
916504	Z1-106 E2	1.58
916512	Z1-107 E	3.23
916522	Z1-108 E	3.11
917502	Z2-087 E	26.28
918052	AA1-018 E	20.57
919221	AA1-146	22.0
919581	AA2-030	22.0
920272	AA2-123 E	3.06
924041	AB2-047 C O1	4.85
924042	AB2-047 E O1	32.43
924471	AB2-096	52.94
925161	AB2-173	3.92
925302	AB2-191 E	1.73
925881	AC1-067 O1	172.23
926311	AC1-109 1	2.39
926321	AC1-109 2	2.39
926331	AC1-110 1	2.37
926341	AC1-110 2	2.37
926351	AC1-111 1	0.96
926361	AC1-111 2	0.96
926371	AC1-111 3	0.96
926381	AC1-111 4	0.96
926391	AC1-111 5	0.96
926401	AC1-111 6	0.96
926431	AC1-114	2.97
926821	AC1-168 C O1	1.46
926822	AC1-168 E O1	9.79
927091	AC1-204 1	90.83
927101	AC1-204 2	90.83
927201	AC1-214 C O1	2.59
927202	AC1-214 E O1	8.24
927451	AC1-142A 1	5.23
927461	AC1-142A 2	5.23
927511	AC1-113 1	1.49
927521	AC1-113 2	1.49
927531	AC1-185 1	0.86
927541	AC1-185 2	0.86
927551	AC1-185 3	0.86
927561	AC1-185 4	0.86
927571	AC1-185 5	0.86
927581	AC1-185 6	0.86
927591	AC1-185 7	0.86
927601	AC1-185 8	0.86
930481	AB1-089	82.21
930501	AB1-091 O1	95.92
930741	AB1-122 1O1	91.25
930751	AB1-122 2O1	92.24

Bus #	Bus	MW Impact
932881	AC2-115 1	2.97
932891	AC2-115 2	2.97
932921	AC2-116	1.04
932931	AC2-117	6.67
933341	AC2-147 C	1.09
933342	AC2-147 E	1.78
933411	AC2-154 C	3.27
933412	AC2-154 E	5.34
933431	AC2-156 C O1	1.2
933432	AC2-156 E O1	1.95
933911	AD1-013 C	2.3
933912	AD1-013 E	3.68
933931	AD1-016 C	1.16
933932	AD1-016 E	1.89
934101	AD1-039 1	8.94
934111	AD1-039 2	9.04
934401	AD1-064 C O1	4.01
934402	AD1-064 E O1	18.76
934431	AD1-067 C	0.16
934432	AD1-067 E	0.69
934651	AD1-096 C	1.11
934652	AD1-096 E	1.82
934701	AD1-098 C O1	8.6
934702	AD1-098 E O1	6.28
934721	AD1-100 C	30.02
934722	AD1-100 E	140.09
934871	AD1-116 C	1.2
934872	AD1-116 E	1.95
934881	AD1-117 C	6.72
934882	AD1-117 E	4.48
934971	AD1-129 C	1.13
934972	AD1-129 E	0.75
935001	AD1-133 C O1	27.99
935002	AD1-133 E O1	18.66
936291	AD2-038 C O1	2.94
936292	AD2-038 E O1	19.7
936371	AD2-047 C O1	2.93
936372	AD2-047 E O1	31.51
936461	AD2-060	3.44
936511	AD2-066 C O1	10.58
936512	AD2-066 E O1	7.05
936781	AD2-101 C	5.95
936782	AD2-101 E	27.88
936791	AD2-102 C	15.03
936792	AD2-102 E	14.44
936961	AD2-130	0.7
937001	AD2-134 C	3.42
937002	AD2-134 E	14.12
937031	AD2-137 C O1	7.31
937032	AD2-137 E O1	34.21
937051	AD2-140 C O1	7.67
937052	AD2-140 E O1	35.93

Bus #	Bus	MW Impact
937061	AD2-141 C O1	7.63
937062	AD2-141 E O1	35.97
937071	AD2-142 C O1	15.35
937072	AD2-142 E O1	71.86
937121	AD2-148 C O1	4.61
937122	AD2-148 E O1	21.57
937131	AD2-149 C O1	4.61
937132	AD2-149 E O1	21.57
937141	AD2-150 C O1	4.61
937142	AD2-150 E O1	21.57
937181	AD2-155 C O1	4.61
937182	AD2-155 E O1	21.57
937311	AD2-172 C	3.08
937312	AD2-172 E	4.25
937321	AD2-175 C	21.46
937322	AD2-175 E	14.31
937331	AD2-176 C O1	9.17
937332	AD2-176 E O1	6.11
937401	AD2-194 1	9.77
937411	AD2-194 2	9.77
938012	AE1-002 E O1	14.67
938511	AE1-070 1	11.48
938521	AE1-070 2	10.5
938851	AE1-113 C O1	10.98
938852	AE1-113 E O1	34.5
938861	AE1-114 C O1	4.5
938862	AE1-114 E O1	17.19
939051	AE1-134 1	1.71
939061	AE1-134 2	1.71
939321	AE1-163 C O1	7.4
939322	AE1-163 E O1	45.45
939351	AE1-166 C O1	14.82
939352	AE1-166 E O1	13.68
939401	AE1-172 C O1	9.71
939402	AE1-172 E O1	45.45
939691	AE1-199	2.99
939701	AE1-201 C	2.51
939702	AE1-201 E	0.55
939732	AE1-204 E	0.37
939741	AE1-205 C O1	12.73
939742	AE1-205 E O1	17.58
939861	AE1-222 1	100.77
939871	AE1-222 2	101.86
939921	AE1-228 C O1	12.57
939922	AE1-228 E O1	8.38
939961	AE1-233 C O1	2.91
939962	AE1-233 E O1	12.02
940101	AE1-252 C O1	16.55
940102	AE1-252 E O1	11.03
AB2-013	AB2-013	20.27
AE1-033	AE1-033	22.58
BLUEG	BLUEG	8.03

Bus #	Bus	MW Impact
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.98
CATAWBA	CATAWBA	0.39
CBM-S1	CBM-S1	1.88
CBM-W1	CBM-W1	38.11
CBM-W2	CBM-W2	72.48
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.96
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.75
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.49
MEC	MEC	47.56
O-066	O-066	9.26
RENSSELAER	RENSSELAER	0.77
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.96
WEC	WEC	9.96
Z1-043	Z1-043	36.25

Index 11

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
161535	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	123.84	124.43	DC	20.28

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	12.57
274654	BRAIDWOOD;1U	26.97
274655	BRAIDWOOD;2U	25.8
274661	LASCO STA;2U	24.66
274687	WILL CNTY;4U	11.24
274704	KENDALL ;1C	3.96
274705	KENDALL ;1S	2.64
274706	KENDALL ;2C	3.96
274707	KENDALL ;2S	2.64
274722	S-055 E	11.77
274751	CRETE EC ;1U	5.74
274752	CRETE EC ;2U	5.74
274753	CRETE EC ;3U	5.74
274754	CRETE EC ;4U	5.74
274859	EASYR;U1 E	11.37
274860	EASYR;U2 E	11.37
274861	TOP CROP ;1U	0.47
274862	TOP CROP ;2U	0.91
274888	PILOT HIL;1E	16.88
274890	CAYUG;1U E	13.45
274891	CAYUG;2U E	13.45
275149	KEMPTON ;1E	16.88
290021	O50 E	20.54
290051	GSG-6; E	10.8
290108	LEEDK;1U E	25.11
293061	N-015 E	16.24
293516	O-009 E1	9.32
293517	O-009 E2	4.73
293518	O-009 E3	5.21
293644	O22 E1	12.21
293645	O22 E2	23.71
293715	O-029 E	10.07
293716	O-029 E	5.52
293717	O-029 E	5.08
294392	P-010 E	20.62
294763	P-046 E	9.71
295109	WESTBROOK E	5.78
295111	SUBLETTE E	2.68
914641	Y2-103	47.06
915011	Y3-013 1	3.92
915021	Y3-013 2	3.92

Bus #	Bus	MW Impact
915031	Y3-013 3	3.92
916221	Z1-073 E	5.57
916502	Z1-106 E1	1.31
916504	Z1-106 E2	1.31
916512	Z1-107 E	2.52
916522	Z1-108 E	2.59
918052	AA1-018 E	15.99
919221	AA1-146	18.16
919581	AA2-030	18.16
920272	AA2-123 E	2.54
924471	AB2-096	43.99
925161	AB2-173	3.24
925302	AB2-191 E	1.43
926311	AC1-109 1	1.97
926321	AC1-109 2	1.97
926331	AC1-110 1	1.98
926341	AC1-110 2	1.98
926351	AC1-111 1	0.79
926361	AC1-111 2	0.79
926371	AC1-111 3	0.79
926381	AC1-111 4	0.79
926391	AC1-111 5	0.79
926401	AC1-111 6	0.79
926431	AC1-114	2.47
926821	AC1-168 C O1	1.18
926822	AC1-168 E O1	7.92
927091	AC1-204 1	77.42
927101	AC1-204 2	77.29
927451	AC1-142A 1	4.48
927461	AC1-142A 2	4.48
927511	AC1-113 1	1.23
927521	AC1-113 2	1.23
927531	AC1-185 1	0.71
927541	AC1-185 2	0.71
927551	AC1-185 3	0.71
927561	AC1-185 4	0.71
927571	AC1-185 5	0.71
927581	AC1-185 6	0.71
927591	AC1-185 7	0.71
927601	AC1-185 8	0.71
930481	AB1-089	68.22
930501	AB1-091 O1	66.51
930741	AB1-122 1O1	73.76
930751	AB1-122 2O1	78.95
932881	AC2-115 1	2.47
932891	AC2-115 2	2.47
932921	AC2-116	0.86
933341	AC2-147 C	0.9
933342	AC2-147 E	1.47
933411	AC2-154 C	2.29
933412	AC2-154 E	3.74
933431	AC2-156 C O1	0.99

Bus #	Bus	MW Impact
933432	AC2-156 E O1	1.61
933911	AD1-013 C	1.9
933912	AD1-013 E	3.04
933931	AD1-016 C	0.97
933932	AD1-016 E	1.58
934101	AD1-039 1	7.23
934111	AD1-039 2	7.74
934401	AD1-064 C O1	3.33
934402	AD1-064 E O1	15.58
934431	AD1-067 C	0.14
934432	AD1-067 E	0.57
934651	AD1-096 C	0.92
934652	AD1-096 E	1.51
934701	AD1-098 C O1	7.11
934702	AD1-098 E O1	5.19
934721	AD1-100 C	19.71
934722	AD1-100 E	91.99
934871	AD1-116 C	0.93
934872	AD1-116 E	1.52
934881	AD1-117 C	5.55
934882	AD1-117 E	3.7
934971	AD1-129 C	0.94
934972	AD1-129 E	0.63
935001	AD1-133 C O1	21.05
935002	AD1-133 E O1	14.03
936291	AD2-038 C O1	2.37
936292	AD2-038 E O1	15.89
936371	AD2-047 C O1	2.05
936372	AD2-047 E O1	22.06
936461	AD2-060	2.41
936511	AD2-066 C O1	8.6
936512	AD2-066 E O1	5.74
936781	AD2-101 C	3.03
936782	AD2-101 E	14.16
936791	AD2-102 C	12.47
936792	AD2-102 E	11.98
936961	AD2-130	0.59
937001	AD2-134 C	2.82
937002	AD2-134 E	11.67
937031	AD2-137 C O1	3.3
937032	AD2-137 E O1	15.44
937051	AD2-140 C O1	3.28
937052	AD2-140 E O1	15.37
937061	AD2-141 C O1	3.27
937062	AD2-141 E O1	15.39
937071	AD2-142 C O1	6.57
937072	AD2-142 E O1	30.75
937121	AD2-148 C O1	3.19
937122	AD2-148 E O1	14.95
937131	AD2-149 C O1	3.19
937132	AD2-149 E O1	14.95
937141	AD2-150 C O1	3.19

Bus #	Bus	MW Impact
937142	AD2-150 E O1	14.95
937181	AD2-155 C O1	3.19
937182	AD2-155 E O1	14.95
937311	AD2-172 C	2.55
937312	AD2-172 E	3.52
937321	AD2-175 C	14.88
937322	AD2-175 E	9.92
937331	AD2-176 C O1	7.62
937332	AD2-176 E O1	5.08
937401	AD2-194 1	8.33
937411	AD2-194 2	8.31
937531	AD2-214 C	4.54
937532	AD2-214 E	2.14
938012	AE1-002 E O1	6.62
938511	AE1-070 1	9.78
938521	AE1-070 2	8.93
938851	AE1-113 C O1	9.29
938852	AE1-113 E O1	29.21
938861	AE1-114 C O1	3.72
938862	AE1-114 E O1	14.22
939051	AE1-134 1	1.41
939061	AE1-134 2	1.41
939321	AE1-163 C O1	5.97
939322	AE1-163 E O1	36.64
939351	AE1-166 C O1	10.54
939352	AE1-166 E O1	9.73
939401	AE1-172 C O1	6.17
939402	AE1-172 E O1	28.89
939641	AE1-194 C	32.38
939642	AE1-194 E	216.73
939651	AE1-195 C	32.38
939652	AE1-195 E	216.73
939691	AE1-199	2.47
939701	AE1-201 C	2.08
939702	AE1-201 E	0.46
939732	AE1-204 E	0.31
939861	AE1-222 1	81.46
939871	AE1-222 2	87.19
939921	AE1-228 C O1	10.39
939922	AE1-228 E O1	6.93
939961	AE1-233 C O1	2.41
939962	AE1-233 E O1	9.95
940101	AE1-252 C O1	10.52
940102	AE1-252 E O1	7.01
AB2-013	AB2-013	16.6
AE1-033	AE1-033	18.74
BLUEG	BLUEG	6.66
CALDERWOOD	CALDERWOOD	0.12
CANNELTON	CANNELTON	0.14
CARR	CARR	0.8
CATAWBA	CATAWBA	0.32
CBM-S1	CBM-S1	1.14

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	25.55
CBM-W2	CBM-W2	51.99
CHEOAH	CHEOAH	0.12
CHILHOWEE	CHILHOWEE	0.04
DEARBORN	DEARBORN	3.16
ELMERSMITH	ELMERSMITH	0.17
G-007	G-007	2.23
GIBSON	GIBSON	0.08
HAMLET	HAMLET	1.22
MEC	MEC	38.45
O-066	O-066	7.49
RENSSELAER	RENSSELAER	0.63
SANTEETLA	SANTEETLA	0.04
TRIMBLE	TRIMBLE	0.78
WEC	WEC	8.32
Z1-043	Z1-043	29.26

Index 12

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
767588	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	134.44	134.98	DC	15.92

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	9.79
274722	S-055 E	9.15
274808	UNIV PK N;4U	1.62
274809	UNIV PK N;5U	1.62
274811	UNIV PK N;7U	1.62
274812	UNIV PK N;8U	1.62
274814	UNIV PK N;0U	1.62
274815	UNIV PK N;XU	1.62
274832	U4-027	8.61
274859	EASYR;U1 E	8.84
274860	EASYR;U2 E	8.84
274888	PILOT HIL;1E	14.86
274890	CAYUG;1U E	10.7
274891	CAYUG;2U E	10.7
275149	KEMPTON ;1E	14.86
290021	O50 E	15.62
290051	GSG-6; E	8.43
290108	LEEDK;1U E	19.61
293061	N-015 E	12.6
293516	O-009 E1	7.26
293517	O-009 E2	3.69
293518	O-009 E3	4.06
293644	O22 E1	7.88
293645	O22 E2	15.3
293715	O-029 E	7.84
293716	O-029 E	4.3
293717	O-029 E	3.95
293771	O-035 E	5.09
294392	P-010 E	16.0
294401	BSHIL;1U E	6.8
294410	BSHIL;2U E	6.8
294763	P-046 E	7.56
295109	WESTBROOK E	4.51
295111	SUBLETTE E	2.08
910542	X3-005 E	0.51
914641	Y2-103	36.59
915011	Y3-013 1	3.05
915021	Y3-013 2	3.05
915031	Y3-013 3	3.05
916211	Z1-072 E	3.85

Bus #	Bus	MW Impact
916221	Z1-073 E	4.35
916502	Z1-106 E1	1.02
916504	Z1-106 E2	1.02
916512	Z1-107 E	2.17
916522	Z1-108 E	2.02
918052	AA1-018 E	14.29
919221	AA1-146	14.12
919581	AA2-030	14.12
919621	AA2-039 C	1.66
919622	AA2-039 E	11.1
920272	AA2-123 E	1.98
924471	AB2-096	34.27
925161	AB2-173	2.52
925302	AB2-191 E	1.12
925581	AC1-033 C	1.11
925582	AC1-033 E	7.46
925881	AC1-067 O1	97.44
926311	AC1-109 1	1.55
926321	AC1-109 2	1.55
926331	AC1-110 1	1.54
926341	AC1-110 2	1.54
926351	AC1-111 1	0.62
926361	AC1-111 2	0.62
926371	AC1-111 3	0.62
926381	AC1-111 4	0.62
926391	AC1-111 5	0.62
926401	AC1-111 6	0.62
926431	AC1-114	1.92
926821	AC1-168 C O1	0.92
926822	AC1-168 E O1	6.18
927091	AC1-204 1	59.17
927101	AC1-204 2	59.21
927201	AC1-214 C O1	1.63
927202	AC1-214 E O1	5.19
927451	AC1-142A 1	3.45
927461	AC1-142A 2	3.45
927511	AC1-113 1	0.96
927521	AC1-113 2	0.96
927531	AC1-185 1	0.55
927541	AC1-185 2	0.55
927551	AC1-185 3	0.55
927561	AC1-185 4	0.55
927571	AC1-185 5	0.55
927581	AC1-185 6	0.55
927591	AC1-185 7	0.55
927601	AC1-185 8	0.55
930481	AB1-089	53.11
930501	AB1-091 O1	57.12
930741	AB1-122 1O1	58.21
930751	AB1-122 2O1	59.68
932881	AC2-115 1	1.92
932891	AC2-115 2	1.92

Bus #	Bus	MW Impact
932921	AC2-116	0.67
932931	AC2-117	10.39
933341	AC2-147 C	0.7
933342	AC2-147 E	1.15
933411	AC2-154 C	2.02
933412	AC2-154 E	3.29
933431	AC2-156 C O1	0.77
933432	AC2-156 E O1	1.26
933911	AD1-013 C	1.48
933912	AD1-013 E	2.37
933931	AD1-016 C	0.75
933932	AD1-016 E	1.23
934051	AD1-031 C O1	2.26
934052	AD1-031 E O1	3.69
934101	AD1-039 1	5.7
934111	AD1-039 2	5.85
934401	AD1-064 C O1	2.59
934402	AD1-064 E O1	12.13
934431	AD1-067 C	0.11
934432	AD1-067 E	0.44
934651	AD1-096 C	0.72
934652	AD1-096 E	1.17
934701	AD1-098 C O1	5.55
934702	AD1-098 E O1	4.05
934721	AD1-100 C	15.58
934722	AD1-100 E	72.69
934871	AD1-116 C	0.83
934872	AD1-116 E	1.36
934881	AD1-117 C	4.32
934882	AD1-117 E	2.88
934971	AD1-129 C	0.73
934972	AD1-129 E	0.49
935001	AD1-133 C O1	16.67
935002	AD1-133 E O1	11.11
936291	AD2-038 C O1	1.97
936292	AD2-038 E O1	13.19
936371	AD2-047 C O1	1.8
936372	AD2-047 E O1	19.42
936461	AD2-060	2.12
936511	AD2-066 C O1	6.83
936512	AD2-066 E O1	4.55
936781	AD2-101 C	3.51
936782	AD2-101 E	16.41
936791	AD2-102 C	9.71
936792	AD2-102 E	9.33
936961	AD2-130	0.46
937001	AD2-134 C	2.2
937002	AD2-134 E	9.1
937031	AD2-137 C O1	2.69
937032	AD2-137 E O1	12.6
937051	AD2-140 C O1	2.69
937052	AD2-140 E O1	12.61

Bus #	Bus	MW Impact
937061	AD2-141 C O1	2.68
937062	AD2-141 E O1	12.63
937071	AD2-142 C O1	5.39
937072	AD2-142 E O1	25.22
937121	AD2-148 C O1	2.74
937122	AD2-148 E O1	12.83
937131	AD2-149 C O1	2.74
937132	AD2-149 E O1	12.83
937141	AD2-150 C O1	2.74
937142	AD2-150 E O1	12.83
937181	AD2-155 C O1	2.74
937182	AD2-155 E O1	12.83
937311	AD2-172 C	1.98
937312	AD2-172 E	2.74
937321	AD2-175 C	12.77
937322	AD2-175 E	8.51
937331	AD2-176 C O1	5.94
937332	AD2-176 E O1	3.96
937401	AD2-194 1	6.36
937411	AD2-194 2	6.37
937531	AD2-214 C	3.53
937532	AD2-214 E	1.66
938012	AE1-002 E O1	5.4
938511	AE1-070 1	7.48
938521	AE1-070 2	6.84
938851	AE1-113 C O1	7.07
938852	AE1-113 E O1	22.22
938861	AE1-114 C O1	2.9
938862	AE1-114 E O1	11.07
939051	AE1-134 1	1.1
939061	AE1-134 2	1.1
939321	AE1-163 C O1	4.95
939322	AE1-163 E O1	30.42
939351	AE1-166 C O1	8.28
939352	AE1-166 E O1	7.64
939401	AE1-172 C O1	4.91
939402	AE1-172 E O1	22.97
939631	AE1-193 C O1	5.53
939632	AE1-193 E O1	37.0
939681	AE1-198 C O1	16.41
939682	AE1-198 E O1	13.95
939691	AE1-199	1.93
939701	AE1-201 C	1.62
939702	AE1-201 E	0.36
939732	AE1-204 E	0.24
939861	AE1-222 1	64.28
939871	AE1-222 2	65.91
939921	AE1-228 C O1	8.11
939922	AE1-228 E O1	5.4
939961	AE1-233 C O1	1.88
939962	AE1-233 E O1	7.77
940101	AE1-252 C O1	8.36

Bus #	Bus	MW Impact
940102	AE1-252 E O1	5.58
990901	L-005 E	5.05
AB2-013	AB2-013	12.84
AE1-033	AE1-033	14.59
BLUEG	BLUEG	4.41
CALDERWOOD	CALDERWOOD	0.05
CANNELTON	CANNELTON	0.06
CARR	CARR	0.61
CATAWBA	CATAWBA	0.23
CBM-S1	CBM-S1	1.22
CBM-W1	CBM-W1	21.89
CBM-W2	CBM-W2	43.2
CHEOAH	CHEOAH	0.05
CHILHOWEE	CHILHOWEE	0.01
DEARBORN	DEARBORN	2.62
ELMERSMITH	ELMERSMITH	0.06
G-007	G-007	1.71
GIBSON	GIBSON	0.02
HAMLET	HAMLET	0.88
MEC	MEC	30.08
O-066	O-066	5.77
RENSSELAER	RENSSELAER	0.49
SANTEETLA	SANTEETLA	0.02
TRIMBLE	TRIMBLE	0.52
WEC	WEC	6.46
Z1-043	Z1-043	22.86

Index 13

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
161502	275232	WILTON ;3M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT5-6__	breaker	1379.0	165.81	166.14	DC	27.93

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	14.81
274722	S-055 E	13.75
274772	LINCOLN ;3U	3.36
274773	LINCOLN ;4U	3.36
274774	LINCOLN ;5U	3.36
274775	LINCOLN ;6U	3.36
274776	LINCOLN ;7U	3.36
274777	LINCOLN ;8U	3.36
274859	EASYR;U1 E	13.46
274860	EASYR;U2 E	13.46
274888	PILOT HIL;1E	23.62
274890	CAYUG;1U E	20.25
274891	CAYUG;2U E	20.25
275149	KEMPTON ;1E	23.62
290021	O50 E	23.75
290051	GSG-6; E	12.8
290108	LEEDK;1U E	29.74
293061	N-015 E	19.44
293516	O-009 E1	1.0
293517	O-009 E2	0.51
293518	O-009 E3	0.56
293644	O22 E1	12.55
293645	O22 E2	24.37
293715	O-029 E	11.98
293716	O-029 E	6.57
293717	O-029 E	6.04
294392	P-010 E	24.69
294763	P-046 E	11.48
295109	WESTBROOK E	6.85
295111	SUBLETTE E	3.18
296125	R-030 C3	4.98
296128	R-030 E3	19.93
296271	R-030 C2	4.92
296272	R-030 E2	19.7
296308	R-030 C1	4.92
296309	R-030 E1	19.7
910542	X3-005 E	0.9
914641	Y2-103	55.02
915011	Y3-013 1	4.58
915021	Y3-013 2	4.58
915031	Y3-013 3	4.58

Bus #	Bus	MW Impact
916221	Z1-073 E	6.61
916502	Z1-106 E1	1.55
916504	Z1-106 E2	1.55
916512	Z1-107 E	3.17
916522	Z1-108 E	3.04
917502	Z2-087 E	25.76
918052	AA1-018 E	20.13
919221	AA1-146	21.54
919581	AA2-030	21.54
920272	AA2-123 E	2.99
924041	AB2-047 C O1	4.75
924042	AB2-047 E O1	31.79
924471	AB2-096	51.84
925161	AB2-173	3.84
925302	AB2-191 E	1.7
925881	AC1-067 O1	168.51
926311	AC1-109 1	2.34
926321	AC1-109 2	2.34
926331	AC1-110 1	2.33
926341	AC1-110 2	2.33
926351	AC1-111 1	0.94
926361	AC1-111 2	0.94
926371	AC1-111 3	0.94
926381	AC1-111 4	0.94
926391	AC1-111 5	0.94
926401	AC1-111 6	0.94
926431	AC1-114	2.91
926821	AC1-168 C O1	1.43
926822	AC1-168 E O1	9.59
927091	AC1-204 1	88.93
927101	AC1-204 2	88.93
927451	AC1-142A 1	5.12
927461	AC1-142A 2	5.12
927511	AC1-113 1	1.46
927521	AC1-113 2	1.46
927531	AC1-185 1	0.84
927541	AC1-185 2	0.84
927551	AC1-185 3	0.84
927561	AC1-185 4	0.84
927571	AC1-185 5	0.84
927581	AC1-185 6	0.84
927591	AC1-185 7	0.84
927601	AC1-185 8	0.84
930481	AB1-089	80.5
930501	AB1-091 O1	93.97
930741	AB1-122 1O1	89.35
930751	AB1-122 2O1	90.31
932881	AC2-115 1	2.91
932891	AC2-115 2	2.91
932921	AC2-116	1.02
932931	AC2-117	6.52
933341	AC2-147 C	1.07

Bus #	Bus	MW Impact
933342	AC2-147 E	1.74
933411	AC2-154 C	3.21
933412	AC2-154 E	5.23
933431	AC2-156 C O1	1.17
933432	AC2-156 E O1	1.91
933911	AD1-013 C	2.25
933912	AD1-013 E	3.6
933931	AD1-016 C	1.14
933932	AD1-016 E	1.85
934101	AD1-039 1	8.76
934111	AD1-039 2	8.85
934401	AD1-064 C O1	3.92
934402	AD1-064 E O1	18.37
934431	AD1-067 C	0.16
934432	AD1-067 E	0.68
934651	AD1-096 C	1.09
934652	AD1-096 E	1.78
934701	AD1-098 C O1	8.43
934702	AD1-098 E O1	6.15
934721	AD1-100 C	29.44
934722	AD1-100 E	137.37
934871	AD1-116 C	1.17
934872	AD1-116 E	1.91
934881	AD1-117 C	6.58
934882	AD1-117 E	4.39
934971	AD1-129 C	1.11
934972	AD1-129 E	0.74
935001	AD1-133 C O1	27.42
935002	AD1-133 E O1	18.28
936291	AD2-038 C O1	2.88
936292	AD2-038 E O1	19.29
936371	AD2-047 C O1	2.87
936372	AD2-047 E O1	30.87
936461	AD2-060	3.37
936511	AD2-066 C O1	10.36
936512	AD2-066 E O1	6.91
936781	AD2-101 C	5.83
936782	AD2-101 E	27.31
936791	AD2-102 C	14.71
936792	AD2-102 E	14.14
936961	AD2-130	0.69
937001	AD2-134 C	3.35
937002	AD2-134 E	13.82
937031	AD2-137 C O1	7.17
937032	AD2-137 E O1	33.59
937051	AD2-140 C O1	7.53
937052	AD2-140 E O1	35.28
937061	AD2-141 C O1	7.49
937062	AD2-141 E O1	35.32
937071	AD2-142 C O1	15.07
937072	AD2-142 E O1	70.55
937121	AD2-148 C O1	4.51

Bus #	Bus	MW Impact
937122	AD2-148 E O1	21.13
937131	AD2-149 C O1	4.51
937132	AD2-149 E O1	21.13
937141	AD2-150 C O1	4.51
937142	AD2-150 E O1	21.13
937181	AD2-155 C O1	4.51
937182	AD2-155 E O1	21.13
937311	AD2-172 C	3.01
937312	AD2-172 E	4.16
937321	AD2-175 C	21.03
937322	AD2-175 E	14.02
937331	AD2-176 C O1	8.97
937332	AD2-176 E O1	5.98
937401	AD2-194 1	9.56
937411	AD2-194 2	9.56
938012	AE1-002 E O1	14.4
938511	AE1-070 1	11.24
938521	AE1-070 2	10.28
938851	AE1-113 C O1	10.75
938852	AE1-113 E O1	33.78
938861	AE1-114 C O1	4.4
938862	AE1-114 E O1	16.84
939051	AE1-134 1	1.67
939061	AE1-134 2	1.67
939321	AE1-163 C O1	7.24
939322	AE1-163 E O1	44.49
939351	AE1-166 C O1	14.52
939352	AE1-166 E O1	13.41
939401	AE1-172 C O1	9.52
939402	AE1-172 E O1	44.57
939691	AE1-199	2.93
939701	AE1-201 C	2.45
939702	AE1-201 E	0.54
939732	AE1-204 E	0.36
939741	AE1-205 C O1	12.48
939742	AE1-205 E O1	17.23
939861	AE1-222 1	98.68
939871	AE1-222 2	99.73
939921	AE1-228 C O1	12.31
939922	AE1-228 E O1	8.21
939961	AE1-233 C O1	2.85
939962	AE1-233 E O1	11.77
940101	AE1-252 C O1	16.23
940102	AE1-252 E O1	10.82
AB2-013	AB2-013	19.85
AE1-033	AE1-033	22.1
BLUEG	BLUEG	7.86
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.96
CATAWBA	CATAWBA	0.38
CBM-S1	CBM-S1	1.85

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	37.32
CBM-W2	CBM-W2	71.02
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.9
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.69
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.46
MEC	MEC	46.58
O-066	O-066	9.06
RENSSELAER	RENSSELAER	0.76
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.94
WEC	WEC	9.75
Z1-043	Z1-043	35.51

Index 14

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
161507	275233	WILTON ;4M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT2-3__	breaker	1379.0	163.55	164.04	DC	28.49

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	15.13
274722	S-055 E	14.05
274772	LINCOLN ;3U	3.45
274773	LINCOLN ;4U	3.45
274774	LINCOLN ;5U	3.45
274775	LINCOLN ;6U	3.45
274776	LINCOLN ;7U	3.45
274777	LINCOLN ;8U	3.45
274832	U4-027	6.82
274859	EASYR;U1 E	13.75
274860	EASYR;U2 E	13.75
274888	PILOT HIL;1E	24.11
274890	CAYUG;1U E	20.66
274891	CAYUG;2U E	20.66
275149	KEMPTON ;1E	24.11
290021	O50 E	24.25
290051	GSG-6; E	13.07
290108	LEEDK;1U E	30.37
293061	N-015 E	19.85
293516	O-009 E1	11.37
293517	O-009 E2	5.78
293518	O-009 E3	6.36
293644	O22 E1	12.82
293645	O22 E2	24.89
293715	O-029 E	12.24
293716	O-029 E	6.71
293717	O-029 E	6.17
293771	O-035 E	8.08
294392	P-010 E	25.21
294763	P-046 E	11.72
295109	WESTBROOK E	7.0
295111	SUBLETTE E	3.24
296125	R-030 C3	5.08
296128	R-030 E3	20.34
296271	R-030 C2	5.02
296272	R-030 E2	20.09
296308	R-030 C1	5.02
296309	R-030 E1	20.09
910542	X3-005 E	0.91
914641	Y2-103	56.19
915011	Y3-013 1	4.68

Bus #	Bus	MW Impact
915021	Y3-013 2	4.68
915031	Y3-013 3	4.68
916211	Z1-072 E	6.11
916221	Z1-073 E	6.75
916502	Z1-106 E1	1.58
916504	Z1-106 E2	1.58
916512	Z1-107 E	3.23
916522	Z1-108 E	3.11
917502	Z2-087 E	26.28
918052	AA1-018 E	20.57
919221	AA1-146	22.0
919581	AA2-030	22.0
920272	AA2-123 E	3.06
924041	AB2-047 C O1	4.85
924042	AB2-047 E O1	32.43
924471	AB2-096	52.94
925161	AB2-173	3.92
925302	AB2-191 E	1.73
925881	AC1-067 O1	172.23
926311	AC1-109 1	2.39
926321	AC1-109 2	2.39
926331	AC1-110 1	2.37
926341	AC1-110 2	2.37
926351	AC1-111 1	0.96
926361	AC1-111 2	0.96
926371	AC1-111 3	0.96
926381	AC1-111 4	0.96
926391	AC1-111 5	0.96
926401	AC1-111 6	0.96
926431	AC1-114	2.97
926821	AC1-168 C O1	1.46
926822	AC1-168 E O1	9.79
927091	AC1-204 1	90.83
927101	AC1-204 2	90.83
927201	AC1-214 C O1	2.59
927202	AC1-214 E O1	8.24
927451	AC1-142A 1	5.23
927461	AC1-142A 2	5.23
927511	AC1-113 1	1.49
927521	AC1-113 2	1.49
927531	AC1-185 1	0.86
927541	AC1-185 2	0.86
927551	AC1-185 3	0.86
927561	AC1-185 4	0.86
927571	AC1-185 5	0.86
927581	AC1-185 6	0.86
927591	AC1-185 7	0.86
927601	AC1-185 8	0.86
930481	AB1-089	82.21
930501	AB1-091 O1	95.92
930741	AB1-122 1O1	91.25
930751	AB1-122 2O1	92.24

Bus #	Bus	MW Impact
932881	AC2-115 1	2.97
932891	AC2-115 2	2.97
932921	AC2-116	1.04
932931	AC2-117	6.67
933341	AC2-147 C	1.09
933342	AC2-147 E	1.78
933411	AC2-154 C	3.27
933412	AC2-154 E	5.34
933431	AC2-156 C O1	1.2
933432	AC2-156 E O1	1.95
933911	AD1-013 C	2.3
933912	AD1-013 E	3.68
933931	AD1-016 C	1.16
933932	AD1-016 E	1.89
934101	AD1-039 1	8.94
934111	AD1-039 2	9.04
934401	AD1-064 C O1	4.01
934402	AD1-064 E O1	18.76
934431	AD1-067 C	0.16
934432	AD1-067 E	0.69
934651	AD1-096 C	1.11
934652	AD1-096 E	1.82
934701	AD1-098 C O1	8.6
934702	AD1-098 E O1	6.28
934721	AD1-100 C	30.02
934722	AD1-100 E	140.09
934871	AD1-116 C	1.2
934872	AD1-116 E	1.95
934881	AD1-117 C	6.72
934882	AD1-117 E	4.48
934971	AD1-129 C	1.13
934972	AD1-129 E	0.75
935001	AD1-133 C O1	27.99
935002	AD1-133 E O1	18.66
936291	AD2-038 C O1	2.94
936292	AD2-038 E O1	19.7
936371	AD2-047 C O1	2.93
936372	AD2-047 E O1	31.51
936461	AD2-060	3.44
936511	AD2-066 C O1	10.58
936512	AD2-066 E O1	7.05
936781	AD2-101 C	5.95
936782	AD2-101 E	27.88
936791	AD2-102 C	15.03
936792	AD2-102 E	14.44
936961	AD2-130	0.7
937001	AD2-134 C	3.42
937002	AD2-134 E	14.12
937031	AD2-137 C O1	7.31
937032	AD2-137 E O1	34.21
937051	AD2-140 C O1	7.67
937052	AD2-140 E O1	35.93

Bus #	Bus	MW Impact
937061	AD2-141 C O1	7.63
937062	AD2-141 E O1	35.97
937071	AD2-142 C O1	15.35
937072	AD2-142 E O1	71.86
937121	AD2-148 C O1	4.61
937122	AD2-148 E O1	21.57
937131	AD2-149 C O1	4.61
937132	AD2-149 E O1	21.57
937141	AD2-150 C O1	4.61
937142	AD2-150 E O1	21.57
937181	AD2-155 C O1	4.61
937182	AD2-155 E O1	21.57
937311	AD2-172 C	3.08
937312	AD2-172 E	4.25
937321	AD2-175 C	21.46
937322	AD2-175 E	14.31
937331	AD2-176 C O1	9.17
937332	AD2-176 E O1	6.11
937401	AD2-194 1	9.77
937411	AD2-194 2	9.77
938012	AE1-002 E O1	14.67
938511	AE1-070 1	11.48
938521	AE1-070 2	10.5
938851	AE1-113 C O1	10.98
938852	AE1-113 E O1	34.5
938861	AE1-114 C O1	4.5
938862	AE1-114 E O1	17.19
939051	AE1-134 1	1.71
939061	AE1-134 2	1.71
939321	AE1-163 C O1	7.4
939322	AE1-163 E O1	45.45
939351	AE1-166 C O1	14.82
939352	AE1-166 E O1	13.68
939401	AE1-172 C O1	9.71
939402	AE1-172 E O1	45.45
939691	AE1-199	2.99
939701	AE1-201 C	2.51
939702	AE1-201 E	0.55
939732	AE1-204 E	0.37
939741	AE1-205 C O1	12.73
939742	AE1-205 E O1	17.58
939861	AE1-222 1	100.77
939871	AE1-222 2	101.86
939921	AE1-228 C O1	12.57
939922	AE1-228 E O1	8.38
939961	AE1-233 C O1	2.91
939962	AE1-233 E O1	12.02
940101	AE1-252 C O1	16.55
940102	AE1-252 E O1	11.03
AB2-013	AB2-013	20.27
AE1-033	AE1-033	22.58
BLUEG	BLUEG	8.03

Bus #	Bus	MW Impact
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.98
CATAWBA	CATAWBA	0.39
CBM-S1	CBM-S1	1.88
CBM-W1	CBM-W1	38.11
CBM-W2	CBM-W2	72.48
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.96
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.75
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.49
MEC	MEC	47.56
O-066	O-066	9.26
RENSSELAER	RENSSELAER	0.77
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.96
WEC	WEC	9.96
Z1-043	Z1-043	36.25

Index 15

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
162841	934720	AD1-100 TAP	CE	937030	AD2-137 TAP	CE	1	COMED_P7_345-L17704AR-S_+_345-L17907TB-S-A	tower	1846.0	136.21	138.35	DC	39.47

Bus #	Bus	MW Impact
274654	BRAIDWOOD;1U	33.0
274655	BRAIDWOOD;2U	31.46
274660	LASCO STA;1U	20.77
274661	LASCO STA;2U	20.81
274847	GR RIDGE ;BU	0.46
274853	TWINGROVE;U1	0.88
274854	TWINGROVE;U2	0.88
274863	CAYUGA RI;1U	1.14
274864	CAYUGA RI;2U	1.14
274871	GR RIDGE ;2U	0.59
274881	PLEAS RDG;2U	0.94
274887	PILOT HIL;1U	0.94
274888	PILOT HIL;1E	24.62
274890	CAYUG;1U E	29.8
274891	CAYUG;2U E	29.8
275149	KEMPTON ;1E	24.62
276150	W2-048 E	1.36
290261	S-027 E	23.06
290265	S-028 E	23.06
293061	N-015 E	12.12
294392	P-010 E	15.39
296125	R-030 C3	5.9
296128	R-030 E3	23.58
296271	R-030 C2	5.83
296272	R-030 E2	23.3
296308	R-030 C1	5.83
296309	R-030 E1	23.3
905081	W4-005 C	0.86
905082	W4-005 E	37.37
909052	X2-022 E	18.92
917501	Z2-087 C	0.7
917502	Z2-087 E	30.46
924041	AB2-047 C O1	5.59
924042	AB2-047 E O1	37.43
924261	AB2-070 C O1	2.78
924262	AB2-070 E O1	18.6
925771	AC1-053 C	2.73
925772	AC1-053 E	18.26
925881	AC1-067 O1	219.35
926821	AC1-168 C O1	0.64

Bus #	Bus	MW Impact
926822	AC1-168 E O1	4.29
930501	AB1-091 O1	110.96
933411	AC2-154 C	3.34
933412	AC2-154 E	5.45
934721	AD1-100 C	48.31
934722	AD1-100 E	225.47
935001	AD1-133 C O1	18.1
935002	AD1-133 E O1	12.07
935141	AD1-148	4.94
936371	AD2-047 C O1	2.99
936372	AD2-047 E O1	32.19
936461	AD2-060	3.52
936771	AD2-100 C O1	10.55
936772	AD2-100 E O1	7.04
936781	AD2-101 C	7.11
936782	AD2-101 E	33.27
936972	AD2-131 E O1	2.22
937121	AD2-148 C O1	5.34
937122	AD2-148 E O1	25.01
937131	AD2-149 C O1	5.34
937132	AD2-149 E O1	25.01
937141	AD2-150 C O1	5.34
937142	AD2-150 E O1	25.01
937161	AD2-153 C O1	3.8
937162	AD2-153 E O1	17.78
937171	AD2-154 C O1	3.8
937172	AD2-154 E O1	17.78
937181	AD2-155 C O1	5.34
937182	AD2-155 E O1	25.01
937211	AD2-159 C	4.04
937212	AD2-159 E	18.9
937321	AD2-175 C	24.89
937322	AD2-175 E	16.59
938012	AE1-002 E O1	29.83
939351	AE1-166 C O1	20.52
939352	AE1-166 E O1	18.94
939401	AE1-172 C O1	15.26
939402	AE1-172 E O1	71.45
939741	AE1-205 C O1	14.83
939742	AE1-205 E O1	20.48
940101	AE1-252 C O1	26.01
940102	AE1-252 E O1	17.34
951741	J474 C	1.71
951742	J474 E	9.28
953741	J826 C	1.0
953742	J826 E	5.4
954181	J884	8.88
AB2-013	AB2-013	5.61
BLUEG	BLUEG	0.01
CARR	CARR	0.27
CBM-S1	CBM-S1	2.75
CBM-S2	CBM-S2	0.06

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	5.33
CBM-W2	CBM-W2	48.81
CIN	CIN	2.54
DEARBORN	DEARBORN	1.27
G-007	G-007	0.73
HAMLET	HAMLET	0.06
IPL	IPL	1.1
LGEE	LGEE	0.03
MEC	MEC	13.64
O-066	O-066	2.47
RENSSELAER	RENSSELAER	0.21
TRIMBLE	TRIMBLE	0.04
WEC	WEC	1.22
Z1-043	Z1-043	14.81

Index 16

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
162815	937030	AD2-137 TAP	CE	270926	WILTON ; B	CE	1	COMED_P7_345-L17704AR-S_+_345-L17907TB-S-A	tower	1846.0	143.4	145.54	DC	39.47

Bus #	Bus	MW Impact
274654	BRAIDWOOD;1U	33.0
274655	BRAIDWOOD;2U	31.46
274660	LASCO STA;1U	20.77
274661	LASCO STA;2U	20.81
274847	GR RIDGE ;BU	0.46
274853	TWINGROVE;U1	0.88
274854	TWINGROVE;U2	0.88
274863	CAYUGA RI;1U	1.14
274864	CAYUGA RI;2U	1.14
274871	GR RIDGE ;2U	0.59
274881	PLEAS RDG;2U	0.94
274887	PILOT HIL;1U	0.94
274888	PILOT HIL;1E	24.62
274890	CAYUG;1U E	29.8
274891	CAYUG;2U E	29.8
275149	KEMPTON ;1E	24.62
276150	W2-048 E	1.36
290261	S-027 E	23.06
290265	S-028 E	23.06
293061	N-015 E	12.12
294392	P-010 E	15.39
296125	R-030 C3	5.9
296128	R-030 E3	23.58
296271	R-030 C2	5.83
296272	R-030 E2	23.3
296308	R-030 C1	5.83
296309	R-030 E1	23.3
905081	W4-005 C	0.86
905082	W4-005 E	37.37
909052	X2-022 E	18.92
917501	Z2-087 C	0.7
917502	Z2-087 E	30.46
924041	AB2-047 C O1	5.59
924042	AB2-047 E O1	37.43
924261	AB2-070 C O1	2.78
924262	AB2-070 E O1	18.6
925771	AC1-053 C	2.73
925772	AC1-053 E	18.26
925881	AC1-067 O1	219.35
930501	AB1-091 O1	110.96

Bus #	Bus	MW Impact
933411	AC2-154 C	3.34
933412	AC2-154 E	5.45
934721	AD1-100 C	48.31
934722	AD1-100 E	225.47
935001	AD1-133 C O1	18.1
935002	AD1-133 E O1	12.07
935141	AD1-148	4.94
936371	AD2-047 C O1	2.99
936372	AD2-047 E O1	32.19
936461	AD2-060	3.52
936771	AD2-100 C O1	10.55
936772	AD2-100 E O1	7.04
936781	AD2-101 C	7.11
936782	AD2-101 E	33.27
936972	AD2-131 E O1	2.22
937031	AD2-137 C O1	18.53
937032	AD2-137 E O1	86.74
937121	AD2-148 C O1	5.34
937122	AD2-148 E O1	25.01
937131	AD2-149 C O1	5.34
937132	AD2-149 E O1	25.01
937141	AD2-150 C O1	5.34
937142	AD2-150 E O1	25.01
937161	AD2-153 C O1	3.8
937162	AD2-153 E O1	17.78
937171	AD2-154 C O1	3.8
937172	AD2-154 E O1	17.78
937181	AD2-155 C O1	5.34
937182	AD2-155 E O1	25.01
937211	AD2-159 C	4.04
937212	AD2-159 E	18.9
937321	AD2-175 C	24.89
937322	AD2-175 E	16.59
938012	AE1-002 E O1	70.17
939351	AE1-166 C O1	20.52
939352	AE1-166 E O1	18.94
939401	AE1-172 C O1	15.26
939402	AE1-172 E O1	71.45
939741	AE1-205 C O1	14.83
939742	AE1-205 E O1	20.48
940101	AE1-252 C O1	26.01
940102	AE1-252 E O1	17.34
951741	J474 C	1.71
951742	J474 E	9.28
954181	J884	8.88
AB2-013	AB2-013	5.61
BLUEG	BLUEG	0.01
CARR	CARR	0.27
CBM-S1	CBM-S1	2.75
CBM-S2	CBM-S2	0.06
CBM-W1	CBM-W1	5.33
CBM-W2	CBM-W2	48.81

Bus #	Bus	MW Impact
CIN	CIN	2.54
DEARBORN	DEARBORN	1.27
G-007	G-007	0.73
HAMLET	HAMLET	0.06
IPL	IPL	1.1
LGEE	LGEE	0.03
MEC	MEC	13.64
O-066	O-066	2.47
RENSSELAER	RENSSELAER	0.21
TRIMBLE	TRIMBLE	0.04
WEC	WEC	1.22
Z1-043	Z1-043	14.81

Affected Systems

MISO

MISO Impacts to be determined during later study phases (as applicable).

Contingency Name	Contingency Definition
COMED_P7_345-L6607__B-S+_345-L97008_R-S	CONTINGENCY 'COMED_P7_345-L6607__B-S+_345-L97008_R-S' TRIP BRANCH FROM BUS 270728 TO BUS 274750 CKT 1 / E FRANKFO; B 345 CRETE EC ;BP 345 TRIP BRANCH FROM BUS 274804 TO BUS 243229 CKT 1 / UNIV PK N;RP 345 05OLIVE 345 END
AEP_P1-2_#695A	CONTINGENCY 'AEP_P1-2_#695A' OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1 END
COMED_P7_345-L94507_B-S+_345-L97008_R-S	CONTINGENCY 'COMED_P7_345-L94507_B-S+_345-L97008_R-S' TRIP BRANCH FROM BUS 274750 TO BUS 255112 CKT 1 / CRETE;BP 345 17STJOHN 345 TRIP BRANCH FROM BUS 274804 TO BUS 243229 CKT 1 / UPNOR;RP 345 05OLIVE 345 END
AEP_P1-2_#697A	CONTINGENCY 'AEP_P1-2_#697A' OPEN BRANCH FROM BUS 243229 TO BUS 274804 CKT 1 / 243229 05OLIVE 345 274804 UNIV PK N;RP 345 1 END
COMED_P7_345-L17704AR-S+_345-L17907TB-S-A	CONTINGENCY 'COMED_P7_345-L17704AR-S+_345-L17907TB-S-A' TRIP BRANCH FROM BUS 270675 TO BUS 925880 CKT 1 / BURNHAM ;1R 345 AC1-067 TAP 345 TRIP BRANCH FROM BUS 270662 TO BUS 936780 CKT 1 / BLOOM ; B 345 AD2-101 TAP 345 TRIP BRANCH FROM BUS 270662 TO BUS 271098 TO BUS 275258 CKT 1 / BLOOM ; B 345 BLOOM ; B 138 BLOOM ;4C 34.5 END
COMED_P1-2_345-L8014__-S-B	CONTINGENCY 'COMED_P1-2_345-L8014__-S-B' TRIP BRANCH FROM BUS 935000 TO BUS 270717 CKT 1 / AD1-133 TAP 345 DRESDEN ; R 345 END
COMED_P7_345-L2001__B-S+_345-L2003__R-S	CONTINGENCY 'COMED_P7_345-L2001__B-S+_345-L2003__R-S' TRIP BRANCH FROM BUS 270670 TO BUS 270728 CKT 1 / BRAID; B 345 E FRA; B 345 TRIP BRANCH FROM BUS 270728 TO BUS 270766 CKT 1 / E FRA; B 345 GOODI;3B 345 TRIP BRANCH FROM BUS 270728 TO BUS 274750 CKT 1 / E FRA; B 345 CRETE;BP 345 TRIP BRANCH FROM BUS 270671 TO BUS 270729 CKT 1 / BRAID; R 345 E FRA; R 345 END
COMED_P1-2_345-L11212_B-S-A	CONTINGENCY 'COMED_P1-2_345-L11212_B-S-A' TRIP BRANCH FROM BUS 270926 TO BUS 937030 CKT 1 / WILTO; B 345 AD2-137 TAP 345 END
AEP_P4_#8805_05OLIVE 345_D	CONTINGENCY 'AEP_P4_#8805_05OLIVE 345_D' OPEN BRANCH FROM BUS 243229 TO BUS 932600 CKT 1 / 243229 05OLIVE 345 932600 AC2-080 TAP 345 1 /* CONTINGENCY LINE ADDED FOR AE1 BUILD OPEN BRANCH FROM BUS 243229 TO BUS 274804 CKT 1 / 243229 05OLIVE 345 274804 UNIV PK N;RP 345 1 END

Contingency Name	Contingency Definition
COMED_P4_112-65-BT2-3__	CONTINGENCY 'COMED_P4_112-65-BT2-3__' TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33 END
COMED_P4_112-65-BT3-4__	CONTINGENCY 'COMED_P4_112-65-BT3-4__' TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33 END
AEP_P4_#2978_05DUMONT 765_B	CONTINGENCY 'AEP_P4_#2978_05DUMONT 765_B' OPEN BRANCH FROM BUS 243206 TO BUS 243207 CKT 1 / 243206 05DUMONT 765 243207 05GRNTWN 765 1 OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1 END
COMED_P1-2_765-L11216__-S	CONTINGENCY 'COMED_P1-2_765-L11216__-S' TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765 END
Base Case	
COMED_P4_023-65-BT2-3__	CONTINGENCY 'COMED_P4_023-65-BT2-3__' TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765 END
COMED_P4_112-65-BT5-6__	CONTINGENCY 'COMED_P4_112-65-BT5-6__' TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33 END
COMED_P4_112-65-BT4-5__	CONTINGENCY 'COMED_P4_112-65-BT4-5__' TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33 END
COMED_P4_023-65-BT4-5__	CONTINGENCY 'COMED_P4_023-65-BT4-5__' TRIP BRANCH FROM BUS 275168 TO BUS 270607 CKT 1 / COLLI;2M 345 COLLI; 765 TRIP BRANCH FROM BUS 275168 TO BUS 270697 CKT 1 / COLLI;2M 345 COLLI; R 345 TRIP BRANCH FROM BUS 275168 TO BUS 275268 CKT 1 / COLLI;2M 345 COLLI;2C 33 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 END

Short Circuit

No issues identified

Secondary Point of Interconnection Network Impacts

Under this option, Queue Position AE1-166, a 150 MW solar facility, proposes to interconnect with the ComEd transmission system by tying into the Wilmington-Davis Creek 138kV Line 8607, approximately 8.7 miles from Wilmington.

:

The Queue Project AE1-166 was evaluated as a 150 MW (Capacity 78 MW) tapping the Wilmington to Davis Creek; R 138 kV line in the ComEd area. Project AE1-166 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE1-166 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Load Flow

Network Impacts

The Queue Project AE1-166 was evaluated as a 150 MW (Capacity 78 MW) injection tapping the Wilmington to Davis Creek; R 138 kV line in the ComEd area in the ComEd area. Project AE1-166 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE1-166 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
292137	255104	17GREEN_ACR E	NIPS	270771	GREENACR E; T	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	102.91	103.28	DC	13.09
292252	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P4_#8805_05OLIVE 345_D	breaker	4105.0	96.86	97.18	DC	44.36
756881	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P4_#8805_05OLIVE 345_D	breaker	4105.0	96.86	97.18	DC	44.36
291661	270716	DRESDEN ; B	CE	274702	KENDALL ;BU	CE	1	COMED_P2-2_111-EJ-345B_2	bus	1195.0	85.39	85.92	DC	14.35
292156	270716	DRESDEN ; B	CE	270928	WOLFS ; B	CE	1	COMED_P4_012-45-BT5-6_	breaker	1479.0	91.3	93.02	DC	25.36
292243	270716	DRESDEN ; B	CE	274702	KENDALL ;BU	CE	1	COMED_P4_111-45-L16704T	breaker	1195.0	85.77	86.3	DC	14.34
292244	270716	DRESDEN ; B	CE	274702	KENDALL ;BU	CE	1	COMED_P4_111-45-L11126_	breaker	1195.0	85.44	85.97	DC	14.37
293242	270716	DRESDEN ; B	CE	274702	KENDALL ;BU	CE	1	COMED_P7_345-L1221__B-S+_345-L1223_TR-S	tower	1195.0	90.79	91.33	DC	14.44

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
291972	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	108.56	109.03	DC	13.83

291973	255112	17STJOHN	NIPS	270886	ST JOHN ;T	CE	1	COMED_P4_023-65-BT2-3	breake r	1091.0	110.89	111.33	DC	13.96
291974	255112	17STJOHN	NIPS	270886	ST JOHN ;T	CE	1	COMED_P4_112-65-BT4-5	breake r	1091.0	108.77	109.24	DC	13.95
291975	255112	17STJOHN	NIPS	270886	ST JOHN ;T	CE	1	COMED_P4_112-65-BT3-4	breake r	1091.0	108.77	109.23	DC	13.95
756253	255113	17STILLWEL L	NIPS	243219	05DUMONT	AEP	1	AEP_P4_#2978_05DUMO NT 765_B	breake r	1409.0	173.35	173.76	DC	23.18
293339	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345- L94507_B-S_+_345- L97008_R-S	tower	4105.0	103.6	103.88	DC	48.01
293340	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345- L6607__B-S_+_345- L97008_R-S	tower	4105.0	103.82	104.07	DC	48.08
758106	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345- L94507_B-S_+_345- L97008_R-S	tower	4105.0	103.6	103.88	DC	48.01
758107	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345- L6607__B-S_+_345- L97008_R-S	tower	4105.0	103.82	104.07	DC	48.08
293237	270662	BLOOM ; B	CE	999034	BLOOM 84	CE	1	COMED_P7_345- L17704AR-S_+_345- L17908TB-S-A	tower	530.0	130.0	130.64	DC	7.61
292142	270677	BURNHAM ;OR	CE	255109	17MUNSTER	NIPS	1	AEP_P4_#2978_05DUMO NT 765_B	breake r	1441.0	112.78	113.19	DC	20.64
293241	270716	DRESDEN ; B	CE	274702	KENDALL ;BU	CE	1	COMED_P7_345- L11620_B-S_+_345- L11622_R-S	tower	1195.0	111.86	112.34	DC	12.7
292121	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	AEP_P4_#2978_05DUMO NT 765_B	breake r	1399.0	110.66	111.17	DC	19.04
292122	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	COMED_P4_023-65-BT2-3	breake r	1399.0	110.33	110.83	DC	19.17
292123	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	COMED_P4_112-65-BT4-5	breake r	1399.0	110.24	110.74	DC	19.16
292124	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	COMED_P4_112-65-BT3-4	breake r	1399.0	110.24	110.74	DC	19.16
292019	270771	GREENACRE ;T	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMO NT 765_B	breake r	971.0	115.61	116.02	DC	13.09
756517	270771	GREENACRE ;T	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMO NT 765_B	breake r	971.0	115.61	116.02	DC	13.09
291977	270886	ST JOHN ;T	CE	255104	17GREEN_ACR E	NIPS	1	AEP_P4_#2978_05DUMO NT 765_B	breake r	1091.0	108.56	109.03	DC	13.83
291978	270886	ST JOHN ;T	CE	255104	17GREEN_ACR E	NIPS	1	COMED_P4_023-65-BT2-3	breake r	1091.0	110.89	111.33	DC	13.96
291979	270886	ST JOHN ;T	CE	255104	17GREEN_ACR E	NIPS	1	COMED_P4_112-65-BT4-5	breake r	1091.0	108.76	109.23	DC	13.95
291980	270886	ST JOHN ;T	CE	255104	17GREEN_ACR E	NIPS	1	COMED_P4_112-65-BT3-4	breake r	1091.0	108.76	109.23	DC	13.95
291838	270926	WILTON ; B	CE	275232	WILTON ;3M	CE	1	COMED_P4_112-65-BT5-6	breake r	1379.0	165.76	166.05	DC	24.59
291840	270927	WILTON ; R	CE	275233	WILTON ;4M	CE	1	COMED_P4_112-65-BT2-3	breake r	1379.0	163.51	163.94	DC	25.1
291865	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	AEP_P4_#2978_05DUMO NT 765_B	breake r	1399.0	123.9	124.45	DC	18.81
291866	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	COMED_P4_023-65-BT2-3	breake r	1399.0	123.32	123.87	DC	18.93
291867	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	COMED_P4_112-65-BT4-5	breake r	1399.0	123.25	123.8	DC	18.92
291868	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	COMED_P4_112-65-BT3-4	breake r	1399.0	123.25	123.8	DC	18.92
291927	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMO NT 765_B	breake r	971.0	134.38	134.92	DC	15.88
291928	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT2-3	breake r	971.0	132.3	132.9	DC	16.03
291929	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT4-5	breake r	971.0	133.14	133.69	DC	16.02
291930	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT3-4	breake r	971.0	133.14	133.69	DC	16.02
291931	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT4-5	breake r	971.0	133.14	133.69	DC	16.02
75638	27480	UNIV PK	CE	24322	05OLIVE	AEP	1	AEP_P4_#2978_05DUMO	breake	971.0	134.38	134.92	DC	15.88

6	4	N;RP		9				NT 765_B	r					
756387	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT2-3__	break	971.0	132.3	132.9	DC	16.03
756388	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT4-5__	break	971.0	133.14	133.69	DC	16.02
756389	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_112-65-BT3-4__	break	971.0	133.14	133.69	DC	16.02
756390	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	COMED_P4_023-65-BT4-5__	break	971.0	133.14	133.69	DC	16.02
291837	275232	WILTON ;3M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT5-6__	break	1379.0	165.76	166.05	DC	24.59
291842	275233	WILTON ;4M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT2-3__	break	1379.0	163.51	163.94	DC	25.1
292087	925880	AC1-067 TAP	CE	270675	BURNHAM ;1R	CE	1	COMED_P4_179-38-TR84__	break	1383.0	122.35	123.57	DC	17.01
293238	999034	BLOOM 84	CE	271098	BLOOM ;B	CE	1	COMED_P7_345-L17704AR-S_+345-L17908TB-S-A	tower	530.0	129.98	130.63	DC	7.61

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
292846	255104	17GREEN_ACRE	NIPS	270771	GREENACRE; T	CE	1	AEP_P1-2_#695A	operation	1091.0	101.62	101.99	DC	13.26
292684	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	AEP_P1-2_#695A	operation	1091.0	108.75	109.22	DC	13.95
757077	255113	17STILLWELL	NIPS	243219	05DUMONT	AEP	1	AEP_P1-2_#695A	operation	1409.0	169.82	170.25	DC	23.89
757083	255113	17STILLWELL	NIPS	243219	05DUMONT	AEP	1	Base Case	operation	1409.0	110.96	111.23	DC	14.37
292925	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	Base Case	operation	3555.0	105.56	105.82	DC	40.75
292926	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P1-2_#697A	operation	4105.0	96.83	97.15	DC	44.39
757606	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	Base Case	operation	3555.0	105.56	105.82	DC	40.75
757607	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	AEP_P1-2_#697A	operation	4105.0	96.83	97.15	DC	44.39
292845	270677	BURNHAM ;OR	CE	255109	17MUNSTER	NIPS	1	AEP_P1-2_#695A	operation	1441.0	111.82	112.22	DC	20.79
292970	270716	DRESDEN ; B	CE	274702	KENDALL ;BU	CE	1	COMED_P1-2_345-L1221_B-S	operation	1195.0	84.56	85.09	DC	14.36
292838	270728	E FRANKFO; B	CE	274750	CRETE EC ;BP	CE	1	AEP_P1-2_#695A	operation	1399.0	110.2	110.7	DC	19.16
292718	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	114.16	114.58	DC	13.26
757322	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	114.16	114.58	DC	13.26
292681	270886	ST JOHN ; T	CE	255104	17GREEN_ACRE	NIPS	1	AEP_P1-2_#695A	operation	1091.0	108.75	109.22	DC	13.95
292952	270926	WILTON ; B	CE	275232	WILTON ;3M	CE	1	COMED_P1-2_765-	operation	1379.0	104.06	104.24	DC	15.43

								L11216_-S						
292924	270927	WILTON ; R	CE	275233	WILTON ;4M	CE	1	COMED_P1-2_765-L11216_-S	operation	1379.0	105.45	105.73	DC	16.19
292583	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	AEP_P1-2_#695A	operation	1399.0	123.22	123.76	DC	18.92
292584	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	Base Case	operation	1091.0	80.18	80.69	DC	12.17
292663	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	133.13	133.68	DC	16.02
757247	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P1-2_#695A	operation	971.0	133.13	133.68	DC	16.02
292771	925880	AC1-067 TAP	CE	270675	BURNHAM ;1R	CE	1	Base Case	operation	1201.0	124.03	124.54	DC	13.7
292772	925880	AC1-067 TAP	CE	270675	BURNHAM ;1R	CE	1	COMED_P1-2_345-L17907TB-S-A	operation	1383.0	121.57	122.76	DC	16.59

Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gauge other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
292137	255104	17GREEN_ACR E	NIPS	270771	GREENACR E; T	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1091.0	102.91	103.28	DC	13.09

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	8.06
274722	S-055 E	7.52
274751	CRETE EC ;1U	1.93
274752	CRETE EC ;2U	1.93
274753	CRETE EC ;3U	1.93
274754	CRETE EC ;4U	1.93
274832	U4-027	7.11
274859	EASYR;U1 E	7.3
274860	EASYR;U2 E	7.3
274888	PILOT HIL;1E	12.4
274890	CAYUG;1U E	8.92
274891	CAYUG;2U E	8.92
275149	KEMPTON ;1E	12.4
290021	O50 E	12.98
290051	GSG-6; E	6.94
290108	LEEDK;1U E	16.14
293061	N-015 E	10.24
293516	O-009 E1	5.99
293517	O-009 E2	3.04
293518	O-009 E3	3.35
293644	O22 E1	7.24
293645	O22 E2	14.06
293715	O-029 E	6.47
293716	O-029 E	3.55
293717	O-029 E	3.26
294392	P-010 E	13.0
294763	P-046 E	6.23
295109	WESTBROOK E	3.72
295111	SUBLETTE E	1.72
910542	X3-005 E	0.52
914641	Y2-103	30.09
915011	Y3-013 1	2.51
915021	Y3-013 2	2.51
915031	Y3-013 3	2.51
916221	Z1-073 E	3.58
916502	Z1-106 E1	0.84
916504	Z1-106 E2	0.84
916512	Z1-107 E	1.71
916522	Z1-108 E	1.66
918052	AA1-018 E	10.62
919221	AA1-146	11.67

Bus #	Bus	MW Impact
919581	AA2-030	11.67
920272	AA2-123 E	1.63
924471	AB2-096	28.21
925161	AB2-173	2.08
925302	AB2-191 E	0.92
925881	AC1-067 O1	102.57
926311	AC1-109 1	1.27
926321	AC1-109 2	1.27
926331	AC1-110 1	1.27
926341	AC1-110 2	1.27
926351	AC1-111 1	0.51
926361	AC1-111 2	0.51
926371	AC1-111 3	0.51
926381	AC1-111 4	0.51
926391	AC1-111 5	0.51
926401	AC1-111 6	0.51
926431	AC1-114	1.58
926821	AC1-168 C O1	0.76
926822	AC1-168 E O1	5.08
927091	AC1-204 1	48.76
927101	AC1-204 2	48.73
927201	AC1-214 C O1	0.74
927202	AC1-214 E O1	2.34
927451	AC1-142A 1	2.83
927461	AC1-142A 2	2.83
927511	AC1-113 1	0.79
927521	AC1-113 2	0.79
927531	AC1-185 1	0.46
927541	AC1-185 2	0.46
927551	AC1-185 3	0.46
927561	AC1-185 4	0.46
927571	AC1-185 5	0.46
927581	AC1-185 6	0.46
927591	AC1-185 7	0.46
927601	AC1-185 8	0.46
930481	AB1-089	43.76
930501	AB1-091 O1	49.15
930741	AB1-122 1O1	47.58
930751	AB1-122 2O1	49.75
932881	AC2-115 1	1.58
932891	AC2-115 2	1.58
932921	AC2-116	0.55
933341	AC2-147 C	0.58
933342	AC2-147 E	0.94
933411	AC2-154 C	1.68
933412	AC2-154 E	2.75
933431	AC2-156 C O1	0.64
933432	AC2-156 E O1	1.04
933911	AD1-013 C	1.22
933912	AD1-013 E	1.95
933931	AD1-016 C	0.62
933932	AD1-016 E	1.01

Bus #	Bus	MW Impact
934101	AD1-039 1	4.66
934111	AD1-039 2	4.88
934401	AD1-064 C O1	2.13
934402	AD1-064 E O1	9.99
934431	AD1-067 C	0.09
934432	AD1-067 E	0.37
934651	AD1-096 C	0.59
934652	AD1-096 E	0.97
934701	AD1-098 C O1	4.57
934702	AD1-098 E O1	3.34
934721	AD1-100 C	12.94
934722	AD1-100 E	60.39
934871	AD1-116 C	0.62
934872	AD1-116 E	1.01
934881	AD1-117 C	3.57
934882	AD1-117 E	2.38
934971	AD1-129 C	0.6
934972	AD1-129 E	0.4
935001	AD1-133 C O1	13.73
935002	AD1-133 E O1	9.15
936291	AD2-038 C O1	1.54
936292	AD2-038 E O1	10.32
936371	AD2-047 C O1	1.51
936372	AD2-047 E O1	16.21
936461	AD2-060	1.77
936511	AD2-066 C O1	5.56
936512	AD2-066 E O1	3.71
936781	AD2-101 C	3.17
936782	AD2-101 E	14.84
936791	AD2-102 C	8.0
936792	AD2-102 E	7.69
936961	AD2-130	0.38
937001	AD2-134 C	1.82
937002	AD2-134 E	7.5
937031	AD2-137 C O1	2.31
937032	AD2-137 E O1	10.8
937051	AD2-140 C O1	2.32
937052	AD2-140 E O1	10.87
937061	AD2-141 C O1	2.31
937062	AD2-141 E O1	10.88
937071	AD2-142 C O1	4.64
937072	AD2-142 E O1	21.73
937121	AD2-148 C O1	2.36
937122	AD2-148 E O1	11.04
937131	AD2-149 C O1	2.36
937132	AD2-149 E O1	11.04
937141	AD2-150 C O1	2.36
937142	AD2-150 E O1	11.04
937181	AD2-155 C O1	2.36
937182	AD2-155 E O1	11.04
937311	AD2-172 C	1.64
937312	AD2-172 E	2.26

Bus #	Bus	MW Impact
937321	AD2-175 C	10.99
937322	AD2-175 E	7.33
937331	AD2-176 C O1	4.89
937332	AD2-176 E O1	3.26
937401	AD2-194 1	5.24
937411	AD2-194 2	5.24
937531	AD2-214 C	2.92
937532	AD2-214 E	1.37
938012	AE1-002 E O1	4.63
938511	AE1-070 1	6.16
938521	AE1-070 2	5.63
938851	AE1-113 C O1	5.72
938852	AE1-113 E O1	17.99
938861	AE1-114 C O1	2.37
938862	AE1-114 E O1	9.06
939051	AE1-134 1	0.91
939061	AE1-134 2	0.91
939321	AE1-163 C O1	4.03
939322	AE1-163 E O1	24.74
939351	AE1-166 C O2	6.81
939352	AE1-166 E O2	6.28
939401	AE1-172 C O1	4.1
939402	AE1-172 E O1	19.18
939641	AE1-194 C	10.88
939642	AE1-194 E	72.84
939651	AE1-195 C	10.88
939652	AE1-195 E	72.84
939691	AE1-199	1.59
939701	AE1-201 C	1.34
939702	AE1-201 E	0.29
939732	AE1-204 E	0.2
939861	AE1-222 1	52.55
939871	AE1-222 2	54.95
939921	AE1-228 C O1	6.63
939922	AE1-228 E O1	4.42
939961	AE1-233 C O1	1.55
939962	AE1-233 E O1	6.39
940101	AE1-252 C O1	6.69
940102	AE1-252 E O1	4.46
951721	J643	15.51
952581	J740 C	3.4
952582	J740 E	18.42
953871	J847	8.38
AB2-013	AB2-013	10.64
AE1-033	AE1-033	12.03
BLUEG	BLUEG	2.86
CANNELTON	CANNELTON	0.0
CARR	CARR	0.5
CATAWBA	CATAWBA	0.16
CBM-S1	CBM-S1	1.36
CBM-W1	CBM-W1	19.98
CBM-W2	CBM-W2	38.44

Bus #	Bus	MW Impact
CIN	CIN	0.12
DEARBORN	DEARBORN	2.29
G-007	G-007	1.38
HAMLET	HAMLET	0.65
MEC	MEC	25.05
O-066	O-066	4.65
RENSSELAER	RENSSELAER	0.39
SANTEETLA	SANTEETLA	0.0
TRIMBLE	TRIMBLE	0.34
WEC	WEC	5.32
Z1-043	Z1-043	18.82

Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
758107	270644	WILTON ;	CE	243206	05DUMONT	AEP	1	COMED_P7_345-L6607__B-S+_345-L97008_R-S	tower	4105.0	103.82	104.07	DC	48.08

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	32.21
274722	S-055 E	29.58
274772	LINCOLN ;3U	4.7
274773	LINCOLN ;4U	4.7
274774	LINCOLN ;5U	4.7
274775	LINCOLN ;6U	4.7
274776	LINCOLN ;7U	4.7
274777	LINCOLN ;8U	4.7
274832	U4-027	28.1
274859	EASYR;U1 E	29.17
274860	EASYR;U2 E	29.17
274888	PILOT HIL;1E	44.36
274890	CAYUG;1U E	36.12
274891	CAYUG;2U E	36.12
275149	KEMPTON ;1E	44.36
290021	O50 E	49.31
290051	GSG-6; E	28.12
290108	LEEDK;1U E	65.65
293061	N-015 E	41.27
293516	O-009 E1	23.83
293517	O-009 E2	12.1
293518	O-009 E3	13.33
293644	O22 E1	25.34
293645	O22 E2	49.19
293715	O-029 E	25.82
293716	O-029 E	14.15
293717	O-029 E	13.01
293771	O-035 E	16.52
294392	P-010 E	52.41
294401	BSHIL;1U E	22.13
294410	BSHIL;2U E	22.13
294763	P-046 E	24.91
295109	WESTBROOK E	15.05
295111	SUBLETTE E	6.88
296125	R-030 C3	9.32
296128	R-030 E3	37.3
296271	R-030 C2	9.21
296272	R-030 E2	36.85
296308	R-030 C1	9.21
296309	R-030 E1	36.85

Bus #	Bus	MW Impact
910542	X3-005 E	1.58
914641	Y2-103	118.34
915011	Y3-013 1	9.86
915021	Y3-013 2	9.86
915031	Y3-013 3	9.86
916211	Z1-072 E	12.5
916221	Z1-073 E	14.51
916502	Z1-106 E1	3.41
916504	Z1-106 E2	3.41
916512	Z1-107 E	6.53
916522	Z1-108 E	6.63
917502	Z2-087 E	48.2
918052	AA1-018 E	40.46
919221	AA1-146	46.56
919581	AA2-030	46.56
919621	AA2-039 C	5.39
919622	AA2-039 E	36.1
920272	AA2-123 E	6.51
924041	AB2-047 C O1	8.89
924042	AB2-047 E O1	59.51
924471	AB2-096	112.75
925161	AB2-173	8.3
925302	AB2-191 E	3.72
925581	AC1-033 C	3.62
925582	AC1-033 E	24.26
926311	AC1-109 1	5.22
926321	AC1-109 2	5.22
926331	AC1-110 1	5.13
926341	AC1-110 2	5.13
926351	AC1-111 1	2.07
926361	AC1-111 2	2.07
926371	AC1-111 3	2.07
926381	AC1-111 4	2.07
926391	AC1-111 5	2.07
926401	AC1-111 6	2.07
926431	AC1-114	6.33
926821	AC1-168 C O1	2.99
926822	AC1-168 E O1	20.04
927091	AC1-204 1	184.51
927101	AC1-204 2	184.55
927201	AC1-214 C O1	5.3
927202	AC1-214 E O1	16.85
927451	AC1-142A 1	10.62
927461	AC1-142A 2	10.62
927511	AC1-113 1	3.17
927521	AC1-113 2	3.17
927531	AC1-185 1	1.82
927541	AC1-185 2	1.82
927551	AC1-185 3	1.82
927561	AC1-185 4	1.82
927571	AC1-185 5	1.82
927581	AC1-185 6	1.82

Bus #	Bus	MW Impact
927591	AC1-185 7	1.82
927601	AC1-185 8	1.82
930481	AB1-089	175.38
930501	AB1-091 O1	174.2
930741	AB1-122 101	195.19
930751	AB1-122 201	188.91
932881	AC2-115 1	6.33
932891	AC2-115 2	6.33
932921	AC2-116	2.22
932931	AC2-117	14.97
933341	AC2-147 C	2.31
933342	AC2-147 E	3.78
933411	AC2-154 C	6.02
933412	AC2-154 E	9.82
933431	AC2-156 C O1	2.64
933432	AC2-156 E O1	4.3
933911	AD1-013 C	4.95
933912	AD1-013 E	7.91
933931	AD1-016 C	2.48
933932	AD1-016 E	4.04
934051	AD1-031 C O1	7.36
934052	AD1-031 E O1	12.0
934101	AD1-039 1	19.13
934111	AD1-039 2	18.51
934401	AD1-064 C O1	8.57
934402	AD1-064 E O1	40.14
934431	AD1-067 C	0.35
934432	AD1-067 E	1.48
934651	AD1-096 C	2.37
934652	AD1-096 E	3.87
934701	AD1-098 C O1	18.49
934702	AD1-098 E O1	13.5
934721	AD1-100 C	51.1
934722	AD1-100 E	238.47
934871	AD1-116 C	2.36
934872	AD1-116 E	3.84
934881	AD1-117 C	14.25
934882	AD1-117 E	9.5
934971	AD1-129 C	2.41
934972	AD1-129 E	1.61
935001	AD1-133 C O1	56.03
935002	AD1-133 E O1	37.35
936291	AD2-038 C O1	5.87
936292	AD2-038 E O1	39.26
936371	AD2-047 C O1	5.39
936372	AD2-047 E O1	57.98
936461	AD2-060	6.34
936511	AD2-066 C O1	21.5
936512	AD2-066 E O1	14.33
936781	AD2-101 C	10.69
936782	AD2-101 E	50.05
936791	AD2-102 C	31.93

Bus #	Bus	MW Impact
936792	AD2-102 E	30.68
936961	AD2-130	1.41
937001	AD2-134 C	7.35
937002	AD2-134 E	30.37
937031	AD2-137 C O1	10.27
937032	AD2-137 E O1	48.06
937051	AD2-140 C O1	10.51
937052	AD2-140 E O1	49.22
937061	AD2-141 C O1	10.45
937062	AD2-141 E O1	49.28
937071	AD2-142 C O1	21.03
937072	AD2-142 E O1	98.44
937121	AD2-148 C O1	8.36
937122	AD2-148 E O1	39.16
937131	AD2-149 C O1	8.36
937132	AD2-149 E O1	39.16
937141	AD2-150 C O1	8.36
937142	AD2-150 E O1	39.16
937181	AD2-155 C O1	8.36
937182	AD2-155 E O1	39.16
937311	AD2-172 C	6.54
937312	AD2-172 E	9.03
937321	AD2-175 C	38.97
937322	AD2-175 E	25.98
937331	AD2-176 C O1	19.55
937332	AD2-176 E O1	13.03
937401	AD2-194 1	19.84
937411	AD2-194 2	19.85
937531	AD2-214 C	11.62
937532	AD2-214 E	5.47
938012	AE1-002 E O1	20.61
938511	AE1-070 1	23.31
938521	AE1-070 2	21.33
938851	AE1-113 C O1	21.78
938852	AE1-113 E O1	68.46
938861	AE1-114 C O1	9.47
938862	AE1-114 E O1	36.21
939051	AE1-134 1	3.62
939061	AE1-134 2	3.62
939321	AE1-163 C O1	14.71
939322	AE1-163 E O1	90.37
939351	AE1-166 C O2	25.0
939352	AE1-166 E O2	23.08
939401	AE1-172 C O1	16.59
939402	AE1-172 E O1	77.68
939631	AE1-193 C O1	17.98
939632	AE1-193 E O1	120.33
939681	AE1-198 C O1	53.39
939682	AE1-198 E O1	45.36
939691	AE1-199	6.43
939701	AE1-201 C	5.34
939702	AE1-201 E	1.17

Bus #	Bus	MW Impact
939732	AE1-204 E	0.77
939741	AE1-205 C O1	22.98
939742	AE1-205 E O1	31.74
939861	AE1-222 1	215.56
939871	AE1-222 2	208.62
939921	AE1-228 C O1	26.65
939922	AE1-228 E O1	17.77
939961	AE1-233 C O1	6.29
939962	AE1-233 E O1	26.0
940101	AE1-252 C O1	27.09
940102	AE1-252 E O1	18.06
990901	L-005 E	20.34
AB2-013	AB2-013	41.13
AE1-033	AE1-033	47.76
BLUEG	BLUEG	16.6
CALDERWOOD	CALDERWOOD	0.21
CANNELTON	CANNELTON	0.24
CARR	CARR	1.95
CATAWBA	CATAWBA	0.78
CBM-S1	CBM-S1	3.58
CBM-W1	CBM-W1	77.21
CBM-W2	CBM-W2	141.69
CHEOAH	CHEOAH	0.22
CHILHOWEE	CHILHOWEE	0.06
DEARBORN	DEARBORN	6.39
ELMERSMITH	ELMERSMITH	0.25
G-007	G-007	5.48
GIBSON	GIBSON	0.07
HAMLET	HAMLET	2.97
MEC	MEC	98.4
O-066	O-066	18.45
RENSSELAER	RENSSELAER	1.54
SANTEETLA	SANTEETLA	0.07
TRIMBLE	TRIMBLE	1.97
WEC	WEC	20.97
Z1-043	Z1-043	73.98

Index 3

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
293241	270716	DRESDEN ;B	CE	274702	KENDALL ;BU	CE	1	COMED_P7_345-L11620_B-S+_345-L11622_R-S	tower	1195.0	111.86	112.34	DC	12.7

Bus #	Bus	MW Impact
274658	DRESDEN ;2U	41.47
274728	ELWOOD EC;5P	4.36
274730	ELWOOD EC;6P	4.36
274732	ELWOOD EC;7P	4.36
274734	ELWOOD EC;8P	4.36
274736	ELWOOD EC;9P	4.36
290021	O50 E	26.71
927091	AC1-204 1	105.7
927101	AC1-204 2	104.98
930741	AB1-122 1O1	46.99
930751	AB1-122 2O1	169.63
934101	AD1-039 1	4.61
934111	AD1-039 2	16.62
936511	AD2-066 C O1	9.2
936512	AD2-066 E O1	6.13
937401	AD2-194 1	11.37
937411	AD2-194 2	11.29
938511	AE1-070 1	13.36
938521	AE1-070 2	12.14
939351	AE1-166 C O2	6.6
939352	AE1-166 E O2	6.1
939861	AE1-222 1	51.9
939871	AE1-222 2	187.32
AB2-013	AB2-013	7.79
BLUEG	BLUEG	0.18
CARR	CARR	0.08
CBM-S1	CBM-S1	1.15
CBM-S2	CBM-S2	0.1
CBM-W1	CBM-W1	0.56
CBM-W2	CBM-W2	20.18
CIN	CIN	0.48
DEARBORN	DEARBORN	0.52
G-007	G-007	0.23
IPL	IPL	0.18
MEC	MEC	7.99
O-066	O-066	0.78
RENSSELAER	RENSSELAER	0.07
TRIMBLE	TRIMBLE	0.03
Z1-043	Z1-043	13.41

Index 4

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
292156	270716	DRESDEN ; B	CE	270928	WOLFS ; B	CE	1	COMED_P4_012-45-BT5-6__	breaker	1479.0	91.3	93.02	DC	25.36

Bus #	Bus	MW Impact
274658	DRESDEN ;2U	78.0
274677	POWERTON ;5U	12.82
274678	POWERTON ;6U	12.7
274836	EQUISTAR ; R	4.45
274879	MINONK ;1U	1.89
290021	O50 E	49.28
904211	W3-135	0.36
916502	Z1-106 E1	0.62
916504	Z1-106 E2	0.61
930751	AB1-122 2O1	318.92
934111	AD1-039 2	31.25
936291	AD2-038 C O1	1.49
936292	AD2-038 E O1	9.96
936511	AD2-066 C O1	15.81
936512	AD2-066 E O1	10.54
938851	AE1-113 C O1	5.53
938852	AE1-113 E O1	17.37
939321	AE1-163 C O1	3.84
939322	AE1-163 E O1	23.56
939351	AE1-166 C O2	13.19
939352	AE1-166 E O2	12.17
939871	AE1-222 2	352.2
953201	J715 C	1.34
953202	J715 E	7.25
AB2-013	AB2-013	10.17
BLUEG	BLUEG	0.42
CALDERWOOD	CALDERWOOD	0.01
CARR	CARR	0.07
CATAWBA	CATAWBA	0.03
CBM-S1	CBM-S1	0.09
CBM-W2	CBM-W2	7.73
CHEOAH	CHEOAH	0.01
CHILHOWEE	CHILHOWEE	0.0
CIN	CIN	0.16
DEARBORN	DEARBORN	0.27
FARMERCITY	FARMERCITY	0.1
G-007	G-007	0.2
HAMLET	HAMLET	0.12
IPL	IPL	0.03
O-066	O-066	0.67
RENSSELAER	RENSSELAER	0.06

Bus #	Bus	MW Impact
SANTEETLA	SANTEETLA	0.0
TATANKA	TATANKA	0.72
TRIMBLE	TRIMBLE	0.05
Z1-043	Z1-043	16.14

Index 5

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
291973	255112	17STJOHN	NIPS	270886	ST JOHN ; T	CE	1	COMED_P4_023-65-BT2-3__	breaker	1091.0	110.89	111.33	DC	13.96

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	9.04
274654	BRAIDWOOD;1U	19.05
274655	BRAIDWOOD;2U	18.24
274661	LASCO STA;2U	17.6
274687	WILL CNTY;4U	8.03
274704	KENDALL ;1C	2.81
274705	KENDALL ;1S	1.88
274706	KENDALL ;2C	2.81
274707	KENDALL ;2S	1.88
274722	S-055 E	8.45
274751	CRETE EC ;1U	3.36
274752	CRETE EC ;2U	3.36
274753	CRETE EC ;3U	3.36
274754	CRETE EC ;4U	3.36
274859	EASYR;U1 E	8.17
274860	EASYR;U2 E	8.17
274861	TOP CROP ;1U	0.33
274862	TOP CROP ;2U	0.63
274888	PILOT HIL;1E	12.81
274890	CAYUG;1U E	9.74
274891	CAYUG;2U E	9.74
275149	KEMPTON ;1E	12.81
290021	O50 E	14.65
290051	GSG-6; E	7.78
290108	LEEDK;1U E	18.09
293061	N-015 E	11.61
293516	O-009 E1	6.69
293517	O-009 E2	3.4
293518	O-009 E3	3.74
293644	O22 E1	8.5
293645	O22 E2	16.51
293715	O-029 E	7.24
293716	O-029 E	3.97
293717	O-029 E	3.65
294392	P-010 E	14.75
294763	P-046 E	6.98
295109	WESTBROOK E	4.16
295111	SUBLETTE E	1.92
914641	Y2-103	33.8
915011	Y3-013 1	2.82

Bus #	Bus	MW Impact
915021	Y3-013 2	2.82
915031	Y3-013 3	2.82
916221	Z1-073 E	4.01
916502	Z1-106 E1	0.94
916504	Z1-106 E2	0.94
916512	Z1-107 E	1.85
916522	Z1-108 E	1.86
918052	AA1-018 E	11.64
919221	AA1-146	13.04
919581	AA2-030	13.04
920272	AA2-123 E	1.83
924471	AB2-096	31.63
925161	AB2-173	2.33
925302	AB2-191 E	1.03
926311	AC1-109 1	1.42
926321	AC1-109 2	1.42
926331	AC1-110 1	1.42
926341	AC1-110 2	1.42
926351	AC1-111 1	0.57
926361	AC1-111 2	0.57
926371	AC1-111 3	0.57
926381	AC1-111 4	0.57
926391	AC1-111 5	0.57
926401	AC1-111 6	0.57
926431	AC1-114	1.77
926821	AC1-168 C O1	0.85
926822	AC1-168 E O1	5.68
927091	AC1-204 1	55.19
927101	AC1-204 2	55.12
927451	AC1-142A 1	3.2
927461	AC1-142A 2	3.2
927511	AC1-113 1	0.89
927521	AC1-113 2	0.89
927531	AC1-185 1	0.51
927541	AC1-185 2	0.51
927551	AC1-185 3	0.51
927561	AC1-185 4	0.51
927571	AC1-185 5	0.51
927581	AC1-185 6	0.51
927591	AC1-185 7	0.51
927601	AC1-185 8	0.51
930481	AB1-089	49.05
930501	AB1-091 O1	50.61
930741	AB1-122 1O1	52.99
930751	AB1-122 2O1	56.33
932881	AC2-115 1	1.77
932891	AC2-115 2	1.77
932921	AC2-116	0.62
933341	AC2-147 C	0.65
933342	AC2-147 E	1.06
933411	AC2-154 C	1.74
933412	AC2-154 E	2.84

Bus #	Bus	MW Impact
933431	AC2-156 C O1	0.71
933432	AC2-156 E O1	1.16
933911	AD1-013 C	1.37
933912	AD1-013 E	2.19
933931	AD1-016 C	0.69
933932	AD1-016 E	1.13
934101	AD1-039 1	5.19
934111	AD1-039 2	5.52
934401	AD1-064 C O1	2.39
934402	AD1-064 E O1	11.2
934431	AD1-067 C	0.1
934432	AD1-067 E	0.41
934651	AD1-096 C	0.66
934652	AD1-096 E	1.08
934701	AD1-098 C O1	5.12
934702	AD1-098 E O1	3.74
934721	AD1-100 C	14.27
934722	AD1-100 E	66.6
934871	AD1-116 C	0.68
934872	AD1-116 E	1.11
934881	AD1-117 C	3.99
934882	AD1-117 E	2.66
934971	AD1-129 C	0.67
934972	AD1-129 E	0.45
935001	AD1-133 C O1	15.16
935002	AD1-133 E O1	10.11
936291	AD2-038 C O1	1.71
936292	AD2-038 E O1	11.45
936371	AD2-047 C O1	1.56
936372	AD2-047 E O1	16.75
936461	AD2-060	1.83
936511	AD2-066 C O1	6.19
936512	AD2-066 E O1	4.13
936781	AD2-101 C	3.09
936782	AD2-101 E	14.46
936791	AD2-102 C	8.96
936792	AD2-102 E	8.61
936961	AD2-130	0.42
937001	AD2-134 C	2.03
937002	AD2-134 E	8.4
937031	AD2-137 C O1	2.44
937032	AD2-137 E O1	11.43
937051	AD2-140 C O1	2.44
937052	AD2-140 E O1	11.42
937061	AD2-141 C O1	2.43
937062	AD2-141 E O1	11.44
937071	AD2-142 C O1	4.88
937072	AD2-142 E O1	22.85
937121	AD2-148 C O1	2.43
937122	AD2-148 E O1	11.37
937131	AD2-149 C O1	2.43
937132	AD2-149 E O1	11.37

Bus #	Bus	MW Impact
937141	AD2-150 C O1	2.43
937142	AD2-150 E O1	11.37
937181	AD2-155 C O1	2.43
937182	AD2-155 E O1	11.37
937311	AD2-172 C	1.83
937312	AD2-172 E	2.53
937321	AD2-175 C	11.32
937322	AD2-175 E	7.55
937331	AD2-176 C O1	5.48
937332	AD2-176 E O1	3.65
937401	AD2-194 1	5.94
937411	AD2-194 2	5.93
937531	AD2-214 C	0.8
937532	AD2-214 E	0.38
938012	AE1-002 E O1	4.9
938511	AE1-070 1	6.97
938521	AE1-070 2	6.37
938851	AE1-113 C O1	6.35
938852	AE1-113 E O1	19.97
938861	AE1-114 C O1	2.65
938862	AE1-114 E O1	10.14
939051	AE1-134 1	1.01
939061	AE1-134 2	1.01
939321	AE1-163 C O1	4.63
939322	AE1-163 E O1	28.43
939351	AE1-166 C O2	7.26
939352	AE1-166 E O2	6.7
939401	AE1-172 C O1	4.47
939402	AE1-172 E O1	20.95
939641	AE1-194 C	18.96
939642	AE1-194 E	126.86
939651	AE1-195 C	18.96
939652	AE1-195 E	126.86
939691	AE1-199	1.78
939701	AE1-201 C	1.5
939702	AE1-201 E	0.33
939732	AE1-204 E	0.22
939861	AE1-222 1	58.52
939871	AE1-222 2	62.2
939921	AE1-228 C O1	7.44
939922	AE1-228 E O1	4.96
939961	AE1-233 C O1	1.73
939962	AE1-233 E O1	7.16
940101	AE1-252 C O1	7.31
940102	AE1-252 E O1	4.87
AB2-013	AB2-013	11.87
AE1-033	AE1-033	13.47
BLUEG	BLUEG	5.05
CALDERWOOD	CALDERWOOD	0.09
CANNELTON	CANNELTON	0.11
CARR	CARR	0.56
CATAWBA	CATAWBA	0.23

Bus #	Bus	MW Impact
CBM-S1	CBM-S1	0.77
CBM-W1	CBM-W1	20.04
CBM-W2	CBM-W2	37.14
CHEOAH	CHEOAH	0.09
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.24
ELMERSMITH	ELMERSMITH	0.14
G-007	G-007	1.57
GIBSON	GIBSON	0.06
HAMLET	HAMLET	0.87
MEC	MEC	27.58
O-066	O-066	5.3
RENSSELAER	RENSSELAER	0.45
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.59
WEC	WEC	5.97
Z1-043	Z1-043	20.98

Index 6

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
756253	255113	17STILLWEL	NIPS	243219	05DUMONT	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1409.0	173.35	173.76	DC	23.18

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	13.92
274722	S-055 E	12.95
274724	RIVER EC ;11	4.75
274788	SE CHICAG;5U	1.14
274789	SE CHICAG;6U	1.14
274790	SE CHICAG;7U	1.14
274791	SE CHICAG;8U	1.14
274795	SE CHICAG;2U	1.12
274832	U4-027	12.45
274859	EASYR;U1 E	12.67
274860	EASYR;U2 E	12.67
274888	PILOT HIL;1E	22.3
274890	CAYUG;1U E	15.76
274891	CAYUG;2U E	15.76
275149	KEMPTON ;1E	22.3
290021	O50 E	22.31
290051	GSG-6; E	12.02
290108	LEEDK;1U E	27.92
293061	N-015 E	17.54
293516	O-009 E1	10.45
293517	O-009 E2	5.31
293518	O-009 E3	5.85
293644	O22 E1	11.95
293645	O22 E2	23.2
293715	O-029 E	11.27
293716	O-029 E	6.18
293717	O-029 E	5.68
293771	O-035 E	7.36
294392	P-010 E	22.27
294763	P-046 E	10.8
295109	WESTBROOK E	6.44
295111	SUBLETTE E	2.99
910542	X3-005 E	1.0
914641	Y2-103	51.8
915011	Y3-013 1	4.32
915021	Y3-013 2	4.32
915031	Y3-013 3	4.32
916211	Z1-072 E	5.57
916221	Z1-073 E	6.2
916502	Z1-106 E1	1.45
916504	Z1-106 E2	1.45

Bus #	Bus	MW Impact
916512	Z1-107 E	3.03
916522	Z1-108 E	2.86
918052	AA1-018 E	18.74
919221	AA1-146	20.28
919581	AA2-030	20.28
920272	AA2-123 E	2.81
924471	AB2-096	48.73
925161	AB2-173	3.62
925302	AB2-191 E	1.59
925581	AC1-033 C	1.61
925582	AC1-033 E	10.81
925881	AC1-067 O1	198.49
926311	AC1-109 1	2.19
926321	AC1-109 2	2.19
926331	AC1-110 1	2.18
926341	AC1-110 2	2.18
926351	AC1-111 1	0.88
926361	AC1-111 2	0.88
926371	AC1-111 3	0.88
926381	AC1-111 4	0.88
926391	AC1-111 5	0.88
926401	AC1-111 6	0.88
926431	AC1-114	2.74
926821	AC1-168 C O1	1.32
926822	AC1-168 E O1	8.85
927091	AC1-204 1	83.26
927101	AC1-204 2	83.23
927201	AC1-214 C O1	2.36
927202	AC1-214 E O1	7.51
927451	AC1-142A 1	4.83
927461	AC1-142A 2	4.84
927511	AC1-113 1	1.37
927521	AC1-113 2	1.37
927531	AC1-185 1	0.79
927541	AC1-185 2	0.79
927551	AC1-185 3	0.79
927561	AC1-185 4	0.79
927571	AC1-185 5	0.79
927581	AC1-185 6	0.79
927591	AC1-185 7	0.79
927601	AC1-185 8	0.79
930481	AB1-089	75.67
930501	AB1-091 O1	88.22
930741	AB1-122 1O1	82.42
930751	AB1-122 2O1	84.95
932881	AC2-115 1	2.74
932891	AC2-115 2	2.74
932921	AC2-116	0.96
932931	AC2-117	5.81
933341	AC2-147 C	1.0
933342	AC2-147 E	1.64
933411	AC2-154 C	3.03

Bus #	Bus	MW Impact
933412	AC2-154 E	4.94
933431	AC2-156 C O1	1.1
933432	AC2-156 E O1	1.79
933911	AD1-013 C	2.12
933912	AD1-013 E	3.38
933931	AD1-016 C	1.07
933932	AD1-016 E	1.74
934101	AD1-039 1	8.08
934111	AD1-039 2	8.33
934401	AD1-064 C O1	3.69
934402	AD1-064 E O1	17.25
934431	AD1-067 C	0.15
934432	AD1-067 E	0.63
934651	AD1-096 C	1.03
934652	AD1-096 E	1.67
934701	AD1-098 C O1	7.91
934702	AD1-098 E O1	5.78
934721	AD1-100 C	22.45
934722	AD1-100 E	104.76
934871	AD1-116 C	1.09
934872	AD1-116 E	1.78
934881	AD1-117 C	6.19
934882	AD1-117 E	4.13
934971	AD1-129 C	1.04
934972	AD1-129 E	0.69
935001	AD1-133 C O1	24.06
935002	AD1-133 E O1	16.04
936291	AD2-038 C O1	2.69
936292	AD2-038 E O1	18.02
936371	AD2-047 C O1	2.71
936372	AD2-047 E O1	29.15
936461	AD2-060	3.19
936511	AD2-066 C O1	9.67
936512	AD2-066 E O1	6.45
936781	AD2-101 C	5.9
936782	AD2-101 E	27.62
936791	AD2-102 C	13.85
936792	AD2-102 E	13.3
936961	AD2-130	0.66
937001	AD2-134 C	3.14
937002	AD2-134 E	12.98
937031	AD2-137 C O1	4.08
937032	AD2-137 E O1	19.09
937051	AD2-140 C O1	4.11
937052	AD2-140 E O1	19.25
937061	AD2-141 C O1	4.09
937062	AD2-141 E O1	19.27
937071	AD2-142 C O1	8.22
937072	AD2-142 E O1	38.5
937121	AD2-148 C O1	4.23
937122	AD2-148 E O1	19.82
937131	AD2-149 C O1	4.23

Bus #	Bus	MW Impact
937132	AD2-149 E O1	19.82
937141	AD2-150 C O1	4.23
937142	AD2-150 E O1	19.82
937181	AD2-155 C O1	4.23
937182	AD2-155 E O1	19.82
937311	AD2-172 C	2.83
937312	AD2-172 E	3.91
937321	AD2-175 C	19.73
937322	AD2-175 E	13.15
937331	AD2-176 C O1	8.43
937332	AD2-176 E O1	5.62
937401	AD2-194 1	8.95
937411	AD2-194 2	8.95
937531	AD2-214 C	5.1
937532	AD2-214 E	2.4
938012	AE1-002 E O1	8.18
938511	AE1-070 1	10.52
938521	AE1-070 2	9.62
938851	AE1-113 C O1	10.0
938852	AE1-113 E O1	31.44
938861	AE1-114 C O1	4.11
938862	AE1-114 E O1	15.72
939051	AE1-134 1	1.58
939061	AE1-134 2	1.58
939321	AE1-163 C O1	6.81
939322	AE1-163 E O1	41.82
939351	AE1-166 C O2	12.05
939352	AE1-166 E O2	11.13
939401	AE1-172 C O1	7.21
939402	AE1-172 E O1	33.74
939631	AE1-193 C O1	4.73
939632	AE1-193 E O1	31.63
939641	AE1-194 C	10.24
939642	AE1-194 E	68.55
939651	AE1-195 C	10.24
939652	AE1-195 E	68.55
939681	AE1-198 C O1	23.78
939682	AE1-198 E O1	20.2
939691	AE1-199	2.75
939701	AE1-201 C	2.31
939702	AE1-201 E	0.51
939732	AE1-204 E	0.34
939861	AE1-222 1	91.02
939871	AE1-222 2	93.81
939921	AE1-228 C O1	11.46
939922	AE1-228 E O1	7.64
939961	AE1-233 C O1	2.67
939962	AE1-233 E O1	11.05
940101	AE1-252 C O1	11.82
940102	AE1-252 E O1	7.88
951721	J643	25.73
952581	J740 C	4.3

Bus #	Bus	MW Impact
952582	J740 E	23.28
953871	J847	13.1
954751	J351	434.54
AB2-013	AB2-013	18.6
AE1-033	AE1-033	20.85
BLUEG	BLUEG	1.07
CARR	CARR	0.9
CATAWBA	CATAWBA	0.22
CBM-S1	CBM-S1	3.95
CBM-W1	CBM-W1	35.83
CBM-W2	CBM-W2	81.92
CIN	CIN	3.3
DEARBORN	DEARBORN	4.0
G-007	G-007	2.51
HAMLET	HAMLET	0.96
IPL	IPL	1.12
MEC	MEC	44.69
O-066	O-066	8.44
RENSSELAER	RENSSELAER	0.71
TRIMBLE	TRIMBLE	0.16
WEC	WEC	9.2
Z1-043	Z1-043	32.93

Index 7

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
293237	270662	BLOOM ; B	CE	999034	BLOOM 84	CE	1	COMED_P7_345-L17704AR-S_+_345-L17908TB-S-A	tower	530.0	130.0	130.64	DC	7.61

Bus #	Bus	MW Impact
274888	PILOT HIL;1E	11.75
275149	KEMPTON ;1E	11.75
925881	AC1-067 O1	120.33
930501	AB1-091 O1	60.96
933411	AC2-154 C	1.6
933412	AC2-154 E	2.6
936371	AD2-047 C O1	1.43
936372	AD2-047 E O1	15.37
936461	AD2-060	1.68
936781	AD2-101 C	8.76
936782	AD2-101 E	41.01
937121	AD2-148 C O1	2.96
937122	AD2-148 E O1	13.84
937131	AD2-149 C O1	2.96
937132	AD2-149 E O1	13.84
937141	AD2-150 C O1	2.96
937142	AD2-150 E O1	13.84
937181	AD2-155 C O1	2.96
937182	AD2-155 E O1	13.84
937321	AD2-175 C	13.77
937322	AD2-175 E	9.18
939351	AE1-166 C O2	3.95
939352	AE1-166 E O2	3.65
BLUEG	BLUEG	0.12
CARR	CARR	0.03
CATAWBA	CATAWBA	0.01
CBM-S1	CBM-S1	0.17
CBM-W2	CBM-W2	3.63
CIN	CIN	0.12
DEARBORN	DEARBORN	0.17
G-007	G-007	0.08
HAMLET	HAMLET	0.03
IPL	IPL	0.04
MEC	MEC	1.16
O-066	O-066	0.28
RENSSELAER	RENSSELAER	0.02
TRIMBLE	TRIMBLE	0.01
WEC	WEC	0.09

Index 8

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
292142	270677	BURNHAM ;OR	CE	255109	17MUNSTER	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1441.0	112.78	113.19	DC	20.64

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	11.75
274722	S-055 E	10.96
274723	RIVER EC ;12	4.32
274792	SE CHICAG;9U	0.96
274793	SE CHICAG;0U	0.96
274794	SE CHICAG;1U	0.96
274795	SE CHICAG;2U	0.96
274832	U4-027	10.31
274859	EASYR;U1 E	10.61
274860	EASYR;U2 E	10.61
274888	PILOT HIL;1E	20.48
274890	CAYUG;1U E	13.4
274891	CAYUG;2U E	13.4
275149	KEMPTON ;1E	20.48
290021	O50 E	18.57
290051	GSG-6; E	10.13
290108	LEEDK;1U E	23.57
293061	N-015 E	14.82
293516	O-009 E1	8.7
293517	O-009 E2	4.42
293518	O-009 E3	4.87
293644	O22 E1	9.26
293645	O22 E2	17.98
293715	O-029 E	9.4
293716	O-029 E	5.15
293717	O-029 E	4.74
293771	O-035 E	6.09
294392	P-010 E	18.82
294763	P-046 E	9.07
295109	WESTBROOK E	5.42
295111	SUBLETTE E	2.5
296125	R-030 C3	3.43
296128	R-030 E3	13.71
296271	R-030 C2	3.39
296272	R-030 E2	13.54
296308	R-030 C1	3.39
296309	R-030 E1	13.54
910541	X3-005 C	0.08
910542	X3-005 E	0.91
914641	Y2-103	43.82
915011	Y3-013 1	3.65

Bus #	Bus	MW Impact
915021	Y3-013 2	3.65
915031	Y3-013 3	3.65
916211	Z1-072 E	4.61
916221	Z1-073 E	5.23
916502	Z1-106 E1	1.23
916504	Z1-106 E2	1.23
916512	Z1-107 E	2.58
916522	Z1-108 E	2.42
917502	Z2-087 E	17.71
918052	AA1-018 E	16.81
919221	AA1-146	16.93
919581	AA2-030	16.93
920272	AA2-123 E	2.37
924471	AB2-096	41.11
925161	AB2-173	3.02
925302	AB2-191 E	1.34
925581	AC1-033 C	0.27
925582	AC1-033 E	1.78
925881	AC1-067 O1	301.08
926311	AC1-109 1	1.86
926321	AC1-109 2	1.86
926331	AC1-110 1	1.85
926341	AC1-110 2	1.85
926351	AC1-111 1	0.75
926361	AC1-111 2	0.75
926371	AC1-111 3	0.75
926381	AC1-111 4	0.75
926391	AC1-111 5	0.75
926401	AC1-111 6	0.75
926431	AC1-114	2.31
926821	AC1-168 C O1	1.1
926822	AC1-168 E O1	7.36
927091	AC1-204 1	70.09
927101	AC1-204 2	70.14
927201	AC1-214 C O1	1.95
927202	AC1-214 E O1	6.21
927451	AC1-142A 1	4.09
927461	AC1-142A 2	4.09
927511	AC1-113 1	1.15
927521	AC1-113 2	1.15
927531	AC1-185 1	0.66
927541	AC1-185 2	0.66
927551	AC1-185 3	0.66
927561	AC1-185 4	0.66
927571	AC1-185 5	0.66
927581	AC1-185 6	0.66
927591	AC1-185 7	0.66
927601	AC1-185 8	0.66
930481	AB1-089	63.73
930501	AB1-091 O1	82.27
930741	AB1-122 1O1	70.02
930751	AB1-122 2O1	70.99

Bus #	Bus	MW Impact
932881	AC2-115 1	2.31
932891	AC2-115 2	2.31
932921	AC2-116	0.81
932931	AC2-117	5.3
933341	AC2-147 C	0.84
933342	AC2-147 E	1.37
933411	AC2-154 C	2.78
933412	AC2-154 E	4.53
933431	AC2-156 C O1	0.93
933432	AC2-156 E O1	1.52
933911	AD1-013 C	1.78
933912	AD1-013 E	2.85
933931	AD1-016 C	0.9
933932	AD1-016 E	1.47
934101	AD1-039 1	6.86
934111	AD1-039 2	6.96
934401	AD1-064 C O1	3.11
934402	AD1-064 E O1	14.56
934431	AD1-067 C	0.13
934432	AD1-067 E	0.53
934651	AD1-096 C	0.86
934652	AD1-096 E	1.41
934701	AD1-098 C O1	6.66
934702	AD1-098 E O1	4.86
934721	AD1-100 C	19.54
934722	AD1-100 E	91.19
934871	AD1-116 C	0.98
934872	AD1-116 E	1.6
934881	AD1-117 C	5.18
934882	AD1-117 E	3.46
934971	AD1-129 C	0.88
934972	AD1-129 E	0.58
935001	AD1-133 C O1	20.3
935002	AD1-133 E O1	13.53
936291	AD2-038 C O1	2.33
936292	AD2-038 E O1	15.58
936371	AD2-047 C O1	2.49
936372	AD2-047 E O1	26.77
936461	AD2-060	2.93
936511	AD2-066 C O1	8.14
936512	AD2-066 E O1	5.43
936781	AD2-101 C	4.75
936782	AD2-101 E	22.22
936791	AD2-102 C	11.64
936792	AD2-102 E	11.19
936961	AD2-130	0.56
937001	AD2-134 C	2.65
937002	AD2-134 E	10.94
937031	AD2-137 C O1	3.67
937032	AD2-137 E O1	17.17
937051	AD2-140 C O1	3.72
937052	AD2-140 E O1	17.42

Bus #	Bus	MW Impact
937061	AD2-141 C O1	3.7
937062	AD2-141 E O1	17.44
937071	AD2-142 C O1	7.44
937072	AD2-142 E O1	34.83
937121	AD2-148 C O1	3.94
937122	AD2-148 E O1	18.43
937131	AD2-149 C O1	3.94
937132	AD2-149 E O1	18.43
937141	AD2-150 C O1	3.94
937142	AD2-150 E O1	18.43
937181	AD2-155 C O1	3.94
937182	AD2-155 E O1	18.43
937311	AD2-172 C	2.38
937312	AD2-172 E	3.29
937321	AD2-175 C	18.34
937322	AD2-175 E	12.23
937331	AD2-176 C O1	7.12
937332	AD2-176 E O1	4.75
937401	AD2-194 1	7.54
937411	AD2-194 2	7.54
937531	AD2-214 C	4.24
937532	AD2-214 E	1.99
938012	AE1-002 E O1	7.36
938511	AE1-070 1	8.86
938521	AE1-070 2	8.11
938851	AE1-113 C O1	8.65
938852	AE1-113 E O1	27.18
938861	AE1-114 C O1	3.45
938862	AE1-114 E O1	13.17
939051	AE1-134 1	1.32
939061	AE1-134 2	1.32
939321	AE1-163 C O1	5.47
939322	AE1-163 E O1	33.6
939351	AE1-166 C O2	10.73
939352	AE1-166 E O2	9.91
939401	AE1-172 C O1	6.18
939402	AE1-172 E O1	28.94
939691	AE1-199	2.32
939701	AE1-201 C	1.95
939702	AE1-201 E	0.43
939732	AE1-204 E	0.28
939861	AE1-222 1	77.33
939871	AE1-222 2	78.4
939921	AE1-228 C O1	9.62
939922	AE1-228 E O1	6.42
939961	AE1-233 C O1	2.26
939962	AE1-233 E O1	9.34
940101	AE1-252 C O1	10.05
940102	AE1-252 E O1	6.7
AB2-013	AB2-013	15.32
AE1-033	AE1-033	17.49
BLUEG	BLUEG	5.47

Bus #	Bus	MW Impact
CALDERWOOD	CALDERWOOD	0.06
CANNELTON	CANNELTON	0.08
CARR	CARR	0.73
CATAWBA	CATAWBA	0.27
CBM-S1	CBM-S1	1.44
CBM-W1	CBM-W1	23.88
CBM-W2	CBM-W2	51.81
CHEOAH	CHEOAH	0.06
CHILHOWEE	CHILHOWEE	0.02
DEARBORN	DEARBORN	2.93
ELMERSMITH	ELMERSMITH	0.08
G-007	G-007	2.03
GIBSON	GIBSON	0.04
HAMLET	HAMLET	1.05
MEC	MEC	36.09
O-066	O-066	6.84
RENSSELAER	RENSSELAER	0.58
SANTEETLA	SANTEETLA	0.02
TRIMBLE	TRIMBLE	0.65
WEC	WEC	7.74
Z1-043	Z1-043	27.27

Index 9

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
292121	270728	E FRANKFO; B	CE	274750	CRETE EC;BP	CE	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	110.66	111.17	DC	19.04

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	12.73
274654	BRAIDWOOD;1U	27.26
274655	BRAIDWOOD;2U	26.09
274660	LASCO STA;1U	24.9
274661	LASCO STA;2U	24.94
274675	JOLIET 29;7U	11.25
274676	JOLIET 29;8U	11.26
274687	WILL CNTY;4U	11.37
274704	KENDALL ;1C	4.0
274705	KENDALL ;1S	2.67
274706	KENDALL ;2C	4.0
274707	KENDALL ;2S	2.67
274722	S-055 E	11.91
274736	ELWOOD EC;9P	3.23
274832	U4-027	11.21
274859	EASYR;U1 E	11.52
274860	EASYR;U2 E	11.52
274861	TOP CROP ;1U	0.47
274862	TOP CROP ;2U	0.92
274888	PILOT HIL;1E	17.1
274890	CAYUG;1U E	13.64
274891	CAYUG;2U E	13.64
275149	KEMPTON ;1E	17.1
290021	O50 E	20.79
290051	GSG-6; E	10.94
290108	LEEDK;1U E	25.43
293061	N-015 E	16.43
293516	O-009 E1	9.45
293517	O-009 E2	4.8
293518	O-009 E3	5.29
293644	O22 E1	12.34
293645	O22 E2	23.96
293715	O-029 E	10.21
293716	O-029 E	5.6
293717	O-029 E	5.15
293771	O-035 E	6.61
294392	P-010 E	20.87
294763	P-046 E	9.84
295109	WESTBROOK E	5.86
295111	SUBLETTE E	2.71

Bus #	Bus	MW Impact
914641	Y2-103	47.64
915011	Y3-013 1	3.97
915021	Y3-013 2	3.97
915031	Y3-013 3	3.97
916211	Z1-072 E	5.0
916221	Z1-073 E	5.65
916502	Z1-106 E1	1.33
916504	Z1-106 E2	1.33
916512	Z1-107 E	2.55
916522	Z1-108 E	2.62
918052	AA1-018 E	16.2
919221	AA1-146	18.41
919581	AA2-030	18.41
920272	AA2-123 E	2.57
924471	AB2-096	44.55
925161	AB2-173	3.28
925302	AB2-191 E	1.45
925581	AC1-033 C	1.45
925582	AC1-033 E	9.71
926311	AC1-109 1	2.0
926321	AC1-109 2	2.0
926331	AC1-110 1	2.0
926341	AC1-110 2	2.0
926351	AC1-111 1	0.8
926361	AC1-111 2	0.8
926371	AC1-111 3	0.8
926381	AC1-111 4	0.8
926391	AC1-111 5	0.8
926401	AC1-111 6	0.8
926431	AC1-114	2.5
926821	AC1-168 C O1	1.2
926822	AC1-168 E O1	8.03
927091	AC1-204 1	78.31
927101	AC1-204 2	78.18
927201	AC1-214 C O1	2.12
927202	AC1-214 E O1	6.75
927451	AC1-142A 1	4.53
927461	AC1-142A 2	4.53
927511	AC1-113 1	1.25
927521	AC1-113 2	1.25
927531	AC1-185 1	0.72
927541	AC1-185 2	0.72
927551	AC1-185 3	0.72
927561	AC1-185 4	0.72
927571	AC1-185 5	0.72
927581	AC1-185 6	0.72
927591	AC1-185 7	0.72
927601	AC1-185 8	0.72
930481	AB1-089	69.1
930501	AB1-091 O1	67.39
930741	AB1-122 1O1	74.68
930751	AB1-122 2O1	79.86

Bus #	Bus	MW Impact
932881	AC2-115 1	2.5
932891	AC2-115 2	2.5
932921	AC2-116	0.88
933341	AC2-147 C	0.91
933342	AC2-147 E	1.49
933411	AC2-154 C	2.32
933412	AC2-154 E	3.79
933431	AC2-156 C O1	1.0
933432	AC2-156 E O1	1.63
933911	AD1-013 C	1.93
933912	AD1-013 E	3.08
933931	AD1-016 C	0.98
933932	AD1-016 E	1.6
934101	AD1-039 1	7.32
934111	AD1-039 2	7.83
934401	AD1-064 C O1	3.37
934402	AD1-064 E O1	15.78
934431	AD1-067 C	0.14
934432	AD1-067 E	0.58
934651	AD1-096 C	0.94
934652	AD1-096 E	1.53
934701	AD1-098 C O1	7.2
934702	AD1-098 E O1	5.26
934721	AD1-100 C	19.95
934722	AD1-100 E	93.11
934871	AD1-116 C	0.94
934872	AD1-116 E	1.54
934881	AD1-117 C	5.63
934882	AD1-117 E	3.75
934971	AD1-129 C	0.95
934972	AD1-129 E	0.63
935001	AD1-133 C O1	21.34
935002	AD1-133 E O1	14.23
936291	AD2-038 C O1	2.41
936292	AD2-038 E O1	16.1
936371	AD2-047 C O1	2.08
936372	AD2-047 E O1	22.36
936461	AD2-060	2.44
936511	AD2-066 C O1	8.72
936512	AD2-066 E O1	5.81
936781	AD2-101 C	3.97
936782	AD2-101 E	18.57
936791	AD2-102 C	12.63
936792	AD2-102 E	12.14
936961	AD2-130	0.59
937001	AD2-134 C	2.86
937002	AD2-134 E	11.82
937031	AD2-137 C O1	3.34
937032	AD2-137 E O1	15.64
937051	AD2-140 C O1	3.33
937052	AD2-140 E O1	15.57
937061	AD2-141 C O1	3.31

Bus #	Bus	MW Impact
937062	AD2-141 E O1	15.59
937071	AD2-142 C O1	6.65
937072	AD2-142 E O1	31.14
937121	AD2-148 C O1	3.24
937122	AD2-148 E O1	15.15
937131	AD2-149 C O1	3.24
937132	AD2-149 E O1	15.15
937141	AD2-150 C O1	3.24
937142	AD2-150 E O1	15.15
937181	AD2-155 C O1	3.24
937182	AD2-155 E O1	15.15
937311	AD2-172 C	2.58
937312	AD2-172 E	3.57
937321	AD2-175 C	15.07
937322	AD2-175 E	10.05
937331	AD2-176 C O1	7.72
937332	AD2-176 E O1	5.15
937401	AD2-194 1	8.42
937411	AD2-194 2	8.41
937531	AD2-214 C	4.61
937532	AD2-214 E	2.17
938012	AE1-002 E O1	6.71
938511	AE1-070 1	9.9
938521	AE1-070 2	9.04
938851	AE1-113 C O1	8.93
938852	AE1-113 E O1	28.07
938861	AE1-114 C O1	3.74
938862	AE1-114 E O1	14.3
939051	AE1-134 1	1.43
939061	AE1-134 2	1.43
939321	AE1-163 C O1	6.65
939322	AE1-163 E O1	40.82
939351	AE1-166 C O2	9.9
939352	AE1-166 E O2	9.14
939401	AE1-172 C O1	6.26
939402	AE1-172 E O1	29.29
939631	AE1-193 C O1	1.03
939632	AE1-193 E O1	6.9
939681	AE1-198 C O1	21.36
939682	AE1-198 E O1	18.15
939691	AE1-199	2.5
939701	AE1-201 C	2.11
939702	AE1-201 E	0.46
939732	AE1-204 E	0.31
939861	AE1-222 1	82.47
939871	AE1-222 2	88.2
939921	AE1-228 C O1	10.48
939922	AE1-228 E O1	6.99
939961	AE1-233 C O1	2.44
939962	AE1-233 E O1	10.07
940101	AE1-252 C O1	10.23
940102	AE1-252 E O1	6.82

Bus #	Bus	MW Impact
AB2-013	AB2-013	16.84
AE1-033	AE1-033	19.0
BLUEG	BLUEG	5.85
CALDERWOOD	CALDERWOOD	0.03
CANNELTON	CANNELTON	0.09
CARR	CARR	0.74
CATAWBA	CATAWBA	0.27
CBM-S1	CBM-S1	1.66
CBM-W1	CBM-W1	26.48
CBM-W2	CBM-W2	55.79
CHEOAH	CHEOAH	0.04
CHILHOWEE	CHILHOWEE	0.01
DEARBORN	DEARBORN	3.02
ELMERSMITH	ELMERSMITH	0.09
G-007	G-007	2.06
GIBSON	GIBSON	0.05
HAMLET	HAMLET	1.03
MEC	MEC	39.2
O-066	O-066	6.93
RENSSELAER	RENSSELAER	0.58
SANTEETLA	SANTEETLA	0.01
TRIMBLE	TRIMBLE	0.69
WEC	WEC	8.42
Z1-043	Z1-043	29.68

Index 10

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
756517	270771	GREENACRE; T	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	115.61	116.02	DC	13.09

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	8.06
274722	S-055 E	7.52
274751	CRETE EC ;1U	1.93
274752	CRETE EC ;2U	1.93
274753	CRETE EC ;3U	1.93
274754	CRETE EC ;4U	1.93
274832	U4-027	7.11
274859	EASYR;U1 E	7.3
274860	EASYR;U2 E	7.3
274888	PILOT HIL;1E	12.4
274890	CAYUG;1U E	8.92
274891	CAYUG;2U E	8.92
275149	KEMPTON ;1E	12.4
290021	O50 E	12.98
290051	GSG-6; E	6.94
290108	LEEDK;1U E	16.14
293061	N-015 E	10.24
293516	O-009 E1	5.99
293517	O-009 E2	3.04
293518	O-009 E3	3.35
293644	O22 E1	7.24
293645	O22 E2	14.06
293715	O-029 E	6.47
293716	O-029 E	3.55
293717	O-029 E	3.26
294392	P-010 E	13.0
294763	P-046 E	6.23
295109	WESTBROOK E	3.72
295111	SUBLETTE E	1.72
910542	X3-005 E	0.52
914641	Y2-103	30.09
915011	Y3-013 1	2.51
915021	Y3-013 2	2.51
915031	Y3-013 3	2.51
916221	Z1-073 E	3.58
916502	Z1-106 E1	0.84
916504	Z1-106 E2	0.84
916512	Z1-107 E	1.71
916522	Z1-108 E	1.66
918052	AA1-018 E	10.62
919221	AA1-146	11.67

Bus #	Bus	MW Impact
919581	AA2-030	11.67
920272	AA2-123 E	1.63
924471	AB2-096	28.21
925161	AB2-173	2.08
925302	AB2-191 E	0.92
925881	AC1-067 O1	102.57
926311	AC1-109 1	1.27
926321	AC1-109 2	1.27
926331	AC1-110 1	1.27
926341	AC1-110 2	1.27
926351	AC1-111 1	0.51
926361	AC1-111 2	0.51
926371	AC1-111 3	0.51
926381	AC1-111 4	0.51
926391	AC1-111 5	0.51
926401	AC1-111 6	0.51
926431	AC1-114	1.58
926821	AC1-168 C O1	0.76
926822	AC1-168 E O1	5.08
927091	AC1-204 1	48.76
927101	AC1-204 2	48.73
927201	AC1-214 C O1	0.74
927202	AC1-214 E O1	2.34
927451	AC1-142A 1	2.83
927461	AC1-142A 2	2.83
927511	AC1-113 1	0.79
927521	AC1-113 2	0.79
927531	AC1-185 1	0.46
927541	AC1-185 2	0.46
927551	AC1-185 3	0.46
927561	AC1-185 4	0.46
927571	AC1-185 5	0.46
927581	AC1-185 6	0.46
927591	AC1-185 7	0.46
927601	AC1-185 8	0.46
930481	AB1-089	43.76
930501	AB1-091 O1	49.15
930741	AB1-122 1O1	47.58
930751	AB1-122 2O1	49.75
932881	AC2-115 1	1.58
932891	AC2-115 2	1.58
932921	AC2-116	0.55
933341	AC2-147 C	0.58
933342	AC2-147 E	0.94
933411	AC2-154 C	1.68
933412	AC2-154 E	2.75
933431	AC2-156 C O1	0.64
933432	AC2-156 E O1	1.04
933911	AD1-013 C	1.22
933912	AD1-013 E	1.95
933931	AD1-016 C	0.62
933932	AD1-016 E	1.01

Bus #	Bus	MW Impact
934101	AD1-039 1	4.66
934111	AD1-039 2	4.88
934401	AD1-064 C O1	2.13
934402	AD1-064 E O1	9.99
934431	AD1-067 C	0.09
934432	AD1-067 E	0.37
934651	AD1-096 C	0.59
934652	AD1-096 E	0.97
934701	AD1-098 C O1	4.57
934702	AD1-098 E O1	3.34
934721	AD1-100 C	12.94
934722	AD1-100 E	60.39
934871	AD1-116 C	0.62
934872	AD1-116 E	1.01
934881	AD1-117 C	3.57
934882	AD1-117 E	2.38
934971	AD1-129 C	0.6
934972	AD1-129 E	0.4
935001	AD1-133 C O1	13.73
935002	AD1-133 E O1	9.15
936291	AD2-038 C O1	1.54
936292	AD2-038 E O1	10.32
936371	AD2-047 C O1	1.51
936372	AD2-047 E O1	16.21
936461	AD2-060	1.77
936511	AD2-066 C O1	5.56
936512	AD2-066 E O1	3.71
936781	AD2-101 C	3.17
936782	AD2-101 E	14.84
936791	AD2-102 C	8.0
936792	AD2-102 E	7.69
936961	AD2-130	0.38
937001	AD2-134 C	1.82
937002	AD2-134 E	7.5
937031	AD2-137 C O1	2.31
937032	AD2-137 E O1	10.8
937051	AD2-140 C O1	2.32
937052	AD2-140 E O1	10.87
937061	AD2-141 C O1	2.31
937062	AD2-141 E O1	10.88
937071	AD2-142 C O1	4.64
937072	AD2-142 E O1	21.73
937121	AD2-148 C O1	2.36
937122	AD2-148 E O1	11.04
937131	AD2-149 C O1	2.36
937132	AD2-149 E O1	11.04
937141	AD2-150 C O1	2.36
937142	AD2-150 E O1	11.04
937181	AD2-155 C O1	2.36
937182	AD2-155 E O1	11.04
937311	AD2-172 C	1.64
937312	AD2-172 E	2.26

Bus #	Bus	MW Impact
937321	AD2-175 C	10.99
937322	AD2-175 E	7.33
937331	AD2-176 C O1	4.89
937332	AD2-176 E O1	3.26
937401	AD2-194 1	5.24
937411	AD2-194 2	5.24
937531	AD2-214 C	2.92
937532	AD2-214 E	1.37
938012	AE1-002 E O1	4.63
938511	AE1-070 1	6.16
938521	AE1-070 2	5.63
938851	AE1-113 C O1	5.72
938852	AE1-113 E O1	17.99
938861	AE1-114 C O1	2.37
938862	AE1-114 E O1	9.06
939051	AE1-134 1	0.91
939061	AE1-134 2	0.91
939321	AE1-163 C O1	4.03
939322	AE1-163 E O1	24.74
939351	AE1-166 C O2	6.81
939352	AE1-166 E O2	6.28
939401	AE1-172 C O1	4.1
939402	AE1-172 E O1	19.18
939641	AE1-194 C	10.88
939642	AE1-194 E	72.84
939651	AE1-195 C	10.88
939652	AE1-195 E	72.84
939691	AE1-199	1.59
939701	AE1-201 C	1.34
939702	AE1-201 E	0.29
939732	AE1-204 E	0.2
939861	AE1-222 1	52.55
939871	AE1-222 2	54.95
939921	AE1-228 C O1	6.63
939922	AE1-228 E O1	4.42
939961	AE1-233 C O1	1.55
939962	AE1-233 E O1	6.39
940101	AE1-252 C O1	6.69
940102	AE1-252 E O1	4.46
951721	J643	15.51
952581	J740 C	3.4
952582	J740 E	18.42
953871	J847	8.38
AB2-013	AB2-013	10.64
AE1-033	AE1-033	12.03
BLUEG	BLUEG	2.86
CANNELTON	CANNELTON	0.0
CARR	CARR	0.5
CATAWBA	CATAWBA	0.16
CBM-S1	CBM-S1	1.36
CBM-W1	CBM-W1	19.98
CBM-W2	CBM-W2	38.44

Bus #	Bus	MW Impact
CIN	CIN	0.12
DEARBORN	DEARBORN	2.29
G-007	G-007	1.38
HAMLET	HAMLET	0.65
MEC	MEC	25.05
O-066	O-066	4.65
RENSSELAER	RENSSELAER	0.39
SANTEETLA	SANTEETLA	0.0
TRIMBLE	TRIMBLE	0.34
WEC	WEC	5.32
Z1-043	Z1-043	18.82

Index 11

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
291978	270886	ST JOHN ; T	CE	255104	17GREEN_ACRE	NIPS	1	COMED_P4_023-65-BT2-3__	breaker	1091.0	110.89	111.33	DC	13.96

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	9.04
274654	BRAIDWOOD;1U	19.05
274655	BRAIDWOOD;2U	18.24
274661	LASCO STA;2U	17.6
274687	WILL CNTY;4U	8.03
274704	KENDALL ;1C	2.81
274705	KENDALL ;1S	1.88
274706	KENDALL ;2C	2.81
274707	KENDALL ;2S	1.88
274722	S-055 E	8.45
274751	CRETE EC ;1U	3.36
274752	CRETE EC ;2U	3.36
274753	CRETE EC ;3U	3.36
274754	CRETE EC ;4U	3.36
274859	EASYR;U1 E	8.17
274860	EASYR;U2 E	8.17
274861	TOP CROP ;1U	0.33
274862	TOP CROP ;2U	0.63
274888	PILOT HIL;1E	12.81
274890	CAYUG;1U E	9.74
274891	CAYUG;2U E	9.74
275149	KEMPTON ;1E	12.81
290021	O50 E	14.65
290051	GSG-6; E	7.78
290108	LEEDK;1U E	18.09
293061	N-015 E	11.61
293516	O-009 E1	6.69
293517	O-009 E2	3.4
293518	O-009 E3	3.74
293644	O22 E1	8.5
293645	O22 E2	16.51
293715	O-029 E	7.24
293716	O-029 E	3.97
293717	O-029 E	3.65
294392	P-010 E	14.75
294763	P-046 E	6.98
295109	WESTBROOK E	4.16
295111	SUBLETTE E	1.92
914641	Y2-103	33.8
915011	Y3-013 1	2.82

Bus #	Bus	MW Impact
915021	Y3-013 2	2.82
915031	Y3-013 3	2.82
916221	Z1-073 E	4.01
916502	Z1-106 E1	0.94
916504	Z1-106 E2	0.94
916512	Z1-107 E	1.85
916522	Z1-108 E	1.86
918052	AA1-018 E	11.64
919221	AA1-146	13.04
919581	AA2-030	13.04
920272	AA2-123 E	1.83
924471	AB2-096	31.63
925161	AB2-173	2.33
925302	AB2-191 E	1.03
926311	AC1-109 1	1.42
926321	AC1-109 2	1.42
926331	AC1-110 1	1.42
926341	AC1-110 2	1.42
926351	AC1-111 1	0.57
926361	AC1-111 2	0.57
926371	AC1-111 3	0.57
926381	AC1-111 4	0.57
926391	AC1-111 5	0.57
926401	AC1-111 6	0.57
926431	AC1-114	1.77
926821	AC1-168 C O1	0.85
926822	AC1-168 E O1	5.68
927091	AC1-204 1	55.19
927101	AC1-204 2	55.12
927451	AC1-142A 1	3.2
927461	AC1-142A 2	3.2
927511	AC1-113 1	0.89
927521	AC1-113 2	0.89
927531	AC1-185 1	0.51
927541	AC1-185 2	0.51
927551	AC1-185 3	0.51
927561	AC1-185 4	0.51
927571	AC1-185 5	0.51
927581	AC1-185 6	0.51
927591	AC1-185 7	0.51
927601	AC1-185 8	0.51
930481	AB1-089	49.05
930501	AB1-091 O1	50.61
930741	AB1-122 1O1	52.99
930751	AB1-122 2O1	56.33
932881	AC2-115 1	1.77
932891	AC2-115 2	1.77
932921	AC2-116	0.62
933341	AC2-147 C	0.65
933342	AC2-147 E	1.06
933411	AC2-154 C	1.74
933412	AC2-154 E	2.84

Bus #	Bus	MW Impact
933431	AC2-156 C O1	0.71
933432	AC2-156 E O1	1.16
933911	AD1-013 C	1.37
933912	AD1-013 E	2.19
933931	AD1-016 C	0.69
933932	AD1-016 E	1.13
934101	AD1-039 1	5.19
934111	AD1-039 2	5.52
934401	AD1-064 C O1	2.39
934402	AD1-064 E O1	11.2
934431	AD1-067 C	0.1
934432	AD1-067 E	0.41
934651	AD1-096 C	0.66
934652	AD1-096 E	1.08
934701	AD1-098 C O1	5.12
934702	AD1-098 E O1	3.74
934721	AD1-100 C	14.27
934722	AD1-100 E	66.6
934871	AD1-116 C	0.68
934872	AD1-116 E	1.11
934881	AD1-117 C	3.99
934882	AD1-117 E	2.66
934971	AD1-129 C	0.67
934972	AD1-129 E	0.45
935001	AD1-133 C O1	15.16
935002	AD1-133 E O1	10.11
936291	AD2-038 C O1	1.71
936292	AD2-038 E O1	11.45
936371	AD2-047 C O1	1.56
936372	AD2-047 E O1	16.75
936461	AD2-060	1.83
936511	AD2-066 C O1	6.19
936512	AD2-066 E O1	4.13
936781	AD2-101 C	3.09
936782	AD2-101 E	14.46
936791	AD2-102 C	8.96
936792	AD2-102 E	8.61
936961	AD2-130	0.42
937001	AD2-134 C	2.03
937002	AD2-134 E	8.4
937031	AD2-137 C O1	2.44
937032	AD2-137 E O1	11.43
937051	AD2-140 C O1	2.44
937052	AD2-140 E O1	11.42
937061	AD2-141 C O1	2.43
937062	AD2-141 E O1	11.44
937071	AD2-142 C O1	4.88
937072	AD2-142 E O1	22.85
937121	AD2-148 C O1	2.43
937122	AD2-148 E O1	11.37
937131	AD2-149 C O1	2.43
937132	AD2-149 E O1	11.37

Bus #	Bus	MW Impact
937141	AD2-150 C O1	2.43
937142	AD2-150 E O1	11.37
937181	AD2-155 C O1	2.43
937182	AD2-155 E O1	11.37
937311	AD2-172 C	1.83
937312	AD2-172 E	2.53
937321	AD2-175 C	11.32
937322	AD2-175 E	7.55
937331	AD2-176 C O1	5.48
937332	AD2-176 E O1	3.65
937401	AD2-194 1	5.94
937411	AD2-194 2	5.93
937531	AD2-214 C	0.8
937532	AD2-214 E	0.38
938012	AE1-002 E O1	4.9
938511	AE1-070 1	6.97
938521	AE1-070 2	6.37
938851	AE1-113 C O1	6.35
938852	AE1-113 E O1	19.97
938861	AE1-114 C O1	2.65
938862	AE1-114 E O1	10.14
939051	AE1-134 1	1.01
939061	AE1-134 2	1.01
939321	AE1-163 C O1	4.63
939322	AE1-163 E O1	28.43
939351	AE1-166 C O2	7.26
939352	AE1-166 E O2	6.7
939401	AE1-172 C O1	4.47
939402	AE1-172 E O1	20.95
939641	AE1-194 C	18.96
939642	AE1-194 E	126.86
939651	AE1-195 C	18.96
939652	AE1-195 E	126.86
939691	AE1-199	1.78
939701	AE1-201 C	1.5
939702	AE1-201 E	0.33
939732	AE1-204 E	0.22
939861	AE1-222 1	58.52
939871	AE1-222 2	62.2
939921	AE1-228 C O1	7.44
939922	AE1-228 E O1	4.96
939961	AE1-233 C O1	1.73
939962	AE1-233 E O1	7.16
940101	AE1-252 C O1	7.31
940102	AE1-252 E O1	4.87
AB2-013	AB2-013	11.87
AE1-033	AE1-033	13.47
BLUEG	BLUEG	5.05
CALDERWOOD	CALDERWOOD	0.09
CANNELTON	CANNELTON	0.11
CARR	CARR	0.56
CATAWBA	CATAWBA	0.23

Bus #	Bus	MW Impact
CBM-S1	CBM-S1	0.77
CBM-W1	CBM-W1	20.04
CBM-W2	CBM-W2	37.14
CHEOAH	CHEOAH	0.09
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.24
ELMERSMITH	ELMERSMITH	0.14
G-007	G-007	1.57
GIBSON	GIBSON	0.06
HAMLET	HAMLET	0.87
MEC	MEC	27.58
O-066	O-066	5.3
RENSSELAER	RENSSELAER	0.45
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.59
WEC	WEC	5.97
Z1-043	Z1-043	20.98

Index 12

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
291838	270926	WILTON ; B	CE	275232	WILTON ;3M	CE	1	COMED_P4_112-65-BT5-6__	breaker	1379.0	165.76	166.05	DC	24.59

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	14.81
274722	S-055 E	13.75
274772	LINCOLN ;3U	3.36
274773	LINCOLN ;4U	3.36
274774	LINCOLN ;5U	3.36
274775	LINCOLN ;6U	3.36
274776	LINCOLN ;7U	3.36
274777	LINCOLN ;8U	3.36
274859	EASYR;U1 E	13.46
274860	EASYR;U2 E	13.46
274888	PILOT HIL;1E	23.62
274890	CAYUG;1U E	20.25
274891	CAYUG;2U E	20.25
275149	KEMPTON ;1E	23.62
290021	O50 E	23.75
290051	GSG-6; E	12.8
290108	LEEDK;1U E	29.74
293061	N-015 E	19.44
293516	O-009 E1	1.0
293517	O-009 E2	0.51
293518	O-009 E3	0.56
293644	O22 E1	12.55
293645	O22 E2	24.37
293715	O-029 E	11.98
293716	O-029 E	6.57
293717	O-029 E	6.04
294392	P-010 E	24.69
294763	P-046 E	11.48
295109	WESTBROOK E	6.85
295111	SUBLETTE E	3.18
296125	R-030 C3	4.98
296128	R-030 E3	19.93
296271	R-030 C2	4.92
296272	R-030 E2	19.7
296308	R-030 C1	4.92
296309	R-030 E1	19.7
910542	X3-005 E	0.9
914641	Y2-103	55.02
915011	Y3-013 1	4.58
915021	Y3-013 2	4.58
915031	Y3-013 3	4.58

Bus #	Bus	MW Impact
916221	Z1-073 E	6.61
916502	Z1-106 E1	1.55
916504	Z1-106 E2	1.55
916512	Z1-107 E	3.17
916522	Z1-108 E	3.04
917502	Z2-087 E	25.76
918052	AA1-018 E	20.13
919221	AA1-146	21.54
919581	AA2-030	21.54
920272	AA2-123 E	2.99
924041	AB2-047 C O1	4.75
924042	AB2-047 E O1	31.79
924471	AB2-096	51.84
925161	AB2-173	3.84
925302	AB2-191 E	1.7
925881	AC1-067 O1	168.51
926311	AC1-109 1	2.34
926321	AC1-109 2	2.34
926331	AC1-110 1	2.33
926341	AC1-110 2	2.33
926351	AC1-111 1	0.94
926361	AC1-111 2	0.94
926371	AC1-111 3	0.94
926381	AC1-111 4	0.94
926391	AC1-111 5	0.94
926401	AC1-111 6	0.94
926431	AC1-114	2.91
926821	AC1-168 C O1	1.43
926822	AC1-168 E O1	9.59
927091	AC1-204 1	88.93
927101	AC1-204 2	88.93
927451	AC1-142A 1	5.12
927461	AC1-142A 2	5.12
927511	AC1-113 1	1.46
927521	AC1-113 2	1.46
927531	AC1-185 1	0.84
927541	AC1-185 2	0.84
927551	AC1-185 3	0.84
927561	AC1-185 4	0.84
927571	AC1-185 5	0.84
927581	AC1-185 6	0.84
927591	AC1-185 7	0.84
927601	AC1-185 8	0.84
930481	AB1-089	80.5
930501	AB1-091 O1	93.97
930741	AB1-122 1O1	89.35
930751	AB1-122 2O1	90.31
932881	AC2-115 1	2.91
932891	AC2-115 2	2.91
932921	AC2-116	1.02
932931	AC2-117	6.52
933341	AC2-147 C	1.07

Bus #	Bus	MW Impact
933342	AC2-147 E	1.74
933411	AC2-154 C	3.21
933412	AC2-154 E	5.23
933431	AC2-156 C O1	1.17
933432	AC2-156 E O1	1.91
933911	AD1-013 C	2.25
933912	AD1-013 E	3.6
933931	AD1-016 C	1.14
933932	AD1-016 E	1.85
934101	AD1-039 1	8.76
934111	AD1-039 2	8.85
934401	AD1-064 C O1	3.92
934402	AD1-064 E O1	18.37
934431	AD1-067 C	0.16
934432	AD1-067 E	0.68
934651	AD1-096 C	1.09
934652	AD1-096 E	1.78
934701	AD1-098 C O1	8.43
934702	AD1-098 E O1	6.15
934721	AD1-100 C	29.44
934722	AD1-100 E	137.37
934871	AD1-116 C	1.17
934872	AD1-116 E	1.91
934881	AD1-117 C	6.58
934882	AD1-117 E	4.39
934971	AD1-129 C	1.11
934972	AD1-129 E	0.74
935001	AD1-133 C O1	27.42
935002	AD1-133 E O1	18.28
936291	AD2-038 C O1	2.88
936292	AD2-038 E O1	19.29
936371	AD2-047 C O1	2.87
936372	AD2-047 E O1	30.87
936461	AD2-060	3.37
936511	AD2-066 C O1	10.36
936512	AD2-066 E O1	6.91
936781	AD2-101 C	5.83
936782	AD2-101 E	27.31
936791	AD2-102 C	14.71
936792	AD2-102 E	14.14
936961	AD2-130	0.69
937001	AD2-134 C	3.35
937002	AD2-134 E	13.82
937031	AD2-137 C O1	7.17
937032	AD2-137 E O1	33.59
937051	AD2-140 C O1	7.53
937052	AD2-140 E O1	35.28
937061	AD2-141 C O1	7.49
937062	AD2-141 E O1	35.32
937071	AD2-142 C O1	15.07
937072	AD2-142 E O1	70.55
937121	AD2-148 C O1	4.51

Bus #	Bus	MW Impact
937122	AD2-148 E O1	21.13
937131	AD2-149 C O1	4.51
937132	AD2-149 E O1	21.13
937141	AD2-150 C O1	4.51
937142	AD2-150 E O1	21.13
937181	AD2-155 C O1	4.51
937182	AD2-155 E O1	21.13
937311	AD2-172 C	3.01
937312	AD2-172 E	4.16
937321	AD2-175 C	21.03
937322	AD2-175 E	14.02
937331	AD2-176 C O1	8.97
937332	AD2-176 E O1	5.98
937401	AD2-194 1	9.56
937411	AD2-194 2	9.56
938012	AE1-002 E O1	14.4
938511	AE1-070 1	11.24
938521	AE1-070 2	10.28
938851	AE1-113 C O1	10.7
938852	AE1-113 E O1	33.64
938861	AE1-114 C O1	4.37
938862	AE1-114 E O1	16.72
939051	AE1-134 1	1.67
939061	AE1-134 2	1.67
939321	AE1-163 C O1	7.21
939322	AE1-163 E O1	44.26
939351	AE1-166 C O2	12.78
939352	AE1-166 E O2	11.8
939401	AE1-172 C O1	9.52
939402	AE1-172 E O1	44.57
939691	AE1-199	2.93
939701	AE1-201 C	2.45
939702	AE1-201 E	0.54
939732	AE1-204 E	0.36
939741	AE1-205 C O1	12.28
939742	AE1-205 E O1	16.95
939861	AE1-222 1	98.68
939871	AE1-222 2	99.73
939921	AE1-228 C O1	12.2
939922	AE1-228 E O1	8.13
939961	AE1-233 C O1	2.85
939962	AE1-233 E O1	11.77
940101	AE1-252 C O1	15.19
940102	AE1-252 E O1	10.13
AB2-013	AB2-013	19.85
AE1-033	AE1-033	22.1
BLUEG	BLUEG	7.86
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.96
CATAWBA	CATAWBA	0.38
CBM-S1	CBM-S1	1.85

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	37.32
CBM-W2	CBM-W2	71.02
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.9
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.69
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.46
MEC	MEC	46.58
O-066	O-066	9.06
RENSSELAER	RENSSELAER	0.76
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.94
WEC	WEC	9.75
Z1-043	Z1-043	35.51

Index 13

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
291840	270927	WILTON	CE	275233	WILTON	CE	1	COMED_P4_112-65-BT2-3__	breaker	1379.0	163.51	163.94	DC	25.1

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	15.13
274722	S-055 E	14.05
274772	LINCOLN ;3U	3.45
274773	LINCOLN ;4U	3.45
274774	LINCOLN ;5U	3.45
274775	LINCOLN ;6U	3.45
274776	LINCOLN ;7U	3.45
274777	LINCOLN ;8U	3.45
274832	U4-027	6.82
274859	EASYR;U1 E	13.75
274860	EASYR;U2 E	13.75
274888	PILOT HIL;1E	24.11
274890	CAYUG;1U E	20.66
274891	CAYUG;2U E	20.66
275149	KEMPTON ;1E	24.11
290021	O50 E	24.25
290051	GSG-6; E	13.07
290108	LEEDK;1U E	30.37
293061	N-015 E	19.85
293516	O-009 E1	11.37
293517	O-009 E2	5.78
293518	O-009 E3	6.36
293644	O22 E1	12.82
293645	O22 E2	24.89
293715	O-029 E	12.24
293716	O-029 E	6.71
293717	O-029 E	6.17
293771	O-035 E	8.08
294392	P-010 E	25.21
294763	P-046 E	11.72
295109	WESTBROOK E	7.0
295111	SUBLETTE E	3.24
296125	R-030 C3	5.08
296128	R-030 E3	20.34
296271	R-030 C2	5.02
296272	R-030 E2	20.09
296308	R-030 C1	5.02
296309	R-030 E1	20.09
910542	X3-005 E	0.91
914641	Y2-103	56.19
915011	Y3-013 1	4.68

Bus #	Bus	MW Impact
915021	Y3-013 2	4.68
915031	Y3-013 3	4.68
916211	Z1-072 E	6.11
916221	Z1-073 E	6.75
916502	Z1-106 E1	1.58
916504	Z1-106 E2	1.58
916512	Z1-107 E	3.23
916522	Z1-108 E	3.11
917502	Z2-087 E	26.28
918052	AA1-018 E	20.57
919221	AA1-146	22.0
919581	AA2-030	22.0
920272	AA2-123 E	3.06
924041	AB2-047 C O1	4.85
924042	AB2-047 E O1	32.43
924471	AB2-096	52.94
925161	AB2-173	3.92
925302	AB2-191 E	1.73
925881	AC1-067 O1	172.23
926311	AC1-109 1	2.39
926321	AC1-109 2	2.39
926331	AC1-110 1	2.37
926341	AC1-110 2	2.37
926351	AC1-111 1	0.96
926361	AC1-111 2	0.96
926371	AC1-111 3	0.96
926381	AC1-111 4	0.96
926391	AC1-111 5	0.96
926401	AC1-111 6	0.96
926431	AC1-114	2.97
926821	AC1-168 C O1	1.46
926822	AC1-168 E O1	9.79
927091	AC1-204 1	90.83
927101	AC1-204 2	90.83
927201	AC1-214 C O1	2.59
927202	AC1-214 E O1	8.24
927451	AC1-142A 1	5.23
927461	AC1-142A 2	5.23
927511	AC1-113 1	1.49
927521	AC1-113 2	1.49
927531	AC1-185 1	0.86
927541	AC1-185 2	0.86
927551	AC1-185 3	0.86
927561	AC1-185 4	0.86
927571	AC1-185 5	0.86
927581	AC1-185 6	0.86
927591	AC1-185 7	0.86
927601	AC1-185 8	0.86
930481	AB1-089	82.21
930501	AB1-091 O1	95.92
930741	AB1-122 1O1	91.25
930751	AB1-122 2O1	92.24

Bus #	Bus	MW Impact
932881	AC2-115 1	2.97
932891	AC2-115 2	2.97
932921	AC2-116	1.04
932931	AC2-117	6.67
933341	AC2-147 C	1.09
933342	AC2-147 E	1.78
933411	AC2-154 C	3.27
933412	AC2-154 E	5.34
933431	AC2-156 C O1	1.2
933432	AC2-156 E O1	1.95
933911	AD1-013 C	2.3
933912	AD1-013 E	3.68
933931	AD1-016 C	1.16
933932	AD1-016 E	1.89
934101	AD1-039 1	8.94
934111	AD1-039 2	9.04
934401	AD1-064 C O1	4.01
934402	AD1-064 E O1	18.76
934431	AD1-067 C	0.16
934432	AD1-067 E	0.69
934651	AD1-096 C	1.11
934652	AD1-096 E	1.82
934701	AD1-098 C O1	8.6
934702	AD1-098 E O1	6.28
934721	AD1-100 C	30.02
934722	AD1-100 E	140.09
934871	AD1-116 C	1.2
934872	AD1-116 E	1.95
934881	AD1-117 C	6.72
934882	AD1-117 E	4.48
934971	AD1-129 C	1.13
934972	AD1-129 E	0.75
935001	AD1-133 C O1	27.99
935002	AD1-133 E O1	18.66
936291	AD2-038 C O1	2.94
936292	AD2-038 E O1	19.7
936371	AD2-047 C O1	2.93
936372	AD2-047 E O1	31.51
936461	AD2-060	3.44
936511	AD2-066 C O1	10.58
936512	AD2-066 E O1	7.05
936781	AD2-101 C	5.95
936782	AD2-101 E	27.88
936791	AD2-102 C	15.03
936792	AD2-102 E	14.44
936961	AD2-130	0.7
937001	AD2-134 C	3.42
937002	AD2-134 E	14.12
937031	AD2-137 C O1	7.31
937032	AD2-137 E O1	34.21
937051	AD2-140 C O1	7.67
937052	AD2-140 E O1	35.93

Bus #	Bus	MW Impact
937061	AD2-141 C O1	7.63
937062	AD2-141 E O1	35.97
937071	AD2-142 C O1	15.35
937072	AD2-142 E O1	71.86
937121	AD2-148 C O1	4.61
937122	AD2-148 E O1	21.57
937131	AD2-149 C O1	4.61
937132	AD2-149 E O1	21.57
937141	AD2-150 C O1	4.61
937142	AD2-150 E O1	21.57
937181	AD2-155 C O1	4.61
937182	AD2-155 E O1	21.57
937311	AD2-172 C	3.08
937312	AD2-172 E	4.25
937321	AD2-175 C	21.46
937322	AD2-175 E	14.31
937331	AD2-176 C O1	9.17
937332	AD2-176 E O1	6.11
937401	AD2-194 1	9.77
937411	AD2-194 2	9.77
938012	AE1-002 E O1	14.67
938511	AE1-070 1	11.48
938521	AE1-070 2	10.5
938851	AE1-113 C O1	10.93
938852	AE1-113 E O1	34.37
938861	AE1-114 C O1	4.47
938862	AE1-114 E O1	17.07
939051	AE1-134 1	1.71
939061	AE1-134 2	1.71
939321	AE1-163 C O1	7.36
939322	AE1-163 E O1	45.2
939351	AE1-166 C O2	13.05
939352	AE1-166 E O2	12.05
939401	AE1-172 C O1	9.71
939402	AE1-172 E O1	45.45
939691	AE1-199	2.99
939701	AE1-201 C	2.51
939702	AE1-201 E	0.55
939732	AE1-204 E	0.37
939741	AE1-205 C O1	12.53
939742	AE1-205 E O1	17.3
939861	AE1-222 1	100.77
939871	AE1-222 2	101.86
939921	AE1-228 C O1	12.45
939922	AE1-228 E O1	8.3
939961	AE1-233 C O1	2.91
939962	AE1-233 E O1	12.02
940101	AE1-252 C O1	15.49
940102	AE1-252 E O1	10.33
AB2-013	AB2-013	20.27
AE1-033	AE1-033	22.58
BLUEG	BLUEG	8.03

Bus #	Bus	MW Impact
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.98
CATAWBA	CATAWBA	0.39
CBM-S1	CBM-S1	1.88
CBM-W1	CBM-W1	38.11
CBM-W2	CBM-W2	72.48
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.96
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.75
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.49
MEC	MEC	47.56
O-066	O-066	9.26
RENSSELAER	RENSSELAER	0.77
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.96
WEC	WEC	9.96
Z1-043	Z1-043	36.25

Index 14

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
291865	274750	CRETE EC ;BP	CE	255112	17STJOHN	NIPS	1	AEP_P4_#2978_05DUMONT 765_B	breaker	1399.0	123.9	124.45	DC	18.81

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	12.57
274654	BRAIDWOOD;1U	26.97
274655	BRAIDWOOD;2U	25.8
274661	LASCO STA;2U	24.66
274687	WILL CNTY;4U	11.24
274704	KENDALL ;1C	3.96
274705	KENDALL ;1S	2.64
274706	KENDALL ;2C	3.96
274707	KENDALL ;2S	2.64
274722	S-055 E	11.77
274751	CRETE EC ;1U	5.74
274752	CRETE EC ;2U	5.74
274753	CRETE EC ;3U	5.74
274754	CRETE EC ;4U	5.74
274859	EASYR;U1 E	11.37
274860	EASYR;U2 E	11.37
274861	TOP CROP ;1U	0.47
274862	TOP CROP ;2U	0.91
274888	PILOT HIL;1E	16.88
274890	CAYUG;1U E	13.45
274891	CAYUG;2U E	13.45
275149	KEMPTON ;1E	16.88
290021	O50 E	20.54
290051	GSG-6; E	10.8
290108	LEEDK;1U E	25.11
293061	N-015 E	16.24
293516	O-009 E1	9.32
293517	O-009 E2	4.73
293518	O-009 E3	5.21
293644	O22 E1	12.21
293645	O22 E2	23.71
293715	O-029 E	10.07
293716	O-029 E	5.52
293717	O-029 E	5.08
294392	P-010 E	20.62
294763	P-046 E	9.71
295109	WESTBROOK E	5.78
295111	SUBLETTE E	2.68
914641	Y2-103	47.06
915011	Y3-013 1	3.92
915021	Y3-013 2	3.92

Bus #	Bus	MW Impact
915031	Y3-013 3	3.92
916221	Z1-073 E	5.57
916502	Z1-106 E1	1.31
916504	Z1-106 E2	1.31
916512	Z1-107 E	2.52
916522	Z1-108 E	2.59
918052	AA1-018 E	15.99
919221	AA1-146	18.16
919581	AA2-030	18.16
920272	AA2-123 E	2.54
924471	AB2-096	43.99
925161	AB2-173	3.24
925302	AB2-191 E	1.43
926311	AC1-109 1	1.97
926321	AC1-109 2	1.97
926331	AC1-110 1	1.98
926341	AC1-110 2	1.98
926351	AC1-111 1	0.79
926361	AC1-111 2	0.79
926371	AC1-111 3	0.79
926381	AC1-111 4	0.79
926391	AC1-111 5	0.79
926401	AC1-111 6	0.79
926431	AC1-114	2.47
926821	AC1-168 C O1	1.18
926822	AC1-168 E O1	7.92
927091	AC1-204 1	77.42
927101	AC1-204 2	77.29
927451	AC1-142A 1	4.48
927461	AC1-142A 2	4.48
927511	AC1-113 1	1.23
927521	AC1-113 2	1.23
927531	AC1-185 1	0.71
927541	AC1-185 2	0.71
927551	AC1-185 3	0.71
927561	AC1-185 4	0.71
927571	AC1-185 5	0.71
927581	AC1-185 6	0.71
927591	AC1-185 7	0.71
927601	AC1-185 8	0.71
930481	AB1-089	68.22
930501	AB1-091 O1	66.51
930741	AB1-122 1O1	73.76
930751	AB1-122 2O1	78.95
932881	AC2-115 1	2.47
932891	AC2-115 2	2.47
932921	AC2-116	0.86
933341	AC2-147 C	0.9
933342	AC2-147 E	1.47
933411	AC2-154 C	2.29
933412	AC2-154 E	3.74
933431	AC2-156 C O1	0.99

Bus #	Bus	MW Impact
933432	AC2-156 E O1	1.61
933911	AD1-013 C	1.9
933912	AD1-013 E	3.04
933931	AD1-016 C	0.97
933932	AD1-016 E	1.58
934101	AD1-039 1	7.23
934111	AD1-039 2	7.74
934401	AD1-064 C O1	3.33
934402	AD1-064 E O1	15.58
934431	AD1-067 C	0.14
934432	AD1-067 E	0.57
934651	AD1-096 C	0.92
934652	AD1-096 E	1.51
934701	AD1-098 C O1	7.11
934702	AD1-098 E O1	5.19
934721	AD1-100 C	19.71
934722	AD1-100 E	91.99
934871	AD1-116 C	0.93
934872	AD1-116 E	1.52
934881	AD1-117 C	5.55
934882	AD1-117 E	3.7
934971	AD1-129 C	0.94
934972	AD1-129 E	0.63
935001	AD1-133 C O1	21.05
935002	AD1-133 E O1	14.03
936291	AD2-038 C O1	2.37
936292	AD2-038 E O1	15.89
936371	AD2-047 C O1	2.05
936372	AD2-047 E O1	22.06
936461	AD2-060	2.41
936511	AD2-066 C O1	8.6
936512	AD2-066 E O1	5.74
936781	AD2-101 C	3.03
936782	AD2-101 E	14.16
936791	AD2-102 C	12.47
936792	AD2-102 E	11.98
936961	AD2-130	0.59
937001	AD2-134 C	2.82
937002	AD2-134 E	11.67
937031	AD2-137 C O1	3.3
937032	AD2-137 E O1	15.44
937051	AD2-140 C O1	3.28
937052	AD2-140 E O1	15.37
937061	AD2-141 C O1	3.27
937062	AD2-141 E O1	15.39
937071	AD2-142 C O1	6.57
937072	AD2-142 E O1	30.75
937121	AD2-148 C O1	3.19
937122	AD2-148 E O1	14.95
937131	AD2-149 C O1	3.19
937132	AD2-149 E O1	14.95
937141	AD2-150 C O1	3.19

Bus #	Bus	MW Impact
937142	AD2-150 E O1	14.95
937181	AD2-155 C O1	3.19
937182	AD2-155 E O1	14.95
937311	AD2-172 C	2.55
937312	AD2-172 E	3.52
937321	AD2-175 C	14.88
937322	AD2-175 E	9.92
937331	AD2-176 C O1	7.62
937332	AD2-176 E O1	5.08
937401	AD2-194 1	8.33
937411	AD2-194 2	8.31
937531	AD2-214 C	4.54
937532	AD2-214 E	2.14
938012	AE1-002 E O1	6.62
938511	AE1-070 1	9.78
938521	AE1-070 2	8.93
938851	AE1-113 C O1	8.81
938852	AE1-113 E O1	27.71
938861	AE1-114 C O1	3.69
938862	AE1-114 E O1	14.11
939051	AE1-134 1	1.41
939061	AE1-134 2	1.41
939321	AE1-163 C O1	6.57
939322	AE1-163 E O1	40.34
939351	AE1-166 C O2	9.78
939352	AE1-166 E O2	9.03
939401	AE1-172 C O1	6.17
939402	AE1-172 E O1	28.89
939641	AE1-194 C	32.38
939642	AE1-194 E	216.73
939651	AE1-195 C	32.38
939652	AE1-195 E	216.73
939691	AE1-199	2.47
939701	AE1-201 C	2.08
939702	AE1-201 E	0.46
939732	AE1-204 E	0.31
939861	AE1-222 1	81.46
939871	AE1-222 2	87.19
939921	AE1-228 C O1	10.34
939922	AE1-228 E O1	6.9
939961	AE1-233 C O1	2.41
939962	AE1-233 E O1	9.95
940101	AE1-252 C O1	10.09
940102	AE1-252 E O1	6.73
AB2-013	AB2-013	16.6
AE1-033	AE1-033	18.74
BLUEG	BLUEG	6.66
CALDERWOOD	CALDERWOOD	0.12
CANNELTON	CANNELTON	0.14
CARR	CARR	0.8
CATAWBA	CATAWBA	0.32
CBM-S1	CBM-S1	1.14

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	25.55
CBM-W2	CBM-W2	51.99
CHEOAH	CHEOAH	0.12
CHILHOWEE	CHILHOWEE	0.04
DEARBORN	DEARBORN	3.16
ELMERSMITH	ELMERSMITH	0.17
G-007	G-007	2.23
GIBSON	GIBSON	0.08
HAMLET	HAMLET	1.22
MEC	MEC	38.45
O-066	O-066	7.49
RENSSELAER	RENSSELAER	0.63
SANTEETLA	SANTEETLA	0.04
TRIMBLE	TRIMBLE	0.78
WEC	WEC	8.32
Z1-043	Z1-043	29.26

Index 15

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
756386	274804	UNIV PK N;RP	CE	243229	05OLIVE	AEP	1	AEP_P4_#2978_05DUMONT 765_B	breaker	971.0	134.38	134.92	DC	15.88

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	9.79
274722	S-055 E	9.15
274808	UNIV PK N;4U	1.62
274809	UNIV PK N;5U	1.62
274811	UNIV PK N;7U	1.62
274812	UNIV PK N;8U	1.62
274814	UNIV PK N;0U	1.62
274815	UNIV PK N;XU	1.62
274832	U4-027	8.61
274859	EASYR;U1 E	8.84
274860	EASYR;U2 E	8.84
274888	PILOT HIL;1E	14.86
274890	CAYUG;1U E	10.7
274891	CAYUG;2U E	10.7
275149	KEMPTON ;1E	14.86
290021	O50 E	15.62
290051	GSG-6; E	8.43
290108	LEEDK;1U E	19.61
293061	N-015 E	12.6
293516	O-009 E1	7.26
293517	O-009 E2	3.69
293518	O-009 E3	4.06
293644	O22 E1	7.88
293645	O22 E2	15.3
293715	O-029 E	7.84
293716	O-029 E	4.3
293717	O-029 E	3.95
293771	O-035 E	5.09
294392	P-010 E	16.0
294401	BSHIL;1U E	6.8
294410	BSHIL;2U E	6.8
294763	P-046 E	7.56
295109	WESTBROOK E	4.51
295111	SUBLETTE E	2.08
910542	X3-005 E	0.51
914641	Y2-103	36.59
915011	Y3-013 1	3.05
915021	Y3-013 2	3.05
915031	Y3-013 3	3.05
916211	Z1-072 E	3.85

Bus #	Bus	MW Impact
916221	Z1-073 E	4.35
916502	Z1-106 E1	1.02
916504	Z1-106 E2	1.02
916512	Z1-107 E	2.17
916522	Z1-108 E	2.02
918052	AA1-018 E	14.29
919221	AA1-146	14.12
919581	AA2-030	14.12
919621	AA2-039 C	1.66
919622	AA2-039 E	11.1
920272	AA2-123 E	1.98
924471	AB2-096	34.27
925161	AB2-173	2.52
925302	AB2-191 E	1.12
925581	AC1-033 C	1.11
925582	AC1-033 E	7.46
925881	AC1-067 O1	97.44
926311	AC1-109 1	1.55
926321	AC1-109 2	1.55
926331	AC1-110 1	1.54
926341	AC1-110 2	1.54
926351	AC1-111 1	0.62
926361	AC1-111 2	0.62
926371	AC1-111 3	0.62
926381	AC1-111 4	0.62
926391	AC1-111 5	0.62
926401	AC1-111 6	0.62
926431	AC1-114	1.92
926821	AC1-168 C O1	0.92
926822	AC1-168 E O1	6.18
927091	AC1-204 1	59.17
927101	AC1-204 2	59.21
927201	AC1-214 C O1	1.63
927202	AC1-214 E O1	5.19
927451	AC1-142A 1	3.45
927461	AC1-142A 2	3.45
927511	AC1-113 1	0.96
927521	AC1-113 2	0.96
927531	AC1-185 1	0.55
927541	AC1-185 2	0.55
927551	AC1-185 3	0.55
927561	AC1-185 4	0.55
927571	AC1-185 5	0.55
927581	AC1-185 6	0.55
927591	AC1-185 7	0.55
927601	AC1-185 8	0.55
930481	AB1-089	53.11
930501	AB1-091 O1	57.12
930741	AB1-122 1O1	58.21
930751	AB1-122 2O1	59.68
932881	AC2-115 1	1.92
932891	AC2-115 2	1.92

Bus #	Bus	MW Impact
932921	AC2-116	0.67
932931	AC2-117	10.39
933341	AC2-147 C	0.7
933342	AC2-147 E	1.15
933411	AC2-154 C	2.02
933412	AC2-154 E	3.29
933431	AC2-156 C O1	0.77
933432	AC2-156 E O1	1.26
933911	AD1-013 C	1.48
933912	AD1-013 E	2.37
933931	AD1-016 C	0.75
933932	AD1-016 E	1.23
934051	AD1-031 C O1	2.26
934052	AD1-031 E O1	3.69
934101	AD1-039 1	5.7
934111	AD1-039 2	5.85
934401	AD1-064 C O1	2.59
934402	AD1-064 E O1	12.13
934431	AD1-067 C	0.11
934432	AD1-067 E	0.44
934651	AD1-096 C	0.72
934652	AD1-096 E	1.17
934701	AD1-098 C O1	5.55
934702	AD1-098 E O1	4.05
934721	AD1-100 C	15.58
934722	AD1-100 E	72.69
934871	AD1-116 C	0.83
934872	AD1-116 E	1.36
934881	AD1-117 C	4.32
934882	AD1-117 E	2.88
934971	AD1-129 C	0.73
934972	AD1-129 E	0.49
935001	AD1-133 C O1	16.67
935002	AD1-133 E O1	11.11
936291	AD2-038 C O1	1.97
936292	AD2-038 E O1	13.19
936371	AD2-047 C O1	1.8
936372	AD2-047 E O1	19.42
936461	AD2-060	2.12
936511	AD2-066 C O1	6.83
936512	AD2-066 E O1	4.55
936781	AD2-101 C	3.51
936782	AD2-101 E	16.41
936791	AD2-102 C	9.71
936792	AD2-102 E	9.33
936961	AD2-130	0.46
937001	AD2-134 C	2.2
937002	AD2-134 E	9.1
937031	AD2-137 C O1	2.69
937032	AD2-137 E O1	12.6
937051	AD2-140 C O1	2.69
937052	AD2-140 E O1	12.61

Bus #	Bus	MW Impact
937061	AD2-141 C O1	2.68
937062	AD2-141 E O1	12.63
937071	AD2-142 C O1	5.39
937072	AD2-142 E O1	25.22
937121	AD2-148 C O1	2.74
937122	AD2-148 E O1	12.83
937131	AD2-149 C O1	2.74
937132	AD2-149 E O1	12.83
937141	AD2-150 C O1	2.74
937142	AD2-150 E O1	12.83
937181	AD2-155 C O1	2.74
937182	AD2-155 E O1	12.83
937311	AD2-172 C	1.98
937312	AD2-172 E	2.74
937321	AD2-175 C	12.77
937322	AD2-175 E	8.51
937331	AD2-176 C O1	5.94
937332	AD2-176 E O1	3.96
937401	AD2-194 1	6.36
937411	AD2-194 2	6.37
937531	AD2-214 C	3.53
937532	AD2-214 E	1.66
938012	AE1-002 E O1	5.4
938511	AE1-070 1	7.48
938521	AE1-070 2	6.84
938851	AE1-113 C O1	7.32
938852	AE1-113 E O1	23.0
938861	AE1-114 C O1	2.87
938862	AE1-114 E O1	10.98
939051	AE1-134 1	1.1
939061	AE1-134 2	1.1
939321	AE1-163 C O1	4.63
939322	AE1-163 E O1	28.42
939351	AE1-166 C O2	8.26
939352	AE1-166 E O2	7.62
939401	AE1-172 C O1	4.91
939402	AE1-172 E O1	22.97
939631	AE1-193 C O1	5.53
939632	AE1-193 E O1	37.0
939681	AE1-198 C O1	16.41
939682	AE1-198 E O1	13.95
939691	AE1-199	1.93
939701	AE1-201 C	1.62
939702	AE1-201 E	0.36
939732	AE1-204 E	0.24
939861	AE1-222 1	64.28
939871	AE1-222 2	65.91
939921	AE1-228 C O1	8.02
939922	AE1-228 E O1	5.35
939961	AE1-233 C O1	1.88
939962	AE1-233 E O1	7.77
940101	AE1-252 C O1	8.02

Bus #	Bus	MW Impact
940102	AE1-252 E O1	5.35
990901	L-005 E	5.05
AB2-013	AB2-013	12.84
AE1-033	AE1-033	14.59
BLUEG	BLUEG	4.41
CALDERWOOD	CALDERWOOD	0.05
CANNELTON	CANNELTON	0.06
CARR	CARR	0.61
CATAWBA	CATAWBA	0.23
CBM-S1	CBM-S1	1.22
CBM-W1	CBM-W1	21.89
CBM-W2	CBM-W2	43.2
CHEOAH	CHEOAH	0.05
CHILHOWEE	CHILHOWEE	0.01
DEARBORN	DEARBORN	2.62
ELMERSMITH	ELMERSMITH	0.06
G-007	G-007	1.71
GIBSON	GIBSON	0.02
HAMLET	HAMLET	0.88
MEC	MEC	30.08
O-066	O-066	5.77
RENSSELAER	RENSSELAER	0.49
SANTEETLA	SANTEETLA	0.02
TRIMBLE	TRIMBLE	0.52
WEC	WEC	6.46
Z1-043	Z1-043	22.86

Index 16

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
291837	275232	WILTON ;3M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT5-6__	breaker	1379.0	165.76	166.05	DC	24.59

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	14.81
274722	S-055 E	13.75
274772	LINCOLN ;3U	3.36
274773	LINCOLN ;4U	3.36
274774	LINCOLN ;5U	3.36
274775	LINCOLN ;6U	3.36
274776	LINCOLN ;7U	3.36
274777	LINCOLN ;8U	3.36
274859	EASYR;U1 E	13.46
274860	EASYR;U2 E	13.46
274888	PILOT HIL;1E	23.62
274890	CAYUG;1U E	20.25
274891	CAYUG;2U E	20.25
275149	KEMPTON ;1E	23.62
290021	O50 E	23.75
290051	GSG-6; E	12.8
290108	LEEDK;1U E	29.74
293061	N-015 E	19.44
293516	O-009 E1	1.0
293517	O-009 E2	0.51
293518	O-009 E3	0.56
293644	O22 E1	12.55
293645	O22 E2	24.37
293715	O-029 E	11.98
293716	O-029 E	6.57
293717	O-029 E	6.04
294392	P-010 E	24.69
294763	P-046 E	11.48
295109	WESTBROOK E	6.85
295111	SUBLETTE E	3.18
296125	R-030 C3	4.98
296128	R-030 E3	19.93
296271	R-030 C2	4.92
296272	R-030 E2	19.7
296308	R-030 C1	4.92
296309	R-030 E1	19.7
910542	X3-005 E	0.9
914641	Y2-103	55.02
915011	Y3-013 1	4.58
915021	Y3-013 2	4.58
915031	Y3-013 3	4.58

Bus #	Bus	MW Impact
916221	Z1-073 E	6.61
916502	Z1-106 E1	1.55
916504	Z1-106 E2	1.55
916512	Z1-107 E	3.17
916522	Z1-108 E	3.04
917502	Z2-087 E	25.76
918052	AA1-018 E	20.13
919221	AA1-146	21.54
919581	AA2-030	21.54
920272	AA2-123 E	2.99
924041	AB2-047 C O1	4.75
924042	AB2-047 E O1	31.79
924471	AB2-096	51.84
925161	AB2-173	3.84
925302	AB2-191 E	1.7
925881	AC1-067 O1	168.51
926311	AC1-109 1	2.34
926321	AC1-109 2	2.34
926331	AC1-110 1	2.33
926341	AC1-110 2	2.33
926351	AC1-111 1	0.94
926361	AC1-111 2	0.94
926371	AC1-111 3	0.94
926381	AC1-111 4	0.94
926391	AC1-111 5	0.94
926401	AC1-111 6	0.94
926431	AC1-114	2.91
926821	AC1-168 C O1	1.43
926822	AC1-168 E O1	9.59
927091	AC1-204 1	88.93
927101	AC1-204 2	88.93
927451	AC1-142A 1	5.12
927461	AC1-142A 2	5.12
927511	AC1-113 1	1.46
927521	AC1-113 2	1.46
927531	AC1-185 1	0.84
927541	AC1-185 2	0.84
927551	AC1-185 3	0.84
927561	AC1-185 4	0.84
927571	AC1-185 5	0.84
927581	AC1-185 6	0.84
927591	AC1-185 7	0.84
927601	AC1-185 8	0.84
930481	AB1-089	80.5
930501	AB1-091 O1	93.97
930741	AB1-122 1O1	89.35
930751	AB1-122 2O1	90.31
932881	AC2-115 1	2.91
932891	AC2-115 2	2.91
932921	AC2-116	1.02
932931	AC2-117	6.52
933341	AC2-147 C	1.07

Bus #	Bus	MW Impact
933342	AC2-147 E	1.74
933411	AC2-154 C	3.21
933412	AC2-154 E	5.23
933431	AC2-156 C O1	1.17
933432	AC2-156 E O1	1.91
933911	AD1-013 C	2.25
933912	AD1-013 E	3.6
933931	AD1-016 C	1.14
933932	AD1-016 E	1.85
934101	AD1-039 1	8.76
934111	AD1-039 2	8.85
934401	AD1-064 C O1	3.92
934402	AD1-064 E O1	18.37
934431	AD1-067 C	0.16
934432	AD1-067 E	0.68
934651	AD1-096 C	1.09
934652	AD1-096 E	1.78
934701	AD1-098 C O1	8.43
934702	AD1-098 E O1	6.15
934721	AD1-100 C	29.44
934722	AD1-100 E	137.37
934871	AD1-116 C	1.17
934872	AD1-116 E	1.91
934881	AD1-117 C	6.58
934882	AD1-117 E	4.39
934971	AD1-129 C	1.11
934972	AD1-129 E	0.74
935001	AD1-133 C O1	27.42
935002	AD1-133 E O1	18.28
936291	AD2-038 C O1	2.88
936292	AD2-038 E O1	19.29
936371	AD2-047 C O1	2.87
936372	AD2-047 E O1	30.87
936461	AD2-060	3.37
936511	AD2-066 C O1	10.36
936512	AD2-066 E O1	6.91
936781	AD2-101 C	5.83
936782	AD2-101 E	27.31
936791	AD2-102 C	14.71
936792	AD2-102 E	14.14
936961	AD2-130	0.69
937001	AD2-134 C	3.35
937002	AD2-134 E	13.82
937031	AD2-137 C O1	7.17
937032	AD2-137 E O1	33.59
937051	AD2-140 C O1	7.53
937052	AD2-140 E O1	35.28
937061	AD2-141 C O1	7.49
937062	AD2-141 E O1	35.32
937071	AD2-142 C O1	15.07
937072	AD2-142 E O1	70.55
937121	AD2-148 C O1	4.51

Bus #	Bus	MW Impact
937122	AD2-148 E O1	21.13
937131	AD2-149 C O1	4.51
937132	AD2-149 E O1	21.13
937141	AD2-150 C O1	4.51
937142	AD2-150 E O1	21.13
937181	AD2-155 C O1	4.51
937182	AD2-155 E O1	21.13
937311	AD2-172 C	3.01
937312	AD2-172 E	4.16
937321	AD2-175 C	21.03
937322	AD2-175 E	14.02
937331	AD2-176 C O1	8.97
937332	AD2-176 E O1	5.98
937401	AD2-194 1	9.56
937411	AD2-194 2	9.56
938012	AE1-002 E O1	14.4
938511	AE1-070 1	11.24
938521	AE1-070 2	10.28
938851	AE1-113 C O1	10.7
938852	AE1-113 E O1	33.64
938861	AE1-114 C O1	4.37
938862	AE1-114 E O1	16.72
939051	AE1-134 1	1.67
939061	AE1-134 2	1.67
939321	AE1-163 C O1	7.21
939322	AE1-163 E O1	44.26
939351	AE1-166 C O2	12.78
939352	AE1-166 E O2	11.8
939401	AE1-172 C O1	9.52
939402	AE1-172 E O1	44.57
939691	AE1-199	2.93
939701	AE1-201 C	2.45
939702	AE1-201 E	0.54
939732	AE1-204 E	0.36
939741	AE1-205 C O1	12.28
939742	AE1-205 E O1	16.95
939861	AE1-222 1	98.68
939871	AE1-222 2	99.73
939921	AE1-228 C O1	12.2
939922	AE1-228 E O1	8.13
939961	AE1-233 C O1	2.85
939962	AE1-233 E O1	11.77
940101	AE1-252 C O1	15.19
940102	AE1-252 E O1	10.13
AB2-013	AB2-013	19.85
AE1-033	AE1-033	22.1
BLUEG	BLUEG	7.86
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.96
CATAWBA	CATAWBA	0.38
CBM-S1	CBM-S1	1.85

Bus #	Bus	MW Impact
CBM-W1	CBM-W1	37.32
CBM-W2	CBM-W2	71.02
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.9
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.69
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.46
MEC	MEC	46.58
O-066	O-066	9.06
RENSSELAER	RENSSELAER	0.76
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.94
WEC	WEC	9.75
Z1-043	Z1-043	35.51

Index 17

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
291842	275233	WILTON ;4M	CE	270644	WILTON ;	CE	1	COMED_P4_112-65-BT2-3__	breaker	1379.0	163.51	163.94	DC	25.1

Bus #	Bus	MW Impact
270859	PWR VTR EC;R	15.13
274722	S-055 E	14.05
274772	LINCOLN ;3U	3.45
274773	LINCOLN ;4U	3.45
274774	LINCOLN ;5U	3.45
274775	LINCOLN ;6U	3.45
274776	LINCOLN ;7U	3.45
274777	LINCOLN ;8U	3.45
274832	U4-027	6.82
274859	EASYR;U1 E	13.75
274860	EASYR;U2 E	13.75
274888	PILOT HIL;1E	24.11
274890	CAYUG;1U E	20.66
274891	CAYUG;2U E	20.66
275149	KEMPTON ;1E	24.11
290021	O50 E	24.25
290051	GSG-6; E	13.07
290108	LEEDK;1U E	30.37
293061	N-015 E	19.85
293516	O-009 E1	11.37
293517	O-009 E2	5.78
293518	O-009 E3	6.36
293644	O22 E1	12.82
293645	O22 E2	24.89
293715	O-029 E	12.24
293716	O-029 E	6.71
293717	O-029 E	6.17
293771	O-035 E	8.08
294392	P-010 E	25.21
294763	P-046 E	11.72
295109	WESTBROOK E	7.0
295111	SUBLETTE E	3.24
296125	R-030 C3	5.08
296128	R-030 E3	20.34
296271	R-030 C2	5.02
296272	R-030 E2	20.09
296308	R-030 C1	5.02
296309	R-030 E1	20.09
910542	X3-005 E	0.91
914641	Y2-103	56.19
915011	Y3-013 1	4.68

Bus #	Bus	MW Impact
915021	Y3-013 2	4.68
915031	Y3-013 3	4.68
916211	Z1-072 E	6.11
916221	Z1-073 E	6.75
916502	Z1-106 E1	1.58
916504	Z1-106 E2	1.58
916512	Z1-107 E	3.23
916522	Z1-108 E	3.11
917502	Z2-087 E	26.28
918052	AA1-018 E	20.57
919221	AA1-146	22.0
919581	AA2-030	22.0
920272	AA2-123 E	3.06
924041	AB2-047 C O1	4.85
924042	AB2-047 E O1	32.43
924471	AB2-096	52.94
925161	AB2-173	3.92
925302	AB2-191 E	1.73
925881	AC1-067 O1	172.23
926311	AC1-109 1	2.39
926321	AC1-109 2	2.39
926331	AC1-110 1	2.37
926341	AC1-110 2	2.37
926351	AC1-111 1	0.96
926361	AC1-111 2	0.96
926371	AC1-111 3	0.96
926381	AC1-111 4	0.96
926391	AC1-111 5	0.96
926401	AC1-111 6	0.96
926431	AC1-114	2.97
926821	AC1-168 C O1	1.46
926822	AC1-168 E O1	9.79
927091	AC1-204 1	90.83
927101	AC1-204 2	90.83
927201	AC1-214 C O1	2.59
927202	AC1-214 E O1	8.24
927451	AC1-142A 1	5.23
927461	AC1-142A 2	5.23
927511	AC1-113 1	1.49
927521	AC1-113 2	1.49
927531	AC1-185 1	0.86
927541	AC1-185 2	0.86
927551	AC1-185 3	0.86
927561	AC1-185 4	0.86
927571	AC1-185 5	0.86
927581	AC1-185 6	0.86
927591	AC1-185 7	0.86
927601	AC1-185 8	0.86
930481	AB1-089	82.21
930501	AB1-091 O1	95.92
930741	AB1-122 1O1	91.25
930751	AB1-122 2O1	92.24

Bus #	Bus	MW Impact
932881	AC2-115 1	2.97
932891	AC2-115 2	2.97
932921	AC2-116	1.04
932931	AC2-117	6.67
933341	AC2-147 C	1.09
933342	AC2-147 E	1.78
933411	AC2-154 C	3.27
933412	AC2-154 E	5.34
933431	AC2-156 C O1	1.2
933432	AC2-156 E O1	1.95
933911	AD1-013 C	2.3
933912	AD1-013 E	3.68
933931	AD1-016 C	1.16
933932	AD1-016 E	1.89
934101	AD1-039 1	8.94
934111	AD1-039 2	9.04
934401	AD1-064 C O1	4.01
934402	AD1-064 E O1	18.76
934431	AD1-067 C	0.16
934432	AD1-067 E	0.69
934651	AD1-096 C	1.11
934652	AD1-096 E	1.82
934701	AD1-098 C O1	8.6
934702	AD1-098 E O1	6.28
934721	AD1-100 C	30.02
934722	AD1-100 E	140.09
934871	AD1-116 C	1.2
934872	AD1-116 E	1.95
934881	AD1-117 C	6.72
934882	AD1-117 E	4.48
934971	AD1-129 C	1.13
934972	AD1-129 E	0.75
935001	AD1-133 C O1	27.99
935002	AD1-133 E O1	18.66
936291	AD2-038 C O1	2.94
936292	AD2-038 E O1	19.7
936371	AD2-047 C O1	2.93
936372	AD2-047 E O1	31.51
936461	AD2-060	3.44
936511	AD2-066 C O1	10.58
936512	AD2-066 E O1	7.05
936781	AD2-101 C	5.95
936782	AD2-101 E	27.88
936791	AD2-102 C	15.03
936792	AD2-102 E	14.44
936961	AD2-130	0.7
937001	AD2-134 C	3.42
937002	AD2-134 E	14.12
937031	AD2-137 C O1	7.31
937032	AD2-137 E O1	34.21
937051	AD2-140 C O1	7.67
937052	AD2-140 E O1	35.93

Bus #	Bus	MW Impact
937061	AD2-141 C O1	7.63
937062	AD2-141 E O1	35.97
937071	AD2-142 C O1	15.35
937072	AD2-142 E O1	71.86
937121	AD2-148 C O1	4.61
937122	AD2-148 E O1	21.57
937131	AD2-149 C O1	4.61
937132	AD2-149 E O1	21.57
937141	AD2-150 C O1	4.61
937142	AD2-150 E O1	21.57
937181	AD2-155 C O1	4.61
937182	AD2-155 E O1	21.57
937311	AD2-172 C	3.08
937312	AD2-172 E	4.25
937321	AD2-175 C	21.46
937322	AD2-175 E	14.31
937331	AD2-176 C O1	9.17
937332	AD2-176 E O1	6.11
937401	AD2-194 1	9.77
937411	AD2-194 2	9.77
938012	AE1-002 E O1	14.67
938511	AE1-070 1	11.48
938521	AE1-070 2	10.5
938851	AE1-113 C O1	10.93
938852	AE1-113 E O1	34.37
938861	AE1-114 C O1	4.47
938862	AE1-114 E O1	17.07
939051	AE1-134 1	1.71
939061	AE1-134 2	1.71
939321	AE1-163 C O1	7.36
939322	AE1-163 E O1	45.2
939351	AE1-166 C O2	13.05
939352	AE1-166 E O2	12.05
939401	AE1-172 C O1	9.71
939402	AE1-172 E O1	45.45
939691	AE1-199	2.99
939701	AE1-201 C	2.51
939702	AE1-201 E	0.55
939732	AE1-204 E	0.37
939741	AE1-205 C O1	12.53
939742	AE1-205 E O1	17.3
939861	AE1-222 1	100.77
939871	AE1-222 2	101.86
939921	AE1-228 C O1	12.45
939922	AE1-228 E O1	8.3
939961	AE1-233 C O1	2.91
939962	AE1-233 E O1	12.02
940101	AE1-252 C O1	15.49
940102	AE1-252 E O1	10.33
AB2-013	AB2-013	20.27
AE1-033	AE1-033	22.58
BLUEG	BLUEG	8.03

Bus #	Bus	MW Impact
CALDERWOOD	CALDERWOOD	0.1
CANNELTON	CANNELTON	0.09
CARR	CARR	0.98
CATAWBA	CATAWBA	0.39
CBM-S1	CBM-S1	1.88
CBM-W1	CBM-W1	38.11
CBM-W2	CBM-W2	72.48
CHEOAH	CHEOAH	0.1
CHILHOWEE	CHILHOWEE	0.03
DEARBORN	DEARBORN	2.96
ELMERSMITH	ELMERSMITH	0.07
G-007	G-007	2.75
GIBSON	GIBSON	0.0
HAMLET	HAMLET	1.49
MEC	MEC	47.56
O-066	O-066	9.26
RENSSELAER	RENSSELAER	0.77
SANTEETLA	SANTEETLA	0.03
TRIMBLE	TRIMBLE	0.96
WEC	WEC	9.96
Z1-043	Z1-043	36.25

Index 18

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
292087	925880	AC1-067 TAP	CE	270675	BURNHAM ;1R	CE	1	COMED_P4_179-38-TR84____	breaker	1383.0	122.35	123.57	DC	17.01

Bus #	Bus	MW Impact
274881	PLEAS RDG;2U	0.94
274887	PILOT HIL;1U	0.94
274888	PILOT HIL;1E	24.47
275149	KEMPTON ;1E	24.47
925881	AC1-067 O1	814.05
930501	AB1-091 O1	110.7
933411	AC2-154 C	3.32
933412	AC2-154 E	5.42
934721	AD1-100 C	11.23
934722	AD1-100 E	52.4
936371	AD2-047 C O1	2.97
936372	AD2-047 E O1	31.99
936461	AD2-060	3.5
936781	AD2-101 C	7.01
936782	AD2-101 E	32.81
937121	AD2-148 C O1	5.27
937122	AD2-148 E O1	24.67
937131	AD2-149 C O1	5.27
937132	AD2-149 E O1	24.67
937141	AD2-150 C O1	5.27
937142	AD2-150 E O1	24.67
937181	AD2-155 C O1	5.27
937182	AD2-155 E O1	24.67
937321	AD2-175 C	24.55
937322	AD2-175 E	16.37
939351	AE1-166 C O2	8.84
939352	AE1-166 E O2	8.16
BLUEG	BLUEG	1.04
CALDERWOOD	CALDERWOOD	0.03
CANNELTON	CANNELTON	0.02
CARR	CARR	0.13
CATAWBA	CATAWBA	0.06
CBM-S1	CBM-S1	0.13
CBM-W1	CBM-W1	1.15
CBM-W2	CBM-W2	7.9
CHEOAH	CHEOAH	0.03
CHILHOWEE	CHILHOWEE	0.01
DEARBORN	DEARBORN	0.56
ELMERSMITH	ELMERSMITH	0.02
G-007	G-007	0.36

Bus #	Bus	MW Impact
GIBSON	GIBSON	0.01
HAMLET	HAMLET	0.21
MEC	MEC	4.35
O-066	O-066	1.21
RENSSELAER	RENSSELAER	0.1
SANTEETLA	SANTEETLA	0.01
TRIMBLE	TRIMBLE	0.12
WEC	WEC	0.67

Index 19

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
293238	999034	BLOOM 84	CE	271098	BLOOM ; B	CE	1	COMED_P7_345-L17704AR-S_+_345-L17908TB-S-A	tower	530.0	129.98	130.63	DC	7.61

Bus #	Bus	MW Impact
274888	PILOT HIL;1E	11.75
275149	KEMPTON ;1E	11.75
925881	AC1-067 O1	120.33
930501	AB1-091 O1	60.96
933411	AC2-154 C	1.6
933412	AC2-154 E	2.6
936371	AD2-047 C O1	1.43
936372	AD2-047 E O1	15.37
936461	AD2-060	1.68
936781	AD2-101 C	8.76
936782	AD2-101 E	41.01
937121	AD2-148 C O1	2.96
937122	AD2-148 E O1	13.84
937131	AD2-149 C O1	2.96
937132	AD2-149 E O1	13.84
937141	AD2-150 C O1	2.96
937142	AD2-150 E O1	13.84
937181	AD2-155 C O1	2.96
937182	AD2-155 E O1	13.84
937321	AD2-175 C	13.77
937322	AD2-175 E	9.18
939351	AE1-166 C O2	3.95
939352	AE1-166 E O2	3.65
BLUEG	BLUEG	0.12
CARR	CARR	0.03
CATAWBA	CATAWBA	0.01
CBM-S1	CBM-S1	0.17
CBM-W2	CBM-W2	3.63
CIN	CIN	0.12
DEARBORN	DEARBORN	0.17
G-007	G-007	0.08
HAMLET	HAMLET	0.03
IPL	IPL	0.04
MEC	MEC	1.16
O-066	O-066	0.28
RENSSELAER	RENSSELAER	0.02
TRIMBLE	TRIMBLE	0.01
WEC	WEC	0.09

Affected Systems

MISO

MISO Impacts to be determined during later study phases (as applicable).

Contingency Name	Contingency Definition
COMED_P4_111-45-L16704T	CONTINGENCY 'COMED_P4_111-45-L16704T' TRIP BRANCH FROM BUS 270846 TO BUS 270730 CKT 1 / PLANO ; B 345 ELEC JUNC; B 345 TRIP BRANCH FROM BUS 272250 TO BUS 272278 CKT 1 / PLANO ; B 138 PLANO;1I 138 TRIP BRANCH FROM BUS 272250 TO BUS 272278 CKT 2 / PLANO ; B 138 PLANO;1I 138 TRIP BRANCH FROM BUS 270846 TO BUS 272278 TO BUS 275354 CKT 1 / PLANO ; B 345 PLANO;1I 138 PLANO;1C 34.5 TRIP BRANCH FROM BUS 270730 TO BUS 270916 CKT 1 / ELEC JUNC; B 345 WAYNE ; B 345 TRIP BRANCH FROM BUS 270730 TO BUS 270928 CKT 1 / ELEC JUNC; B 345 WOLFS ; B 345 TRIP BRANCH FROM BUS 270928 TO BUS 272794 TO BUS 275334 CKT 1 / WOLFS ; B 345 WOLFS ; B 138 WOLFS ;1C 34.5 DISCONNECT BUS 275239 / ELEC JUNC;2M 138 END
COMED_P4_179-38-TR84__	CONTINGENCY 'COMED_P4_179-38-TR84__' TRIP BRANCH FROM BUS 270662 TO BUS 936780 CKT 1 / BLOOM ; B 345 AD2-101 TAP 345 /* CONTINGENCY LINE ADDED FOR AE1 BUILD TRIP BRANCH FROM BUS 270662 TO BUS 271098 TO BUS 275258 CKT 1 / BLOOM ; B 345 BLOOM ; B 138 BLOOM ;4C 34.5 DISCONNECT BUS 271098 / BLOOM ; B 138 END
COMED_P4_112-65-BT3-4__	CONTINGENCY 'COMED_P4_112-65-BT3-4__' TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33 END
COMED_P4_012-45-BT5-6__	CONTINGENCY 'COMED_P4_012-45-BT5-6__' TRIP BRANCH FROM BUS 270716 TO BUS 270736 CKT 1 / DRESO; B 345 ELWOO; B 345 TRIP BRANCH FROM BUS 270736 TO BUS 270737 CKT 1 / ELWOO; B 345 ELWOO; R 345 TRIP BRANCH FROM BUS 274702 TO BUS 270716 CKT 1 / KEND
COMED_P4_023-65-BT2-3__	CONTINGENCY 'COMED_P4_023-65-BT2-3__' TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 TRIP BRANCH FROM BUS 270607 TO BUS 270630 CKT 1 / COLLI; 765 PLANO; 765 END
COMED_P1-2_345-L1221__B-S	CONTINGENCY 'COMED_P1-2_345-L1221__B-S' TRIP BRANCH FROM BUS 270716 TO BUS 270928 CKT 1 / DRESO; B 345 WOLFS; B 345 END
COMED_P7_345-L94507_B-S_+_345-L97008_R-S	CONTINGENCY 'COMED_P7_345-L94507_B-S_+_345-L97008_R-S' TRIP BRANCH FROM BUS 274750 TO BUS 255112 CKT 1 / CRETE;BP 345 17STJOHN 345 TRIP BRANCH FROM BUS 274804 TO BUS 243229 CKT 1 / UPNOR;RP 345 05OLIVE 345 END
COMED_P7_345-L11620_B-S_+_345-L11622_R-S	CONTINGENCY 'COMED_P7_345-L11620_B-S_+_345-L11622_R-S' TRIP BRANCH FROM BUS 270736 TO BUS 270770 CKT 1 / ELWOO; B 345 GOODI;3B 345 TRIP BRANCH FROM BUS 270737 TO BUS 270769 CKT 1 / ELWOO; R 345 GOODI;1R 345 END
COMED_P4_023-65-BT4-5__	CONTINGENCY 'COMED_P4_023-65-BT4-5__'

	TRIP BRANCH FROM BUS 275168 TO BUS 270607 CKT 1 / COLLI;2M 345 COLLI; 765 TRIP BRANCH FROM BUS 275168 TO BUS 270697 CKT 1 / COLLI;2M 345 COLLI; R 345 TRIP BRANCH FROM BUS 275168 TO BUS 275268 CKT 1 / COLLI;2M 345 COLLI;2C 33 TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 END
COMED_P4_112-65-BT4-5__	CONTINGENCY 'COMED_P4_112-65-BT4-5__' TRIP BRANCH FROM BUS 270644 TO BUS 243206 CKT 1 / WILTO; 765 05DUMONT 765 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33 END
COMED_P7_345-L6607__B-S+_345-L97008_R-S	CONTINGENCY 'COMED_P7_345-L6607__B-S+_345-L97008_R-S' TRIP BRANCH FROM BUS 270728 TO BUS 274750 CKT 1 / E FRANKFO; B 345 CRETE EC ;BP 345 TRIP BRANCH FROM BUS 274804 TO BUS 243229 CKT 1 / UNIV PK N;RP 345 05OLIVE 345 END
COMED_P7_345-L1221__B-S+_345-L1223_TR-S	CONTINGENCY 'COMED_P7_345-L1221__B-S+_345-L1223_TR-S' TRIP BRANCH FROM BUS 270716 TO BUS 270928 CKT 1 / DRES; B 345 WOLFS; B 345 TRIP BRANCH FROM BUS 270717 TO BUS 270731 CKT 1 / DRES; R 345 ELECT;4R 345 TRIP BRANCH FROM BUS 275180 TO BUS 270717 CKT 1 / DRES;3M 138 DRES; R 345 TRIP BRANCH FROM BUS 275180 TO BUS 271336 CKT 1 / DRES;3M 138 DRES; B 138 TRIP BRANCH FROM BUS 275180 TO BUS 275280 CKT 1 / DRES;3M 138 DRES;3C 34.5 END
COMED_P7_345-L17704AR-S+_345-L17908TB-S-A	CONTINGENCY 'COMED_P7_345-L17704AR-S+_345-L17908TB-S-A' TRIP BRANCH FROM BUS 270675 TO BUS 925880 CKT 1 / BURNHAM ;1R 345 AC1-067 TAP 345 TRIP BRANCH FROM BUS 270662 TO BUS 270674 CKT 1 / BLOOM ; B 345 BURNHAM ; B 345 TRIP BRANCH FROM BUS 275163 TO BUS 270674 CKT 1 / BURNHAM ;1M 138 BURNHAM ; B 345 TRIP BRANCH FROM BUS 275163 TO BUS 271122 CKT 1 / BURNHAM ;1M 138 BURNHAM ; B 138 TRIP BRANCH FROM BUS 275163 TO BUS 275263 CKT 1 / BURNHAM ;1M 138 BURNHAM ;1C 36.2 END
COMED_P1-2_345-L17907TB-S-A	CONTINGENCY 'COMED_P1-2_345-L17907TB-S-A' TRIP BRANCH FROM BUS 270662 TO BUS 936780 CKT 1 / BLOOM ; B 345 AD2-101 TAP 345 TRIP BRANCH FROM BUS 270662 TO BUS 271098 TO BUS 275258 CKT 1 / BLOOM ; B 345 BLOOM ; B 138 BLOOM ;4C 34.5 END
Base Case	
COMED_P1-2_765-L11216__S	CONTINGENCY 'COMED_P1-2_765-L11216__S' TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765 END
COMED_P4_111-45-L11126_	CONTINGENCY 'COMED_P4_111-45-L11126_' TRIP BRANCH FROM BUS 270730 TO BUS 270916 CKT 1 / ELEC JUNC; B 345 WAYNE ; B 345 TRIP BRANCH FROM BUS 270916 TO BUS 270917 CKT 1 / WAYNE ; B 345 WAYNE ; R 345 TRIP BRANCH FROM BUS 270730 TO BUS 270846 CKT 1 / ELEC JUNC; B 345 PLANO ; B 345 TRIP BRANCH FROM BUS 270730 TO BUS 270928 CKT 1 / ELEC JUNC; B 345 WOLFS ; B 345 TRIP BRANCH FROM BUS 270928 TO BUS 272794 TO BUS 275334 CKT 1 / WOLFS ; B 345 WOLFS ; B 138 WOLFS ;1C 34.5 DISCONNECT BUS 275239 / ELEC JUNC;2M 138 END

AEP_P1-2_#695A	CONTINGENCY 'AEP_P1-2_#695A' OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1 END
AEP_P4_#8805_05OLIVE 345_D	CONTINGENCY 'AEP_P4_#8805_05OLIVE 345_D' OPEN BRANCH FROM BUS 243229 TO BUS 932600 CKT 1 / 243229 05OLIVE 345 932600 AC2-080 TAP 345 1 /* CONTINGENCY LINE ADDED FOR AE1 BUILD OPEN BRANCH FROM BUS 243229 TO BUS 274804 CKT 1 / 243229 05OLIVE 345 274804 UNIV PK N;RP 345 1 END
COMED_P4_112-65-BT2-3__	CONTINGENCY 'COMED_P4_112-65-BT2-3__' TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765 TRIP BRANCH FROM BUS 275232 TO BUS 270644 CKT 1 / WILTO;3M 345 WILTO; 765 TRIP BRANCH FROM BUS 275232 TO BUS 270926 CKT 1 / WILTO;3M 345 WILTO; B 345 TRIP BRANCH FROM BUS 275232 TO BUS 275332 CKT 1 / WILTO;3M 345 WILTO;3C 33 END
AEP_P4_#2978_05DUMONT 765_B	CONTINGENCY 'AEP_P4_#2978_05DUMONT 765_B' OPEN BRANCH FROM BUS 243206 TO BUS 243207 CKT 1 / 243206 05DUMONT 765 243207 05GRNTWN 765 1 OPEN BRANCH FROM BUS 243206 TO BUS 270644 CKT 1 / 243206 05DUMONT 765 270644 WILTON ; 765 1 END
COMED_P2-2_111_EJ-345B__2	CONTINGENCY 'COMED_P2-2_111_EJ-345B__2' TRIP BRANCH FROM BUS 270730 TO BUS 270846 CKT 1 / ELECT; B 345 PLANO; B 345 TRIP BRANCH FROM BUS 270730 TO BUS 270916 CKT 1 / ELECT; B 345 WAYNE; B 345 TRIP BRANCH FROM BUS 270730 TO BUS 270928 CKT 1 / ELECT; B 345 WOLFS; B 345 TRIP BRANCH FROM BUS 270928 TO BUS 272794 TO BUS 275334 CKT 1 / WOLFS; B 345 WOLFS; B 138 WOLFS;1C 34.5 DISCONNECT BUS 275239 / ELECT;2M 138 END
COMED_P4_112-65-BT5-6__	CONTINGENCY 'COMED_P4_112-65-BT5-6__' TRIP BRANCH FROM BUS 270644 TO BUS 270607 CKT 1 / WILTO; 765 COLLI; 765 TRIP BRANCH FROM BUS 275233 TO BUS 270644 CKT 1 / WILTO;4M 345 WILTO; 765 TRIP BRANCH FROM BUS 275233 TO BUS 270927 CKT 1 / WILTO;4M 345 WILTO; R 345 TRIP BRANCH FROM BUS 275233 TO BUS 275333 CKT 1 / WILTO;4M 345 WILTO;4C 33 END
AEP_P1-2_#697A	CONTINGENCY 'AEP_P1-2_#697A' OPEN BRANCH FROM BUS 243229 TO BUS 274804 CKT 1 / 243229 05OLIVE 345 274804 UNIV PK N;RP 345 1 END

Short Circuit

No issues identified.