



Generation Interconnection

Combined Feasibility / System Impact Study Report

for

Queue Project AE2-055

SHINGLETOWN-BOALSBURG 46 KV

12 MW Capacity / 20 MW Energy

November, 2019

Table of Contents

1	Introduction	4
2	Preface	4
3	General.....	5
3.1	Point of Interconnection	6
3.2	Cost Summary	6
4	Transmission Owner Scope of Work	7
5	Attachment Facilities	8
6	Direct Connection Cost Estimate	9
7	Non-Direct Connection Cost Estimate	10
8	Schedule.....	11
9	Transmission Owner Analysis	12
10	Interconnection Customer Requirements	13
10.1	System Protection	13
10.2	Compliance Issues and Interconnection Customer Requirements.....	13
10.3	Power Factor Requirements	14
11	Revenue Metering and SCADA Requirements	15
11.1	PJM Requirements	15
11.1.1	Meteorological Data Reporting Requirement	15
11.2	FE Requirements	15
12	Network Impacts.....	16
13	Generation Deliverability	18
14	Multiple Facility Contingency.....	18
15	Contribution to Previously Identified Overloads	18
16	Potential Congestion due to Local Energy Deliverability	18
17	Steady State Voltage Requirements	18
18	Stability	18
19	System Reinforcements:	19
20	Light Load Analysis.....	19
21	Affected Systems.....	21
22	Short Circuit	23

Attachment 1 – One Line 24

Attachment 2 – Project Location 25

1 Introduction

This Combined Feasibility/Impact Study report has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between GPPT, LLC, the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is West Penn Power Company (WPP).

2 Preface

The intent of the Combined Feasibility/System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation, if any, is included in the System Impact Study.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

The Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs associated with them will be addressed when seeking an Interconnection Agreement as outlined below. Developer will also be responsible for providing and installing metering equipment in compliance with applicable PJM and Transmission Owner standards.

3 General

The Interconnection Customer (IC) has proposed a Solar generating facility located in Centre County, Harris Township, Pennsylvania. The installed facilities will have a total capability of 20 MW with 12 MW of this output being recognized by PJM as Capacity. The proposed Commercial Operation Date for this project is December 31, 2020.

Queue Number	AE2-055
Project Name	SHINGLETOWN-BOALSBURG 46 KV
Interconnection Customer	GPPT, LLC
State	Pennsylvania
County	Centre
Transmission Owner	West Penn Power
MFO	20
MWE	20
MWC	12
Fuel	Solar
Basecase Study Year	2022

3.1 Point of Interconnection

The interconnection of the project at the Primary POI will be accomplished by tapping the Shingletown-Boalsburg 46 kV line and constructing a one span tap. The transmission line tap will be located approximately 1.5 miles from Shingletown substation. The IC will be responsible for acquiring all easements, properties, and permits that may be required to construct both the new interconnection line tap and the associated attachment facilities.

Attachment 1 shows a one-line diagram of the proposed primary direct connection facilities for the AE2-055 generation project to connect to the FirstEnergy ("FE") transmission system. Attachment 2 provides the proposed location for the point of interconnection. IC will be responsible for constructing all of the facilities on its side of the POI, including the attachment facilities which connect the generator to the FE transmission system's direct connection facilities.

3.2 Cost Summary

The AE2-055 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$ 22,034
Direct Connection Network Upgrade	\$ 44,066
Non Direct Connection Network Upgrades	\$ 0
System Upgrades	\$ 0
Total Costs	\$ 66,100

The costs provided above exclude the Contribution in Aid of Construction ("CIAC") Federal Income Tax Gross Up charge. If, at a future date, it is determined that the CIAC Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

4 Transmission Owner Scope of Work

The interconnection of the project at the Primary POI will be accomplished by tapping the Shingletown-Boalburg 46 kV line and constructing a one span tap. The transmission line tap will be located approximately 1.5 miles from Shingletown substation. The IC will be responsible for acquiring all easements, properties, and permits that may be required to construct both the new interconnection line tap and the associated attachment facilities.

Attachment 1 shows a one-line diagram of the proposed primary direct connection facilities for the AE2-055 generation project to connect to the FirstEnergy (“FE”) transmission system. Attachment 2 provides the proposed location for the point of interconnection. IC will be responsible for constructing all of the facilities on its side of the POI, including the attachment facilities which connect the generator to the FE transmission system’s direct connection facilities.

5 Attachment Facilities

The total preliminary cost estimate for the Attachment Facilities work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Install 46 kV Tap Switch and Provide Revenue Meter Package	\$ 22,034
Total Direct Connection Facility Costs	\$ 22,034

6 Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection Facility work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Tap the Shingletown – Boalsburg 46 kV Line and Install 2-46 kV Line Switches	\$ 44,066
Total Attachment Facility Costs	\$ 44,066

7 Non-Direct Connection Cost Estimate

There is no Non-Direct Connection scope of work required for this interconnection.

8 Schedule

Based on the scope of work for the Attachment Facilities and the Direct and Non-Direct Connection facilities, it is expected to take a minimum of **10 months** after the signing of an Interconnection Construction Service Agreement to complete the installation. This includes the requirement for the IC to make a preliminary payment that compensates FE for the first three months of the engineering design work that is related to the construction of the interconnection substation. This assumes that there will be no environmental issues with any of the new properties associated with this project, that there will be no delays in acquiring the necessary permits for implementing the defined direct connection and network upgrades, and that all transmission system outages will be allowed when requested.

9 Transmission Owner Analysis

FE performed an analysis of its underlying transmission <100 kV system. The AE2-055 project did not contribute to any overloads on the FE transmission <100 kV system.

10 Interconnection Customer Requirements

10.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in FE's "Requirements for Transmission Connected Facilities" document located at:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>

Detailed Protection Requirements will be provided once the project enters the construction phase.

The IC's GSU transformers shall be designed with a delta winding on the high (utility) side. Transformers with other configurations must be studied by FE to determine if they would be acceptable for installation on the FE transmission system. Furthermore, other transformer winding configurations may result in additional upgrades to the transmission system.

10.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with FE's "Requirements for Transmission Connected Facilities" document located at:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated 34.5 kV circuit breaker to protect the AE2-055 generator lead line. A single circuit breaker must be used to protect this line; if the project has several GSU transformers, the individual GSU transformer breakers cannot be used to protect this line.
2. The purchase and installation of the minimum required FE generation interconnection relaying and control facilities. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition ("SCADA") equipment to provide information in a compatible format to the FE Transmission System Control Center.
4. Compliance with the FE and PJM generator power factor and voltage control requirements.
5. The execution of a back-up service agreement to serve the customer load supplied from the AE2-055 generation project metering point when the units are out-of-service. This assumes the intent of the IC is to net the generation with the load.

The IC will also be required to meet all PJM, ReliabilityFirst, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and ReliabilityFirst

audits. Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the FE system.

10.3 Power Factor Requirements

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the FE transmission system.

11 Revenue Metering and SCADA Requirements

11.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

11.1.1 Meteorological Data Reporting Requirement

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Temperature (degrees Fahrenheit)
- Atmospheric pressure (hectopascals)
- Irradiance
- Forced outage data

11.2 FE Requirements

The IC will be required to comply with all FE revenue metering requirements for generation interconnection customers which can be found in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>

12 Network Impacts

The Queue Project AE2-055 was evaluated as a 20 MW (Capacity 12 MW) injection tapping the Boalsburg – Shingletown 46kV in the West Penn Power (APS) area. Project AE2-055 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE2-055 was studied with a commercial probability of 100%. Potential network impacts were as follows:

Summer Peak Load Flow

13 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

14 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

15 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

16 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

17 Steady State Voltage Requirements

None

18 Stability

Not required for this project.

19 System Reinforcements:

None

20 Light Load Analysis

Not required for this project.

Affected Systems

21 Affected Systems

None


Short Circuit

22 Short Circuit

The following Breakers are overduty:

None

Attachment 1 – One Line



—◆— = POI (POINT OF INTERCONNECTION) LOCATED AT GPPT, LLC OWNED DEAD-END STRUCTURE WHERE WEST PENN POWER (WPP) OWNED TRANSMISSION LINE TERMINATES.

M = REVENUE METERING FOR INTERCONNECTION CUSTOMER IS OWNED, OPERATED, AND MAINTAINED BY WEST PENN POWER (WPP)

FirstEnergy Energy Delivery Technical Services		TITLE GPPT, LLC GENERATION SUBSTATION INTERCONNECTION TO THE WPP OWNED SHINGLETOWN-CENTRE HALL 46 kV LINE	
BY: J. L. H. DATE: 09/25/2025	ISSUED: PRELIMINARY	AGREED BY:	POI-WP-AE2-055.dwg REV: -

Attachment 2 – Project Location

