



**Generation Interconnection
Feasibility Study Report
for
Queue Project AE2-227
HARROWGATE 34 KV
12 MW Capacity / 20 MW Energy**

July, 2019

Table of Contents

1	Preface.....	4
2	General.....	5
2.1	Point of Interconnection	6
2.1.1	Primary Point of Interconnection.....	6
2.1.2	Secondary Point of Interconnection.....	6
2.2	Cost Summary.....	6
3	Transmission Owner Scope of Work.....	7
4	Attachment Facilities	8
5	Direct Connection Cost Estimate.....	8
6	Non-Direct Connection Cost Estimate.....	8
7	Schedule.....	8
8	Transmission Owner Analysis.....	9
8.1	Power Flow Analysis	9
8.2	Short Circuit Analysis.....	9
8.3	Stability Analysis.....	9
9	Interconnection Customer Requirements.....	10
9.1	System Protection.....	10
9.2	Compliance Issues and Interconnection Customer Requirements	10
9.3	Power Factor Requirements.....	10
10	Revenue Metering and SCADA Requirements	11
10.1	PJM Requirements	11
10.2	Dominion Requirements.....	11
11	Network Impacts – Primary Point of Interconnection.....	12
11.1	Generation Deliverability	14
11.2	Multiple Facility Contingency	14
11.3	Contribution to Previously Identified Overloads.....	14
11.4	Potential Congestion due to Local Energy Deliverability.....	14
11.5	System Reinforcements.....	15
11.6	Flow Gate Details.....	15
11.7	Affected Systems	17
11.7.1	LG&E	17

11.7.2	MISO.....	17
11.7.3	TVA.....	17
11.7.4	Duke Energy Progress.....	17
11.7.5	NYISO.....	17
11.8	Contingency Descriptions.....	18
11.9	Short Circuit.....	20
12	Network Impacts – Secondary Point of Interconnection	21
12.1	Generation Deliverability	23
12.2	Multiple Facility Contingency	23
12.3	Contribution to Previously Identified Overloads.....	23
12.4	Potential Congestion due to Local Energy Deliverability.....	23
12.5	Flow Gate Details.....	24
12.6	Affected Systems	26
12.6.1	LG&E	26
12.6.2	MISO.....	26
12.6.3	TVA.....	26
12.6.4	Duke Energy Progress.....	26
12.6.5	NYISO.....	26
12.7	Contingency Descriptions.....	27
12.8	Short Circuit.....	29
13	Attachment 1: One Line Diagram.....	30

1 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model. The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

2 General

The Interconnection Customer (IC) has proposed a Solar generating facility located in Chesterfield County, Virginia. The installed facilities will have a total capability of 20 MW with 12 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is 10/31/2022. This study does not imply a Transmission Owner (TO) commitment to this in-service date.

Queue Number	AE2-227
Project Name	HARROWGATE 34 KV
Interconnection Customer	
State	Virginia
County	Chesterfield
Transmission Owner	Dominion
MFO	20
MWE	20
MWC	12
Fuel	Solar
Basecase Study Year	2022

2.1 Point of Interconnection

2.1.1 Primary Point of Interconnection

AE2-227 will interconnect with the Dominion's transmission system at the Harrowgate 34.5kV substation. This is the primary Point of Interconnection (POI) chosen by the IC with the ITO's transmission system. The IC is responsible for securing right-of-way, permits and constructing the proposed attachment line from the solar facility site to the Harrowgate 34.5 kV substation. Attachment 1 shows a one-line diagram of the proposed interconnection facilities. The IC may not install any facilities on Dominion's right-of-way without first obtaining the necessary approval from Dominion Energy.

2.1.2 Secondary Point of Interconnection

The IC requested that a secondary POI "Iron Bridge 230 kV Substation" be reviewed for network impacts (Option 2). This report does not provide costs for the physical interconnection of Option 2. It was just analyzed for network impacts. Results are shown in the "Network Impacts – Secondary Point of Interconnection" section of this report.

2.2 Cost Summary¹

The AE2-227 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$ To be provided in IA
Direct Connection Network Upgrade	\$ To be provided in IA
Non Direct Connection Network Upgrades	\$ To be provided in IA
Total Costs	\$ To be provided in IA

In addition, the AE2-227 project may be responsible for a contribution to the following costs:

Description	Total Cost
System Upgrades	\$0

Cost allocations for these upgrades will be provided in the System Impact Study Report.

¹ Attachment facilities and local upgrades (if required) along with terms and conditions to interconnect AE2-227 will be specified in a separate two party Interconnection Agreement (IA) between ITO and the IC as this project is considered FERC non-jurisdictional per the PJM Open Access Transmission Tariff (OATT).

3 Transmission Owner Scope of Work

Attachment facilities and local upgrades (if required) along with terms and conditions to interconnect AE2-227 will be specified in a separate two party Interconnection Agreement (IA) between ITO and the IC as this project is considered FERC non-jurisdictional per the PJM Open Access Transmission Tariff (OATT). From the transmission system perspective, no network reinforcements are required as shown in the Network Impact Section below. The single line is shown below in Attachment 1.

Dominion assessed the impact of the proposed Queue Project AE2-227 was evaluated as a 12.0 MW Capacity (20.0 MW Energy) injection at the Harrowgate 34.5 kV substation bus in the Dominion Transmission System, for compliance with NERC Reliability Criteria on Dominion Transmission System. The system was assessed using the summer 2022 AE2 case provided to Dominion by PJM. When performing a generation analysis, Dominion's main analysis will be load flow study results under single contingency (both normal and stressed system conditions). Dominion Criteria considers a transmission facility overloaded if it exceeds 94% of its emergency rating under normal and stressed system conditions. A full listing of Dominion's Planning Criteria and interconnection requirements can be found in the Company's Facility Connection Requirements which are publicly available at: <http://www.dominionenergy.com>.

The results of these studies evaluate the system under a limited set of operating conditions and do not guarantee the full delivery of the capacity and associated energy of this proposed generation facility under all operating conditions. NERC Planning and Operating Reliability Criteria allow for the re-dispatch of generating units to resolve projected and actual deficiencies in real time and planning studies. Specifically in Planning Studies NERC Category C Contingency Conditions (Bus Fault, Tower Line, N-1-1, and Stuck Breaker scenarios) allow for re-dispatch of generating units to resolve potential reliability deficiencies. For Dominion Planning Criteria the re-dispatch of generating units for these contingency conditions is allowed as long as the projected loading does not exceed 100% of a facility Load Dump Rating.

The required Attachment Facilities, Direct Connection and Non-Direct Connection work for the interconnection of the AE2-227 generation project to the Dominion Transmission System is detailed in the following sections. The associated one-line with the generation project attachment facilities and primary direct and non-direct connection are shown in Attachment 1.

Note that the ITO findings were made from a conceptual review of this project. A more detailed review of the connection facilities and their cost will be identified in a future study phases. Further note that the cost estimate data contained in this document should be considered high level estimates since it was produced without a detailed engineering review. The applicant will be responsible for the actual cost of construction. ITO herein reserves the right to return to any issues in this document and, upon appropriate justification, request additional monies to complete any reinforcements to the transmission systems.

4 Attachment Facilities

The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

To be provided in IA.

5 Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

To be provided in IA.

6 Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Remote Terminal Work	\$ TBD in Facilities Study Phase
Total Non-Direct Connection Facility Costs	\$ TBD in Facilities Study Phase

Remote Terminal Work: During the Facilities Study, ITO's System Protection Engineering Department will review transmission line protection as well as anti-islanding required to accommodate the new generation and interconnection substation. System Protection Engineering will determine the minimal acceptable protection requirements to reliably interconnect the proposed generating facility with the transmission system. The review is based on maintaining system reliability by reviewing ITO's protection requirements with the known transmission system configuration which includes generating facilities in the area. This review may determine that transmission line protection and communication upgrades are required at remote substations.

7 Schedule

The schedule of work by Dominion to interconnect the IC will be specified in a separate two party Interconnection Agreement (IA) between ITO and the IC as this project is considered FERC non-jurisdictional per the PJM Open Access Transmission Tariff (OATT).

8 Transmission Owner Analysis

8.1 Power Flow Analysis

PJM performed a power flow analysis of the transmission system using a 2022 summer peak load flow model and the results were verified by Dominion. Additionally, Dominion performed an analysis of its transmission system. At the Primary POI, the AE2-227 project contributes to overloads on the Dominion transmission system as shown in the “Network Impact – Primary Point of Interconnection” section of the report. The estimated cost of system reinforcements necessary to mitigate these overloads is also provided.

8.2 Short Circuit Analysis

PJM performed a short circuit analysis and the results were verified by Dominion. The connection of AE2-051 project to the system does not result in any newly overdutied circuit breakers on the Dominion transmission system and does not have a significant fault current contribution to existing overdutied circuit breakers

8.3 Stability Analysis

PJM will complete a dynamic stability analysis, if necessary, as part of the System Impact Study. The results of this analysis will be reviewed by Dominion. Should stability concerns be identified in PJM’s study, Dominion will develop appropriate system reinforcement(s) and included the estimated cost of any reinforcement(s) in Dominion’s System Impact Study report.

9 Interconnection Customer Requirements

9.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in Dominion's "Dominion Energy Electric Transmission Generator Interconnection Requirements" documented in Dominion's Facility Interconnection Requirements "Exhibit C" located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

9.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with Dominion's "Dominion's Facility Interconnection Requirements" document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated protection device (circuit breaker, circuit switcher, fuse) to protect the IC's GSU transformer(s).
2. The purchase and installation of the minimum required Dominion generation interconnection relaying and control facilities as described in the System Protection noted above. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition ("SCADA") equipment to provide information in a compatible format to the Dominion Transmission System Control Center.
4. Compliance with the Dominion and PJM generator power factor and voltage control requirements.

The GSU(s) associated with the IC queue request shall meet the grounding requirements as noted in Dominion's "Dominion's Facility Interconnection Requirements" document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>.

The IC will also be required to meet all PJM, SERC, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and SERC audits. Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the Dominion system.

9.3 Power Factor Requirements

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the Dominion transmission system.

10 Revenue Metering and SCADA Requirements

10.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

10.2 Dominion Requirements

See Section 3.4.6 "Metering and Telecommunications" of Dominion's "Dominion's Facility Interconnection Requirements" document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>.

11 Network Impacts – Primary Point of Interconnection

The Queue Project AE2-227 was evaluated as a 20.0 MW (Capacity 12.0 MW) injection at the Harrowgate 230 kV substation in the Dominion area. Project AE2-227 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE2-227 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Load Flow

11.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

11.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

11.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

11.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
8016826	314314	3LOCKS	DVP	940430	AE2-027 TAP	DVP	1	DVP_P1-2: LN 259	operation	138.18	103.42	103.88	DC	1.4
8016290	940430	AE2-027 TAP	DVP	314298	3HARROWG	DVP	1	DVP_P1-2: LN 259	operation	138.18	146.9	147.36	DC	1.4

11.5 System Reinforcements

None

11.6 Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

None

Affected Systems

11.7 Affected Systems

11.7.1 LG&E

LG&E Impacts to be determined during later study phases (as applicable).

11.7.2 MISO

MISO Impacts to be determined during later study phases (as applicable).

11.7.3 TVA

TVA Impacts to be determined during later study phases (as applicable).

11.7.4 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

11.7.5 NYISO

NYISO Impacts to be determined during later study phases (as applicable).

11.8 Contingency Descriptions

Contingency Name	Contingency Definition
DVP_P1-2: LN 259	CONTINGENCY 'DVP_P1-2: LN 259' OPEN BRANCH FROM BUS 314276 TO BUS 314287 CKT 1 /* 6BASIN 230.00 - 6CHESTF B 230.00 END

Short Circuit

11.9 Short Circuit

The following Breakers are overduty:

None

12 Network Impacts – Secondary Point of Interconnection

The Queue Project AE2-227 was evaluated as a 20.0 MW (Capacity 12.0 MW) injection at the Iron Bridge 230 kV substation in the Dominion area. Project AE2-227 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE2-227 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Load Flow

12.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

12.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

12.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

12.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

12.5 Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Affected Systems

12.6 Affected Systems

12.6.1 LG&E

LG&E Impacts to be determined during later study phases (as applicable).

12.6.2 MISO

MISO Impacts to be determined during later study phases (as applicable).

12.6.3 TVA

TVA Impacts to be determined during later study phases (as applicable).

12.6.4 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

12.6.5 NYISO

NYISO Impacts to be determined during later study phases (as applicable).

12.7 Contingency Descriptions

None

Short Circuit

12.8 Short Circuit

The following Breakers are overduty:

None

13 Attachment 1: One Line Diagram