



**Generation Interconnection
Feasibility Study Report
for
Queue Project AE2-233
CARSON-ROGERS RD 500 KV
67.7 MW Capacity / 94 MW Energy**

July, 2019

Table of Contents

| | | |
|------|---|----|
| 1 | Preface..... | 4 |
| 2 | General..... | 5 |
| 2.1 | Point of Interconnection | 6 |
| 2.2 | Cost Summary..... | 6 |
| 3 | Transmission Owner Scope of Work..... | 7 |
| 4 | Attachment Facilities | 8 |
| 5 | Direct Connection Cost Estimate..... | 9 |
| 6 | Non-Direct Connection Cost Estimate..... | 10 |
| 7 | System Reinforcements Cost Estimate | 10 |
| 8 | Schedule..... | 11 |
| 9 | Transmission Owner Analysis..... | 12 |
| 9.1 | Power Flow Analysis | 12 |
| 9.2 | Short Circuit Analysis..... | 12 |
| 9.3 | Stability Analysis..... | 12 |
| 10 | Interconnection Customer Requirements..... | 13 |
| 10.1 | System Protection..... | 13 |
| 10.2 | Compliance Issues and Interconnection Customer Requirements | 13 |
| 10.3 | Power Factor Requirements..... | 13 |
| 11 | Revenue Metering and SCADA Requirements | 14 |
| 11.1 | PJM Requirements | 14 |
| 11.2 | Dominion Requirements..... | 14 |
| 12 | Network Impacts..... | 15 |
| 13 | Generation Deliverability | 17 |
| 14 | Multiple Facility Contingency | 17 |
| 15 | Contribution to Previously Identified Overloads | 17 |
| 16 | Potential Congestion due to Local Energy Deliverability..... | 17 |
| 17 | System Reinforcements..... | 19 |
| 18 | Flow Gate Details | 20 |
| 18.1 | Index 1 | 21 |
| 18.2 | Index 2 | 22 |
| 18.3 | Index 3 | 24 |

| | | |
|------|--------------------------------------|----|
| 19 | Affected Systems | 30 |
| 19.1 | LG&E..... | 30 |
| 19.2 | MISO | 30 |
| 19.3 | TVA..... | 30 |
| 19.4 | Duke Energy Progress..... | 30 |
| 19.5 | NYISO | 30 |
| 20 | Contingency Descriptions..... | 31 |
| 21 | Short Circuit..... | 34 |
| 22 | Attachment 1: One Line Diagram | 35 |

1 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model. The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

2 General

The Interconnection Customer (IC) has proposed a Solar + Storage generating facility located in Sussex County, Virginia. The installed facilities will have a total capability of 94 MW with 67.7 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is June 1, 2022. This study does not imply a TO commitment to this in-service date.

| | |
|---------------------------------|-------------------------|
| Queue Number | AE2-233 |
| Project Name | CARSON-ROGERS RD 500 KV |
| Interconnection Customer | |
| State | Virginia |
| County | Sussex |
| Transmission Owner | Dominion |
| MFO | 94 |
| MWE | 94 |
| MWC | 67.7 |
| Fuel | Solar; Storage |
| Basecase Study Year | 2022 |

2.1 Point of Interconnection

AE2-233 will interconnect with the Dominion transmission system at the AE2-094 500 kV switching station. The AE2-094 switching station will intersect the Carson to Rogers Road 500 kV line. This is the primary Point of Interconnection (POI) chosen by the IC with the ITO's transmission system. The IC is responsible for securing right-of-way, permits and constructing the proposed attachment line from the solar/storage facility site to the proposed new switching station. Attachment 1 shows a one-line diagram of the proposed interconnection facilities. The IC may not install any facilities on Dominion's right-of-way without first obtaining the necessary approval from Dominion Energy. **Costs provided are contingent on the AE2-094 switching station being built.**¹

2.2 Cost Summary

The AE2-233 project will be responsible for the following costs:

| Description | Total Cost |
|--|-------------------------------------|
| Attachment Facilities | \$2,750,000 |
| Direct Connection Network Upgrade | \$4,200,000 |
| Non Direct Connection Network Upgrades | \$TBD |
| Total Costs | \$6,950,000 + Remote Relay Upgrades |

In addition, the AE2-233 project may be responsible for a contribution to the following costs

| Description | Total Cost |
|-----------------|--------------|
| System Upgrades | \$45,043,000 |

Cost allocations for these upgrades will be provided in the System Impact Study Report.

¹ Note that the AE2-233 project intends to interconnect to the Dominion system through the AE2-094 interconnection switchyard. Should the AE2-094 project drop from the Interconnection Queue, the AE2-233 project will be responsible to assume the Direct Connection and Non-Direction costs identified in the AE2-094 Feasibility Study report for connection to the Dominion system.

3 Transmission Owner Scope of Work

Dominion assessed the impact of the proposed Queue Project AE2-233 was evaluated as a 67.7 MW Capacity (94.0 MW Energy) injection at the AE2-094 500 kV substation in the Dominion Transmission System, for compliance with NERC Reliability Criteria on Dominion Transmission System. The system was assessed using the summer 2022 AE2 case provided to Dominion by PJM. When performing a generation analysis, Dominion's main analysis will be load flow study results under single contingency (both normal and stressed system conditions). Dominion Criteria considers a transmission facility overloaded if it exceeds 94% of its emergency rating under normal and stressed system conditions. A full listing of Dominion's Planning Criteria and interconnection requirements can be found in the Company's Facility Connection Requirements which are publicly available at: <http://www.dominionenergy.com>.

The results of these studies evaluate the system under a limited set of operating conditions and do not guarantee the full delivery of the capacity and associated energy of this proposed generation facility under all operating conditions. NERC Planning and Operating Reliability Criteria allow for the re-dispatch of generating units to resolve projected and actual deficiencies in real time and planning studies. Specifically in Planning Studies NERC Category C Contingency Conditions (Bus Fault, Tower Line, N-1-1, and Stuck Breaker scenarios) allow for re-dispatch of generating units to resolve potential reliability deficiencies. For Dominion Planning Criteria the re-dispatch of generating units for these contingency conditions is allowed as long as the projected loading does not exceed 100% of a facility Load Dump Rating.

The required Attachment Facilities, Direct Connection and Non-Direct Connection work for the interconnection of the AE2-233 generation project to the Dominion Transmission System is detailed in the following sections. The associated one-line with the generation project attachment facilities and primary direct and non-direct connection are shown in Attachment 1.

Note that the ITO findings were made from a conceptual review of this project. A more detailed review of the connection facilities and their cost will be identified in a future study phases. Further note that the cost estimate data contained in this document should be considered high level estimates since it was produced without a detailed engineering review. The applicant will be responsible for the actual cost of construction. ITO herein reserves the right to return to any issues in this document and, upon appropriate justification, request additional monies to complete any reinforcements to the transmission systems.

4 Attachment Facilities

To accommodate the proposed AE2-233 Project, Dominion Energy will install one span of overhead 500 kV line to the point of interconnection (“POI”) including 500 kV interconnection metering. The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

| Description | Total Cost |
|--|---------------------|
| Substation (Metering) | \$ 750,000 |
| Transmission (one span) | \$ 2,000,000 |
| Total Attachment Facility Costs | \$ 2,750,000 |

It is estimated to take 18-24 months to complete this work upon execution of an Interconnection Construction Service Agreement (ICSA). These preliminary cost estimates are based on typical engineering costs. A more detailed engineering cost estimates are normally done when the IC provides an exact site plan location for the generation substation during the Facility Study phase. See Attachment 1.

5 Direct Connection Cost Estimate

To accommodate the proposed AE2-233 Project, Dominion Energy will add an additional 500 kV circuit breaker bay to the AE2-094 Switching Station and re-arrange the existing section of line between Carson and Rogers Rd Substations to allow for the proposed interconnection. The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

| Description | Total Cost |
|---|---------------------|
| One breaker and Associated Equipment | \$ 2,000,000 |
| Transmission (one span) | \$ 2,200,000 |
| Total Direct Connection Facility Costs | \$ 4,200,000 |

It is estimated to take 24-30 months to complete this work upon execution of an Interconnection Construction Service Agreement (ICSA). These preliminary cost estimates are based on typical engineering costs. A more detailed engineering cost estimates are normally done when the IC provides an exact site plan location for the generation substation during the Facility Study phase. See Attachment 1.

6 Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

| Description | Total Cost |
|---|---|
| Remote Terminal Work | \$ TBD in Facilities Study phase |
| Total Non-Direct Connection Facility Costs | \$ TBD in Facilities Study phase |

Remote Terminal Work: During the Facilities Study, ITO's System Protection Engineering Department will review transmission line protection as well as anti-islanding required to accommodate the new generation and interconnection substation. System Protection Engineering will determine the minimal acceptable protection requirements to reliably interconnect the proposed generating facility with the transmission system. The review is based on maintaining system reliability by reviewing ITO's protection requirements with the known transmission system configuration which includes generating facilities in the area. This review may determine that transmission line protection and communication upgrades are required at remote substations.

7 System Reinforcements Cost Estimate

| Upgrade Description | Cost |
|--|---------------------|
| Rebuild 14.53 miles of 500 kV Line 575 from North Anna to Ladysmith with 3-1351.5 113C ACSR. | \$45,043,000 |
| TOTAL COST | \$45,043,000 |

8 Schedule

Elapsed time for Attachment Facility and Direct Connection work is provided in Sections 4 and 5 of the report. The schedule for the required Network Impact Reinforcements will be more clearly identified in future study phases. The estimate elapsed time to complete each of the required reinforcements is identified in the “System Reinforcements” section of the report.

9 Transmission Owner Analysis

9.1 Power Flow Analysis

PJM performed a power flow analysis of the transmission system using a 2022 summer peak load flow model and the results were verified by Dominion. Additionally, Dominion performed an analysis of its transmission system. At the Primary POI, the AE2-233 project contributes to overloads on the Dominion transmission system as shown in the “Network Impact – Option 1” section of the report. The estimated cost of system reinforcements necessary to mitigate these overloads is also provided.

9.2 Short Circuit Analysis

PJM performed a short circuit analysis and the results were verified by Dominion. The connection of AE2-233 project to the system does not result in any newly overdutied circuit breakers on the Dominion transmission system and does not have a significant fault current contribution to existing overdutied circuit breakers

9.3 Stability Analysis

PJM will complete a dynamic stability analysis, if necessary, as part of the System Impact Study. The results of this analysis will be reviewed by Dominion. Should stability concerns be identified in PJM’s study, Dominion will develop appropriate system reinforcement(s) and included the estimated cost of any reinforcement(s) in Dominion’s System Impact Study report.

10 Interconnection Customer Requirements

10.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in Dominion's "Dominion Energy Electric Transmission Generator Interconnection Requirements" documented in Dominion's Facility Interconnection Requirements "Exhibit C" located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

10.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with Dominion's "Dominion's Facility Interconnection Requirements" document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated protection device (circuit breaker, circuit switcher, fuse) to protect the IC's GSU transformer(s).
2. The purchase and installation of the minimum required Dominion generation interconnection relaying and control facilities as described in the System Protection noted above. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition ("SCADA") equipment to provide information in a compatible format to the Dominion Transmission System Control Center.
4. Compliance with the Dominion and PJM generator power factor and voltage control requirements.

The GSU(s) associated with the IC queue request shall meet the grounding requirements as noted in Dominion's "Dominion's Facility Interconnection Requirements" document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>.

The IC will also be required to meet all PJM, SERC, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and SERC audits. Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the Dominion system.

10.3 Power Factor Requirements

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the Dominion transmission system.

11 Revenue Metering and SCADA Requirements

11.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

11.2 Dominion Requirements

See Section 3.4.6 "Metering and Telecommunications" of Dominion's "Dominion's Facility Interconnection Requirements" document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>.

12 Network Impacts

The Queue Project AE2-233 was evaluated as a 94.0 MW (Capacity 67.7 MW) injection at the AE2-094 500 kV switching station which intersects the Carson to Rogers Road 500 kV line in the Dominion area. Project AE2-233 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE2-233 was studied with a commercial probability of 53%. Potential network impacts were as follows:

Summer Peak Load Flow

13 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

| ID | FROM BUS# | FROM BUS | FROM BUS AREA | TO BUS# | TO BUS | TO BUS AREA | CKT ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADING % | POST PROJECT LOADING % | AC DC | MW IMPACT |
|---------|-----------|-------------|---------------|---------|---------|-------------|--------|--------------------|--------|------------|-----------------------|------------------------|-------|-----------|
| 8024918 | 314902 | 8CARSON | DVP | 314282 | 6CARSON | DVP | 1 | DVP_P1-2: LN 563 | single | 903.9 | 91.71 | 92.98 | DC | 11.55 |
| 8025042 | 941030 | AE2-094 TAP | DVP | 314902 | 8CARSON | DVP | 1 | DVP_P1-2: LN 511-A | single | 4070.2 | 96.68 | 97.81 | DC | 45.93 |

14 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

| ID | FROM BUS# | FROM BUS | FROM BUS AREA | TO BUS# | TO BUS | TO BUS AREA | CKT ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADING % | POST PROJECT LOADING % | AC DC | MW IMPACT |
|---------|-----------|----------|---------------|---------|------------|-------------|--------|------------------------|---------|------------|-----------------------|------------------------|-------|-----------|
| 7686403 | 314918 | 8NO ANNA | DVP | 314911 | 8LADYSMITH | DVP | 1 | DVP_P4-2: SPOTS H1T594 | breaker | 3938.0 | 99.5 | 100.0 | DC | 18.82 |

15 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

16 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

| ID | FROM BUS# | FROM BUS | FROM BUS AREA | TO BUS# | TO BUS | TO BUS AREA | CKT ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADING % | POST PROJECT LOADING % | AC DC | MW IMPACT |
|---------|-----------|----------|---------------|---------|----------|-------------|--------|------------------|-----------|------------|-----------------------|------------------------|-------|-----------|
| 8024677 | 314282 | 6CARSON | DVP | 314285 | 6CHRL249 | DVP | 1 | DVP_P1-2: LN 563 | operation | 559.3 | 129.74 | 130.35 | DC | 7.52 |
| 8024758 | 314285 | 6CHRL249 | DVP | 314316 | 6LOCKS | DVP | 1 | DVP_P1-2: LN 563 | operation | 559.3 | 126.08 | 126.68 | DC | 7.52 |

| ID | FROM BUS# | FROM BUS | FROM BUS AREA | TO BUS# | TO BUS | TO BUS AREA | CKT ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADING % | POST PROJECT LOADING % | AC DC | MW IMPACT |
|---------|-----------|-------------|---------------|---------|-------------|-------------|--------|-----------------------|-----------|------------|-----------------------|------------------------|-------|-----------|
| 8024038 | 314287 | 6CHESTF B | DVP | 314276 | 6BASIN | DVP | 1 | DVP_P1-2: LN 563 | operation | 449.32 | 185.32 | 185.92 | DC | 5.98 |
| 8024929 | 314299 | 6HARROWG | DVP | 314263 | 6TYLER1 | DVP | 1 | DVP_P1-2: LN 563 | operation | 441.8 | 111.2 | 111.78 | DC | 5.69 |
| 8024926 | 314331 | 6POE | DVP | 314299 | 6HARROWG | DVP | 1 | DVP_P1-2: LN 563 | operation | 441.8 | 111.22 | 111.81 | DC | 5.69 |
| 8024976 | 314686 | 6CLOVER | DVP | 934610 | AD1-087 TAP | DVP | 1 | DVP_P1-2: LN 570 | operation | 814.98 | 93.78 | 95.09 | DC | 10.66 |
| 8024977 | 314686 | 6CLOVER | DVP | 934610 | AD1-087 TAP | DVP | 1 | DVP_P1-2: LN 6002_FSA | operation | 814.98 | 93.78 | 95.09 | DC | 10.66 |
| 8024563 | 314902 | 8CARSON | DVP | 314914 | 8MDLTHAN | DVP | 1 | DVP_P1-2: LN 557 | operation | 3218.56 | 146.59 | 147.04 | DC | 34.29 |
| 8024917 | 314902 | 8CARSON | DVP | 314282 | 6CARSON | DVP | 1 | DVP_P1-2: LN 563 | operation | 903.9 | 109.99 | 111.77 | DC | 16.03 |
| 8024087 | 314903 | 8CHCKAHM | DVP | 314908 | 8ELMONT | DVP | 1 | DVP_P1-2: LN 563 | operation | 2442.12 | 183.8 | 184.24 | DC | 24.47 |
| 8023926 | 314908 | 8ELMONT | DVP | 314911 | 8LADYSMITH | DVP | 1 | DVP_P1-2: LN 576 | operation | 2442.12 | 216.53 | 217.04 | DC | 27.52 |
| 8024068 | 314914 | 8MDLTHAN | DVP | 314918 | 8NO ANNA | DVP | 1 | DVP_P1-2: LN 574 | operation | 2442.12 | 186.94 | 187.32 | DC | 30.42 |
| 8024075 | 314914 | 8MDLTHAN | DVP | 314918 | 8NO ANNA | DVP | 1 | Base Case | operation | 2442.12 | 133.52 | 134.16 | DC | 25.27 |
| 8025090 | 314936 | 8RAWLINGS | DVP | 942930 | AE2-313 TAP | DVP | 1 | DVP_P1-2: LN 585-A-A | operation | 4070.2 | 105.44 | 106.8 | DC | 55.76 |
| 8024907 | 934610 | AD1-087 TAP | DVP | 314697 | 6SEDGE HILL | DVP | 1 | DVP_P1-2: LN 6002_FSA | operation | 814.98 | 104.04 | 105.36 | DC | 10.66 |
| 8024908 | 934610 | AD1-087 TAP | DVP | 314697 | 6SEDGE HILL | DVP | 1 | DVP_P1-2: LN 570 | operation | 814.98 | 104.04 | 105.36 | DC | 10.66 |
| 8025040 | 941030 | AE2-094 TAP | DVP | 314902 | 8CARSON | DVP | 1 | DVP_P1-2: LN 511-A | operation | 4070.2 | 104.32 | 105.89 | DC | 63.78 |
| 8025019 | 942930 | AE2-313 TAP | DVP | 314902 | 8CARSON | DVP | 1 | DVP_P1-2: LN 585-A-A | operation | 4070.2 | 105.12 | 106.49 | DC | 55.76 |

17 System Reinforcements

| ID | Index | Facility | Upgrade Description | Cost |
|---------|-------|---|--|--------------|
| 8024918 | 1 | 8CARSON 500.0 kV - 6CARSON 230.0 kV Ckt 1 | No Reinforcement Needed. Not a valid violation | \$0 |
| 7686403 | 3 | 8NO ANNA 500.0 kV - 8LADYSMITH 500.0 kV Ckt 1 | dom-044 (117) : Rebuild 14.53 miles of 500 kV Line 575 from North Anna to Ladysmith with 3-1351.5 113C ACSR. Project Type : FAC Cost : \$45,043,000 Time Estimate : 48-60 Months | \$45,043,000 |
| 8025042 | 2 | AE2-094 TAP 500.0 kV - 8CARSON 500.0 kV Ckt 1 | No Reinforcement Needed. Not a valid violation | \$0 |
| | | | TOTAL COST | \$45,043,000 |

18 Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

18.1 Index 1

| ID | FROM BUS# | FROM BUS | FROM BUS AREA | TO BUS# | TO BUS | TO BUS AREA | CKT ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADING % | POST PROJECT LOADING % | AC DC | MW IMPACT |
|---------|-----------|----------|---------------|---------|---------|-------------|--------|------------------|--------|------------|-----------------------|------------------------|-------|-----------|
| 8024918 | 314902 | 8CARSON | DVP | 314282 | 6CARSON | DVP | 1 | DVP_P1-2: LN 563 | single | 903.9 | 91.71 | 92.98 | DC | 11.55 |

| Bus # | Bus | MW Impact |
|------------|--------------|-----------|
| 315102 | 1BRUNSWICKG1 | 5.24 |
| 315103 | 1BRUNSWICKG2 | 5.24 |
| 315104 | 1BRUNSWICKG3 | 5.24 |
| 315105 | 1BRUNSWICKS1 | 10.89 |
| 315153 | 1CLOVER1 | 5.99 |
| 315154 | 1CLOVER2 | 5.91 |
| 916301 | Z1-086 C | 32.26 |
| 938491 | AE1-068 C O1 | 53.23 |
| 938501 | AE1-069 C O1 | 41.34 |
| 939411 | AE1-173 C | 67.3 |
| 940471 | AE2-031 C O1 | 22.51 |
| 940641 | AE2-051 C O1 | 14.9 |
| 941031 | AE2-094 C | 35.34 |
| 942211 | AE2-233 C | 11.55 |
| 942921 | AE2-311 C O1 | 34.88 |
| 942931 | AE2-313 C | 31.57 |
| AA2-074 | AA2-074 | 2.05 |
| CARR | CARR | 0.28 |
| CBM-S1 | CBM-S1 | 5.66 |
| CBM-S2 | CBM-S2 | 6.27 |
| CBM-W1 | CBM-W1 | 5.58 |
| CBM-W2 | CBM-W2 | 36.81 |
| CIN | CIN | 2.54 |
| CPL | CPL | 3.01 |
| IPL | IPL | 1.59 |
| LGEE | LGEE | 0.73 |
| MEC | MEC | 5.66 |
| MECS | MECS | 2.31 |
| RENSSELAER | RENSSELAER | 0.22 |
| WEC | WEC | 0.68 |

18.2 Index 2

| ID | FROM BUS# | FROM BUS | FROM BUS AREA | TO BUS# | TO BUS | TO BUS AREA | CKT ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADING % | POST PROJECT LOADING % | AC DC | MW IMPACT |
|---------|-----------|-------------|---------------|---------|---------|-------------|--------|--------------------|--------|------------|-----------------------|------------------------|-------|-----------|
| 8025042 | 941030 | AE2-094 TAP | DVP | 314902 | 8CARSON | DVP | 1 | DVP_P1-2: LN 511-A | single | 4070.2 | 96.68 | 97.81 | DC | 45.93 |

| Bus # | Bus | MW Impact |
|--------|--------------|-----------|
| 314429 | 3JTRSVLE | 0.27 |
| 315102 | 1BRUNSWICKG1 | 19.58 |
| 315103 | 1BRUNSWICKG2 | 19.58 |
| 315104 | 1BRUNSWICKG3 | 19.58 |
| 315105 | 1BRUNSWICKS1 | 40.68 |
| 315150 | 1BUGGS 1 | 12.24 |
| 315151 | 1BUGGS 2 | 12.24 |
| 315153 | 1CLOVER1 | 22.3 |
| 315154 | 1CLOVER2 | 22.01 |
| 315156 | 1HALLBR1 | 0.94 |
| 315158 | 1KERR 1 | 0.23 |
| 315159 | 1KERR 2 | 0.92 |
| 315160 | 1KERR 3 | 0.91 |
| 315161 | 1KERR 4 | 0.91 |
| 315162 | 1KERR 5 | 0.91 |
| 315163 | 1KERR 6 | 0.91 |
| 315164 | 1KERR 7 | 0.91 |
| 315165 | 1HURT 1 | 5.31 |
| 315166 | 1HURT 2 | 5.31 |
| 315266 | 1PLYWOOD A | 1.38 |
| 916301 | Z1-086 C | 123.02 |
| 924021 | AB2-043 C O1 | 0.36 |
| 924161 | AB2-060 C O1 | 1.04 |
| 924301 | AB2-077 C O1 | 0.23 |
| 924311 | AB2-078 C O1 | 0.23 |
| 924321 | AB2-079 C O1 | 0.23 |
| 925611 | AC1-036 C | 0.11 |
| 925831 | AC1-062 | 0.04 |
| 925991 | AC1-075 C | 7.77 |
| 926021 | AC1-080 C | 2.6 |
| 926051 | AC1-083 C O1 | 4.99 |
| 926271 | AC1-105 C O1 | 8.38 |
| 927251 | AC1-221 C | 3.79 |
| 927261 | AC1-222 C | 5.84 |
| 932761 | AC2-100 C | 8.73 |
| 933941 | AD1-017 C | 1.0 |
| 934311 | AD1-055 C | 4.05 |
| 934341 | AD1-058 C | 9.51 |
| 934611 | AD1-087 C O1 | 17.7 |
| 934621 | AD1-088 C | 24.42 |
| 934991 | AD1-131 C | 3.12 |

| Bus # | Bus | MW Impact |
|------------|--------------|-----------|
| 935171 | AD1-152 C O1 | 17.59 |
| 935221 | AD1-157 C | 0.17 |
| 935231 | AD1-160 C | 1.03 |
| 936161 | AD2-022 C O1 | 12.81 |
| 936171 | AD2-023 C O1 | 7.5 |
| 936261 | AD2-033 C | 12.17 |
| 936331 | AD2-043 C | 7.59 |
| 936361 | AD2-046 C O1 | 7.95 |
| 936391 | AD2-049 C | 1.55 |
| 936481 | AD2-063 C O1 | 14.06 |
| 937481 | AD2-202 C O1 | 4.87 |
| 938371 | AE1-056 C | 6.03 |
| 938491 | AE1-068 C O1 | 206.12 |
| 938501 | AE1-069 C O1 | 157.63 |
| 938941 | AE1-122 O1 | 61.69 |
| 939181 | AE1-148 C O1 | 7.87 |
| 939371 | AE1-168 C | 14.02 |
| 939421 | AE1-174 C | 0.3 |
| 940081 | AE1-250 C | 13.49 |
| 940241 | AE2-006 | 0.45 |
| 940601 | AE2-047 C O1 | 4.07 |
| 940661 | AE2-053 | 2.93 |
| 941031 | AE2-094 C | 140.59 |
| 941431 | AE2-140 C O1 | 16.12 |
| 941791 | AE2-182 C | 4.42 |
| 942211 | AE2-233 C | 45.93 |
| 942451 | AE2-258 | 2.2 |
| 942461 | AE2-259 C O1 | 9.31 |
| 942552 | AE2-270 BAT | 22.28 |
| 942751 | AE2-291 C O1 | 11.05 |
| 942761 | AE2-292 C O1 | 13.76 |
| 942931 | AE2-313 C | 106.54 |
| 943051 | AE2-328 C | 16.12 |
| AA2-074 | AA2-074 | 9.7 |
| CARR | CARR | 1.24 |
| CBM-S1 | CBM-S1 | 26.15 |
| CBM-S2 | CBM-S2 | 29.04 |
| CBM-W1 | CBM-W1 | 26.03 |
| CBM-W2 | CBM-W2 | 170.15 |
| CIN | CIN | 11.81 |
| CPL | CPL | 14.26 |
| IPL | IPL | 7.4 |
| LGEE | LGEE | 3.42 |
| MEC | MEC | 26.27 |
| MECS | MECS | 10.86 |
| RENSSELAER | RENSSELAER | 0.98 |
| WEC | WEC | 3.15 |
| Z1-043 | Z1-043 | 12.41 |

18.3 Index 3

| ID | FROM BUS# | FROM BUS | FROM BUS AREA | TO BUS# | TO BUS | TO BUS AREA | CKT ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADING % | POST PROJECT LOADING % | AC DC | MW IMPACT |
|---------|-----------|----------|---------------|---------|------------|-------------|--------|------------------------|---------|------------|-----------------------|------------------------|-------|-----------|
| 7686403 | 314918 | 8NO ANNA | DVP | 314911 | 8LADYSMITH | DVP | 1 | DVP_P4-2: SPOTS H1T594 | breaker | 3938.0 | 99.5 | 100.0 | DC | 18.82 |

| Bus # | Bus | MW Impact |
|--------|--------------|-----------|
| 314539 | 3UNCAMP | 1.95 |
| 314541 | 3WATKINS | 0.56 |
| 314566 | 3CRESWEL | 1.94 |
| 314572 | 3EMPORIA | 0.35 |
| 314578 | 3HORNRTN | 2.73 |
| 314594 | 6PLYMOTH | 0.69 |
| 314617 | 3TUNIS | 0.68 |
| 314620 | 6CASHIE | 0.68 |
| 314648 | 6SUNBURY | 0.71 |
| 314651 | 6WINFALL | 1.41 |
| 315172 | 1LOISA A | 2.16 |
| 315173 | 1LOISA B | 2.17 |
| 315174 | 1LOISA C | 2.17 |
| 315175 | 1LOISA D | 2.17 |
| 315176 | 1LOISA E | 4.43 |
| 315177 | 1S ANNAG1 | 1.32 |
| 315178 | 1S ANNAS1 | 0.68 |
| 315179 | 1S ANNAG2 | 1.32 |
| 315180 | 1S ANNAS2 | 0.68 |
| 315225 | 1N ANNA1 | 79.64 |
| 315226 | 1N ANNA2 | 79.82 |
| 900672 | V4-068 E | 0.24 |
| 901082 | W1-029 E | 36.91 |
| 907092 | X1-038 E | 4.88 |
| 913392 | Y1-086 E | 1.76 |
| 916042 | Z1-036 E | 36.68 |
| 916192 | Z1-068 E | 1.5 |
| 916302 | Z1-086 E | 9.93 |
| 917122 | Z2-027 E | 0.85 |
| 918492 | AA1-063AE OP | 3.28 |
| 918512 | AA1-065 E OP | 3.59 |
| 919152 | AA1-139 E | 5.15 |
| 919692 | AA2-053 E | 3.08 |
| 920042 | AA2-088 E OP | 8.57 |
| 920672 | AA2-174 E | 0.36 |
| 920692 | AA2-178 E | 3.32 |
| 923801 | AB2-015 C O1 | 6.96 |
| 923802 | AB2-015 E O1 | 5.71 |
| 923832 | AB2-022 E | 1.0 |
| 923852 | AB2-025 E | 0.94 |
| 923862 | AB2-026 E | 1.12 |

| Bus # | Bus | MW Impact |
|--------|--------------|-----------|
| 923911 | AB2-031 C O1 | 1.88 |
| 923912 | AB2-031 E O1 | 0.92 |
| 923992 | AB2-040 E O1 | 5.04 |
| 924022 | AB2-043 E O1 | 4.22 |
| 924032 | AB2-045 E | 0.89 |
| 924162 | AB2-060 E O1 | 3.49 |
| 924302 | AB2-077 E O1 | 1.09 |
| 924312 | AB2-078 E O1 | 1.09 |
| 924322 | AB2-079 E O1 | 1.09 |
| 924501 | AB2-099 C | 0.48 |
| 924502 | AB2-099 E | 0.2 |
| 924511 | AB2-100 C | 9.71 |
| 924512 | AB2-100 E | 4.78 |
| 925021 | AB2-158 C | 3.03 |
| 925022 | AB2-158 E | 11.1 |
| 925061 | AB2-161 C O1 | 2.59 |
| 925062 | AB2-161 E O1 | 4.22 |
| 925171 | AB2-174 C O1 | 5.91 |
| 925172 | AB2-174 E O1 | 5.35 |
| 925522 | AC1-027 E | 0.92 |
| 925612 | AC1-036 E | 0.71 |
| 926071 | AC1-086 C | 17.11 |
| 926072 | AC1-086 E | 7.79 |
| 926662 | AC1-147 E | 1.05 |
| 926731 | AC1-158 C | 239.37 |
| 926732 | AC1-158 E | 105.05 |
| 926751 | AC1-161 C O1 | 24.38 |
| 926752 | AC1-161 E O1 | 10.41 |
| 930862 | AB1-132 E O1 | 4.98 |
| 931232 | AB1-173 E | 0.88 |
| 931242 | AB1-173AE | 0.88 |
| 932041 | AC2-012 C | 8.12 |
| 932042 | AC2-012 E | 13.25 |
| 932512 | AC2-071 E | 0.95 |
| 932591 | AC2-079 C O1 | 4.48 |
| 932592 | AC2-079 E O1 | 7.3 |
| 933291 | AC2-141 C | 24.38 |
| 933292 | AC2-141 E | 10.41 |
| 933501 | AC2-165 C | 9.87 |
| 933502 | AC2-165 E | 7.43 |
| 933732 | AC2-196 E | 0.96 |
| 933991 | AD1-023 C | 10.64 |
| 933992 | AD1-023 E | 5.79 |
| 934061 | AD1-033 C | 6.03 |
| 934062 | AD1-033 E | 4.02 |
| 934201 | AD1-047 C | 6.72 |
| 934202 | AD1-047 E | 4.48 |
| 934521 | AD1-076 C | 44.05 |
| 934522 | AD1-076 E | 22.43 |
| 934571 | AD1-082 C | 5.9 |
| 934572 | AD1-082 E | 3.36 |
| 934611 | AD1-087 C O1 | 7.47 |

| Bus # | Bus | MW Impact |
|--------|--------------|-----------|
| 934612 | AD1-087 E O1 | 3.51 |
| 934621 | AD1-088 C | 12.01 |
| 934622 | AD1-088 E | 5.64 |
| 935112 | AD1-144 E | 0.73 |
| 935171 | AD1-152 C O1 | 7.42 |
| 935172 | AD1-152 E O1 | 4.95 |
| 935212 | AD1-156 E | 1.09 |
| 935222 | AD1-157 E | 0.85 |
| 935231 | AD1-160 C | 0.93 |
| 935232 | AD1-160 E | 1.29 |
| 936261 | AD2-033 C | 10.78 |
| 936262 | AD2-033 E | 7.18 |
| 936401 | AD2-051 C O1 | 7.12 |
| 936402 | AD2-051 E O1 | 3.06 |
| 936481 | AD2-063 C O1 | 12.34 |
| 936482 | AD2-063 E O1 | 8.23 |
| 936661 | AD2-085 C | 2.68 |
| 936662 | AD2-085 E | 4.38 |
| 936711 | AD2-090 C O1 | 5.83 |
| 936712 | AD2-090 E O1 | 3.89 |
| 937221 | AD2-160 C O1 | 4.7 |
| 937222 | AD2-160 E O1 | 2.47 |
| 937481 | AD2-202 C O1 | 2.06 |
| 937482 | AD2-202 E O1 | 1.04 |
| 937541 | AD2-215 C | 1.35 |
| 937542 | AD2-215 E | 0.71 |
| 937571 | AD2-169 C | 8.36 |
| 937572 | AD2-169 E | 5.57 |
| 938171 | AE1-026 C1 O | 22.69 |
| 938172 | AE1-026 C2 O | 3.28 |
| 938173 | AE1-026 E O1 | 6.85 |
| 938181 | AE1-027 C | 1.88 |
| 938182 | AE1-027 E | 0.99 |
| 938191 | AE1-028 C | 1.09 |
| 938192 | AE1-028 E | 0.63 |
| 938221 | AE1-035 C | 1.82 |
| 938222 | AE1-035 E | 0.9 |
| 938371 | AE1-056 C | 5.49 |
| 938372 | AE1-056 E | 3.0 |
| 938491 | AE1-068 C O1 | 63.34 |
| 938492 | AE1-068 E O1 | 34.99 |
| 938501 | AE1-069 C O1 | 49.57 |
| 938502 | AE1-069 E O1 | 28.34 |
| 938531 | AE1-072 C O1 | 14.1 |
| 938532 | AE1-072 E O1 | 7.35 |
| 938551 | AE1-074 C | 2.12 |
| 938552 | AE1-074 E | 1.07 |
| 938561 | AE1-075 C | 2.19 |
| 938562 | AE1-075 E | 1.07 |
| 938771 | AE1-103 C O1 | 2.93 |
| 938772 | AE1-103 E O1 | 4.04 |
| 939071 | AE1-135 C O1 | 17.49 |

| Bus # | Bus | MW Impact |
|--------|--------------|-----------|
| 939072 | AE1-135 E O1 | 11.66 |
| 939231 | AE1-154 C | 4.08 |
| 939232 | AE1-154 E | 2.86 |
| 939371 | AE1-168 C | 12.59 |
| 939372 | AE1-168 E | 8.4 |
| 939411 | AE1-173 C | 87.97 |
| 939412 | AE1-173 E | 58.65 |
| 940061 | AE1-248 C O1 | 12.26 |
| 940062 | AE1-248 E O1 | 8.17 |
| 940241 | AE2-006 | 0.4 |
| 940251 | AE2-007 | 138.19 |
| 940421 | AE2-026 C | 7.75 |
| 940422 | AE2-026 E | 10.53 |
| 940471 | AE2-031 C O1 | 29.9 |
| 940472 | AE2-031 E O1 | 19.93 |
| 940481 | AE2-033 C | 13.45 |
| 940482 | AE2-033 E | 9.07 |
| 940491 | AE2-034 C | 6.79 |
| 940492 | AE2-034 E | 2.91 |
| 940521 | AE2-037 C O1 | 6.54 |
| 940522 | AE2-037 E O1 | 3.16 |
| 940541 | AE2-040 | 2.7 |
| 940641 | AE2-051 C O1 | 17.69 |
| 940642 | AE2-051 E O1 | 11.8 |
| 941031 | AE2-094 C | 41.48 |
| 941032 | AE2-094 E | 18.58 |
| 941101 | AE2-104 C O1 | 2.78 |
| 941102 | AE2-104 E O1 | 4.42 |
| 941281 | AE2-122 C O1 | 22.75 |
| 941282 | AE2-122 E O1 | 91.81 |
| 941291 | AE2-123 C O1 | 23.38 |
| 941292 | AE2-123 E O1 | 91.18 |
| 941301 | AE2-124 C O1 | 21.27 |
| 941302 | AE2-124 E O1 | 93.34 |
| 941501 | AE2-147 C | 12.73 |
| 941502 | AE2-147 E | 8.48 |
| 941541 | AE2-151 C | 0.88 |
| 941542 | AE2-151 E | 0.48 |
| 941591 | AE2-156 | 14.28 |
| 941791 | AE2-182 C | 2.17 |
| 941792 | AE2-182 E | 1.02 |
| 942131 | AE2-225 C | 1.71 |
| 942132 | AE2-225 E | 1.14 |
| 942171 | AE2-229 C | 1.71 |
| 942172 | AE2-229 E | 1.14 |
| 942211 | AE2-233 C | 13.55 |
| 942212 | AE2-233 E | 5.27 |
| 942341 | AE2-247 C | 1.16 |
| 942342 | AE2-247 E | 1.61 |
| 942401 | AE2-253 C | 4.94 |
| 942402 | AE2-253 E | 2.22 |
| 942451 | AE2-258 | 1.92 |

| Bus # | Bus | MW Impact |
|------------|--------------|-----------|
| 942461 | AE2-259 C O1 | 8.6 |
| 942462 | AE2-259 E O1 | 5.73 |
| 942471 | AE2-260 C O1 | 12.05 |
| 942472 | AE2-260 E O1 | 17.1 |
| 942711 | AE2-287 C O1 | 10.92 |
| 942712 | AE2-287 E O1 | 7.28 |
| 942851 | AE2-304 C | 0.51 |
| 942852 | AE2-304 E | 0.2 |
| 942921 | AE2-311 C O1 | 43.87 |
| 942922 | AE2-311 E O1 | 29.25 |
| 942931 | AE2-313 C | 37.44 |
| 942932 | AE2-313 E | 24.96 |
| 943051 | AE2-328 C | 10.38 |
| 943052 | AE2-328 E | 4.86 |
| 943171 | AE2-346 C | 1.43 |
| 943172 | AE2-346 E | 0.61 |
| AA2-074 | AA2-074 | 4.87 |
| CARR | CARR | 1.55 |
| CBM-S1 | CBM-S1 | 11.53 |
| CBM-S2 | CBM-S2 | 14.0 |
| CBM-W1 | CBM-W1 | 9.1 |
| CBM-W2 | CBM-W2 | 72.39 |
| CIN | CIN | 4.42 |
| CPL | CPL | 7.15 |
| G-007 | G-007 | 5.04 |
| IPL | IPL | 2.74 |
| LGEE | LGEE | 1.31 |
| MEC | MEC | 10.38 |
| MECS | MECS | 2.63 |
| O-066 | O-066 | 32.1 |
| RENSSELAER | RENSSELAER | 1.23 |
| WEC | WEC | 1.15 |

Affected Systems

19 Affected Systems

19.1 LG&E

LG&E Impacts to be determined during later study phases (as applicable).

19.2 MISO

MISO Impacts to be determined during later study phases (as applicable).

19.3 TVA

TVA Impacts to be determined during later study phases (as applicable).

19.4 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

19.5 NYISO

NYISO Impacts to be determined during later study phases (as applicable).

20 Contingency Descriptions

| Contingency Name | Contingency Definition |
|-----------------------|---|
| DVP_P1-2: LN 585-A-A | CONTINGENCY 'DVP_P1-2: LN 585-A-A' OPEN BRANCH FROM BUS 314902 TO BUS 941030 CKT 1 /* 8CARSON 500.00 - AE2-094 TAP 500.00 END |
| DVP_P1-2: LN 557 | CONTINGENCY 'DVP_P1-2: LN 557' OPEN BRANCH FROM BUS 314214 TO BUS 314903 CKT 1 /* 6CHCKAHM 230.00 - 8CHCKAHM 500.00 OPEN BRANCH FROM BUS 314903 TO BUS 314908 CKT 1 /* 8CHCKAHM 500.00 - 8ELMONT 500.00 END |
| DVP_P1-2: LN 563 | CONTINGENCY 'DVP_P1-2: LN 563' OPEN BRANCH FROM BUS 314902 TO BUS 314914 CKT 1 /* 8CARSON 500.00 - 8MDLTHAN 500.00 END |
| DVP_P1-2: LN 570 | CONTINGENCY 'DVP_P1-2: LN 570' OPEN BRANCH FROM BUS 304183 TO BUS 918500 CKT 1 /* 8WAKE 500 TT500.00 - AA1-064 TAP 500.00 OPEN BRANCH FROM BUS 314935 TO BUS 918500 CKT 1 /* 8HERITAGE 500.00 - AA1-064 TAP 500.00 OPEN BUS 918500 /* ISLAND: AA1-064 TAP 500.00 END |
| DVP_P1-2: LN 574 | CONTINGENCY 'DVP_P1-2: LN 574' OPEN BRANCH FROM BUS 314908 TO BUS 314911 CKT 1 /* 8ELMONT 500.00 - 8LADYSMITH 500.00 END |
| DVP_P1-2: LN 576 | CONTINGENCY 'DVP_P1-2: LN 576' OPEN BRANCH FROM BUS 314914 TO BUS 314918 CKT 1 /* 8MDLTHAN 500.00 - 8NO ANNA 500.00 END |
| DVP_P1-2: LN 6002_FSA | CONTINGENCY 'DVP_P1-2: LN 6002_FSA' OPEN BRANCH FROM BUS 314935 TO BUS 918500 CKT 1 /* 8HERITAGE 500.00 - AA1-064 TAP 500.00 END |
| DVP_P1-2: LN 511-A | CONTINGENCY 'DVP_P1-2: LN 511-A' OPEN BRANCH FROM BUS 314902 TO BUS 942930 CKT 1 /* 8CARSON 500.00 - AE2-313 TAP 500.00 END |
| Base Case | |

| Contingency Name | Contingency Definition |
|------------------------|---|
| DVP_P4-2: SPOTS H1T594 | CONTINGENCY 'DVP_P4-2: SPOTS H1T594' /* SPOTSYLVANIA 500 KV OPEN BRANCH FROM BUS 314916 TO BUS 314934 CKT 1 /* 8MORRSVL 500.00 - 8SPOTSYL 500.00 OPEN BRANCH FROM BUS 314755 TO BUS 314934 CKT 1 /* 3SPOTSYL 115.00 - 8SPOTSYL 500.00 END |

Short Circuit

21 Short Circuit

The following Breakers are overduty:

None

22 Attachment 1: One Line Diagram