



**Generation Interconnection
Feasibility Study Report
for
Queue Project AE2-297
MADISON-TANNERS CREEK 138 KV
91.5 MW Capacity / 152.5 MW Energy**

December, 2019

Table of Contents

1	Preface.....	4
2	General.....	6
2.1	Point of Interconnection	7
2.2	Cost Summary.....	7
3	Transmission Owner Scope of Work.....	8
4	Attachment Facilities	8
5	Direct Connection Cost Estimate.....	8
6	Non-Direct Connection Cost Estimate.....	8
7	Incremental Capacity Transfer Rights (ICTRs)	9
8	Schedule.....	9
9	Interconnection Customer Requirements.....	9
10	Revenue Metering and SCADA Requirements	9
10.1	PJM Requirements	9
10.2	AEP Requirements.....	10
11	Network Impacts.....	11
12	Generation Deliverability	13
13	Multiple Facility Contingency	13
14	Contribution to Previously Identified Overloads	13
15	Potential Congestion due to Local Energy Deliverability.....	13
16	System Reinforcements.....	15
17	Flow Gate Details	16
17.1	Index 1	17
17.2	Index 2	18
17.3	Index 3	19
17.4	Index 4	21
17.5	Index 5	23
18	Affected Systems	25
18.1	LG&E.....	25
18.2	MISO	25
18.3	TVA.....	25
18.4	Duke Energy Progress.....	25

18.5	NYISO	25
19	Contingency Descriptions:	26
20	Short Circuit.....	29
21	Network Impacts – Secondary POI	31
22	Generation Deliverability	33
23	Multiple Facility Contingency	33
24	Contribution to Previously Identified Overloads	33
25	Potential Congestion due to Local Energy Deliverability.....	33
26	Flow Gate Details	35
26.1	Index 1	36
26.2	Index 2	37
26.3	Index 3	38
26.4	Index 4	39
26.5	Index 5	41
26.6	Index 6	43
27	Affected Systems	45
27.1	LG&E.....	45
27.2	MISO	45
27.3	TVA.....	45
27.4	Duke Energy Progress.....	45
27.5	NYISO	45
28	Contingency Descriptions.....	46
29	Short Circuit.....	49

1 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model. The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

2 General

The Interconnection Customer (IC), has proposed a Solar generating facility located in Henry County, Indiana. The installed facilities will have a total capability of 152.5 MW with 91.5 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is 12.31.2021. This study does not imply a TO commitment to this in-service date.

Queue Number	AE2-297
Project Name	MADISON-TANNERS CREEK 138 KV
State	Indiana
County	Henry
Transmission Owner	AEP
MFO	152.5
MWE	152.5
MWC	91.5
Fuel	Solar
Basecase Study Year	2022

2.1 Point of Interconnection

AE2-297 will interconnect with the AEP transmission system as a tap of the Madison to Tanners Creek 138 kV line.

To accommodate the interconnection on the Madison to Tanners Creek 138 kV Circuit, a new three (3) circuit breaker 138kV switching station physically configured in a breaker and half bus arrangement but operated as a ring-bus will be constructed (see Figure 1). Installation of associated protection and control equipment, 138 kV line risers, SCADA, and 138 kV revenue metering will also be required. AEP reserves the right to specify the final acceptable configuration considering design practices, future expansion, and compliance requirements.

2.2 Cost Summary

This project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$ 250,000
Direct Connection Network Upgrade	\$ 7,000,000
Non Direct Connection Network Upgrades	\$ 500,000
Total Costs	\$ 7,750,000

In addition, this project may be responsible for a contribution to the following costs

Description	Total Cost
System Upgrades	\$125,000 + TBD

Cost allocations for these upgrades will be provided in the System Impact Study Report.

3 Transmission Owner Scope of Work

4 Attachment Facilities

The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
138kV Revenue Metering	\$ 250,000
Total Attachment Facility Costs	\$250,000

5 Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Construct a new three (3) circuit breaker 138 kV switching station physically configured in a breaker and half bus arrangement but operated as a ring-bus (See Figure 1). Installation of associated protection and control equipment, 138 kV line risers and SCADA will also be required.	\$6,000,000
138kV Transmission Line Cut In	\$ 1,000,000
Total Direct Connection Facility Costs	\$7,000,000

6 Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Upgrade line protections & Controls at the 138kV Remote end Substation #1	\$ 250,000
Upgrade line protections & Controls at the 138kV Remote end Substation #2	\$ 250,000
Total Non-Direct Connection Facility Costs	\$500,000

7 Incremental Capacity Transfer Rights (ICTRs)

Will be determined at a later study phase

8 Schedule

It is anticipated that the time between receipt of executed Agreements and Commercial Operation may range from 12 to 18 months if no line work is required. If line work is required, construction time would generally be between 24 to 36 months after Agreement execution.

9 Interconnection Customer Requirements

It is understood that the Interconnection Customer is responsible for all costs associated with this interconnection. The costs above are reimbursable to AEP. The cost of the Interconnection Customer's generating plant and the costs for the line connecting the generating plant to the AEP Transmission circuit are not included in this report; these are assumed to be the Interconnection Customer's responsibility.

The Generation Interconnection Agreement does not in or by itself establish a requirement for American Electric Power to provide power for consumption at the developer's facilities. A separate agreement may be reached with the local utility that provides service in the area to ensure that infrastructure is in place to meet this demand and proper metering equipment is installed. It is the responsibility of the developer to contact the local service provider to determine if a local service agreement is required.

Requirement from the PJM Open Access Transmission Tariff:

1. An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.
2. The Interconnection Customer may be required to install and/or pay for metering as necessary to properly track real time output of the facility as well as installing metering which shall be used for billing purposes. See Section 8 of Appendix 2 to the Interconnection Service Agreement as well as Section 4 of PJM Manual 14D for additional information.

10 Revenue Metering and SCADA Requirements

10.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

10.2 AEP Requirements

The Interconnection Customer will be required to comply with all AEP Revenue Metering Requirements for Generation Interconnection Customers. The Revenue Metering Requirements may be found within the “Requirements for Connection of New Facilities or Changes to Existing Facilities Connected to the AEP Transmission System” document located at the following link:

<http://www.pjm.com/~media/planning/plan-standards/private-aep/aep-interconnection-requirements.ashx>

11 Network Impacts

The Queue Project AE2-297 was evaluated as a 152.5 MW (Capacity 91.5 MW) injection tapping the Madison to Tanners Creek 138 kV line in the AEP area. Project AE2-297 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE2-297 was studied with a commercial probability of 0.53. Potential network impacts were as follows:

Summer Peak Load Flow

12 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

13 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

14 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7382669	243311	05HOGAN	AEP	243275	05DELAWARE	AEP	1	AEP_P4_#2965_05DESOTO345_A2	breaker	231.0	113.3	120.39	DC	16.4
7382631	246763	05PIPECK	AEP	243303	05GRNTT A	AEP	1	AEP_P4_#8781_05HOGAN138_B	breaker	205.0	120.42	122.67	DC	10.24
8956815	248001	06DEARB1	OVEC	248013	06PIERCE	OVEC	1	.345.DE0&K-AEP.C54504MFTANNERS4512EBTANNERS	tower	972.0	110.62	113.03	DC	23.16
7384203	923880	AB2-028 TAP	AEP	243218	05DESOTO	AEP	1	AEP_P7-1_#11042	tower	1160.0	102.68	104.12	DC	16.65
7382576	936560	AD2-071 TAP	AEP	246763	05PIPECK	AEP	1	AEP_P4_#8781_05HOGAN138_B	breaker	205.0	122.42	124.67	DC	10.24

15 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7383783	243218	05DESOTO	AEP	243232	05SORENS	AEP	2	AEP_P1-2_#4817	operation	971.0	101.52	103.48	DC	19.34

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7383551	243311	05HOGAN	AEP	243275	05DELAWR	AEP	1	AEP_P1-2_#673-A	operation	231.0	111.79	119.12	DC	16.93
7383552	243311	05HOGAN	AEP	243275	05DELAWR	AEP	1	Base Case	operation	167.0	110.52	114.61	DC	15.17
7383578	246763	05PIPECK	AEP	243303	05GRNTTA	AEP	1	AEP_P1-2_#6957	operation	205.0	114.87	116.82	DC	8.86
7383227	247588	W4-004 C	AEP	243382	05TANNER	AEP	1	AEP_P1-2_#8182-A	operation	220.0	79.5	148.82	DC	152.5
7383556	936560	AD2-071 TAP	AEP	246763	05PIPECK	AEP	1	AEP_P1-2_#6957	operation	205.0	116.87	118.82	DC	8.86
7383222	942790	AE2-297 TAP	AEP	243333	05MADISO	AEP	1	AEP_P1-2_#8181	operation	220.0	79.5	148.82	DC	152.5
7383223	942790	AE2-297 TAP	AEP	243333	05MADISO	AEP	1	Base Case	operation	187.0	74.8	130.85	DC	104.81

16 System Reinforcements

ID	Index	Facility	Upgrade Description	Cost
7382669	1	05HOGAN 138.0 kV - 05DELAWR 138.0 kV Ckt 1	s0738 (89) : PJM Supplemental Upgrade s0738. Upgrade the Delaware - Hogan 138 kV risers. The supplemental project has an projected in-service date of 12/18/2021. Project Type : FAC Cost : \$0 Time Estimate : 12-18 Months s1498.2 (90) : PJM Supplemental Upgrade s1498.2. Replace risers at Delaware station with 1200A AAC jumpers. The supplemental project has an projected in-service date of 12/18/2021. Project Type : FAC Cost : \$0 Time Estimate : 12-18 Months	\$0
7384203	4	AB2-028 TAP 345.0 kV - 05DESOTO 345.0 kV Ckt 1	<u>7384203</u> Current AEP Ratings are S/N: 1025 MVA S/E: 1318 MVA. Current AEP ratings are sufficient to mitigate the overloads.	\$0
7382576	5	AD2-071 TAP 138.0 kV - 05PIPECK 138.0 kV Ckt 1	<u>AEP</u> (sXXXX): Contingency is no longer valid. It is going away with the Southern Muncie project proposed by AEP (waiting for a Supplemental ID# for this project) Note: This queue project may have a cost responsibility for upgrading the overloaded element if the supplemental project is not approved. Further information will be provided during the Impact Study Phase. Project Type : CON Cost : TBD Time Estimate : TBD An AEP supplemental project may rebuild a portion or all of this line. PJM is in the process of assigning this project a Supplemental ID number. Determination of allocation of cost for the scope of SXXXX to AE2-297 (if any) or other queue positions will occur during the System Impact Study.	TBD
7382631	2	05PIPECK 138.0 kV - 05GRNTTA 138.0 kV Ckt 1		
8956815	3	06DEARB1 345.0 kV - 06PIERCE 345.0 kV Ckt 1	OVEC_CPI_r0003 (913) : Perform a sag study. OVECs cost estimate for performing the sag study is \$125K. Project Type : FAC Cost : \$125,000 Time Estimate : 6-12 Months	\$125,000
			TOTAL COST	\$125,000 + TBD

17 Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

17.1 Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC DC	MW IMPACT
7382669	243311	05HOGAN	AEP	243275	05DELAWARE	AEP	1	AEP_P4_#2965_05DESOTO 345_A2	breaker	231.0	113.3	120.39	DC	16.4

Bus #	Bus	MW Impact
246991	05WLD G1 C	0.35
247255	05WLD G2 C	0.37
247914	05WLD G1 E	19.45
247958	05WLD G2 E	20.41
247968	Z2-115 E	0.14
920501	AA2-148 C O1	2.36
920502	AA2-148 E O1	15.76
923881	AB2-028 C	1.67
923882	AB2-028 E	11.19
934161	AD1-043 C O1	9.63
934162	AD1-043 E O1	15.71
936561	AD2-071 C	12.55
936562	AD2-071 E	6.18
941692	AE2-169 BAT	7.71
941711	AE2-171	6.35
942791	AE2-297 C O1	9.84
942792	AE2-297 E O1	6.56
CARR	CARR	0.03
CBM-S1	CBM-S1	1.92
CBM-S2	CBM-S2	0.35
CBM-W1	CBM-W1	1.39
CBM-W2	CBM-W2	22.59
CIN	CIN	5.06
CPLE	CPLE	0.1
G-007	G-007	0.08
IPL	IPL	4.13
LGEE	LGEE	0.51
MEC	MEC	2.63
O-066	O-066	0.53
RENSSELAER	RENSSELAER	0.03
WEC	WEC	0.25

17.2 Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC DC	MW IMPACT
7382631	246763	05PIPECK	AEP	243303	05GRNTT	AEP	1	AEP_P4_#8781_05HOGAN 138_B	breaker	205.0	120.42	122.67	DC	10.24

Bus #	Bus	MW Impact
246991	05WLD G1 C	0.79
247255	05WLD G2 C	0.83
247914	05WLD G1 E	43.28
247958	05WLD G2 E	45.41
920501	AA2-148 C O1	1.49
920502	AA2-148 E O1	9.95
934161	AD1-043 C O1	19.67
934162	AD1-043 E O1	32.1
936561	AD2-071 C	39.86
936562	AD2-071 E	19.63
941702	AE2-170 BAT	1.67
941711	AE2-171	12.99
941722	AE2-172 BAT	1.81
942791	AE2-297 C O1	6.14
942792	AE2-297 E O1	4.1
CBM-N	CBM-N	0.02
CBM-S1	CBM-S1	0.68
CBM-S2	CBM-S2	0.15
CBM-W2	CBM-W2	4.86
CIN	CIN	1.62
CPL	CPL	0.05
DUCKCREEK	DUCKCREEK	0.23
EDWARDS	EDWARDS	0.13
FARMERCITY	FARMERCITY	0.03
G-007A	G-007A	0.06
IPL	IPL	1.62
LGEE	LGEE	0.3
NYISO	NYISO	0.07
TATANKA	TATANKA	0.1
VFT	VFT	0.16

17.3 Index 3

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
8956815	248001	06DEARB1	OVEC	248013	06PIERC E	OVEC	1	.345.DEO&K-AEP.C5 4504MFTANNERS4512EBTANNERS	tower	972.0	110.62	113.03	DC	23.16

Bus #	Bus	MW Impact
243795	05HDWTR1G C	0.49
247264	05LAWG1A	6.07
247265	05LAWG1B	6.07
247266	05LAWG1S	9.7
247267	05LAWG2A	6.07
247268	05LAWG2B	6.07
247269	05LAWG2S	9.7
247543	V3-007 C	0.49
247914	05WLD G1 E	8.0
247929	S-071 E	8.56
247935	V3-007 E	26.83
247958	05WLD G2 E	8.4
247963	05HDWTR1G E	9.66
247968	Z2-115 E	0.16
915662	Y3-099 E	0.2
915672	Y3-100 E	0.2
916182	Z1-065 E	0.38
920501	AA2-148 C O1	3.54
920502	AA2-148 E O1	23.67
923881	AB2-028 C	2.91
923882	AB2-028 E	19.46
925242	AB2-178 E	1.98
926691	AC1-152	15.72
926851	AC1-172	15.72
926881	AC1-175 C	11.72
926882	AC1-175 E	19.12
932681	AC2-090 C	5.86
932682	AC2-090 E	9.56
932841	AC2-111 C O1	2.77
932842	AC2-111 E O1	4.52
933591	AC2-176 C O1	1.52
933592	AC2-176 E O1	10.14
933601	AC2-177 C O1	4.01
933602	AC2-177 E O1	26.83
934161	AD1-043 C O1	4.47
934162	AD1-043 E O1	7.29
934961	AD1-128 C O1	5.62
934962	AD1-128 E O1	9.17
936561	AD2-071 C	5.94
936562	AD2-071 E	2.92
936681	AD2-087 C O1	3.17

Bus #	Bus	MW Impact
936682	AD2-087 E O1	14.83
938061	AE1-008 C	0.69
938062	AE1-008 E	1.13
939761	AE1-207 C	5.95
939762	AE1-207 E	8.22
939771	AE1-208 C	5.24
939772	AE1-208 E	7.14
939781	AE1-209 C O1	1.28
939782	AE1-209 E O1	8.58
939791	AE1-210 C O1	1.61
939792	AE1-210 E O1	10.76
939811	AE1-217 C O1	7.95
939812	AE1-217 E O1	10.98
940981	AE2-089 C O1	7.24
940982	AE2-089 E O1	4.83
940991	AE2-090 C	7.78
940992	AE2-090 E	5.19
941691	AE2-169	3.15
941701	AE2-170	4.74
941711	AE2-171	2.95
941721	AE2-172	3.55
942071	AE2-219 C	3.77
942072	AE2-219 E	5.2
942081	AE2-220 C	8.1
942082	AE2-220 E	11.18
942221	AE2-234 C O1	1.8
942222	AE2-234 E O1	0.81
942791	AE2-297 C O1	13.9
942792	AE2-297 E O1	9.26
950161	J401	1.31
CARR	CARR	0.32
CATAWBA	CATAWBA	0.09
CBM-S1	CBM-S1	4.29
CBM-W1	CBM-W1	17.07
CBM-W2	CBM-W2	71.97
CIN	CIN	13.65
G-007	G-007	0.94
HAMLET	HAMLET	0.19
IPL	IPL	12.55
LGEE	LGEE	1.08
MEC	MEC	15.37
MECS	MECS	7.23
O-066	O-066	6.01
RENSSELAER	RENSSELAER	0.25
WEC	WEC	2.43
Z1-043	Z1-043	9.75

17.4 Index 4

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7384203	923880	AB2-028 TAP	AEP	243218	05DESOTO	AEP	1	AEP_P7-1_#11042	tower	1160.0	102.68	104.12	DC	16.65

Bus #	Bus	MW Impact
247285	05AND G1	0.8
247286	05AND G2	0.8
247287	05AND G3	1.68
247900	05FR-11G E	6.19
247901	05FR-12G E	6.08
247902	05FR-21G E	6.5
247903	05FR-22G E	6.23
247904	05FR-3G E	12.61
247905	05FR-4G E	9.48
247906	05MDL-1G E	12.62
247907	05MDL-2G E	6.26
247912	05MDL-3G E	6.54
247913	05MDL-4G E	6.32
247943	T-127 E	6.32
920501	AA2-148 C O1	2.39
920502	AA2-148 E O1	16.03
923881	AB2-028 C	12.83
923882	AB2-028 E	85.84
930042	AB1-006 E	13.75
930461	AB1-087	37.87
930471	AB1-088	37.87
933441	AC2-157 C	5.23
933442	AC2-157 E	8.54
934161	AD1-043 C O1	3.11
934162	AD1-043 E O1	5.08
935271	AD1-137 C	5.14
935272	AD1-137 E	34.37
941571	AE2-154 C	2.57
941572	AE2-154 E	17.18
941692	AE2-169 BAT	1.07
941702	AE2-170 BAT	2.57
941711	AE2-171	2.06
941722	AE2-172 BAT	1.57
942601	AE2-276	3.45
942791	AE2-297 C O1	9.99
942792	AE2-297 E O1	6.66
950161	J401	3.11
950302	J453 E	1.19
950981	J333	12.48
950991	J334	12.51
952471	J708	20.13
952801	J754 C	2.55

Bus #	Bus	MW Impact
952802	J754 E	13.79
953101	J714 C	1.75
953102	J714 E	9.48
953351	J805	32.88
953501	J478 C	1.99
953502	J478 E	10.79
953721	J824	17.31
953761	J829	17.08
953831	J842 C	2.1
953832	J842 E	11.37
953841	J843 C	2.17
953842	J843 E	11.74
953931	J856	4.73
954351	J903	16.06
954772	J515 E	27.88
CARR	CARR	0.11
CBM-S1	CBM-S1	10.24
CBM-S2	CBM-S2	2.01
CBM-W1	CBM-W1	2.94
CBM-W2	CBM-W2	117.1
CIN	CIN	26.41
CPLE	CPLE	0.61
G-007	G-007	0.26
IPL	IPL	22.65
LGEE	LGEE	2.77
MEC	MEC	10.81
O-066	O-066	1.66
RENSSELAER	RENSSELAER	0.09
WEC	WEC	0.58

17.5 Index 5

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7382576	936560	AD2-071 TAP	AEP	246763	05PIPECK	AEP	1	AEP_P4_#8781_05HOGAN 138_B	breaker	205.0	122.42	124.67	DC	10.24

Bus #	Bus	MW Impact
246991	05WLD G1 C	0.79
247255	05WLD G2 C	0.83
247914	05WLD G1 E	43.28
247958	05WLD G2 E	45.41
920501	AA2-148 C O1	1.49
920502	AA2-148 E O1	9.95
934161	AD1-043 C O1	19.67
934162	AD1-043 E O1	32.1
936561	AD2-071 C	39.86
936562	AD2-071 E	19.63
941702	AE2-170 BAT	1.67
941711	AE2-171	12.99
941722	AE2-172 BAT	1.81
942791	AE2-297 C O1	6.14
942792	AE2-297 E O1	4.1
CBM-N	CBM-N	0.02
CBM-S1	CBM-S1	0.68
CBM-S2	CBM-S2	0.15
CBM-W2	CBM-W2	4.86
CIN	CIN	1.62
CPLE	CPLE	0.05
DUCKCREEK	DUCKCREEK	0.23
EDWARDS	EDWARDS	0.13
FARMERCITY	FARMERCITY	0.03
G-007A	G-007A	0.06
IPL	IPL	1.62
LGEE	LGEE	0.3
NYISO	NYISO	0.07
TATANKA	TATANKA	0.1
VFT	VFT	0.16

Affected Systems

18 Affected Systems

18.1 LG&E

LG&E Impacts to be determined during later study phases (as applicable).

18.2 MISO

MISO Impacts to be determined during later study phases (as applicable).

18.3 TVA

TVA Impacts to be determined during later study phases (as applicable).

18.4 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

18.5 NYISO

NYISO Impacts to be determined during later study phases (as applicable).

19 Contingency Descriptions:

Contingency Name	Contingency Definition
AEP_P1-2_#8181	CONTINGENCY 'AEP_P1-2_#8181' OPEN BRANCH FROM BUS 243382 TO BUS 247588 CKT 1 / 243382 05TANNER 138 247588 W4-004 C 138 1 END
AEP_P1-2_#4817	CONTINGENCY 'AEP_P1-2_#4817' OPEN BRANCH FROM BUS 243225 TO BUS 243232 CKT 1 / 243225 05KEYSTN 345 243232 05SORENS 345 1 END
AEP_P1-2_#8182-A	CONTINGENCY 'AEP_P1-2_#8182-A' OPEN BRANCH FROM BUS 243333 TO BUS 942790 CKT 1 / 243333 05MADISO 138 942790 AE2-297 TAP 138 1 END
.345.DEO&K-AEP.C5 4504MFTANNERS4512EBTANNERS	CONTINGENCY '.345.DEO&K-AEP.C5 4504MFTANNERS4512EBTANNERS' OPEN BRANCH FROM BUS 243233 TO BUS 249567 CKT 1 OPEN BRANCH FROM BUS 243233 TO BUS 249565 CKT 1 END
AEP_P1-2_#673-A	CONTINGENCY 'AEP_P1-2_#673-A' OPEN BRANCH FROM BUS 243218 TO BUS 923880 CKT 1 / 243218 05DESOTO 345 923880 AB2-028 TAP 345 1 END
AEP_P1-2_#6957	CONTINGENCY 'AEP_P1-2_#6957' OPEN BRANCH FROM BUS 247116 TO BUS 246913 CKT 1 / 247116 05ALADDIN 138 246913 05JONES 138 1 OPEN BRANCH FROM BUS 247116 TO BUS 246988 CKT 1 / 247116 05ALADDIN 138 246988 05STRWTN 138 1 OPEN BRANCH FROM BUS 243311 TO BUS 246913 CKT 1 / 243311 05HOGAN 138 246913 05JONES 138 1 END
AEP_P4_#2965_05DESOTO 345_A2	CONTINGENCY 'AEP_P4_#2965_05DESOTO 345_A2' OPEN BRANCH FROM BUS 243218 TO BUS 923880 CKT 1 / 243218 05DESOTO 345 923880 AB2-028 TAP 345 1 /* CONTINGENCY LINE ADDED FOR AE1 BUILD OPEN BRANCH FROM BUS 243218 TO BUS 243278 CKT 1 / 243218 05DESOTO 345 243278 05DESOTO 138 1 END
Base Case	
AEP_P7-1_#11042	CONTINGENCY 'AEP_P7-1_#11042' OPEN BRANCH FROM BUS 243878 TO BUS 255205 CKT 1 / 243878 05MEADOW 345 255205 17REYNOLDS 345 1 OPEN BRANCH FROM BUS 243878 TO BUS 255205 CKT 2 / 243878 05MEADOW 345 255205 17REYNOLDS 345 2 END

Contingency Name	Contingency Definition
AEP_P4_#8781_05HOGAN 138_B	CONTINGENCY 'AEP_P4_#8781_05HOGAN 138_B' OPEN BRANCH FROM BUS 247116 TO BUS 246913 CKT 1 / 247116 05ALADDIN 138 246913 05JONES 138 1 OPEN BRANCH FROM BUS 247116 TO BUS 246988 CKT 1 / 247116 05ALADDIN 138 246988 05STRWTN 138 1 OPEN BRANCH FROM BUS 247420 TO BUS 243311 CKT 1 / 247420 05CROSS ST Z 138 243311 05HOGAN 138 1 OPEN BRANCH FROM BUS 243275 TO BUS 243311 CKT 1 / 243275 05DELAWR 138 243311 05HOGAN 138 1 OPEN BRANCH FROM BUS 243311 TO BUS 246913 CKT 1 / 243311 05HOGAN 138 246913 05JONES 138 1 OPEN BRANCH FROM BUS 243311 TO BUS 246046 CKT 1 / 243311 05HOGAN 138 246046 05HOGAN 34.5 1 OPEN BRANCH FROM BUS 243311 TO BUS 246047 CKT 1 / 243311 05HOGAN 138 246047 05HOGAN L 12.0 1 END

Short Circuit

20 Short Circuit

The following Breakers are overduty

None.

Secondary Point Of Interconnection

21 Network Impacts – Secondary POI

The Queue Project AE2-297 was evaluated as a 152.5 MW (Capacity 91.5 MW) injection tapping the Tanners Creek to Pendleton 138kV line in the AEP area. Project AE2-297 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE2-297 was studied with a commercial probability of 0.53. Potential network impacts were as follows:

Summer Peak Load Flow

22 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

23 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
12201214	243357	05PENDLE	AEP	243339	05MEADOW	AEP	1	AEP_P7-1_#11073-B	tower	185.0	41.84	101.01	DC	109.46
7383008	246988	05STRWTN	AEP	936560	AD2-071 TAP	AEP	1	AEP_P4_#8781_05HOGAN 138_B	breaker	205.0	93.38	100.95	DC	15.52

24 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
7382631	246763	05PIPECK	AEP	243303	05GRNTTA	AEP	1	AEP_P4_#8781_05HOGAN 138_B	breaker	205.0	120.45	128.02	DC	15.52
7382633	246763	05PIPECK	AEP	243303	05GRNTTA	AEP	1	AEP_P4_#6959_05HOGAN 138_A	breaker	205.0	114.5	122.07	DC	15.52
8956815	248001	06DEARB1	OVEC	248013	06PIERCE	OVEC	1	.345.DEOK-AEP.CS 4504MFTANNERS4512EBTANNERS	tower	972.0	110.72	113.18	DC	23.69
7384203	923880	AB2-028 TAP	AEP	243218	05DESOTO	AEP	1	AEP_P7-1_#11042	tower	1160.0	102.67	104.1	DC	16.52
7382576	936560	AD2-071 TAP	AEP	246763	05PIPECK	AEP	1	AEP_P4_#8781_05HOGAN 138_B	breaker	205.0	122.4	129.97	DC	15.52
7382578	936560	AD2-071 TAP	AEP	246763	05PIPECK	AEP	1	AEP_P4_#6959_05HOGAN 138_A	breaker	205.0	116.45	124.02	DC	15.52

25 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7383783	243218	05DESOTO	AEP	243232	05SORENS	AEP	2	AEP_P1-2_#4817	operation	971.0	101.75	103.61	DC	18.35
7383551	243311	05HOGAN	AEP	243275	05DELAWR	AEP	1	AEP_P1-2_#673-A	operation	231.0	111.84	118.56	DC	15.52
7383552	243311	05HOGAN	AEP	243275	05DELAWR	AEP	1	Base Case	operation	167.0	110.48	114.2	DC	13.78
7383579	246763	05PIPECK	AEP	243303	05GRNTTA	AEP	1	AEP_SUBT_P1-3_#844_05HOGAN138_1	operation	205.0	113.96	121.53	DC	15.52
7383557	936560	AD2-071 TAP	AEP	246763	05PIPECK	AEP	1	AEP_SUBT_P1-3_#844_05HOGAN138_1	operation	205.0	115.91	123.48	DC	15.52

26 Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

26.1 Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
12201214	243357	05PENDLE	AEP	243339	05MEADOW	AEP	1	AEP_P7-1_#11073-B	tower	185.0	41.84	101.01	DC	109.46

Bus #	Bus	MW Impact
246991	05WLD G1 C	0.39
247255	05WLD G2 C	0.41
247914	05WLD G1 E	21.58
247958	05WLD G2 E	22.64
247968	Z2-115 E	0.2
934161	AD1-043 C O1	16.01
934162	AD1-043 E O1	26.12
936561	AD2-071 C	14.18
936562	AD2-071 E	6.98
941711	AE2-171	10.57
942791	AE2-297 C O2	65.68
942792	AE2-297 E O2	43.79
BLUEG	BLUEG	1.18
CALDERWOOD	CALDERWOOD	0.05
CANNELTON	CANNELTON	0.09
CARR	CARR	0.01
CATAWBA	CATAWBA	0.02
CBM-W1	CBM-W1	0.66
CHEOAH	CHEOAH	0.05
CHILHOWEE	CHILHOWEE	0.02
COFFEEN	COFFEEN	0.02
COTTONWOOD	COTTONWOOD	0.16
ELMERSMITH	ELMERSMITH	0.15
G-007	G-007	0.03
GIBSON	GIBSON	0.09
HAMLET	HAMLET	0.04
MEC	MEC	0.27
MECS	MECS	0.51
NEWTON	NEWTON	0.14
O-066	O-066	0.17
PRAIRIE	PRAIRIE	0.17
RENSSELAER	RENSSELAER	0.01
SANTEETLA	SANTEETLA	0.01
SMITHLAND	SMITHLAND	0.03
TILTON	TILTON	0.04
TRIMBLE	TRIMBLE	0.12
TVA	TVA	0.19
UNIONPOWER	UNIONPOWER	0.06
WEC	WEC	0.11

26.2 Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7383008	246988	05STRWTN	AEP	936560	AD2-071 TAP	AEP	1	AEP_P4_#8781_05HOGAN 138_B	breaker	205.0	93.38	100.95	DC	15.52

Bus #	Bus	MW Impact
246991	05WLD G1 C	0.79
247255	05WLD G2 C	0.83
247914	05WLD G1 E	43.28
247958	05WLD G2 E	45.41
920501	AA2-148 C O1	1.49
920502	AA2-148 E O1	9.95
934161	AD1-043 C O1	19.67
934162	AD1-043 E O1	32.1
941702	AE2-170 BAT	1.74
941711	AE2-171	12.99
941722	AE2-172 BAT	1.81
942791	AE2-297 C O2	9.31
942792	AE2-297 E O2	6.21
CBM-N	CBM-N	0.02
CBM-S1	CBM-S1	0.68
CBM-S2	CBM-S2	0.15
CBM-W2	CBM-W2	4.86
CIN	CIN	1.62
CPLE	CPLE	0.05
DUCKCREEK	DUCKCREEK	0.23
EDWARDS	EDWARDS	0.13
FARMERCITY	FARMERCITY	0.03
G-007A	G-007A	0.06
IPL	IPL	1.62
LGEE	LGEE	0.3
NYISO	NYISO	0.07
TATANKA	TATANKA	0.1
VFT	VFT	0.16

26.3 Index 3

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC DC	MW IMPACT
738263 1	24676 3	05PIPECK	AEP	24330 3	05GRNTT	AEP	1	AEP_P4_#8781_05HOGA N 138_B	breaker	205.0	120.45	128.02	DC	15.52

Bus #	Bus	MW Impact
246991	05WLD G1 C	0.79
247255	05WLD G2 C	0.83
247914	05WLD G1 E	43.28
247958	05WLD G2 E	45.41
920501	AA2-148 C O1	1.49
920502	AA2-148 E O1	9.95
934161	AD1-043 C O1	19.67
934162	AD1-043 E O1	32.1
936561	AD2-071 C	39.86
936562	AD2-071 E	19.63
941702	AE2-170 BAT	1.74
941711	AE2-171	12.99
941722	AE2-172 BAT	1.81
942791	AE2-297 C O2	9.31
942792	AE2-297 E O2	6.21
CBM-N	CBM-N	0.02
CBM-S1	CBM-S1	0.68
CBM-S2	CBM-S2	0.15
CBM-W2	CBM-W2	4.86
CIN	CIN	1.62
CPL	CPL	0.05
DUCKCREEK	DUCKCREEK	0.23
EDWARDS	EDWARDS	0.13
FARMERCITY	FARMERCITY	0.03
G-007A	G-007A	0.06
IPL	IPL	1.62
LGEE	LGEE	0.3
NYISO	NYISO	0.07
TATANKA	TATANKA	0.1
VFT	VFT	0.16

26.4 Index 4

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC D C	MW IMPACT
8956815	248001	06DEARB1	OVEC	248013	06PIERC E	OVEC	1	.345.DE0&K-AEP.C5 4504MFTANNERS4512EBTANNERS	tower	972.0	110.72	113.18	DC	23.69

Bus #	Bus	MW Impact
243795	05HDWTR1G C	0.49
247264	05LAWG1A	6.07
247265	05LAWG1B	6.07
247266	05LAWG1S	9.7
247267	05LAWG2A	6.07
247268	05LAWG2B	6.07
247269	05LAWG2S	9.7
247543	V3-007 C	0.49
247914	05WLD G1 E	8.0
247929	S-071 E	8.56
247935	V3-007 E	26.83
247958	05WLD G2 E	8.39
247963	05HDWTR1G E	9.66
247968	Z2-115 E	0.16
915662	Y3-099 E	0.2
915672	Y3-100 E	0.2
916182	Z1-065 E	0.38
920501	AA2-148 C O1	3.54
920502	AA2-148 E O1	23.67
923881	AB2-028 C	2.91
923882	AB2-028 E	19.45
925242	AB2-178 E	1.98
926691	AC1-152	15.72
926851	AC1-172	15.72
926881	AC1-175 C	11.72
926882	AC1-175 E	19.12
932681	AC2-090 C	5.86
932682	AC2-090 E	9.56
932841	AC2-111 C O1	2.77
932842	AC2-111 E O1	4.51
933591	AC2-176 C O1	1.52
933592	AC2-176 E O1	10.14
933601	AC2-177 C O1	4.01
933602	AC2-177 E O1	26.83
934161	AD1-043 C O1	4.46
934162	AD1-043 E O1	7.28
934961	AD1-128 C O1	5.62
934962	AD1-128 E O1	9.17
936561	AD2-071 C	5.94
936562	AD2-071 E	2.92
936681	AD2-087 C O1	3.17

Bus #	Bus	MW Impact
936682	AD2-087 E O1	14.82
938061	AE1-008 C	0.69
938062	AE1-008 E	1.13
939761	AE1-207 C	5.95
939762	AE1-207 E	8.22
939771	AE1-208 C	5.24
939772	AE1-208 E	7.14
939781	AE1-209 C O1	1.28
939782	AE1-209 E O1	8.57
939791	AE1-210 C O1	1.61
939792	AE1-210 E O1	10.76
939811	AE1-217 C O1	7.95
939812	AE1-217 E O1	10.97
940981	AE2-089 C O2	7.66
940982	AE2-089 E O2	5.11
940991	AE2-090 C	7.77
940992	AE2-090 E	5.18
941691	AE2-169	3.15
941701	AE2-170	4.71
941711	AE2-171	2.95
941721	AE2-172	3.55
942071	AE2-219 C	3.76
942072	AE2-219 E	5.2
942081	AE2-220 C	8.1
942082	AE2-220 E	11.18
942221	AE2-234 C O2	1.8
942222	AE2-234 E O2	0.81
942791	AE2-297 C O2	14.21
942792	AE2-297 E O2	9.48
950161	J401	1.31
CARR	CARR	0.32
CATAWBA	CATAWBA	0.09
CBM-S1	CBM-S1	4.29
CBM-W1	CBM-W1	17.07
CBM-W2	CBM-W2	71.97
CIN	CIN	13.65
G-007	G-007	0.94
HAMLET	HAMLET	0.19
IPL	IPL	12.54
LGEE	LGEE	1.08
MEC	MEC	15.38
MECS	MECS	7.24
O-066	O-066	6.01
RENSSELAER	RENSSELAER	0.25
WEC	WEC	2.43
Z1-043	Z1-043	9.75

26.5 Index 5

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7384203	923880	AB2-028 TAP	AEP	243218	05DESOTO	AEP	1	AEP_P7-1_#11042	tower	1160.0	102.67	104.1	DC	16.52

Bus #	Bus	MW Impact
247285	05AND G1	0.8
247286	05AND G2	0.8
247287	05AND G3	1.68
247900	05FR-11G E	6.19
247901	05FR-12G E	6.09
247902	05FR-21G E	6.5
247903	05FR-22G E	6.23
247904	05FR-3G E	12.61
247905	05FR-4G E	9.48
247906	05MDL-1G E	12.62
247907	05MDL-2G E	6.26
247912	05MDL-3G E	6.54
247913	05MDL-4G E	6.32
247943	T-127 E	6.32
920501	AA2-148 C O1	2.4
920502	AA2-148 E O1	16.03
923881	AB2-028 C	12.83
923882	AB2-028 E	85.84
930042	AB1-006 E	13.75
930461	AB1-087	37.87
930471	AB1-088	37.87
933441	AC2-157 C	5.23
933442	AC2-157 E	8.54
934161	AD1-043 C O1	3.11
934162	AD1-043 E O1	5.08
935271	AD1-137 C	5.14
935272	AD1-137 E	34.38
941571	AE2-154 C	2.57
941572	AE2-154 E	17.18
941692	AE2-169 BAT	1.07
941702	AE2-170 BAT	2.51
941711	AE2-171	2.06
941722	AE2-172 BAT	1.57
942601	AE2-276	3.45
942791	AE2-297 C O2	9.91
942792	AE2-297 E O2	6.61
950161	J401	3.11
950302	J453 E	1.19
950981	J333	12.48
950991	J334	12.51
952471	J708	20.13
952801	J754 C	2.55

Bus #	Bus	MW Impact
952802	J754 E	13.79
953101	J714 C	1.75
953102	J714 E	9.48
953351	J805	32.88
953501	J478 C	1.99
953502	J478 E	10.79
953721	J824	17.31
953761	J829	17.08
953831	J842 C	2.1
953832	J842 E	11.37
953841	J843 C	2.17
953842	J843 E	11.74
953931	J856	4.73
954351	J903	16.06
954772	J515 E	27.88
CARR	CARR	0.11
CBM-S1	CBM-S1	10.25
CBM-S2	CBM-S2	2.02
CBM-W1	CBM-W1	2.94
CBM-W2	CBM-W2	117.12
CIN	CIN	26.41
CPLE	CPLE	0.61
G-007	G-007	0.25
IPL	IPL	22.66
LGEE	LGEE	2.77
MEC	MEC	10.81
O-066	O-066	1.65
RENSSELAER	RENSSELAER	0.09
WEC	WEC	0.58

26.6 Index 6

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
7382576	936560	AD2-071 TAP	AEP	246763	05PIPECK	AEP	1	AEP_P4_#8781_05HOGAN 138_B	breaker	205.0	122.4	129.97	DC	15.52

Bus #	Bus	MW Impact
246991	05WLD G1 C	0.79
247255	05WLD G2 C	0.83
247914	05WLD G1 E	43.28
247958	05WLD G2 E	45.41
920501	AA2-148 C O1	1.49
920502	AA2-148 E O1	9.95
934161	AD1-043 C O1	19.67
934162	AD1-043 E O1	32.1
936561	AD2-071 C	39.86
936562	AD2-071 E	19.63
941702	AE2-170 BAT	1.74
941711	AE2-171	12.99
941722	AE2-172 BAT	1.81
942791	AE2-297 C O2	9.31
942792	AE2-297 E O2	6.21
CBM-N	CBM-N	0.02
CBM-S1	CBM-S1	0.68
CBM-S2	CBM-S2	0.15
CBM-W2	CBM-W2	4.86
CIN	CIN	1.62
CPLE	CPLE	0.05
DUCKCREEK	DUCKCREEK	0.23
EDWARDS	EDWARDS	0.13
FARMERCITY	FARMERCITY	0.03
G-007A	G-007A	0.06
IPL	IPL	1.62
LGEE	LGEE	0.3
NYISO	NYISO	0.07
TATANKA	TATANKA	0.1
VFT	VFT	0.16

Affected Systems

27 Affected Systems

27.1 LG&E

LG&E Impacts to be determined during later study phases (as applicable).

27.2 MISO

MISO Impacts to be determined during later study phases (as applicable).

27.3 TVA

TVA Impacts to be determined during later study phases (as applicable).

27.4 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

27.5 NYISO

NYISO Impacts to be determined during later study phases (as applicable).

28 Contingency Descriptions

Contingency Name	Contingency Definition
AEP_P4_#6959_05HOGAN 138_A	CONTINGENCY 'AEP_P4_#6959_05HOGAN 138_A' OPEN BRANCH FROM BUS 247420 TO BUS 243311 CKT 1 / 247420 05CROSS ST Z 138 243311 05HOGAN 138 1 OPEN BRANCH FROM BUS 247420 TO BUS 243333 CKT 1 / 247420 05CROSS ST Z 138 243333 05MADISO 138 1 OPEN BRANCH FROM BUS 243275 TO BUS 243311 CKT 1 / 243275 05DELAWR 138 243311 05HOGAN 138 1 OPEN BRANCH FROM BUS 243311 TO BUS 246913 CKT 1 / 243311 05HOGAN 138 246913 05JONES 138 1 OPEN BRANCH FROM BUS 243311 TO BUS 246046 CKT 1 / 243311 05HOGAN 138 246046 05HOGAN 34.5 1 OPEN BRANCH FROM BUS 243311 TO BUS 246047 CKT 1 / 243311 05HOGAN 138 246047 05HOGAN L 12.0 1 END
AEP_SUBT_P1-3_#844_05HOGAN 138_1	CONTINGENCY 'AEP_SUBT_P1-3_#844_05HOGAN 138_1' OPEN BRANCH FROM BUS 247420 TO BUS 243311 CKT 1 / 247420 05CROSS ST Z 138 243311 05HOGAN 138 1 OPEN BRANCH FROM BUS 243275 TO BUS 243311 CKT 1 / 243275 05DELAWR 138 243311 05HOGAN 138 1 OPEN BRANCH FROM BUS 243311 TO BUS 246913 CKT 1 / 243311 05HOGAN 138 246913 05JONES 138 1 OPEN BRANCH FROM BUS 243311 TO BUS 246046 CKT 1 / 243311 05HOGAN 138 246046 05HOGAN 34.5 1 OPEN BRANCH FROM BUS 243311 TO BUS 246047 CKT 1 / 243311 05HOGAN 138 246047 05HOGAN L 12.0 1 END
AEP_P1-2_#4817	CONTINGENCY 'AEP_P1-2_#4817' OPEN BRANCH FROM BUS 243225 TO BUS 243232 CKT 1 / 243225 05KEYSTN 345 243232 05SORENS 345 1 END
.345.DEO&K-AEP.C5 4504MFTANNERS4512EBTANNERS	CONTINGENCY '.345.DEO&K-AEP.C5 4504MFTANNERS4512EBTANNERS' OPEN BRANCH FROM BUS 243233 TO BUS 249567 CKT 1 OPEN BRANCH FROM BUS 243233 TO BUS 249565 CKT 1 END
AEP_P1-2_#673-A	CONTINGENCY 'AEP_P1-2_#673-A' OPEN BRANCH FROM BUS 243218 TO BUS 923880 CKT 1 / 243218 05DESOTO 345 923880 AB2- 028 TAP 345 1 END

Contingency Name	Contingency Definition
AEP_P4_#8781_05HOGAN 138_B	CONTINGENCY 'AEP_P4_#8781_05HOGAN 138_B' OPEN BRANCH FROM BUS 247116 TO BUS 246913 CKT 1 / 247116 05ALADDIN 138 246913 05JONES 138 1 OPEN BRANCH FROM BUS 247116 TO BUS 246988 CKT 1 / 247116 05ALADDIN 138 246988 05STRWTN 138 1 OPEN BRANCH FROM BUS 247420 TO BUS 243311 CKT 1 / 247420 05CROSS ST Z 138 243311 05HOGAN 138 1 OPEN BRANCH FROM BUS 243275 TO BUS 243311 CKT 1 / 243275 05DELAWR 138 243311 05HOGAN 138 1 OPEN BRANCH FROM BUS 243311 TO BUS 246913 CKT 1 / 243311 05HOGAN 138 246913 05JONES 138 1 OPEN BRANCH FROM BUS 243311 TO BUS 246046 CKT 1 / 243311 05HOGAN 138 246046 05HOGAN 34.5 1 OPEN BRANCH FROM BUS 243311 TO BUS 246047 CKT 1 / 243311 05HOGAN 138 246047 05HOGAN L 12.0 1 END
Base Case	
AEP_P7-1_#11073-B	CONTINGENCY 'AEP_P7-1_#11073-B' OPEN BRANCH FROM BUS 243292 TO BUS 243357 CKT 1 / 243292 05FALL C 138 243357 05PEND
AEP_P7-1_#11042	CONTINGENCY 'AEP_P7-1_#11042' OPEN BRANCH FROM BUS 243878 TO BUS 255205 CKT 1 / 243878 05MEADOW 345 255205 17REYNOLDS 345 1 OPEN BRANCH FROM BUS 243878 TO BUS 255205 CKT 2 / 243878 05MEADOW 345 255205 17REYNOLDS 345 2 END

Short Circuit

29 Short Circuit

The following Breakers are overduty

None.