



**Generation Interconnection
Feasibility Study Report
for
Queue Project AF1-117
ATLANTA-STUART 345 KV
152.9 MW Capacity / 200 MW Energy**

January, 2020

Table of Contents

1	Preface.....	3
2	General.....	5
2.1	Point of Interconnection	6
2.2	Cost Summary.....	6
3	Transmission Owner Scope of Work.....	7
4	Attachment Facilities	7
5	Direct Connection Cost Estimate.....	7
6	Non-Direct Connection Cost Estimate.....	7
7	Incremental Capacity Transfer Rights (ICTRs)	8
8	Schedule.....	8
9	Interconnection Customer Requirements.....	8
10	Revenue Metering and SCADA Requirements	8
10.1	PJM Requirements	8
10.2	AEP Requirements.....	9
11	Network Impacts.....	10
12	Generation Deliverability	12
13	Multiple Facility Contingency	12
14	Contribution to Previously Identified Overloads	12
15	Potential Congestion due to Local Energy Deliverability.....	12
16	System Reinforcements.....	14
17	Flow Gate Details	16
17.1	Index 1	17
17.2	Index 2	19
17.3	Index 3	22
18	Affected Systems	26
18.1	LG&E.....	26
18.2	MISO	26
18.3	TVA.....	26
18.4	Duke Energy Progress.....	26
18.5	NYISO	26
19	Short Circuit.....	29

1 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See

Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model. The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

2 General

The Interconnection Customer (IC), has proposed a Solar; Storage generating facility located in Ross County, Ohio. The installed facilities will have a total capability of 200 MW with 152.9 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is June 1, 2023. This study does not imply a TO commitment to this in-service date.

The objective of this Feasibility Study is to determine budgetary cost estimates and approximate construction timelines for identified transmission facilities required to connect the proposed generating facilities to the AEP transmission system. These reinforcements include the Attachment Facilities, Local Upgrades, and Network Upgrades required for maintaining the reliability of the AEP transmission system.

The Feasibility Study includes Short Circuit and Peak Load steady state power flow analyses. The conduct of power flow studies at other load levels, stability analysis, and coordination with non-PJM Transmission Planners, as required under the PJM planning process, is not performed during the Generation Interconnection Feasibility Study phase of the PJM study process. Additional reinforcement requirements for this Interconnection Request may be defined during the conduct of these additional analyses which shall be performed following execution of the System Impact Study agreement

Queue Number	AF1-117
Project Name	ATLANTA-STUART 345 KV
State	Ohio
County	Ross
Transmission Owner	AEP
MFO	200
MWE	200
MWC	152.9
Fuel	Solar; Storage
Basecase Study Year	2023

2.1 Point of Interconnection

AF1-117 will interconnect with the AEP transmission system tapping the Atlanta to Stuart 345 kV line.

To accommodate the interconnection on the Atlanta to Stuart 345 kV circuit, a new three (3) circuit breaker 345 kV switching station physically configured in a breaker and half bus arrangement but operated as a ring-bus will be constructed (see Figure 1). Installation of associated protection and control equipment, 345 kV line risers, SCADA, and 345 kV revenue metering will also be required. AEP reserves the right to specify the final acceptable configuration considering design practices, future expansion, and compliance requirements.

2.2 Cost Summary

The AF1-117 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$350,000
Direct Connection Network Upgrade	\$8,000,000
Non Direct Connection Network Upgrades	\$1,900,000
Total Costs	\$10,250,000

In addition, the AF1-117 project may be responsible for a contribution to the following costs

Description	Total Cost
System Upgrades	\$60,755,000

Cost allocations for these upgrades will be provided in the System Impact Study Report.

3 Transmission Owner Scope of Work

4 Attachment Facilities

The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
345 kV Revenue Metering	\$350,000
Total Attachment Facility Costs	\$350,000

5 Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Construct a new three (3) circuit breaker 345 kV switching station physically configured in a breaker and half bus arrangement but operated as a ring-bus (see Single Line Diagram). Installation of associated protection and control equipment, 345 kV line risers and SCADA will also be required.	\$8,000,000
Total Direct Connection Facility Costs	\$8,000,000

6 Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Upgrade line protections & Controls at the Atlanta 345kV Substation	\$350,000
Upgrade line protections & Controls at the Stuart 345kV Substation	\$350,000
345 kV Transmission Line Cut In	\$1,200,000
Total Non-Direct Connection Facility Costs	\$1,900,000

7 Incremental Capacity Transfer Rights (ICTRs)

Will be determined at a later study phase

8 Schedule

It is anticipated that the time between receipt of executed Agreements and Commercial Operation may range from 12 to 18 months if no line work is required. If line work is required, construction time would generally be between 24 to 36 months after Agreement execution.

9 Interconnection Customer Requirements

It is understood that the Interconnection Customer is responsible for all costs associated with this interconnection. The costs above are reimbursable to AEP. The cost of the Interconnection Customer's generating plant and the costs for the line connecting the generating plant to the AEP Transmission circuit are not included in this report; these are assumed to be the Interconnection Customer's responsibility.

The Generation Interconnection Agreement does not in or by itself establish a requirement for American Electric Power to provide power for consumption at the developer's facilities. A separate agreement may be reached with the local utility that provides service in the area to ensure that infrastructure is in place to meet this demand and proper metering equipment is installed. It is the responsibility of the developer to contact the local service provider to determine if a local service agreement is required.

Requirement from the PJM Open Access Transmission Tariff:

1. An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.
2. The Interconnection Customer may be required to install and/or pay for metering as necessary to properly track real time output of the facility as well as installing metering which shall be used for billing purposes. See Section 8 of Appendix 2 to the Interconnection Service Agreement as well as Section 4 of PJM Manual 14D for additional information.

10 Revenue Metering and SCADA Requirements

10.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

10.2 AEP Requirements

The Interconnection Customer will be required to comply with all AEP Revenue Metering Requirements for Generation Interconnection Customers. The Revenue Metering Requirements may be found within the “Requirements for Connection of New Facilities or Changes to Existing Facilities Connected to the AEP Transmission System” document located at the following link:

<http://www.pjm.com/~media/planning/plan-standards/private-aep/aep-interconnection-requirements.ashx>

11 Network Impacts

The Queue Project AF1-117 was evaluated as a 200.0 MW (Capacity 152.9 MW) injection tapping the Atlanta to Stuart 345 kV line in the AEP area. Project AF1-117 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AF1-117 was studied with a commercial probability of 0.53. Potential network impacts were as follows:

Summer Peak Load Flow

12 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
41201290	253110	09ADKINS	345.0	DAY	243453	05BEATTY	345.0	AEP	1	Base Case	single	1233.0	94.93	101.39	DC	80.27

13 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
43444510	243453	05BEATTY	345.0	AEP	244022	05COLE	345.0	AEP	1	AEP_P4_#3195_05BEATTY 345_304E	breaker	1203.0	95.81	100.6	DC	57.51
41535938	253110	09ADKINS	345.0	DAY	243453	05BEATTY	345.0	AEP	1	DAY_P4_L34526-3	breaker	1372.0	99.87	107.63	DC	106.22

14 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
43444450	243453	05BEATTY	345.0	AEP	243454	05BIXBY	345.0	AEP	1	AEP_P4_#3196_05BEATTY 345_302E	breaker	1203.0	104.36	110.04	DC	68.3
43444451	243453	05BEATTY	345.0	AEP	243454	05BIXBY	345.0	AEP	1	AEP_P4_#10715_05COLE 345_C	breaker	1203.0	104.18	109.62	DC	65.38
40985852	253110	09ADKINS	345.0	DAY	243453	05BEATTY	345.0	AEP	1	DAY_P7_495	tower	1372.0	102.6	110.37	DC	106.43

15 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
4344480 2	24345 3	05BEATT Y	345. 0	AEP	24345 4	05BIXBY	345. 0	AEP	1	AEP_P1- 2_#714	operation	1203. 0	96.82	101.99	DC	62.15
4120128 7	25311 0	09ADKIN S	345. 0	DAY	24345 3	05BEATT Y	345. 0	AEP	1	DAY_P1_AC 1- 085_ST_FSA- B	operation	1372. 0	99.68	107.45	DC	106.32
4120128 9	25311 0	09ADKIN S	345. 0	DAY	24345 3	05BEATT Y	345. 0	AEP	1	Base Case	operation	1233. 0	96.23	104.78	DC	105.0

16 System Reinforcements

ID	Index	Facility	Upgrade Description	Cost
41201290,41535938, 40985852	1	09ADKINS 345.0 kV - 05BEATTY 345.0 kV Ckt 1	<p>AEPO0004a (234) : Rebuild 13.0 miles of 2-983.1 ACAR 30/7 Rail 5 conductor on Beatty-Adkins circuit (3.7 miles of double circuit construction). Bare minimum conductor is 2-1024.5 ACAR 30/7 Rail1 which provide no additional margin. Upgrade other elements previously rated by DP&L. Ratings validation of this equipment is currently underway. This will require relay upgrades at Beatty and Adkins. Project Type : FAC Cost : \$55,000,000 Time Estimate : 24-36 Months</p> <p>AEPO0004b (235) : Replace equipment at Adkins station formerly owned by DP&L that is now owned by AEP. Further investigation is required to see exactly what equipment is to be replaced and whether it can be simply re-rated according to AEP's standards. Project Type : FAC Cost : \$1,000,000 Time Estimate : 36-48 Months</p>	\$56,000,000
43444450,43444451	3	05BEATTY 345.0 kV - 05BIXBY 345.0 kV Ckt 1	<p>AEPO0003a (233) : Upgrade/Replace Three 345kV 1600A switches and 2-954 ACSR risers at Beatty station Project Type : FAC Cost : \$1,500,000 Time Estimate : 12-18 Months</p> <p>AEPO0003b (377) : 1) A sag study will be required on the 9.5 miles of ACSR ~ 954 ~ 45/7 ~ Bundled - Conductor Section 1 to mitigate the overload. Depending on the sag study results, the cost for this upgrade is expected to be between \$38,000 (no remediation required, just sag study) and \$19 million (complete line reconductor/rebuild). New rating after sag study: S/N:1409 S/E: 1887 . Time Estimate: a) Sag Study: 6-12 months. b) Rebuild: The standard time required for construction differs from state to state. An approximate construction time would be 24 to 36 months after signing an interconnection agreement. Project Type : FAC Cost : \$38,000 Time Estimate : 12-18 Months</p> <p>AEPO0003c (378) : Upgrade/Replace four 345kV 2000A Bixby switches Project Type : FAC Cost : \$1,500,000 Time Estimate : 12-18 Months</p> <p>AEPO0003d (379) : Replace 2-954 ACSR risers at Bixby station Project Type : FAC Cost : \$175,000 Time Estimate : 12-19 Months</p>	\$3,213,000

ID	Index	Facility	Upgrade Description	Cost
43444510	2	05BEATTY 345.0 kV - 05COLE 345.0 kV Ckt 1	<p>AEPO0001a (229) : Upgrade/Replace 3-345kV 1600A switches at Beatty station Project Type : FAC Cost : \$1,500,000 Time Estimate : 12-18 Months</p> <p>AEPO0001b (230) : 1) A sag study will be required on the 9.7 miles of ACSR ~ 954 ~ 45/7 ~ Bundled - Conductor Section 1 to mitigate the overload. Depending on the sag study results, the cost for this upgrade is expected to be between \$42,000 (no remediation required, just sag study) and \$40 million (complete line reconductor/rebuild). New rating after sag study: S/N:1409 S/E: 1887 . Time Estimate: a) Sag Study: 6-12 months. b) Rebuild: The standard time required for construction differs from state to state. An approximate construction time would be 24 to 36 months after signing an interconnection agreement. Project Type : FAC Cost : \$42,000 Time Estimate : 6-12 Months</p>	\$1,542,000
			TOTAL COST	\$60,755,000

17 Flow Gate Details

The following indices contain additional information about each flowgate presented in the body of the report. For each index, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

17.1 Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
40985852	253110	09ADKINS	DAY	243453	05BEATTY	AEP	1	DAY_P7_495	tower	1372.0	102.6	110.37	DC	106.43

Bus #	Bus	MW Impact
253110	09ADKINS	49.4595
342960	1SPURLK2G	8.1047
342966	1SPURLK4G	4.2589
923522	AB1-169 C OP	159.9950
925921	AC1-068 C	18.7459
925922	AC1-068 E	8.7665
925931	AC1-069 C	18.7459
925932	AC1-069 E	8.7665
926061	AC1-085 C	22.1084
926062	AC1-085 E	36.0716
926791	AC1-165 C	18.5254
926792	AC1-165 E	8.9870
926801	AC1-166 C	18.5254
926802	AC1-166 E	8.9870
930062	AB1-014 E	5.7627
932381	AC2-055 C	1.5076
932382	AC2-055 E	2.4597
932421	AC2-060 C	5.3453
932422	AC2-060 E	3.0068
932461	AC2-066 C	2.1192
932462	AC2-066 E	3.4576
932651	AC2-087 C O1 (Withdrawn : 01/15/2020)	3.9589
932652	AC2-087 E O1 (Withdrawn : 01/15/2020)	3.1404
932661	AC2-088 C O1	3.3103
932662	AC2-088 E O1	2.7241
934491	AD1-073 C	1.1025
934492	AD1-073 E	0.5679
935031	AD1-136 C	0.4655
935032	AD1-136 E	0.3966
936251	AD2-031 C O1	1.4141
936252	AD2-031 E O1	2.3072
938271	AE1-040 C O1	4.0262
938272	AE1-040 E O1	2.0258
938921	AE1-120	3.2718
939141	AE1-144 C O1	6.2123
939142	AE1-144 E O1	3.0829
940531	AE2-038 C O1	4.1441
940532	AE2-038 E O1	2.0527
942091	AE2-221 C	26.1810
942092	AE2-221 E	17.4540
942981	AE2-320 C O1	36.8853
942982	AE2-320 E O1	18.2497
943191	AE2-319 C O1	36.8853

Bus #	Bus	MW Impact
943192	AE2-319 E O1	18.2497
944521	AF1-117 C	81.3627
944522	AF1-117 E	25.0633
944941	AF1-159	0.4339
945681	AF1-233 C O1	6.2302
945682	AF1-233 E O1	3.0779
945911	AF1-256 C	2.0132
945912	AF1-256 E	1.3421
946171	AF1-282 C	8.7270
946172	AF1-282 E	5.8180
946181	AF1-283 C	11.3451
946182	AF1-283 E	7.5634
LGEE	LGEE	1.8227
CPL	CPL	0.2044
WEC	WEC	0.2035
CBM-W2	CBM-W2	11.2285
NY	NY	0.5336
CBM-W1	CBM-W1	4.2909
TVA	TVA	2.0076
O-066	O-066	6.2765
CBM-S2	CBM-S2	3.2137
CBM-S1	CBM-S1	15.0037
G-007	G-007	0.9672
MEC	MEC	1.4635

17.2 Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
43444510	243453	05BEATTY	AEP	244022	05COLE	AEP	1	AEP_P4_#3195_05BEATTY 345_304E	breaker	1203.0	95.81	100.6	DC	57.51

Bus #	Bus	MW Impact
247964	Y1-063 BAT	0.3062
250164	08BKJDB1	0.1221
250165	08BKJDB2	0.1221
251827	WILLYESP	0.3864
251828	CLNTESP1	0.4043
251829	CLNTESP2	0.2696
253110	09ADKINS	25.3067
253261	09MON D	0.2050
902531	W2-040 C (Withdrawn : 01/23/2020)	0.7288
902532	W2-040 E (Withdrawn : 01/23/2020)	1.1891
904722	V4-073 E	0.1611
913222	Y1-054 E	1.2662
918802	AA1-099 E	0.2696
923522	AB1-169 C OP	109.8438
925242	AB2-178 E (Withdrawn : 12/10/2019)	1.2092
925921	AC1-068 C	10.4859
925922	AC1-068 E	4.9037
925931	AC1-069 C	10.4859
925932	AC1-069 E	4.9037
925981	AC1-074 C O1	3.4396
925982	AC1-074 E O1	1.4741
926011	AC1-078 C O1	4.7584
926012	AC1-078 E O1	7.9307
926061	AC1-085 C	20.0108
926062	AC1-085 E	32.6492
926101	AC1-089 C O1	3.6623
926102	AC1-089 E O1	5.9754
926791	AC1-165 C	10.3626
926792	AC1-165 E	5.0271
926801	AC1-166 C	10.3626
926802	AC1-166 E	5.0271
926951	AC1-182	1.4999
930062	AB1-014 E	6.7608
932381	AC2-055 C	1.7366
932382	AC2-055 E	2.8334
932421	AC2-060 C	6.1575
932422	AC2-060 E	3.4636
932431	AC2-061 C	3.7241
932432	AC2-061 E	3.7754
932461	AC2-066 C	2.4862
932462	AC2-066 E	4.0565
932481	AC2-068 C	2.4559

Bus #	Bus	MW Impact
932482	AC2-068 E	4.0221
932551	AC2-075 C	0.8169
932552	AC2-075 E	0.4115
932651	AC2-087 C O1 (Withdrawn : 01/15/2020)	4.5604
932652	AC2-087 E O1 (Withdrawn : 01/15/2020)	3.6176
932661	AC2-088 C O1	3.4190
932662	AC2-088 E O1	2.8136
934491	AD1-073 C	1.2700
934492	AD1-073 E	0.6542
934561	AD1-081 C	0.9517
934562	AD1-081 E	0.4903
935031	AD1-136 C	0.4808
935032	AD1-136 E	0.4096
935041	AD1-140 C O1	8.3962
935042	AD1-140 E O1	6.9414
936251	AD2-031 C O1	2.3877
936252	AD2-031 E O1	3.8958
936381	AD2-048 C	2.8334
936382	AD2-048 E	1.4137
938051	AE1-007 C	0.7043
938052	AE1-007 E	1.1492
938271	AE1-040 C O1	4.3077
938272	AE1-040 E O1	2.1675
938921	AE1-120	3.8384
939141	AE1-144 C O1	5.8769
939142	AE1-144 E O1	2.9165
940531	AE2-038 C O1	3.9204
940532	AE2-038 E O1	1.9419
941411	AE2-138 C	11.9578
941412	AE2-138 E	4.4227
941511	AE2-148 C	154.4305
941512	AE2-148 E	69.8494
941981	AE2-210 C O1	4.1203
941982	AE2-210 E O1	1.5498
942061	AE2-218 C	7.9874
942062	AE2-218 E	5.4254
942091	AE2-221 C	24.9318
942092	AE2-221 E	16.6212
942521	AE2-267 C O1	1.1814
942522	AE2-267 E O1	0.7303
942951	AE2-315	2.4419
942981	AE2-320 C O1	20.6326
942982	AE2-320 E O1	10.2084
943111	AE2-339 C	1.5465
943112	AE2-339 E	0.7617
943191	AE2-319 C O1	20.6326
943192	AE2-319 E O1	10.2084
943201	AE2-318 C	5.5321
943202	AE2-318 E	2.7002
943771	AF1-045	2.2775
944521	AF1-117 C	43.9679
944522	AF1-117 E	13.5441

Bus #	Bus	MW Impact
944621	AF1-127 C O1	1.7620
944622	AF1-127 E O1	0.8678
944941	AF1-159	1.3824
945631	AF1-228 C	38.2221
945632	AF1-228 E	25.4814
945681	AF1-233 C O1	5.8720
945682	AF1-233 E O1	2.9009
945821	AF1-247 C (Withdrawn : 01/27/2020)	1.1814
945822	AF1-247 E (Withdrawn : 01/27/2020)	0.7303
945841	AF1-249 C	0.5126
945842	AF1-249 E	0.2412
945861	AF1-251 C	4.3749
945862	AF1-251 E	2.9166
945911	AF1-256 C	1.8921
945912	AF1-256 E	1.2614
946102	AF1-275 BAT	18.6700
946171	AF1-282 C	7.8990
946172	AF1-282 E	5.2660
946181	AF1-283 C	10.2687
946182	AF1-283 E	6.8458
946511	AF1-315 C O1	1.5829
946512	AF1-315 E O1	1.0553
LGEE	LGEE	2.6157
CPL	CPL	0.2514
WEC	WEC	0.4158
CBM-W2	CBM-W2	17.8624
NY	NY	0.7250
CBM-W1	CBM-W1	11.5217
TVA	TVA	2.7944
O-066	O-066	8.6486
CBM-S2	CBM-S2	4.1443
CBM-S1	CBM-S1	21.1040
G-007	G-007	1.3322
MEC	MEC	2.6028

17.3 Index 3

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
43444450	243453	05BEATTY	AEP	243454	05BIXBY	AEP	1	AEP_P4_#3196_05BEATTY 345_302E	breaker	1203.0	104.36	110.04	DC	68.3

Bus #	Bus	MW Impact
250164	08BKJDB1	0.1465
250165	08BKJDB2	0.1465
251827	WILLYESP	0.4700
251828	CLNTESP1	0.4757
251829	CLNTESP2	0.3171
253110	09ADKINS	30.1137
253261	09MON D	0.2593
902531	W2-040 C (Withdrawn : 01/23/2020)	0.9122
902532	W2-040 E (Withdrawn : 01/23/2020)	1.4882
904722	V4-073 E	0.2005
913222	Y1-054 E	1.5322
918802	AA1-099 E	0.3171
923522	AB1-169 C OP	128.8336
925242	AB2-178 E (Withdrawn : 12/10/2019)	1.4507
925921	AC1-068 C	12.4535
925922	AC1-068 E	5.8239
925931	AC1-069 C	12.4535
925932	AC1-069 E	5.8239
925981	AC1-074 C O1	4.0931
925982	AC1-074 E O1	1.7542
926011	AC1-078 C O1	7.8899
926012	AC1-078 E O1	13.1498
926061	AC1-085 C	23.9628
926062	AC1-085 E	39.0972
926101	AC1-089 C O1	4.2166
926102	AC1-089 E O1	6.8797
926791	AC1-165 C	12.3070
926792	AC1-165 E	5.9704
926801	AC1-166 C	12.3070
926802	AC1-166 E	5.9704
926951	AC1-182	1.7969
930062	AB1-014 E	8.0585
932381	AC2-055 C	1.8528
932382	AC2-055 E	3.0229
932421	AC2-060 C	6.5693
932422	AC2-060 E	3.6953
932431	AC2-061 C	4.2851
932432	AC2-061 E	4.3441
932461	AC2-066 C	2.9634
932462	AC2-066 E	4.8351
932481	AC2-068 C	3.1003
932482	AC2-068 E	5.0775

Bus #	Bus	MW Impact
932551	AC2-075 C	0.9721
932552	AC2-075 E	0.4897
932651	AC2-087 C O1 (Withdrawn : 01/15/2020)	4.8654
932652	AC2-087 E O1 (Withdrawn : 01/15/2020)	3.8595
932661	AC2-088 C O1	4.0470
932662	AC2-088 E O1	3.3304
934491	AD1-073 C	1.3549
934492	AD1-073 E	0.6980
934561	AD1-081 C	1.5780
934562	AD1-081 E	0.8129
935031	AD1-136 C	0.5691
935032	AD1-136 E	0.4848
935041	AD1-140 C O1	11.5264
935042	AD1-140 E O1	9.5291
936251	AD2-031 C O1	2.4065
936252	AD2-031 E O1	3.9264
936381	AD2-048 C	3.3665
936382	AD2-048 E	1.6797
938051	AE1-007 C	0.8892
938052	AE1-007 E	1.4507
938271	AE1-040 C O1	4.0620
938272	AE1-040 E O1	2.0439
938921	AE1-120	4.5751
939141	AE1-144 C O1	6.9240
939142	AE1-144 E O1	3.4361
940531	AE2-038 C O1	4.6189
940532	AE2-038 E O1	2.2879
941411	AE2-138 C	14.2019
941412	AE2-138 E	5.2528
941511	AE2-148 C	184.4227
941512	AE2-148 E	83.4149
941981	AE2-210 C O1	4.8936
941982	AE2-210 E O1	1.8407
942051	AE2-217 C	9.8015
942052	AE2-217 E	6.5343
942061	AE2-218 C	10.6174
942062	AE2-218 E	7.2118
942091	AE2-221 C	30.1050
942092	AE2-221 E	20.0700
942521	AE2-267 C O1	1.4378
942522	AE2-267 E O1	0.8888
942621	AE2-278 C	6.7842
942622	AE2-278 E	4.5253
942951	AE2-315	3.0392
942981	AE2-320 C O1	24.5041
942982	AE2-320 E O1	12.1239
943111	AE2-339 C	1.8424
943112	AE2-339 E	0.9075
943191	AE2-319 C O1	24.5041
943192	AE2-319 E O1	12.1239
943201	AE2-318 C	6.6168
943202	AE2-318 E	3.2296

Bus #	Bus	MW Impact
943771	AF1-045	2.7241
943943	AF1-062 BAT	20.5100
944521	AF1-117 C	52.2154
944522	AF1-117 E	16.0847
944621	AF1-127 C O1	2.0938
944622	AF1-127 E O1	1.0313
944941	AF1-159	0.7384
945631	AF1-228 C	45.6007
945632	AF1-228 E	30.4005
945681	AF1-233 C O1	6.9168
945682	AF1-233 E O1	3.4171
945821	AF1-247 C (Withdrawn : 01/27/2020)	1.4378
945822	AF1-247 E (Withdrawn : 01/27/2020)	0.8888
945841	AF1-249 C	0.6205
945842	AF1-249 E	0.2920
945861	AF1-251 C	5.1973
945862	AF1-251 E	3.4649
945911	AF1-256 C	2.2292
945912	AF1-256 E	1.4861
946171	AF1-282 C	9.4590
946172	AF1-282 E	6.3060
946181	AF1-283 C	12.2967
946182	AF1-283 E	8.1978
946511	AF1-315 C O1	1.8917
946512	AF1-315 E O1	1.2611
LGEE	LGEE	3.2216
CPL	CPL	0.2156
WEC	WEC	0.7349
CBM-W2	CBM-W2	24.0458
NY	NY	0.9727
CBM-W1	CBM-W1	22.6681
TVA	TVA	3.5112
O-066	O-066	11.6256
CBM-S2	CBM-S2	4.3870
CBM-S1	CBM-S1	26.3353
G-007	G-007	1.7919
MEC	MEC	4.0472

Affected Systems

18 Affected Systems

18.1 LG&E

LG&E Impacts to be determined during later study phases (as applicable).

18.2 MISO

MISO Impacts to be determined during later study phases (as applicable).

18.3 TVA

TVA Impacts to be determined during later study phases (as applicable).

18.4 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

18.5 NYISO

NYISO Impacts to be determined during later study phases (as applicable).

Contingency Name	Contingency Definition
DAY_P1_AC1-085_ST_FSA-B	CONTINGENCY 'DAY_P1_AC1-085_ST_FSA-B' OPEN BRANCH FROM BUS 253014 TO BUS 942090 CKT 1 END
DAY_P7_495	CONTINGENCY 'DAY_P7_495' OPEN BRANCH FROM BUS 249566 TO BUS 253006 CKT 1 / 249566 08FOSTER 345 253006 09BATH 345 1 OPEN BRANCH FROM BUS 253014 TO BUS 253027 CKT 1 / 253014 09CLINTO 345 253027 09GREENE 345 1 OPEN BRANCH FROM BUS 253014 TO BUS 253013 CKT 1 / 253014 09CLINTO 345 253013 09CLINTO 69.0 1 OPEN BRANCH FROM BUS 253014 TO BUS 253013 CKT 2 / 253014 09CLINTO 345 253013 09CLINTO 69.0 1 END
AEP_P1-2_#714	CONTINGENCY 'AEP_P1-2_#714' OPEN BRANCH FROM BUS 244022 TO BUS 243457 CKT 1 / 244022 05COLE 345 243457 05HAYDEN 345 1 END
AEP_P4_#10715_05COLE 345_C	CONTINGENCY 'AEP_P4_#10715_05COLE 345_C' OPEN BRANCH FROM BUS 244022 TO BUS 243457 CKT 1 / 244022 05COLE 345 243457 05HAYDEN 345 1 OPEN BRANCH FROM BUS 244022 TO BUS 244023 CKT 1 / 244022 05COLE 345 244023 05COLE 138 1 END
DAY_P4_L34526-3	CONTINGENCY 'DAY_P4_L34526-3' OPEN LINE FROM BUS 253027 TO BUS 253006 CKT 1 /* 09GREENE 345 - 09BATH 345 OPEN LINE FROM BUS 253027 TO BUS 253014 CKT 1 /* 09GREENE 345 - 09CLINTO 345 OPEN LINE FROM BUS 253014 TO BUS 253013 CKT 1 /* 09CLINTON 69 - 09CLINTO 345 OPEN LINE FROM BUS 253014 TO BUS 253013 CKT 2 /* 09CLINTON 69 - 09CLINTO 345 END
Base Case	
AEP_P4_#3196_05BEATTY 345_302E	CONTINGENCY 'AEP_P4_#3196_05BEATTY 345_302E' OPEN BRANCH FROM BUS 243453 TO BUS 244022 CKT 1 / 243453 05BEATTY 345 244022 05COLE 345 1 OPEN BRANCH FROM BUS 243453 TO BUS 243468 CKT 4 / 243453 05BEATTY 345 243468 05BEATTX 138 4 END
AEP_P4_#3195_05BEATTY 345_304E	CONTINGENCY 'AEP_P4_#3195_05BEATTY 345_304E' OPEN BRANCH FROM BUS 243453 TO BUS 243454 CKT 1 / 243453 05BEATTY 345 243454 05BIXBY 345 1 OPEN BRANCH FROM BUS 243453 TO BUS 243468 CKT 4 / 243453 05BEATTY 345 243468 05BEATTX 138 4 END

Short Circuit

19 Short Circuit

The following Breakers are overduty

Bus Number	Bus Name	BREAKER	Type	Capacity (Amps)	Duty Percentage Post Queue	Duty Percentage Pre Queue