



Generation Interconnection
Combined Feasibility / System Impact Study Report
for
Queue Project AF1-260
ALLENWOOD-LARRABEE 2 34.5 KV
1 MW Capacity / 0 MW Energy

January, 2020

Table of Contents

| | | |
|-------|---|----|
| 1 | Introduction..... | 4 |
| 2 | Preface..... | 4 |
| 3 | General | 5 |
| 3.1 | Point of Interconnection | 5 |
| 3.2 | Cost Summary..... | 5 |
| 4 | Attachment Facilities | 6 |
| 5 | Direct Connection Cost Estimate..... | 6 |
| 6 | Non-Direct Connection Cost Estimate..... | 6 |
| 7 | Transmission Owner Analysis..... | 6 |
| 7.1 | Power Flow Analysis | 6 |
| 8 | Interconnection Customer Requirements..... | 6 |
| 8.1 | System Protection..... | 6 |
| 8.2 | Compliance Issues and Interconnection Customer Requirements | 7 |
| 8.3 | Power Factor Requirements..... | 7 |
| 9 | Revenue Metering and SCADA Requirements | 8 |
| 9.1 | PJM Requirements | 8 |
| 9.1.1 | Meteorological Data Reporting Requirement..... | 8 |
| 9.2 | FirstEnergy Requirements | 8 |
| 10 | Network Impacts..... | 8 |
| 10.1 | Generation Deliverability | 10 |
| 10.2 | Multiple Facility Contingency | 10 |
| 10.3 | Contribution to Previously Identified Overloads..... | 10 |
| 10.4 | Potential Congestion due to Local Energy Deliverability..... | 10 |
| 10.5 | System Reinforcements..... | 10 |
| 11 | Affected Systems | 12 |
| 11.1 | LG&E..... | 12 |
| 11.2 | MISO | 12 |
| 11.3 | TVA..... | 12 |
| 11.4 | Duke Energy Progress..... | 12 |
| 11.5 | NYISO | 12 |
| 12 | Short Circuit..... | 14 |

Attachment 1.....15

1 Introduction

This Combined Feasibility/System Impact Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Jersey Central Power and Light (JCPL).

2 Preface

The intent of the Combined Feasibility/System Impact Study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See

Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model. The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

The Combined Feasibility/System Impact Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

3 General

The Interconnection Customer (IC), has proposed an uprate to an existing solar generating facility (previous queue number W3-079) located in, Monmouth County, New Jersey. This projects requests is an increase of 1 MW to the output being recognized by PJM as Capacity. The output of the installed facilities has not changed with this request and will remain at 7 MW with 3.6 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is 07/01/2020. This study does not imply a TO commitment to this in-service date.

| | |
|----------------------------|-------------------------------------|
| Queue Number | AF1-260 |
| Project Name | ALLENWOOD-LARRABEE 2 34.5 KV |
| State | New Jersey |
| County | Monmouth |
| Transmission Owner | JCPL |
| MFO | 7 |
| MWE | 0 |
| MWC | 1 |
| Fuel | Solar |
| Basecase Study Year | 2023 |

3.1 Point of Interconnection

The project Point of Interconnection (POI) is at a tapped connection to the Larrabee - Allenwood 34.5 kV line in the JCPL area.

Attachment 1 shows a one-line diagram of the connection facilities. IC will be responsible for constructing all of the facilities on its side of the POI, including the Attachment facilities which connect the generator to the FE transmission system.

3.2 Cost Summary

The AF1-260 project will be responsible for the following costs:

| Description | Total Cost |
|--|-------------|
| Attachment Facilities | \$ 0 |
| Direct Connection Network Upgrade | \$ 0 |
| Non Direct Connection Network Upgrades | \$ 0 |
| Total Costs | \$ 0 |

In addition, the AF1-260 project may be responsible for a contribution to the following costs

| Description | Total Cost |
|-----------------|------------|
| System Upgrades | \$ 0 |

The costs provided above exclude the Contribution in Aid of Construction (“CIAC”) Federal Income Tax Gross Up charge. If, at a future date, it is determined that the CIAC Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

4 Attachment Facilities

There is no Attachment Facility scope of work required.

5 Direct Connection Cost Estimate

There is no Direct Connection scope of work required.

6 Non-Direct Connection Cost Estimate

There is no Non-Direct Connection scope of work required.

7 Transmission Owner Analysis

7.1 Power Flow Analysis

FE performed an analysis of its underlying transmission < 100 kV system. The AF1-260 project did not contribute to any overloads on the FE transmission < 100 kV system.

8 Interconnection Customer Requirements

8.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in FE’s “Requirements for Transmission Connected Facilities” document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. Preliminary

Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

8.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated 34.5 kV circuit breaker to protect the AF1-260 generator lead line. A single circuit breaker must be used to protect this line; if the project has several GSU transformers, the individual GSU transformer breakers cannot be used to protect this line.
2. The purchase and installation of the minimum required FE generation interconnection relaying and control facilities. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition ("SCADA") equipment to provide information in a compatible format to the FE Transmission System Control Center.
4. Compliance with the FE and PJM generator power factor and voltage control requirements.
5. The execution of a back-up service agreement to serve the customer load supplied from the AF1-260 generation project metering point when the units are out-of-service. This assumes the intent of the IC is to net the generation with the load.

The IC will also be required to meet all PJM, ReliabilityFirst, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and ReliabilityFirst audits. Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the FE system.

8.3 Power Factor Requirements

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the FE transmission system.

9 Revenue Metering and SCADA Requirements

9.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

9.1.1 Meteorological Data Reporting Requirement

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Temperature (degrees Fahrenheit)
- Atmospheric pressure (hectopascals)
- Irradiance
- Forced outage data

9.2 FirstEnergy Requirements

The IC will be required to comply with all FE revenue metering requirements for generation interconnection customers which can be found in FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>

10 Network Impacts

The Queue Project AF1-260 was evaluated as a 0 MW (Capacity 1.0 MW) injection as an uprate to W3-079 tapping the Allenwood to Larrabee 34.5 kV line in the JCPL area. Project AF1-260 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AF1-260 was studied with a commercial probability of 100%. Potential network impacts were as follows:

Summer Peak Load Flow

10.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

10.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

10.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

10.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

10.5 System Reinforcements

None

Affected Systems

11 Affected Systems

11.1 LG&E

LG&E Impacts to be determined during later study phases (as applicable).

11.2 MISO

MISO Impacts to be determined during later study phases (as applicable).

11.3 TVA

TVA Impacts to be determined during later study phases (as applicable).

11.4 Duke Energy Progress

Duke Energy Progress Impacts to be determined during later study phases (as applicable).

11.5 NYISO

NYISO Impacts to be determined during later study phases (as applicable).

Short Circuit

12 Short Circuit

The following Breakers are overdutied:

None

Attachment 1

System Configuration

