



**Generation Interconnection
Feasibility Study Report
for
Queue Project AG1-263
GLOUCESTER 230 KV
8 MW Capacity / 20 MW Energy**

January 2021

Table of Contents

1	Introduction.....	3
2	Preface.....	3
3	General	4
4	Point of Interconnection.....	4
5	Cost Summary	4
6	Transmission Owner Scope of Work	5
7	Schedule.....	5
8	Revenue Metering and SCADA Requirements	5
8.1	PJM Requirements	5
8.2	Interconnected Transmission Owner Requirements.....	5
9	Summer Peak - Load Flow Analysis	6
9.1	Generation Deliverability	6
9.2	Multiple Facility Contingency	6
9.3	Contribution to Previously Identified Overloads.....	6
9.4	Potential Congestion due to Local Energy Deliverability.....	6
9.5	System Reinforcements - Summer Peak Load Flow - Primary POI.....	7
10	Short Circuit Analysis.....	7
10.1	System Reinforcements - Short Circuit.....	7
11	Affected Systems	7
11.1	NYISO	7

1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is PSEG.

2 Preface

The intent of the Feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

3 General

The Interconnection Customer (IC) has proposed a Storage generating facility co-located with the Camden Cogeneration Facility in Camden County, New Jersey. The installed facilities will have a total capability of 20 MW with 8 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is October 31, 2021. This study does not imply a TO commitment to this in-service date.

Queue Number	AG1-263
Project Name	GLOUCESTER 230 KV
State	New Jersey
County	Camden
Transmission Owner	PSEG
MFO	20
MWE	20
MWC	8
Fuel	Storage
Basecase Study Year	2024

Any new service customers who can feasibly be commercially operable prior to June 1st of the basecase study year are required to request interim deliverability analysis.

4 Point of Interconnection

AG1-263 will interconnect with the PSEG Transmission system at the Gloucester 230 kV, behind the same Point of Interconnection as the existing Camden Cogen Facility.

5 Cost Summary

The AG1-263 project will be responsible for the following costs:

Description	Total Cost
Total Physical Interconnection Costs	\$380,000
Total System Network Upgrade Costs	\$0
Total Costs	\$380,000

This cost excludes a Federal Income Tax Gross Up charges. This tax may or may not be charged based on whether this project meets the eligibility requirements of IRS Notice 2016-36, 2016-25 I.R.B. (6/20/2016). If at a future date it is determined that the Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

6 Transmission Owner Scope of Work

The total physical interconnection costs is given in the table below:

Description	Total Cost
Attachment Facilities Installation of revenue grade metering. Relay modification at Gloucester Switch	\$380,000
Direct Connection Network Upgrades	\$0
Non-Direct Connection Network Upgrades	\$0 -
Total Physical Interconnection Costs	\$380,000

7 Schedule

The estimated time to complete the scope of work is 15 months after the relevant agreement(s) are signed and PSE&G receives Notice to Proceed. This duration does not include time for the IC to obtain necessary permits, and easement, and approvals for Interconnection Facilities. The developer must obtain these approvals prior to PSE&G installation. PSE&G's schedule assumes reasonable efforts will be made by the Interconnection Customer to meet the proposed schedule consequently, Delays to the Interconnection Customer's activities may lead to delays/changes to the TO's schedule as well.

8 Revenue Metering and SCADA Requirements

8.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

8.2 Interconnected Transmission Owner Requirements

The IC will be required to comply with all Interconnected Transmission Owner's revenue metering requirements for generation interconnection customers located at the following link:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/>

9 Summer Peak - Load Flow Analysis

The Queue Project AG1-263 was evaluated as a 20 MW (Capacity 8.0 MW) injection at the Camden 230 kV in the PSEG area. Project AG1-263 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AG1-263 was studied with a commercial probability of 53.0 %. Potential network impacts were as follows:

9.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

9.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

9.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

9.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

9.5 System Reinforcements - Summer Peak Load Flow - Primary POI

None

10 Short Circuit Analysis

The following Breakers are overdutied:

None

10.1 System Reinforcements - Short Circuit

None

11 Affected Systems

11.1 NYISO

NYISO Impacts to be determined during later study phases (as applicable).