



**Generation Interconnection
Feasibility Study Report
for
Queue Project AG1-404
Blue Mound-Chestnut 345 KV
100 MW Capacity / 100 MW Energy**

October 2021

Table of Contents

1	Introduction.....	4
2	Preface.....	4
3	General.....	5
4	Point of Interconnection.....	6
4.1	Primary.....	6
4.2	Secondary.....	6
5	Cost Summary	6
6	Transmission Owner Scope of Work.....	7
7	Schedule.....	8
8	Transmission Owner Analysis.....	8
9	Interconnection Customer Requirements.....	8
10	Revenue Metering and SCADA Requirements	8
10.1	PJM Requirements	8
10.2	Meteorological Data Reporting Requirements	8
10.3	Interconnected Transmission Owner Requirements.....	8
11	Summer Peak - Load Flow Analysis - Primary POI.....	9
11.1	Generation Deliverability	9
11.2	Multiple Facility Contingency	9
11.3	Contribution to Previously Identified Overloads.....	9
11.4	Potential Congestion due to Local Energy Deliverability.....	10
11.5	System Reinforcements.....	12
11.6	Flow Gate Details.....	14
11.6.1	Index 1	15
11.6.2	Index 2	18
11.6.3	Index 3	21
11.6.4	Index 4	25
11.6.5	Index 5	28
11.6.6	Index 6	32
11.6.7	Index 7	37
11.6.8	Index 8	41
11.6.9	Index 9	44

11.6.10	Index 10.....	48
11.7	Queue Dependencies	51
11.8	Contingency Descriptions.....	54
12	Short Circuit Analysis – Primary POI.....	56
13	Summer Peak - Load Flow Analysis - Secondary POI	56
13.1	Generation Deliverability	56
13.2	Multiple Facility Contingency	56
13.3	Contribution to Previously Identified Overloads.....	56
13.4	Potential Congestion due to Local Energy Deliverability.....	57
14	Affected Systems	59
14.1	MISO	59

1 Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 36.2, as well as the Feasibility Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is ComEd.

2 Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

The conduct of light load analysis as required under the PJM planning process is not performed during the Generation Interconnection Feasibility Study phase of the PJM study process. Additional reinforcement requirements for this Interconnection Request may be defined during the conduct of the light load analysis which shall be performed following execution of the System Impact Study agreement.

3 General

The Interconnection Customer (IC), has proposed a Storage generating facility located in McLean County, Illinois. The installed facilities will have a total capability of 100 MW with 100 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is September 24, 2024. This study does not imply a TO commitment to this in-service date.

Queue Number	AG1-404
Project Name	Blue Mound-Chestnut 345 KV
State	Illinois
County	McLean
Transmission Owner	ComEd
MFO	100
MWE	100
MWC	100
Fuel	Storage
Basecase Study Year	2024

Any new service customers who can feasibly be commercially operable prior to June 1st of the basecase study year are required to request interim deliverability analysis.

4 Point of Interconnection

4.1 Primary

AG1-404 proposes a primary Point of Interconnection with the ComEd on transmission system tapping the Blue Mound to Chestnut 345 kV line. Queue Position AG1-404 proposes to connect 'Pumpkin Vine BESS III' with 100 MW battery storage at Pumpkin Vine Wind I to be built under PJM queue AG1-399. The proposed addition is behind the Point-of-Interconnection between ComEd and Pumpkin Vine Wind I.

4.2 Secondary

AG1-404 proposes a secondary Point of Interconnection with the ComEd on transmission system tapping the Brokaw to Mount Pulaski 345 kV line.

5 Cost Summary

The AG1-404 project will be responsible for the following costs:

Description	Total Cost
Total Physical Interconnection Costs	\$250,000
Allocation towards System Network Upgrade Costs (PJM Identified - Summer Peak)*	\$349,200,000
Total Costs	\$349,450,000

This cost excludes a Federal Income Tax Gross Up charges. This tax may or may not be charged based on whether this project meets the eligibility requirements of IRS Notice 88-129. If at a future date it is determined that the Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes. Cost allocations for any System Upgrades will be provided in the System Impact Study Report.

6 Transmission Owner Scope of Work

To accommodate interconnection of AG1-404; the relaying, SCADA, Communication, and metering between ComEd-owned Interconnection Substation to be built under AG1-399 and Pumpkin Vine Wind I would be reviewed and upgraded if needed. The preliminary cost estimate for the Attachment Facilities is estimated at \$ 250,000. ComEd would take approximately 18-months to review and possibly upgrade the relaying, SCADA, Communication, and metering after the ISA / ICSA are signed.

7 Schedule

See Sections 6 and 11.

8 Transmission Owner Analysis

See Sections 6 and 11.

9 Interconnection Customer Requirements

The Interconnection Customer is responsible for all design and construction related activities on the Interconnection Customer's side of the Point of Interconnection.

10 Revenue Metering and SCADA Requirements

10.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

10.2 Meteorological Data Reporting Requirements

The wind generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Wind speed (meters/second) - (Required)
- Wind direction (decimal degrees from true north) - (Required)
- Ambient air temperature (Fahrenheit) - (Required)
- Air Pressure (Hectopascals) - (Required)
- Humidity (Percent) (Accepted, not required)

10.3 Interconnected Transmission Owner Requirements

The IC will be required to comply with all Interconnected Transmission Owner's revenue metering requirements for generation interconnection customers located at the following link:

ComEd interconnection requirements can be found at <https://www.pjm.com/planning/design-engineering/totech-standards/private-comed.aspx>

11 Summer Peak - Load Flow Analysis - Primary POI

The Queue Project AG1-404 was evaluated as a 100.0 MW (Capacity 100.00 MW) injection tapping the Bluemond to Chestnut 345 kV line in the ComEd area. Project AG1-404 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AG1-404 was studied with a commercial probability of 53.0 %. Potential network impacts were as follows:

11.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None.

11.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None.

11.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC/D C	MW IMPACT
168506637	270704	LORETT O ; B	345.0	CE	939400	AE1-172 TAP	345.0	CE	1	COMED_P1-2_345-L8014_R-S-C	single	1528.0	130.72	132.94	AC	34.0
168506638	270704	LORETT O ; B	345.0	CE	939400	AE1-172 TAP	345.0	CE	1	COMED_P1-2_345-L8014_R-S-B	single	1528.0	124.91	127.13	AC	34.0
174291179	270704	LORETT O ; B	345.0	CE	939400	AE1-172 TAP	345.0	CE	1	COMED_P4_012-45-BT12-14	breaker	1528.0	243.21	245.55	AC	34.49
179431273	270704	LORETT O ; B	345.0	CE	939400	AE1-172 TAP	345.0	CE	1	COMED_P4_012-45-BT14-15	breaker	1528.0	233.04	235.34	AC	34.06
168506763	270819	MCLEAN ; R	345.0	CE	270853	PONTIAC ; R	345.0	CE	1	COMED_P1-2_345-L8002_-S	single	1819.0	101.32	102.53	AC	21.74
168506647	270852	PONTIAC ; B	345.0	CE	270704	LORETTO ; B	345.0	CE	1	COMED_P1-2_345-L8014_R-S-C	single	1528.0	130.24	132.46	AC	34.02
168506648	270852	PONTIAC ; B	345.0	CE	270704	LORETTO ; B	345.0	CE	1	COMED_P1-2_345-L8014_R-S-B	single	1528.0	124.43	126.65	AC	34.02
179431360	270852	PONTIAC ; B	345.0	CE	270704	LORETTO ; B	345.0	CE	1	COMED_P4_012-45-BT12-14	breaker	1528.0	230.32	232.63	AC	34.51
179431361	270852	PONTIAC ; B	345.0	CE	270704	LORETTO ; B	345.0	CE	1	COMED_P4_012-45-BT14-15	breaker	1528.0	222.42	224.69	AC	34.08
169733899	934720	AD1-100 TAP	345.0	CE	270926	WILTON ; B	345.0	CE	1	COMED_P1-2_345-L8014_R-S-C	single	1528.0	100.81	101.84	AC	15.92
169733844	935000	AD1-133 TAP	345.0	CE	270717	DRESDEN ; R	345.0	CE	1	COMED_P1-2_345-L11212_B-S-B	single	1656.0	116.85	118.73	AC	31.26

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJE CT LOADIN G %	POST PROJE CT LOADIN G %	AC D C	MW IMPAC T
1697338 45	93500 0	AD1-133 TAP	345.0	CE	27071 7	DRESDEN ; R	345.0	CE	1	COMED_P1-2_345-L11212_B-S-C	single	1656.0	113.58	115.45	AC	31.26
1697338 08	93940 0	AE1-172 TAP	345.0	CE	93472 0	AD1-100 TAP	345.0	CE	1	COMED_P1-2_345-L8014_R-S-C	single	1528.0	136.32	138.53	AC	34.0
1697338 09	93940 0	AE1-172 TAP	345.0	CE	93472 0	AD1-100 TAP	345.0	CE	1	COMED_P1-2_345-L8014_R-S-B	single	1528.0	130.49	132.71	AC	34.0
1742911 75	93940 0	AE1-172 TAP	345.0	CE	93472 0	AD1-100 TAP	345.0	CE	1	COMED_P4_01 2-45-BT12-14	break er	1528.0	260.28	262.62	AC	34.49
1794311 51	93940 0	AE1-172 TAP	345.0	CE	93472 0	AD1-100 TAP	345.0	CE	1	COMED_P4_01 2-45-BT14-15	break er	1528.0	250.11	252.41	AC	34.06
1700184 16	96458 0	AG1-321 TAP	345.0	CE	93500 0	AD1-133 TAP	345.0	CE	1	COMED_P1-2_345-L11212_B-S-B	single	1656.0	109.67	111.55	AC	31.26
1700184 17	96458 0	AG1-321 TAP	345.0	CE	93500 0	AD1-133 TAP	345.0	CE	1	COMED_P1-2_345-L11212_B-S-C	single	1656.0	106.36	108.48	AC	31.26
1802000 07	96534 0	AG1-399 TAP	345.0	CE	27066 8	BLUEMOUN D; B	345.0	CE	1	COMED_P4_BR O-45-BT2-3__	break er	1829.0	128.0	130.31	AC	43.07

11.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJE CT LOADIN G %	POST PROJE CT LOADIN G %	AC D C	MW IMPAC T
168506 710	2706 68	BLUEMOUN D; B	345.0	CE	2708 52	PONTIAC ; B	345.0	CE	1	COMED_P1-2_345-L8001__-S	operati on	1528.0	179.07	181.85	AC	43.0
168506 712	2706 68	BLUEMOUN D; B	345.0	CE	2708 52	PONTIAC ; B	345.0	CE	1	Base Case	operati on	1334.0	139.37	142.48	AC	43.41
168506 830	2706 85	CHESTNU T; B	345.0	CE	3488 56	7LATHAM	345.0	CE	1	COMED_P1-2_345-L8002__-S	operati on	1793.0	127.9	133.29	AC	99.94
168506 634	2707 04	LORETTO ; B	345.0	CE	9394 00	AE1-172 TAP	345.0	CE	1	COMED_P1-2_345-L8014_R-S-C	operati on	1528.0	232.41	234.7	AC	34.0
168506 636	2707 04	LORETTO ; B	345.0	CE	9394 00	AE1-172 TAP	345.0	CE	1	Base Case	operati on	1364.0	176.61	178.36	AC	23.7
168506 785	2707 96	KINCAID ; B	345.0	CE	3479 55	7AUSTIN	345.0	CE	1	COMED_P1-2_345-L2105__-S-D	operati on	1319.0	146.5	148.09	AC	21.56
168506 787	2707 96	KINCAID ; B	345.0	CE	3479 55	7AUSTIN	345.0	CE	1	Base Case	operati on	1200.0	108.7	109.93	AC	15.21
168507 068	2707 97	KINCAID ; R	345.0	CE	9424 80	AE2-261 TAP	345.0	CE	1	EXT_P12:345:AMIL::AUSTI N:PANA:1	operati on	1201.0	112.6	113.66	AC	13.19

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJE CT LOADI NG %	POST PROJE CT LOADI NG %	AC DC	MW IMPA CT
168506760	270819	MCLEAN ; R	345.0	CE	270853	PONTIAC ; R	345.0	CE	1	COMED_P1-2_345-L8002__-S	operati on	1819.0	168.26	169.47	AC	21.74
168506644	270852	PONTIAC ; B	345.0	CE	270704	LORETTO ; B	345.0	CE	1	COMED_P1-2_345-L8014__R-S-C	operati on	1528.0	221.78	224.05	AC	34.02
168506646	270852	PONTIAC ; B	345.0	CE	270704	LORETTO ; B	345.0	CE	1	Base Case	operati on	1364.0	164.87	166.61	AC	23.72
168506681	270853	PONTIAC ; R	345.0	CE	964580	AG1-321 TAP	345.0	CE	1	COMED_P1-2_345-L11212__B-S-B	operati on	1656.0	191.63	193.59	AC	31.26
168506683	270853	PONTIAC ; R	345.0	CE	964580	AG1-321 TAP	345.0	CE	1	Base Case	operati on	1334.0	128.43	129.83	AC	18.63
168506900	348847	7BROKAW	345.0	CE	270819	MCLEAN ; R	345.0	CE	1	COMED_P1-2_345-L8002__-S	operati on	1793.0	143.18	144.41	AC	21.77
179634204	934720	AD1-100 TAP	345.0	CE	270926	WILTON ; B	345.0	CE	1	934725 AD1-100 JNT 345 934730 AD1-100 TAP 345 1	operati on	1528.0	182.58	183.89	AC	19.77
169733841	935000	AD1-133 TAP	345.0	CE	270717	DRESDEN ; R	345.0	CE	1	COMED_P1-2_345-L11212__B-S-B	operati on	1656.0	209.87	211.84	AC	31.26
169733843	935000	AD1-133 TAP	345.0	CE	270717	DRESDEN ; R	345.0	CE	1	Base Case	operati on	1334.0	146.74	148.11	AC	18.63
169734167	936770	AD2-100 TAP	345.0	CE	944220	AF1-090 TAP	345.0	CE	1	EXT_P12:345:AMIL::AUSTI N:PANA:1	operati on	1201.0	136.93	137.96	AC	13.19
169733805	939400	AE1-172 TAP	345.0	CE	934720	AD1-100 TAP	345.0	CE	1	COMED_P1-2_345-L8014__R-S-C	operati on	1528.0	249.46	251.76	AC	34.0
169733807	939400	AE1-172 TAP	345.0	CE	934720	AD1-100 TAP	345.0	CE	1	Base Case	operati on	1364.0	191.18	192.93	AC	23.7
169734231	942480	AE2-261 TAP	345.0	CE	936770	AD2-100 TAP	345.0	CE	1	EXT_P12:345:AMIL::AUSTI N:PANA:1	operati on	1201.0	124.55	125.67	AC	13.19
169734110	944220	AF1-090 TAP	345.0	CE	347945	7PANA	345.0	CE	1	EXT_P12:345:AMIL::AUSTI N:PANA:1	operati on	1201.0	136.36	137.41	AC	13.19
170018413	964580	AG1-321 TAP	345.0	CE	935000	AD1-133 TAP	345.0	CE	1	COMED_P1-2_345-L11212__B-S-B	operati on	1656.0	197.74	199.69	AC	31.26
170018415	964580	AG1-321 TAP	345.0	CE	935000	AD1-133 TAP	345.0	CE	1	Base Case	operati on	1334.0	134.01	135.39	AC	18.63
170018639	965340	AG1-399 TAP	345.0	CE	270668	BLUEMOU ND; B	345.0	CE	1	COMED_P1-2_345-L8001__-S	operati on	1829.0	127.55	129.85	AC	43.03
170018692	965340	AG1-399 TAP	345.0	CE	270685	CHESTNU T; B	345.0	CE	1	COMED_P1-2_345-L8002__-S	operati on	1829.0	99.18	104.42	AC	99.96

11.5 System Reinforcements

ID	Idx	Facility	Upgrade Description	Cost
169733899	8	AD1-100 TAP 345.0 kV - WILTON ; B 345.0 kV Ckt 1	<u>ComEd</u> CE_NUN_L11212_3 : The upgrade will be to replace-2-345kV circuit breakers, upgrade a line relay scheme, station conductor upgrades at both terminals and reconductor a portion of the line along with 5-upgraded motor operated disconnect switches at TSS 112 Wilton Center. Project Type : FAC Cost : \$28,000,000 Time Estimate : 24-30 Months	\$28,000,000
174291179,179 431273,168506 637,168506638	4	LORETTO ; B 345.0 kV - AE1- 172 TAP 345.0 kV Ckt 1	<u>ComEd</u> CE_NUN_L112XX_NEW LINE: Construct a new 345kV line from TSS 93 Loretto to TSS 905 Essex (AD1-100 Interconnection Substation). New 345kV circuit breakers, relay upgrades and 345kV bus expansion. A preliminary estimate is a minimum cost estimate of \$127M with an estimated construction timeline of 6-10 years dependent on right of way access and land availability. Project Type : FAC Cost : \$127,000,000 Time Estimate : 60-120 Months	\$127,000,000
174291175,179 431151,169733 808,169733809	10	AE1-172 TAP 345.0 kV - AD1- 100 TAP 345.0 kV Ckt 1		
180200007	12	AG1-399 TAP 345.0 kV - BLUEMOUND; B 345.0 kV Ckt 1	<u>ComEd</u> CE_NUN_L9515: The upgrade will be to reconductor the line, upgrade station conductor at both stations, new relay settings. A preliminary estimate is \$40M with a construction timeline of 36 months. Upon completion, the ratings will be 1961/2112/2524/3015 MVA (SN/SLTE/SSTE/SLD). Project Type : FAC Cost : \$40,000,000 Time Estimate : 36 Months	\$40,000,000
168506763	5	MCLEAN ; R 345.0 kV - PONTIAC ; R 345.0 kV Ckt 1	<u>ComEd</u> CE_NUN_8001: ComEd L8001 SSTE rating is 1837 MVA. The upgrade will be to perform sag mitigation on the line. A preliminary estimate for the upgrade is \$10.5M with a preliminary construction timeline of 30 months. Upon completion of the upgrades the ratings will be 1679/2058/2107/2280 MVA (SN/SLTE/SSTE/SLD). Project Type : FAC Cost : \$10,500,000 Time Estimate : 30 Months	\$10,500,000

ID	Idx	Facility	Upgrade Description	Cost
170018417,170 018416	11	AG1-321 TAP 345.0 kV - AD1- 133 TAP 345.0 kV Ckt 1	<u>ComEd</u> CE_NUN_8014_3: ComEd 345kV L8014 SSTE rating is 1797 MVA. The upgrade will be to mitigate sag on the line. A preliminary estimate for the upgrade is \$7.2M with an estimated construction timeline of 24 months contingent upon line outage coordination with Dresden station. Upon completion of the upgrades the ratings will be 1461/1656/1909/1912 MVA (SN/SLTE/SSTE/SLD). Project Type : FAC Cost : \$7,200,000 Time Estimate : 24 Months	\$7,200,000
169733844,169 733845	9	AD1-133 TAP 345.0 kV - DRESDEN ; R 345.0 kV Ckt 1	<u>ComEd</u> CE_NUN_8014_2: ComEd 345kV L8014 SSTE rating is 1797 MVA. The upgrade will be to mitigate sag on the line. A preliminary estimate for the upgrade is \$9.5M with an estimated construction timeline of 30 months contingent upon line outage coordination with Dresden station. Upon completion of the upgrades the ratings will be 1679/2058/2107/2280 MVA (SN/SLTE/SSTE/SLD). Project Type : FAC Cost : \$9,500,000 Time Estimate : 30 Months	\$9,500,000
168506648,179 431361,179431 360,168506647	6	PONTIAC ; B 345.0 kV - LORETTO ; B 345.0 kV Ckt 1	<u>ComEd</u> CE_NUN_L80XX_NEW LINE: Construct a new 345kV line from TSS 80 Pontiac to TSS 196 Katydid. New 345kV circuit breakers, relay upgrades and 345kV bus expansion. A preliminary estimate is a minimum cost estimate of \$127M with an estimated construction timeline of 6-10 years dependent on right of way access and land availability. Project Type : FAC Cost : \$127,000,000 Time Estimate : 60-120 Months	\$127,000,000
			TOTAL COST	\$349,200,000

11.6 Flow Gate Details

The following indices contain additional information about each facility presented in the body of the report. For each index, a description of the flowgate and its contingency was included for convenience. The intent of the indices is to provide more details on which projects/generators have contributions to the flowgate in question. All New Service Queue Requests, through the end of the Queue under study, that are contributors to a flowgate will be listed in the indices. Please note that there may be contributors that are subsequently queued after the queue under study that are not listed in the indices. Although this information is not used "as is" for cost allocation purposes, it can be used to gage the impact of other projects/generators. It should be noted the project/generator MW contributions presented in the body of the report are Full MW Impact contributions which are also noted in the indices column named "Full MW Impact", whereas the loading percentages reported in the body of the report, take into consideration the PJM Generator Deliverability Test rules such as commercial probability of each project as well as the ramping impact of "Adder" contributions. The MW Impact found and used in the analysis is shown in the indices column named "Gendeliv MW Impact".

11.6.1 Index 1

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
179431600	270668	BLUEMOUND; B	CE	270852	PONTIAC ; B	CE	1	COMED_P4_BRO-45-BT2-3__	breaker	1528.0	179.65	182.43	AC	43.04

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
274650	KINCAID ;1U	15.11	80 50	15.11
274651	KINCAID ;2U	15.13	80 50	15.13
274853	TWINGROVE;U1	3.25	80 50	3.25
274854	TWINGROVE;U2	3.34	80 50	3.34
274880	RADFORD R;1U	2.32	80 50	2.32
274889	BRIGHTSTK;1U	0.69	80 50	0.69
276615	W2-048 GEN	8.05	80 50	8.05
276621	X2-022 GEN	30.2	80 50	30.2
290261	S-027 E	90.05	80 50	90.05
290265	S-028 E	90.05	80 50	90.05
293798	W4-005 E	80.74	80 50	80.74
917502	Z2-087 E	27.96	80 50	27.96
924041	AB2-047 C O1	0.86	80 50	0.86
924042	AB2-047 E O1	34.95	80 50	34.95
924261	AB2-070 C O1	4.22	80 50	4.22
924262	AB2-070 E O1	25.54	80 50	25.54
925771	AC1-053 C	4.23	80 50	4.23
925772	AC1-053 E	28.28	80 50	28.28
935141	AD1-148	8.0	80 50	8.0
936771	AD2-100 C	19.89	80 50	19.89
936772	AD2-100 E	13.26	80 50	13.26
936971	AD2-131 C	1.31	80 50	1.31
936972	AD2-131 E	6.58	80 50	6.58
937211	AD2-159 C	10.23	80 50	10.23
937212	AD2-159 E	47.9	80 50	47.9
939741	AE1-205 C O1	13.5	80 50	13.5
939742	AE1-205 E O1	18.64	80 50	18.64
941731	AE2-173 O1	8.03	80 50	8.03
942111	AE2-223 C	3.13	80 50	3.13
942112	AE2-223 E	20.97	80 50	20.97
942481	AE2-261 C	29.34	80 50	29.34
942482	AE2-261 E	19.56	80 50	19.56
944221	AF1-090 C O1	4.97	80 50	4.97
944222	AF1-090 E O1	23.28	80 50	23.28
945871	AF1-252 O1	8.81	80 50	8.81
945881	AF1-253	6.1	80 50	6.1
957381	AF2-032 C	2.25	80 50	2.25
957382	AF2-032 E	1.06	80 50	1.06
959341	AF2-225 C	10.12	80 50	10.12
959342	AF2-225 E	13.98	80 50	13.98
959611	AF2-252 C	11.37	80 50	11.37
959612	AF2-252 E	17.06	80 50	17.06

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
960141	AF2-305	1.49	80 50	1.49
960261	AF2-317	2.56	80 50	2.56
960611	AF2-352 C	11.37	80 50	11.37
960612	AF2-352 E	17.06	80 50	17.06
963831	AG1-236 C	4.23	80 50	4.23
963832	AG1-236 E	28.28	80 50	28.28
965091	AG1-374 C	102.33	80 50	102.33
965092	AG1-374 E	68.22	80 50	68.22
965331	AG1-398	1.19	80 50	1.19
965341	AG1-399 C	22.72	80 50	22.72
965342	AG1-399 E	106.38	80 50	106.38
965351	AG1-400	64.55	80 50	64.55
965361	AG1-401 C	22.72	80 50	22.72
965362	AG1-401 E	106.38	80 50	106.38
965371	AG1-402	64.55	80 50	64.55
965381	AG1-403 C	15.15	80 50	15.15
965382	AG1-403 E	70.92	80 50	70.92
965391	AG1-404	43.04	80 50	43.04
965911	AG1-460 C	1.96	80 50	1.96
965912	AG1-460 E	2.94	80 50	2.94
951741	J474 C	3.42	Queue MISO	3.42
951742	J474 E	18.49	Queue MISO	18.49
952651	J756 C	3.89	Queue MISO	3.89
952652	J756 E	21.04	Queue MISO	21.04
952871	J757 C	4.56	Queue MISO	4.56
952872	J757 E	24.69	Queue MISO	24.69
953401	J811	9.02	Queue MISO	9.02
953651	J815	32.09	Queue MISO	32.09
953741	J826 C	1.83	Queue MISO	1.83
953742	J826 E	9.9	Queue MISO	9.9
953851	J845 C	1.82	Queue MISO	1.82
953852	J845 E	9.84	Queue MISO	9.84
953881	J848 C	4.93	Queue MISO	4.93
953882	J848 E	26.67	Queue MISO	26.67
954411	J912	12.12	Queue MISO	12.12
954721	J750 C	3.11	Queue MISO	3.11
954722	J750 E	16.83	Queue MISO	16.83
954821	J955	154.2	Queue MISO	154.2
955031	J979 C	3.94	Queue MISO	3.94
955032	J979 E	21.34	Queue MISO	21.34
955401	J1022 C	2.75	Queue MISO	2.75
955402	J1022 E	14.86	Queue MISO	14.86
956151	J1102	10.09	Queue MISO	10.09
956281	J1115 C	6.94	Queue MISO	6.94
956282	J1115 E	37.57	Queue MISO	37.57
956451	J1139	13.05	Queue MISO	13.05
990056	J1201	4.21	Queue MISO	4.21
990641	J1354	25.15	Queue MISO	25.15
990671	J1360 C	6.72	Queue MISO	6.72
990672	J1360 E	36.37	Queue MISO	36.37
990856	J1408	13.14	Queue MISO	13.14
991001	J1453 C	2.6	Queue MISO	2.6

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
991002	J1453 E	14.07	Queue MISO	14.07
991006	J1454 C	0.93	Queue MISO	0.93
991007	J1454 E	5.04	Queue MISO	5.04
991036	J1464	57.12	Queue MISO	57.12
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.616	Confirmed LTF	0.616
LTFEXP_CBM-N	LTFEXP_CBM-N->LTFIMP_CBM-N	0.7853	LTF/CBM	0.7853
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	1.0083	LTF/CBM	1.0083
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	16.2765	LTF/CBM	16.2765
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	34.7585	LTF/CBM	34.7585
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	0.9254	Confirmed LTF	0.9254
LTFEXP_G-007A	LTFEXP_G-007A->LTFIMP_G-007A	1.5771	LTF/CMTX	1.5771
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	5.0667	Confirmed LTF	5.0667
LTFEXP_LGE-0012019	LTFEXP_LGE-0012019->LTFIMP_LGE-0012019	0.0342	Confirmed LTF	0.0342
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	1.2238	Confirmed LTF	1.2238
LTFEXP_MEC	LTFEXP_MEC->LTFIMP_MEC	0.839	Confirmed LTF	0.839
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.3276	Confirmed LTF	0.3276
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	3.9341	Confirmed LTF	3.9341
LTFEXP_VFT	LTFEXP_VFT->LTFIMP_VFT	4.2361	Confirmed LTF	4.2361

11.6.2 Index 2

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
174291179	270704	LORETTO ; B	CE	939400	AE1-172 TAP	CE	1	COMED_P4_012-45-BT12-14	breaker	1528.0	243.21	245.55	AC	34.49

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
274650	KINCAID ;1U	18.83	80 50	18.83
274651	KINCAID ;2U	18.82	80 50	18.82
274853	TWINGROVE;U1	2.33	80 50	2.33
274854	TWINGROVE;U2	2.4	80 50	2.4
274863	CAYUGA RI;1U	2.25	80 50	2.25
274864	CAYUGA RI;2U	2.25	80 50	2.25
274880	RADFORD R;1U	2.16	80 50	2.16
274889	BRIGHTSTK;1U	1.87	80 50	1.87
276615	W2-048 GEN	12.21	80 50	12.21
276621	X2-022 GEN	45.79	80 50	45.79
290261	S-027 E	64.75	80 50	64.75
290265	S-028 E	64.75	80 50	64.75
293777	CAYUG;1U E	73.06	80 50	73.06
293778	CAYUG;2U E	73.06	80 50	73.06
293798	W4-005 E	75.31	80 50	75.31
917502	Z2-087 E	76.44	80 50	76.44
924041	AB2-047 C O1	2.34	80 50	2.34
924042	AB2-047 E O1	95.55	80 50	95.55
924261	AB2-070 C O1	7.14	80 50	7.14
924262	AB2-070 E O1	43.27	80 50	43.27
925771	AC1-053 C	6.92	80 50	6.92
925772	AC1-053 E	46.3	80 50	46.3
935001	AD1-133 C O1	90.15	80 50	90.15
935002	AD1-133 E O1	60.1	80 50	60.1
935141	AD1-148	12.13	80 50	12.13
936771	AD2-100 C	24.87	80 50	24.87
936772	AD2-100 E	16.58	80 50	16.58
936971	AD2-131 C	1.64	80 50	1.64
936972	AD2-131 E	8.23	80 50	8.23
937211	AD2-159 C	9.54	80 50	9.54
937212	AD2-159 E	44.68	80 50	44.68
939741	AE1-205 C O1	36.9	80 50	36.9
939742	AE1-205 E O1	50.96	80 50	50.96
941731	AE2-173 O1	21.97	80 50	21.97
942111	AE2-223 C	8.57	80 50	8.57
942112	AE2-223 E	57.33	80 50	57.33
942481	AE2-261 C	36.59	80 50	36.59
942482	AE2-261 E	24.39	80 50	24.39
944221	AF1-090 C O1	6.27	80 50	6.27
944222	AF1-090 E O1	29.37	80 50	29.37
945871	AF1-252 O1	11.12	80 50	11.12

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
945881	AF1-253	7.7	80 50	7.7
957381	AF2-032 C	2.81	80 50	2.81
957382	AF2-032 E	1.32	80 50	1.32
958013	AF2-095 BAT	4.54	80 50	4.54
958023	AF2-096 BAT	9.06	80 50	9.06
959341	AF2-225 C	27.68	80 50	27.68
959342	AF2-225 E	38.22	80 50	38.22
959611	AF2-252 C	8.18	80 50	8.18
959612	AF2-252 E	12.26	80 50	12.26
960141	AF2-305	2.53	80 50	2.53
960261	AF2-317	3.88	80 50	3.88
960603	AF2-351 BAT	2.27	80 50	2.27
960611	AF2-352 C	8.18	80 50	8.18
960612	AF2-352 E	12.26	80 50	12.26
963831	AG1-236 C	6.92	80 50	6.92
963832	AG1-236 E	46.3	80 50	46.3
964581	AG1-321 C O1	63.3	80 50	63.3
964582	AG1-321 E O1	36.86	80 50	36.86
965091	AG1-374 C	73.58	80 50	73.58
965092	AG1-374 E	49.05	80 50	49.05
965331	AG1-398	2.01	80 50	2.01
965341	AG1-399 C	18.21	80 50	18.21
965342	AG1-399 E	85.25	80 50	85.25
965351	AG1-400	51.73	80 50	51.73
965361	AG1-401 C	18.21	80 50	18.21
965362	AG1-401 E	85.25	80 50	85.25
965371	AG1-402	51.73	80 50	51.73
965381	AG1-403 C	12.14	80 50	12.14
965382	AG1-403 E	56.84	80 50	56.84
965391	AG1-404	34.49	80 50	34.49
965911	AG1-460 C	2.45	80 50	2.45
965912	AG1-460 E	3.67	80 50	3.67
951741	J474 C	5.35	Queue MISO	5.35
951742	J474 E	28.93	Queue MISO	28.93
952651	J756 C	4.84	Queue MISO	4.84
952652	J756 E	26.21	Queue MISO	26.21
952871	J757 C	5.98	Queue MISO	5.98
952872	J757 E	32.33	Queue MISO	32.33
953401	J811	11.09	Queue MISO	11.09
953651	J815	39.31	Queue MISO	39.31
953741	J826 C	3.16	Queue MISO	3.16
953742	J826 E	17.1	Queue MISO	17.1
953851	J845 C	3.11	Queue MISO	3.11
953852	J845 E	16.83	Queue MISO	16.83
953881	J848 C	6.01	Queue MISO	6.01
953882	J848 E	32.53	Queue MISO	32.53
954411	J912	14.81	Queue MISO	14.81
954721	J750 C	3.98	Queue MISO	3.98
954722	J750 E	21.54	Queue MISO	21.54
954821	J955	187.12	Queue MISO	187.12
955031	J979 C	4.81	Queue MISO	4.81
955032	J979 E	26.02	Queue MISO	26.02

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
955401	J1022 C	4.74	Queue MISO	4.74
955402	J1022 E	25.64	Queue MISO	25.64
955711	J1055 C	2.37	Queue MISO	2.37
955712	J1055 E	12.84	Queue MISO	12.84
956151	J1102	12.11	Queue MISO	12.11
956281	J1115 C	7.66	Queue MISO	7.66
956282	J1115 E	41.46	Queue MISO	41.46
956451	J1139	17.91	Queue MISO	17.91
990056	J1201	5.18	Queue MISO	5.18
990121	J1216	26.23	Queue MISO	26.23
990641	J1354	30.76	Queue MISO	30.76
990671	J1360 C	9.12	Queue MISO	9.12
990672	J1360 E	49.35	Queue MISO	49.35
990856	J1408	16.3	Queue MISO	16.3
991001	J1453 C	3.67	Queue MISO	3.67
991002	J1453 E	19.85	Queue MISO	19.85
991006	J1454 C	1.22	Queue MISO	1.22
991007	J1454 E	6.61	Queue MISO	6.61
991036	J1464	74.79	Queue MISO	74.79
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.8114	Confirmed LTF	0.8114
LTFEXP_CBM-N	LTFEXP_CBM-N->LTFIMP_CBM-N	0.9256	LTF/CBM	0.9256
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	1.3887	LTF/CBM	1.3887
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	21.7447	LTF/CBM	21.7447
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	49.4763	LTF/CBM	49.4763
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	1.2196	Confirmed LTF	1.2196
LTFEXP_G-007A	LTFEXP_G-007A->LTFIMP_G-007A	1.861	LTF/CMTX	1.861
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	7.2908	Confirmed LTF	7.2908
LTFEXP_LGE-0012019	LTFEXP_LGE-0012019->LTFIMP_LGE-0012019	0.072	Confirmed LTF	0.072
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	1.6099	Confirmed LTF	1.6099
LTFEXP_MEC	LTFEXP_MEC->LTFIMP_MEC	3.2482	Confirmed LTF	3.2482
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.4395	Confirmed LTF	0.4395
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	5.4556	Confirmed LTF	5.4556
LTFEXP_VFT	LTFEXP_VFT->LTFIMP_VFT	4.9968	Confirmed LTF	4.9968

11.6.3 Index 3

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168506763	270819	MCLEAN ;R	CE	270853	PONTIAC ;R	CE	1	COMED_P1-2_345-L8002___-S	single	1819.0	101.32	102.53	AC	21.74

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
274650	KINCAID ;1U	17.3	80 50	17.3
274651	KINCAID ;2U	17.27	80 50	17.27
274853	TWINGROVE;U1	1.24	80 50	1.24
274854	TWINGROVE;U2	1.28	80 50	1.28
274880	RADFORD R;1U	1.63	80 50	1.63
274889	BRIGHTSTK;1U	2.51	80 50	2.51
924041	AB2-047 C O1	3.13	80 50	3.13
924261	AB2-070 C O1	8.01	80 50	8.01
925771	AC1-053 C	7.62	80 50	7.62
930461	AB1-087 CT1	17.2	80 50	17.2
930462	AB1-087 ST1	13.68	80 50	13.68
930471	AB1-088 CT1	17.2	80 50	17.2
930472	AB1-088 ST1	13.68	80 50	13.68
933446	AC2-157 1C	2.13	80 50	2.13
933447	AC2-157 2C	2.13	80 50	2.13
935141	AD1-148	12.77	80 50	12.77
936771	AD2-100 C	22.88	80 50	22.88
936971	AD2-131 C	1.51	80 50	1.51
937211	AD2-159 C	7.18	80 50	7.18
939741	AE1-205 C O1	49.34	80 50	49.34
941731	AE2-173 O1	29.37	80 50	29.37
942111	AE2-223 C	11.45	80 50	11.45
942481	AE2-261 C	33.62	80 50	33.62
942601	AE2-276	2.81	80 50	2.81
944201	AF1-088 FTIR	56.14	80 50	56.14
944221	AF1-090 C O1	5.79	80 50	5.79
945391	AF1-204 C O1	4.38	80 50	4.38
945871	AF1-252 O1	10.26	80 50	10.26
945881	AF1-253	7.1	80 50	7.1
957141	AF2-008 FTIR	28.07	80 50	28.07
957381	AF2-032 C	2.58	80 50	2.58
959341	AF2-225 C	37.01	80 50	37.01
959611	AF2-252 C	4.35	80 50	4.35
960141	AF2-305	2.83	80 50	2.83
960261	AF2-317	4.09	80 50	4.09
960611	AF2-352 C	4.35	80 50	4.35
963831	AG1-236 C	7.62	80 50	7.62
965091	AG1-374 C	39.13	80 50	39.13
965331	AG1-398	2.26	80 50	2.26
965341	AG1-399 C	11.48	80 50	11.48
965351	AG1-400	32.61	80 50	32.61

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
965361	AG1-401 C	11.48	80 50	11.48
965371	AG1-402	32.61	80 50	32.61
965381	AG1-403 C	7.65	80 50	7.65
965391	AG1-404	21.74	80 50	21.74
965911	AG1-460 C	2.25	80 50	2.25
951741	J474 C	5.89	Queue MISO	5.89
952651	J756 C	4.07	Queue MISO	4.07
952871	J757 C	5.18	Queue MISO	5.18
953401	J811	10.83	Queue MISO	10.83
953651	J815	37.35	Queue MISO	37.35
953741	J826 C	3.68	Queue MISO	3.68
953851	J845 C	3.64	Queue MISO	3.64
953881	J848 C	5.75	Queue MISO	5.75
954411	J912	14.22	Queue MISO	14.22
954681	J949 C	16.27	Queue MISO	16.27
954721	J750 C	3.7	Queue MISO	3.7
954821	J955	175.9	Queue MISO	175.9
955031	J979 C	4.6	Queue MISO	4.6
955401	J1022 C	5.51	Queue MISO	5.51
956151	J1102	10.46	Queue MISO	10.46
956281	J1115 C	7.01	Queue MISO	7.01
956451	J1139	19.49	Queue MISO	19.49
990056	J1201	5.0	Queue MISO	5.0
990181	J1232	9.91	Queue MISO	9.91
990641	J1354	29.83	Queue MISO	29.83
990671	J1360 C	9.65	Queue MISO	9.65
990856	J1408	15.11	Queue MISO	15.11
991001	J1453 C	3.02	Queue MISO	3.02
991006	J1454 C	0.99	Queue MISO	0.99
991036	J1464	64.83	Queue MISO	64.83
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.7934	Confirmed LTF	0.7934
LTFEXP_CBM-N	LTFEXP_CBM-N->LTFIMP_CBM-N	1.0627	LTF/CBM	1.0627
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	1.2671	LTF/CBM	1.2671
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	20.7921	LTF/CBM	20.7921
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	44.4916	LTF/CBM	44.4916
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	1.1913	Confirmed LTF	1.1913
LTFEXP_G-007A	LTFEXP_G-007A->LTFIMP_G-007A	2.1333	LTF/CMTX	2.1333
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	6.1981	Confirmed LTF	6.1981
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	1.6331	Confirmed LTF	1.6331
LTFEXP_MEC	LTFEXP_MEC->LTFIMP_MEC	0.6863	Confirmed LTF	0.6863
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.4338	Confirmed LTF	0.4338

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	4.8966	Confirmed LTF	4.8966
LTFEXP_VFT	LTFEXP_VFT->LTFIMP_VFT	5.7307	Confirmed LTF	5.7307
274650	KINCAID ;1U	17.3	80 50	17.3
274651	KINCAID ;2U	17.27	80 50	17.27
274853	TWINGROVE;U1	1.24	80 50	1.24
274854	TWINGROVE;U2	1.28	80 50	1.28
274880	RADFORD R;1U	1.63	80 50	1.63
274889	BRIGHTSTK;1U	2.51	80 50	2.51
924041	AB2-047 C O1	3.13	80 50	3.13
924261	AB2-070 C O1	8.01	80 50	8.01
925771	AC1-053 C	7.62	80 50	7.62
930461	AB1-087 CT1	17.2	80 50	17.2
930462	AB1-087 ST1	13.68	80 50	13.68
930471	AB1-088 CT1	17.2	80 50	17.2
930472	AB1-088 ST1	13.68	80 50	13.68
933446	AC2-157 1C	2.13	80 50	2.13
933447	AC2-157 2C	2.13	80 50	2.13
935141	AD1-148	12.77	80 50	12.77
936771	AD2-100 C	22.88	80 50	22.88
936971	AD2-131 C	1.51	80 50	1.51
937211	AD2-159 C	7.18	80 50	7.18
939741	AE1-205 C O1	49.34	80 50	49.34
941731	AE2-173 O1	29.37	80 50	29.37
942111	AE2-223 C	11.45	80 50	11.45
942481	AE2-261 C	33.62	80 50	33.62
942601	AE2-276	2.81	80 50	2.81
944201	AF1-088 FTIR	56.14	80 50	56.14
944221	AF1-090 C O1	5.79	80 50	5.79
945391	AF1-204 C O1	4.38	80 50	4.38
945871	AF1-252 O1	10.26	80 50	10.26
945881	AF1-253	7.1	80 50	7.1
957141	AF2-008 FTIR	28.07	80 50	28.07
957381	AF2-032 C	2.58	80 50	2.58
959341	AF2-225 C	37.01	80 50	37.01
959611	AF2-252 C	4.35	80 50	4.35
960141	AF2-305	2.83	80 50	2.83
960261	AF2-317	4.09	80 50	4.09
960611	AF2-352 C	4.35	80 50	4.35
963831	AG1-236 C	7.62	80 50	7.62
965091	AG1-374 C	39.13	80 50	39.13
965331	AG1-398	2.26	80 50	2.26
965341	AG1-399 C	11.48	80 50	11.48
965351	AG1-400	32.61	80 50	32.61
965361	AG1-401 C	11.48	80 50	11.48
965371	AG1-402	32.61	80 50	32.61
965381	AG1-403 C	7.65	80 50	7.65
965391	AG1-404	21.74	80 50	21.74
965911	AG1-460 C	2.25	80 50	2.25
951741	J474 C	5.89	Queue MISO	5.89
952651	J756 C	4.07	Queue MISO	4.07
952871	J757 C	5.18	Queue MISO	5.18
953401	J811	10.83	Queue MISO	10.83

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
953651	J815	37.35	Queue MISO	37.35
953741	J826 C	3.68	Queue MISO	3.68
953851	J845 C	3.64	Queue MISO	3.64
953881	J848 C	5.75	Queue MISO	5.75
954411	J912	14.22	Queue MISO	14.22
954681	J949 C	16.27	Queue MISO	16.27
954721	J750 C	3.7	Queue MISO	3.7
954821	J955	175.9	Queue MISO	175.9
955031	J979 C	4.6	Queue MISO	4.6
955401	J1022 C	5.51	Queue MISO	5.51
956151	J1102	10.46	Queue MISO	10.46
956281	J1115 C	7.01	Queue MISO	7.01
956451	J1139	19.49	Queue MISO	19.49
990056	J1201	5.0	Queue MISO	5.0
990181	J1232	9.91	Queue MISO	9.91
990641	J1354	29.83	Queue MISO	29.83
990671	J1360 C	9.65	Queue MISO	9.65
990856	J1408	15.11	Queue MISO	15.11
991001	J1453 C	3.02	Queue MISO	3.02
991006	J1454 C	0.99	Queue MISO	0.99
991036	J1464	64.83	Queue MISO	64.83
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.7934	Confirmed LTF	0.7934
LTFEXP_CBM-N	LTFEXP_CBM-N->LTFIMP_CBM-N	1.0627	LTF/CBM	1.0627
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	1.2671	LTF/CBM	1.2671
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	20.7921	LTF/CBM	20.7921
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	44.4916	LTF/CBM	44.4916
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	1.1913	Confirmed LTF	1.1913
LTFEXP_G-007A	LTFEXP_G-007A->LTFIMP_G-007A	2.1333	LTF/CMTX	2.1333
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	6.1981	Confirmed LTF	6.1981
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	1.6331	Confirmed LTF	1.6331
LTFEXP_MEC	LTFEXP_MEC->LTFIMP_MEC	0.6863	Confirmed LTF	0.6863
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.4338	Confirmed LTF	0.4338
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	4.8966	Confirmed LTF	4.8966
LTFEXP_VFT	LTFEXP_VFT->LTFIMP_VFT	5.7307	Confirmed LTF	5.7307

11.6.4 Index 4

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
179431360	270852	PONTIAC ; B	CE	270704	LORETTO ; B	CE	1	COMED_P4_012-45-BT12-14	breaker	1528.0	230.32	232.63	AC	34.51

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
274650	KINCAID ;1U	18.85	80 50	18.85
274651	KINCAID ;2U	18.84	80 50	18.84
274853	TWINGROVE;U1	2.34	80 50	2.34
274854	TWINGROVE;U2	2.4	80 50	2.4
274880	RADFORD R;1U	2.17	80 50	2.17
274889	BRIGHTSTK;1U	1.88	80 50	1.88
276615	W2-048 GEN	12.22	80 50	12.22
276621	X2-022 GEN	45.83	80 50	45.83
290261	S-027 E	64.79	80 50	64.79
290265	S-028 E	64.79	80 50	64.79
293798	W4-005 E	75.37	80 50	75.37
917502	Z2-087 E	76.48	80 50	76.48
924041	AB2-047 C O1	2.34	80 50	2.34
924042	AB2-047 E O1	95.6	80 50	95.6
924261	AB2-070 C O1	7.15	80 50	7.15
924262	AB2-070 E O1	43.31	80 50	43.31
925771	AC1-053 C	6.92	80 50	6.92
925772	AC1-053 E	46.34	80 50	46.34
935001	AD1-133 C O1	90.19	80 50	90.19
935002	AD1-133 E O1	60.13	80 50	60.13
935141	AD1-148	12.14	80 50	12.14
936771	AD2-100 C	24.9	80 50	24.9
936772	AD2-100 E	16.6	80 50	16.6
936971	AD2-131 C	1.64	80 50	1.64
936972	AD2-131 E	8.24	80 50	8.24
937211	AD2-159 C	9.55	80 50	9.55
937212	AD2-159 E	44.72	80 50	44.72
939741	AE1-205 C O1	36.92	80 50	36.92
939742	AE1-205 E O1	50.99	80 50	50.99
941731	AE2-173 O1	21.98	80 50	21.98
942111	AE2-223 C	8.57	80 50	8.57
942112	AE2-223 E	57.36	80 50	57.36
942481	AE2-261 C	36.63	80 50	36.63
942482	AE2-261 E	24.42	80 50	24.42
944221	AF1-090 C O1	6.28	80 50	6.28
944222	AF1-090 E O1	29.41	80 50	29.41
945871	AF1-252 O1	11.14	80 50	11.14
945881	AF1-253	7.71	80 50	7.71
957381	AF2-032 C	2.81	80 50	2.81
957382	AF2-032 E	1.32	80 50	1.32
958013	AF2-095 BAT	4.53	80 50	4.53
958023	AF2-096 BAT	9.04	80 50	9.04

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
959341	AF2-225 C	27.69	80 50	27.69
959342	AF2-225 E	38.24	80 50	38.24
959611	AF2-252 C	8.18	80 50	8.18
959612	AF2-252 E	12.27	80 50	12.27
960141	AF2-305	2.53	80 50	2.53
960261	AF2-317	3.88	80 50	3.88
960603	AF2-351 BAT	2.27	80 50	2.27
960611	AF2-352 C	8.18	80 50	8.18
960612	AF2-352 E	12.27	80 50	12.27
963831	AG1-236 C	6.92	80 50	6.92
963832	AG1-236 E	46.34	80 50	46.34
964581	AG1-321 C O1	63.33	80 50	63.33
964582	AG1-321 E O1	36.87	80 50	36.87
965091	AG1-374 C	73.62	80 50	73.62
965092	AG1-374 E	49.08	80 50	49.08
965331	AG1-398	2.02	80 50	2.02
965341	AG1-399 C	18.22	80 50	18.22
965342	AG1-399 E	85.31	80 50	85.31
965351	AG1-400	51.77	80 50	51.77
965361	AG1-401 C	18.22	80 50	18.22
965362	AG1-401 E	85.31	80 50	85.31
965371	AG1-402	51.77	80 50	51.77
965381	AG1-403 C	12.15	80 50	12.15
965382	AG1-403 E	56.87	80 50	56.87
965391	AG1-404	34.51	80 50	34.51
965911	AG1-460 C	2.45	80 50	2.45
965912	AG1-460 E	3.68	80 50	3.68
951741	J474 C	5.35	Queue MISO	5.35
951742	J474 E	28.93	Queue MISO	28.93
952651	J756 C	4.84	Queue MISO	4.84
952652	J756 E	26.21	Queue MISO	26.21
952871	J757 C	5.98	Queue MISO	5.98
952872	J757 E	32.33	Queue MISO	32.33
953401	J811	11.09	Queue MISO	11.09
953651	J815	39.31	Queue MISO	39.31
953741	J826 C	3.16	Queue MISO	3.16
953742	J826 E	17.1	Queue MISO	17.1
953851	J845 C	3.11	Queue MISO	3.11
953852	J845 E	16.83	Queue MISO	16.83
953881	J848 C	6.01	Queue MISO	6.01
953882	J848 E	32.53	Queue MISO	32.53
954411	J912	14.81	Queue MISO	14.81
954721	J750 C	3.98	Queue MISO	3.98
954722	J750 E	21.54	Queue MISO	21.54
954821	J955	187.12	Queue MISO	187.12
955031	J979 C	4.81	Queue MISO	4.81
955032	J979 E	26.02	Queue MISO	26.02
955401	J1022 C	4.74	Queue MISO	4.74
955402	J1022 E	25.64	Queue MISO	25.64
955711	J1055 C	2.37	Queue MISO	2.37
955712	J1055 E	12.84	Queue MISO	12.84
956151	J1102	12.11	Queue MISO	12.11

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
956281	J1115 C	7.66	Queue MISO	7.66
956282	J1115 E	41.46	Queue MISO	41.46
956451	J1139	17.91	Queue MISO	17.91
990056	J1201	5.18	Queue MISO	5.18
990121	J1216	26.23	Queue MISO	26.23
990641	J1354	30.76	Queue MISO	30.76
990671	J1360 C	9.12	Queue MISO	9.12
990672	J1360 E	49.35	Queue MISO	49.35
990856	J1408	16.3	Queue MISO	16.3
991001	J1453 C	3.67	Queue MISO	3.67
991002	J1453 E	19.85	Queue MISO	19.85
991006	J1454 C	1.22	Queue MISO	1.22
991007	J1454 E	6.61	Queue MISO	6.61
991036	J1464	74.79	Queue MISO	74.79
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.8221	Confirmed LTF	0.8221
LTFEXP_CBM-N	LTFEXP_CBM-N->LTFIMP_CBM-N	0.9538	LTF/CBM	0.9538
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	1.3976	LTF/CBM	1.3976
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	21.9899	LTF/CBM	21.9899
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	49.6868	LTF/CBM	49.6868
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	1.2356	Confirmed LTF	1.2356
LTFEXP_G-007A	LTFEXP_G-007A->LTFIMP_G-007A	1.9173	LTF/CMTX	1.9173
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	7.3319	Confirmed LTF	7.3319
LTFEXP_LGE-0012019	LTFEXP_LGE-0012019->LTFIMP_LGE-0012019	0.072	Confirmed LTF	0.072
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	1.6247	Confirmed LTF	1.6247
LTFEXP_MEC	LTFEXP_MEC->LTFIMP_MEC	3.2855	Confirmed LTF	3.2855
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.442	Confirmed LTF	0.442
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	5.4885	Confirmed LTF	5.4885
LTFEXP_VFT	LTFEXP_VFT->LTFIMP_VFT	5.1483	Confirmed LTF	5.1483

11.6.5 Index 5

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
168506684	270853	PONTIAC ;R	CE	964580	AG1-321 TAP	CE	1	COMED_P1-2_345-L11212_B-S-B	single	1656.0	106.19	108.08	AC	31.26

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
274650	KINCAID ;1U	16.13	80 50	16.13
274651	KINCAID ;2U	16.13	80 50	16.13
274853	TWINGROVE;U1	2.14	80 50	2.14
274854	TWINGROVE;U2	2.2	80 50	2.2
274863	CAYUGA RI;1U	1.72	80 50	1.72
274864	CAYUGA RI;2U	1.72	80 50	1.72
274880	RADFORD R;1U	1.93	80 50	1.93
274889	BRIGHTSTK;1U	1.73	80 50	1.73
904211	W3-135	-0.97	Adder	-1.14
924041	AB2-047 C O1	2.17	80 50	2.17
924261	AB2-070 C O1	6.34	80 50	6.34
925771	AC1-053 C	6.12	80 50	6.12
930461	AB1-087 CT1	15.37	80 50	15.37
930462	AB1-087 ST1	12.22	80 50	12.22
930471	AB1-088 CT1	15.37	80 50	15.37
930472	AB1-088 ST1	12.22	80 50	12.22
930761	AB1-122 CT1	-51.45	Adder	-60.53
933446	AC2-157 1C	1.91	80 50	1.91
933447	AC2-157 2C	1.91	80 50	1.91
935141	AD1-148	10.62	80 50	10.62
936771	AD2-100 C	21.28	80 50	21.28
936971	AD2-131 C	1.4	80 50	1.4
937211	AD2-159 C	8.53	80 50	8.53
939401	AE1-172 C O1	20.86	80 50	20.86
939741	AE1-205 C O1	34.1	80 50	34.1
940101	AE1-252 C O1	41.91	80 50	41.91
941731	AE2-173 O1	20.3	80 50	20.3
942111	AE2-223 C	7.92	80 50	7.92
942481	AE2-261 C	31.34	80 50	31.34
942601	AE2-276	2.51	80 50	2.51
944201	AF1-088 FTIR	50.16	80 50	50.16
944221	AF1-090 C O1	5.35	80 50	5.35
945391	AF1-204 C O1	3.85	80 50	3.85
945871	AF1-252 O1	9.49	80 50	9.49
945881	AF1-253	6.57	80 50	6.57
957141	AF2-008 FTIR	25.08	80 50	25.08
957381	AF2-032 C	2.4	80 50	2.4
959341	AF2-225 C	25.58	80 50	25.58
959611	AF2-252 C	7.5	80 50	7.5
960141	AF2-305	2.24	80 50	2.24
960261	AF2-317	3.4	80 50	3.4

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
960611	AF2-352 C	7.5	80 50	7.5
963831	AG1-236 C	6.12	80 50	6.12
965091	AG1-374 C	67.48	80 50	67.48
965331	AG1-398	1.79	80 50	1.79
965341	AG1-399 C	16.51	80 50	16.51
965351	AG1-400	46.89	80 50	46.89
965361	AG1-401 C	16.51	80 50	16.51
965371	AG1-402	46.89	80 50	46.89
965381	AG1-403 C	11.0	80 50	11.0
965391	AG1-404	31.26	80 50	31.26
965911	AG1-460 C	2.1	80 50	2.1
951741	J474 C	4.91	Queue MISO	4.91
952651	J756 C	3.89	Queue MISO	3.89
952871	J757 C	4.78	Queue MISO	4.78
953401	J811	10.28	Queue MISO	10.28
953651	J815	35.48	Queue MISO	35.48
953741	J826 C	2.96	Queue MISO	2.96
953851	J845 C	2.95	Queue MISO	2.95
953881	J848 C	5.48	Queue MISO	5.48
954411	J912	13.52	Queue MISO	13.52
954721	J750 C	3.43	Queue MISO	3.43
954821	J955	168.03	Queue MISO	168.03
955031	J979 C	4.38	Queue MISO	4.38
955401	J1022 C	4.44	Queue MISO	4.44
956151	J1102	10.19	Queue MISO	10.19
956281	J1115 C	7.11	Queue MISO	7.11
956451	J1139	17.36	Queue MISO	17.36
990056	J1201	4.75	Queue MISO	4.75
990181	J1232	9.2	Queue MISO	9.2
990641	J1354	28.27	Queue MISO	28.27
990671	J1360 C	8.58	Queue MISO	8.58
990856	J1408	14.28	Queue MISO	14.28
991006	J1454 C	0.92	Queue MISO	0.92
991036	J1464	59.78	Queue MISO	59.78
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.7143	Confirmed LTF	0.7143
LTFEXP_CBM-N	LTFEXP_CBM-N->LTFIMP_CBM-N	1.0198	LTF/CBM	1.0198
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	1.1057	LTF/CBM	1.1057
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	18.5397	LTF/CBM	18.5397
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	38.0111	LTF/CBM	38.0111
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	1.0721	Confirmed LTF	1.0721
LTFEXP_G-007A	LTFEXP_G-007A->LTFIMP_G-007A	2.0462	LTF/CMTX	2.0462
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	5.2112	Confirmed LTF	5.2112
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	1.4737	Confirmed LTF	1.4737

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.3866	Confirmed LTF	0.3866
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	4.249	Confirmed LTF	4.249
LTFEXP_VFT	LTFEXP_VFT->LTFIMP_VFT	5.4977	Confirmed LTF	5.4977
274650	KINCAID ;1U	16.14	80 50	16.14
274651	KINCAID ;2U	16.13	80 50	16.13
274853	TWINGROVE;U1	2.14	80 50	2.14
274854	TWINGROVE;U2	2.2	80 50	2.2
274863	CAYUGA RI;1U	1.72	80 50	1.72
274864	CAYUGA RI;2U	1.72	80 50	1.72
274880	RADFORD R;1U	1.93	80 50	1.93
274889	BRIGHTSTK;1U	1.73	80 50	1.73
904211	W3-135	-0.97	Adder	-1.14
924041	AB2-047 C O1	2.17	80 50	2.17
924261	AB2-070 C O1	6.34	80 50	6.34
925771	AC1-053 C	6.12	80 50	6.12
930461	AB1-087 CT1	15.37	80 50	15.37
930462	AB1-087 ST1	12.22	80 50	12.22
930471	AB1-088 CT1	15.37	80 50	15.37
930472	AB1-088 ST1	12.22	80 50	12.22
930761	AB1-122 CT1	-51.45	Adder	-60.53
933446	AC2-157 1C	1.91	80 50	1.91
933447	AC2-157 2C	1.91	80 50	1.91
935141	AD1-148	10.62	80 50	10.62
936771	AD2-100 C	21.28	80 50	21.28
936971	AD2-131 C	1.4	80 50	1.4
937211	AD2-159 C	8.53	80 50	8.53
939401	AE1-172 C O1	20.86	80 50	20.86
939741	AE1-205 C O1	34.1	80 50	34.1
940101	AE1-252 C O1	41.91	80 50	41.91
941731	AE2-173 O1	20.3	80 50	20.3
942111	AE2-223 C	7.92	80 50	7.92
942481	AE2-261 C	31.34	80 50	31.34
942601	AE2-276	2.51	80 50	2.51
944201	AF1-088 FTIR	50.16	80 50	50.16
944221	AF1-090 C O1	5.35	80 50	5.35
945391	AF1-204 C O1	3.85	80 50	3.85
945871	AF1-252 O1	9.49	80 50	9.49
945881	AF1-253	6.57	80 50	6.57
957141	AF2-008 FTIR	25.08	80 50	25.08
957381	AF2-032 C	2.4	80 50	2.4
959341	AF2-225 C	25.58	80 50	25.58
959611	AF2-252 C	7.5	80 50	7.5
960141	AF2-305	2.24	80 50	2.24
960261	AF2-317	3.4	80 50	3.4
960611	AF2-352 C	7.5	80 50	7.5
963831	AG1-236 C	6.12	80 50	6.12
965091	AG1-374 C	67.48	80 50	67.48
965331	AG1-398	1.79	80 50	1.79
965341	AG1-399 C	16.51	80 50	16.51
965351	AG1-400	46.89	80 50	46.89
965361	AG1-401 C	16.51	80 50	16.51

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
965371	AG1-402	46.89	80 50	46.89
965381	AG1-403 C	11.0	80 50	11.0
965391	AG1-404	31.26	80 50	31.26
965911	AG1-460 C	2.1	80 50	2.1
951741	J474 C	4.91	Queue MISO	4.91
952651	J756 C	3.89	Queue MISO	3.89
952871	J757 C	4.78	Queue MISO	4.78
953401	J811	10.28	Queue MISO	10.28
953651	J815	35.48	Queue MISO	35.48
953741	J826 C	2.96	Queue MISO	2.96
953851	J845 C	2.95	Queue MISO	2.95
953881	J848 C	5.48	Queue MISO	5.48
954411	J912	13.52	Queue MISO	13.52
954721	J750 C	3.43	Queue MISO	3.43
954821	J955	168.03	Queue MISO	168.03
955031	J979 C	4.38	Queue MISO	4.38
955401	J1022 C	4.44	Queue MISO	4.44
956151	J1102	10.19	Queue MISO	10.19
956281	J1115 C	7.11	Queue MISO	7.11
956451	J1139	17.36	Queue MISO	17.36
990056	J1201	4.75	Queue MISO	4.75
990181	J1232	9.2	Queue MISO	9.2
990641	J1354	28.27	Queue MISO	28.27
990671	J1360 C	8.58	Queue MISO	8.58
990856	J1408	14.28	Queue MISO	14.28
991006	J1454 C	0.92	Queue MISO	0.92
991036	J1464	59.78	Queue MISO	59.78
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.7143	Confirmed LTF	0.7143
LTFEXP_CBM-N	LTFEXP_CBM-N->LTFIMP_CBM-N	1.0198	LTF/CBM	1.0198
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	1.1057	LTF/CBM	1.1057
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	18.5397	LTF/CBM	18.5397
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	38.0111	LTF/CBM	38.0111
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	1.0721	Confirmed LTF	1.0721
LTFEXP_G-007A	LTFEXP_G-007A->LTFIMP_G-007A	2.0462	LTF/CMTX	2.0462
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	5.2112	Confirmed LTF	5.2112
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	1.4737	Confirmed LTF	1.4737
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.3866	Confirmed LTF	0.3866
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	4.249	Confirmed LTF	4.249
LTFEXP_VFT	LTFEXP_VFT->LTFIMP_VFT	5.4977	Confirmed LTF	5.4977

11.6.6 Index 6

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
169733899	934720	AD1-100 TAP	CE	270926	WILTON ; B	CE	1	COMED_P1-2_345-L8014__R-S-C	single	1528.0	100.81	101.84	AC	15.92

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
274650	KINCAID ;1U	8.76	80 50	8.76
274651	KINCAID ;2U	8.76	80 50	8.76
274654	BRAIDWOOD;1U	28.58	80 50	28.58
274655	BRAIDWOOD;2U	27.64	80 50	27.64
274660	LASCO STA;1U	16.96	80 50	16.96
274661	LASCO STA;2U	17.03	80 50	17.03
274847	GR RIDGE ;BU	0.34	80 50	0.34
274853	TWINGROVE;U1	1.08	80 50	1.08
274854	TWINGROVE;U2	1.11	80 50	1.11
274863	CAYUGA RI;1U	1.03	80 50	1.03
274864	CAYUGA RI;2U	1.03	80 50	1.03
274871	GR RIDGE ;2U	0.13	80 50	0.13
274880	RADFORD R;1U	1.0	80 50	1.0
274887	PILOT HIL;1U	0.61	80 50	0.61
274888	KELLY CRK;1U	0.61	80 50	0.61
274889	BRIGHTSTK;1U	0.86	80 50	0.86
276173	Z2-081	0.13	80 50	0.13
924041	AB2-047 C O1	1.08	80 50	1.08
924261	AB2-070 C O1	3.32	80 50	3.32
925771	AC1-053 C	3.21	80 50	3.21
930501	AB1-091 CT	37.6	80 50	37.6
930502	AB1-091 ST	29.89	80 50	29.89
933411	AC2-154 C	2.02	80 50	2.02
934721	AD1-100 C	45.18	80 50	45.18
935001	AD1-133 C O1	41.49	80 50	41.49
935141	AD1-148	5.64	80 50	5.64
936371	AD2-047 C O1	3.62	80 50	3.62
936461	AD2-060	2.13	80 50	2.13
936771	AD2-100 C	11.56	80 50	11.56
936971	AD2-131 C	0.76	80 50	0.76
937211	AD2-159 C	4.41	80 50	4.41
939351	AE1-166 C O1	18.15	80 50	18.15
939401	AE1-172 C O1	13.77	80 50	13.77
939741	AE1-205 C O1	17.01	80 50	17.01
940101	AE1-252 C O1	27.66	80 50	27.66
941551	AE2-152 C O1	20.95	80 50	20.95
941561	AE2-153 C O1	4.86	80 50	4.86
941731	AE2-173 O1	10.12	80 50	10.12
942111	AE2-223 C	3.95	80 50	3.95
942481	AE2-261 C	17.02	80 50	17.02
944221	AF1-090 C O1	2.91	80 50	2.91

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
944911	AF1-156 C	12.42	80 50	12.42
945871	AF1-252 O1	5.15	80 50	5.15
945881	AF1-253	3.57	80 50	3.57
957381	AF2-032 C	1.31	80 50	1.31
958011	AF2-095 C O1	14.47	80 50	14.47
958021	AF2-096 C	34.65	80 50	34.65
959341	AF2-225 C	12.76	80 50	12.76
959611	AF2-252 C	3.77	80 50	3.77
960141	AF2-305	1.17	80 50	1.17
960261	AF2-317	1.8	80 50	1.8
960591	AF2-350 C O1	6.39	80 50	6.39
960601	AF2-351 C O1	0.85	80 50	0.85
960611	AF2-352 C	3.77	80 50	3.77
963831	AG1-236 C	3.21	80 50	3.21
964581	AG1-321 C O1	29.13	80 50	29.13
965091	AG1-374 C	33.91	80 50	33.91
965331	AG1-398	0.93	80 50	0.93
965341	AG1-399 C	8.4	80 50	8.4
965351	AG1-400	23.88	80 50	23.88
965361	AG1-401 C	8.4	80 50	8.4
965371	AG1-402	23.88	80 50	23.88
965381	AG1-403 C	5.6	80 50	5.6
965391	AG1-404	15.92	80 50	15.92
965911	AG1-460 C	1.14	80 50	1.14
951741	J474 C	2.35	Queue MISO	2.35
952651	J756 C	2.13	Queue MISO	2.13
952871	J757 C	2.59	Queue MISO	2.59
953651	J815	16.66	Queue MISO	16.66
953741	J826 C	1.35	Queue MISO	1.35
953851	J845 C	1.3	Queue MISO	1.3
953881	J848 C	2.53	Queue MISO	2.53
954411	J912	6.2	Queue MISO	6.2
954721	J750 C	1.73	Queue MISO	1.73
954821	J955	80.69	Queue MISO	80.69
955031	J979 C	2.03	Queue MISO	2.03
955401	J1022 C	2.03	Queue MISO	2.03
956151	J1102	5.31	Queue MISO	5.31
956281	J1115 C	3.34	Queue MISO	3.34
990641	J1354	13.31	Queue MISO	13.31
990671	J1360 C	3.87	Queue MISO	3.87
990856	J1408	7.03	Queue MISO	7.03
991001	J1453 C	1.62	Queue MISO	1.62
991006	J1454 C	0.54	Queue MISO	0.54
991036	J1464	32.45	Queue MISO	32.45
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.0987	Confirmed LTF	0.0987
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	0.512	LTF/CBM	0.512
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	4.2137	LTF/CBM	4.2137
LTFEXP_CBM-W1	LTFEXP_CBM-W1->LTFIMP_CBM-W1	6.2964	LTF/CBM	6.2964

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	21.929	LTF/CBM	21.929
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	0.1508	Confirmed LTF	0.1508
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	3.2839	Confirmed LTF	3.2839
LTFEXP_LGE-0012019	LTFEXP_LGE-0012019->LTFIMP_LGE-0012019	0.0846	Confirmed LTF	0.0846
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	0.3521	Confirmed LTF	0.3521
LTFEXP_MEC	LTFEXP_MEC->LTFIMP_MEC	3.5738	Confirmed LTF	3.5738
LTFEXP_NY	LTFEXP_NY->LTFIMP_NY	0.2266	Confirmed LTF	0.2266
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.1513	Confirmed LTF	0.1513
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	2.1309	Confirmed LTF	2.1309
LTFEXP_WEC	LTFEXP_WEC->LTFIMP_WEC	0.1379	Confirmed LTF	0.1379
274650	KINCAID ;1U	8.76	80 50	8.76
274651	KINCAID ;2U	8.76	80 50	8.76
274654	BRAIDWOOD;1U	28.58	80 50	28.58
274655	BRAIDWOOD;2U	27.64	80 50	27.64
274660	LASCO STA;1U	16.96	80 50	16.96
274661	LASCO STA;2U	17.03	80 50	17.03
274847	GR RIDGE ;BU	0.34	80 50	0.34
274853	TWINGROVE;U1	1.08	80 50	1.08
274854	TWINGROVE;U2	1.11	80 50	1.11
274863	CAYUGA RI;1U	1.03	80 50	1.03
274864	CAYUGA RI;2U	1.03	80 50	1.03
274871	GR RIDGE ;2U	0.13	80 50	0.13
274880	RADFORD R;1U	1.0	80 50	1.0
274887	PILOT HIL;1U	0.61	80 50	0.61
274888	KELLY CRK;1U	0.61	80 50	0.61
274889	BRIGHTSTK;1U	0.86	80 50	0.86
276173	Z2-081	0.13	80 50	0.13
924041	AB2-047 C O1	1.08	80 50	1.08
924261	AB2-070 C O1	3.32	80 50	3.32
925771	AC1-053 C	3.21	80 50	3.21
930501	AB1-091 CT	37.6	80 50	37.6
930502	AB1-091 ST	29.89	80 50	29.89
933411	AC2-154 C	2.02	80 50	2.02
934721	AD1-100 C	45.18	80 50	45.18
935001	AD1-133 C O1	41.49	80 50	41.49
935141	AD1-148	5.64	80 50	5.64
936371	AD2-047 C O1	3.62	80 50	3.62
936461	AD2-060	2.13	80 50	2.13
936771	AD2-100 C	11.56	80 50	11.56
936971	AD2-131 C	0.76	80 50	0.76
937211	AD2-159 C	4.41	80 50	4.41
939351	AE1-166 C O1	18.15	80 50	18.15
939401	AE1-172 C O1	13.77	80 50	13.77
939741	AE1-205 C O1	17.01	80 50	17.01

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
940101	AE1-252 C O1	27.66	80 50	27.66
941551	AE2-152 C O1	20.95	80 50	20.95
941561	AE2-153 C O1	4.86	80 50	4.86
941731	AE2-173 O1	10.12	80 50	10.12
942111	AE2-223 C	3.95	80 50	3.95
942481	AE2-261 C	17.02	80 50	17.02
944221	AF1-090 C O1	2.91	80 50	2.91
944911	AF1-156 C	12.42	80 50	12.42
945871	AF1-252 O1	5.15	80 50	5.15
945881	AF1-253	3.57	80 50	3.57
957381	AF2-032 C	1.31	80 50	1.31
958011	AF2-095 C O1	14.47	80 50	14.47
958021	AF2-096 C	34.65	80 50	34.65
959341	AF2-225 C	12.76	80 50	12.76
959611	AF2-252 C	3.77	80 50	3.77
960141	AF2-305	1.17	80 50	1.17
960261	AF2-317	1.8	80 50	1.8
960591	AF2-350 C O1	6.39	80 50	6.39
960601	AF2-351 C O1	0.85	80 50	0.85
960611	AF2-352 C	3.77	80 50	3.77
963831	AG1-236 C	3.21	80 50	3.21
964581	AG1-321 C O1	29.13	80 50	29.13
965091	AG1-374 C	33.91	80 50	33.91
965331	AG1-398	0.93	80 50	0.93
965341	AG1-399 C	8.4	80 50	8.4
965351	AG1-400	23.88	80 50	23.88
965361	AG1-401 C	8.4	80 50	8.4
965371	AG1-402	23.88	80 50	23.88
965381	AG1-403 C	5.6	80 50	5.6
965391	AG1-404	15.92	80 50	15.92
965911	AG1-460 C	1.14	80 50	1.14
951741	J474 C	2.35	Queue MISO	2.35
952651	J756 C	2.13	Queue MISO	2.13
952871	J757 C	2.59	Queue MISO	2.59
953651	J815	16.66	Queue MISO	16.66
953741	J826 C	1.35	Queue MISO	1.35
953851	J845 C	1.3	Queue MISO	1.3
953881	J848 C	2.53	Queue MISO	2.53
954411	J912	6.2	Queue MISO	6.2
954721	J750 C	1.73	Queue MISO	1.73
954821	J955	80.69	Queue MISO	80.69
955031	J979 C	2.03	Queue MISO	2.03
955401	J1022 C	2.03	Queue MISO	2.03
956151	J1102	5.31	Queue MISO	5.31
956281	J1115 C	3.34	Queue MISO	3.34
990641	J1354	13.31	Queue MISO	13.31
990671	J1360 C	3.87	Queue MISO	3.87
990856	J1408	7.03	Queue MISO	7.03
991001	J1453 C	1.62	Queue MISO	1.62
991006	J1454 C	0.54	Queue MISO	0.54
991036	J1464	32.45	Queue MISO	32.45
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.0987	Confirmed LTF	0.0987

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	0.512	LTF/CBM	0.512
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	4.2137	LTF/CBM	4.2137
LTFEXP_CBM-W1	LTFEXP_CBM-W1->LTFIMP_CBM-W1	6.2964	LTF/CBM	6.2964
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	21.929	LTF/CBM	21.929
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	0.1508	Confirmed LTF	0.1508
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	3.2839	Confirmed LTF	3.2839
LTFEXP_LGE-0012019	LTFEXP_LGE-0012019->LTFIMP_LGE-0012019	0.0846	Confirmed LTF	0.0846
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	0.3521	Confirmed LTF	0.3521
LTFEXP_MEC	LTFEXP_MEC->LTFIMP_MEC	3.5738	Confirmed LTF	3.5738
LTFEXP_NY	LTFEXP_NY->LTFIMP_NY	0.2266	Confirmed LTF	0.2266
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.1513	Confirmed LTF	0.1513
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	2.1309	Confirmed LTF	2.1309
LTFEXP_WEC	LTFEXP_WEC->LTFIMP_WEC	0.1379	Confirmed LTF	0.1379

11.6.7 Index 7

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
169733844	935000	AD1-133 TAP	CE	270717	DRESDEN ; R	CE	1	COMED_P1-2_345-L11212_B-S-B	single	1656.0	116.85	118.73	AC	31.26

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
274650	KINCAID ;1U	16.13	80 50	16.13
274651	KINCAID ;2U	16.13	80 50	16.13
274853	TWINGROVE;U1	2.14	80 50	2.14
274854	TWINGROVE;U2	2.2	80 50	2.2
274863	CAYUGA RI;1U	1.72	80 50	1.72
274864	CAYUGA RI;2U	1.72	80 50	1.72
274880	RADFORD R;1U	1.93	80 50	1.93
274889	BRIGHTSTK;1U	1.73	80 50	1.73
924041	AB2-047 C O1	2.17	80 50	2.17
924261	AB2-070 C O1	6.34	80 50	6.34
925771	AC1-053 C	6.12	80 50	6.12
930461	AB1-087 CT1	15.37	80 50	15.37
930462	AB1-087 ST1	12.22	80 50	12.22
930471	AB1-088 CT1	15.37	80 50	15.37
930472	AB1-088 ST1	12.22	80 50	12.22
930761	AB1-122 CT1	-51.45	Adder	-60.53
933446	AC2-157 1C	1.91	80 50	1.91
933447	AC2-157 2C	1.91	80 50	1.91
935001	AD1-133 C O1	122.22	80 50	122.22
935141	AD1-148	10.62	80 50	10.62
936771	AD2-100 C	21.28	80 50	21.28
936971	AD2-131 C	1.4	80 50	1.4
937211	AD2-159 C	8.53	80 50	8.53
939401	AE1-172 C O1	20.86	80 50	20.86
939741	AE1-205 C O1	34.1	80 50	34.1
940101	AE1-252 C O1	41.91	80 50	41.91
941731	AE2-173 O1	20.3	80 50	20.3
942111	AE2-223 C	7.92	80 50	7.92
942481	AE2-261 C	31.34	80 50	31.34
942601	AE2-276	2.51	80 50	2.51
944201	AF1-088 FTIR	50.16	80 50	50.16
944221	AF1-090 C O1	5.35	80 50	5.35
945391	AF1-204 C O1	3.85	80 50	3.85
945871	AF1-252 O1	9.49	80 50	9.49
945881	AF1-253	6.57	80 50	6.57
957141	AF2-008 FTIR	25.08	80 50	25.08
957381	AF2-032 C	2.4	80 50	2.4
959341	AF2-225 C	25.58	80 50	25.58
959611	AF2-252 C	7.5	80 50	7.5
960141	AF2-305	2.24	80 50	2.24
960261	AF2-317	3.4	80 50	3.4

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
960611	AF2-352 C	7.5	80 50	7.5
963831	AG1-236 C	6.12	80 50	6.12
964581	AG1-321 C O1	67.67	80 50	67.67
965091	AG1-374 C	67.48	80 50	67.48
965331	AG1-398	1.79	80 50	1.79
965341	AG1-399 C	16.51	80 50	16.51
965351	AG1-400	46.89	80 50	46.89
965361	AG1-401 C	16.51	80 50	16.51
965371	AG1-402	46.89	80 50	46.89
965381	AG1-403 C	11.0	80 50	11.0
965391	AG1-404	31.26	80 50	31.26
965911	AG1-460 C	2.1	80 50	2.1
951741	J474 C	4.91	Queue MISO	4.91
952651	J756 C	3.89	Queue MISO	3.89
952871	J757 C	4.78	Queue MISO	4.78
953401	J811	10.28	Queue MISO	10.28
953651	J815	35.48	Queue MISO	35.48
953741	J826 C	2.96	Queue MISO	2.96
953851	J845 C	2.95	Queue MISO	2.95
953881	J848 C	5.48	Queue MISO	5.48
954411	J912	13.52	Queue MISO	13.52
954721	J750 C	3.43	Queue MISO	3.43
954821	J955	168.03	Queue MISO	168.03
955031	J979 C	4.38	Queue MISO	4.38
955401	J1022 C	4.44	Queue MISO	4.44
956151	J1102	10.19	Queue MISO	10.19
956281	J1115 C	7.11	Queue MISO	7.11
956451	J1139	17.36	Queue MISO	17.36
990056	J1201	4.75	Queue MISO	4.75
990641	J1354	28.27	Queue MISO	28.27
990671	J1360 C	8.58	Queue MISO	8.58
990856	J1408	14.28	Queue MISO	14.28
991006	J1454 C	0.92	Queue MISO	0.92
991036	J1464	59.78	Queue MISO	59.78
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.7143	Confirmed LTF	0.7143
LTFEXP_CBM-N	LTFEXP_CBM-N->LTFIMP_CBM-N	1.0198	LTF/CBM	1.0198
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	1.1057	LTF/CBM	1.1057
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	18.5397	LTF/CBM	18.5397
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	38.0111	LTF/CBM	38.0111
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	1.0721	Confirmed LTF	1.0721
LTFEXP_G-007A	LTFEXP_G-007A->LTFIMP_G-007A	2.0462	LTF/CMTX	2.0462
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	5.2112	Confirmed LTF	5.2112
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	1.4737	Confirmed LTF	1.4737

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.3866	Confirmed LTF	0.3866
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	4.249	Confirmed LTF	4.249
LTFEXP_VFT	LTFEXP_VFT->LTFIMP_VFT	5.4977	Confirmed LTF	5.4977
274650	KINCAID ;1U	16.14	80 50	16.14
274651	KINCAID ;2U	16.13	80 50	16.13
274853	TWINGROVE;U1	2.14	80 50	2.14
274854	TWINGROVE;U2	2.2	80 50	2.2
274863	CAYUGA RI;1U	1.72	80 50	1.72
274864	CAYUGA RI;2U	1.72	80 50	1.72
274880	RADFORD R;1U	1.93	80 50	1.93
274889	BRIGHTSTK;1U	1.73	80 50	1.73
924041	AB2-047 C O1	2.17	80 50	2.17
924261	AB2-070 C O1	6.34	80 50	6.34
925771	AC1-053 C	6.12	80 50	6.12
930461	AB1-087 CT1	15.37	80 50	15.37
930462	AB1-087 ST1	12.22	80 50	12.22
930471	AB1-088 CT1	15.37	80 50	15.37
930472	AB1-088 ST1	12.22	80 50	12.22
930761	AB1-122 CT1	-51.45	Adder	-60.53
933446	AC2-157 1C	1.91	80 50	1.91
933447	AC2-157 2C	1.91	80 50	1.91
935001	AD1-133 C O1	122.22	80 50	122.22
935141	AD1-148	10.62	80 50	10.62
936771	AD2-100 C	21.28	80 50	21.28
936971	AD2-131 C	1.4	80 50	1.4
937211	AD2-159 C	8.53	80 50	8.53
939401	AE1-172 C O1	20.86	80 50	20.86
939741	AE1-205 C O1	34.1	80 50	34.1
940101	AE1-252 C O1	41.91	80 50	41.91
941731	AE2-173 O1	20.3	80 50	20.3
942111	AE2-223 C	7.92	80 50	7.92
942481	AE2-261 C	31.34	80 50	31.34
942601	AE2-276	2.51	80 50	2.51
944201	AF1-088 FTIR	50.16	80 50	50.16
944221	AF1-090 C O1	5.35	80 50	5.35
945391	AF1-204 C O1	3.85	80 50	3.85
945871	AF1-252 O1	9.49	80 50	9.49
945881	AF1-253	6.57	80 50	6.57
957141	AF2-008 FTIR	25.08	80 50	25.08
957381	AF2-032 C	2.4	80 50	2.4
959341	AF2-225 C	25.58	80 50	25.58
959611	AF2-252 C	7.5	80 50	7.5
960141	AF2-305	2.24	80 50	2.24
960261	AF2-317	3.4	80 50	3.4
960611	AF2-352 C	7.5	80 50	7.5
963831	AG1-236 C	6.12	80 50	6.12
964581	AG1-321 C O1	67.67	80 50	67.67
965091	AG1-374 C	67.48	80 50	67.48
965331	AG1-398	1.79	80 50	1.79
965341	AG1-399 C	16.51	80 50	16.51
965351	AG1-400	46.89	80 50	46.89

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
965361	AG1-401 C	16.51	80 50	16.51
965371	AG1-402	46.89	80 50	46.89
965381	AG1-403 C	11.0	80 50	11.0
965391	AG1-404	31.26	80 50	31.26
965911	AG1-460 C	2.1	80 50	2.1
951741	J474 C	4.91	Queue MISO	4.91
952651	J756 C	3.89	Queue MISO	3.89
952871	J757 C	4.78	Queue MISO	4.78
953401	J811	10.28	Queue MISO	10.28
953651	J815	35.48	Queue MISO	35.48
953741	J826 C	2.96	Queue MISO	2.96
953851	J845 C	2.95	Queue MISO	2.95
953881	J848 C	5.48	Queue MISO	5.48
954411	J912	13.52	Queue MISO	13.52
954721	J750 C	3.43	Queue MISO	3.43
954821	J955	168.03	Queue MISO	168.03
955031	J979 C	4.38	Queue MISO	4.38
955401	J1022 C	4.44	Queue MISO	4.44
956151	J1102	10.19	Queue MISO	10.19
956281	J1115 C	7.11	Queue MISO	7.11
956451	J1139	17.36	Queue MISO	17.36
990056	J1201	4.75	Queue MISO	4.75
990641	J1354	28.27	Queue MISO	28.27
990671	J1360 C	8.58	Queue MISO	8.58
990856	J1408	14.28	Queue MISO	14.28
991006	J1454 C	0.92	Queue MISO	0.92
991036	J1464	59.78	Queue MISO	59.78
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.7143	Confirmed LTF	0.7143
LTFEXP_CBM-N	LTFEXP_CBM-N->LTFIMP_CBM-N	1.0198	LTF/CBM	1.0198
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	1.1057	LTF/CBM	1.1057
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	18.5397	LTF/CBM	18.5397
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	38.0111	LTF/CBM	38.0111
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	1.0721	Confirmed LTF	1.0721
LTFEXP_G-007A	LTFEXP_G-007A->LTFIMP_G-007A	2.0462	LTF/CMTX	2.0462
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	5.2112	Confirmed LTF	5.2112
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	1.4737	Confirmed LTF	1.4737
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.3866	Confirmed LTF	0.3866
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	4.249	Confirmed LTF	4.249
LTFEXP_VFT	LTFEXP_VFT->LTFIMP_VFT	5.4977	Confirmed LTF	5.4977

11.6.8 Index 8

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
174291175	939400	AE1-172 TAP	CE	934720	AD1-100 TAP	CE	1	COMED_P4_012-45-BT12-14	breaker	1528.0	260.28	262.62	AC	34.49

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
274650	KINCAID ;1U	18.83	80 50	18.83
274651	KINCAID ;2U	18.82	80 50	18.82
274853	TWINGROVE;U1	2.33	80 50	2.33
274854	TWINGROVE;U2	2.4	80 50	2.4
274863	CAYUGA RI;1U	2.25	80 50	2.25
274864	CAYUGA RI;2U	2.25	80 50	2.25
274880	RADFORD R;1U	2.16	80 50	2.16
274889	BRIGHTSTK;1U	1.87	80 50	1.87
276615	W2-048 GEN	12.21	80 50	12.21
276621	X2-022 GEN	45.79	80 50	45.79
290261	S-027 E	64.75	80 50	64.75
290265	S-028 E	64.75	80 50	64.75
293777	CAYUG;1U E	73.06	80 50	73.06
293778	CAYUG;2U E	73.06	80 50	73.06
293798	W4-005 E	75.31	80 50	75.31
917502	Z2-087 E	76.44	80 50	76.44
924041	AB2-047 C O1	2.34	80 50	2.34
924042	AB2-047 E O1	95.55	80 50	95.55
924261	AB2-070 C O1	7.14	80 50	7.14
924262	AB2-070 E O1	43.27	80 50	43.27
925771	AC1-053 C	6.92	80 50	6.92
925772	AC1-053 E	46.3	80 50	46.3
935001	AD1-133 C O1	90.15	80 50	90.15
935002	AD1-133 E O1	60.1	80 50	60.1
935141	AD1-148	12.13	80 50	12.13
936771	AD2-100 C	24.87	80 50	24.87
936772	AD2-100 E	16.58	80 50	16.58
936971	AD2-131 C	1.64	80 50	1.64
936972	AD2-131 E	8.23	80 50	8.23
937211	AD2-159 C	9.54	80 50	9.54
937212	AD2-159 E	44.68	80 50	44.68
939401	AE1-172 C O1	29.99	80 50	29.99
939402	AE1-172 E O1	140.72	80 50	140.72
939741	AE1-205 C O1	36.9	80 50	36.9
939742	AE1-205 E O1	50.96	80 50	50.96
940101	AE1-252 C O1	60.25	80 50	60.25
940102	AE1-252 E O1	40.17	80 50	40.17
941731	AE2-173 O1	21.97	80 50	21.97
942111	AE2-223 C	8.57	80 50	8.57
942112	AE2-223 E	57.33	80 50	57.33
942481	AE2-261 C	36.59	80 50	36.59

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
942482	AE2-261 E	24.39	80 50	24.39
944221	AF1-090 C O1	6.27	80 50	6.27
944222	AF1-090 E O1	29.37	80 50	29.37
945871	AF1-252 O1	11.12	80 50	11.12
945881	AF1-253	7.7	80 50	7.7
957381	AF2-032 C	2.81	80 50	2.81
957382	AF2-032 E	1.32	80 50	1.32
958013	AF2-095 BAT	4.54	80 50	4.54
958023	AF2-096 BAT	9.06	80 50	9.06
959341	AF2-225 C	27.68	80 50	27.68
959342	AF2-225 E	38.22	80 50	38.22
959611	AF2-252 C	8.18	80 50	8.18
959612	AF2-252 E	12.26	80 50	12.26
960141	AF2-305	2.53	80 50	2.53
960261	AF2-317	3.88	80 50	3.88
960603	AF2-351 BAT	2.27	80 50	2.27
960611	AF2-352 C	8.18	80 50	8.18
960612	AF2-352 E	12.26	80 50	12.26
963831	AG1-236 C	6.92	80 50	6.92
963832	AG1-236 E	46.3	80 50	46.3
964581	AG1-321 C O1	63.3	80 50	63.3
964582	AG1-321 E O1	36.86	80 50	36.86
965091	AG1-374 C	73.58	80 50	73.58
965092	AG1-374 E	49.05	80 50	49.05
965331	AG1-398	2.01	80 50	2.01
965341	AG1-399 C	18.21	80 50	18.21
965342	AG1-399 E	85.25	80 50	85.25
965351	AG1-400	51.73	80 50	51.73
965361	AG1-401 C	18.21	80 50	18.21
965362	AG1-401 E	85.25	80 50	85.25
965371	AG1-402	51.73	80 50	51.73
965381	AG1-403 C	12.14	80 50	12.14
965382	AG1-403 E	56.84	80 50	56.84
965391	AG1-404	34.49	80 50	34.49
965911	AG1-460 C	2.45	80 50	2.45
965912	AG1-460 E	3.67	80 50	3.67
951741	J474 C	5.35	Queue MISO	5.35
951742	J474 E	28.93	Queue MISO	28.93
952651	J756 C	4.84	Queue MISO	4.84
952652	J756 E	26.21	Queue MISO	26.21
952871	J757 C	5.98	Queue MISO	5.98
952872	J757 E	32.33	Queue MISO	32.33
953401	J811	11.09	Queue MISO	11.09
953651	J815	39.31	Queue MISO	39.31
953741	J826 C	3.16	Queue MISO	3.16
953742	J826 E	17.1	Queue MISO	17.1
953851	J845 C	3.11	Queue MISO	3.11
953852	J845 E	16.83	Queue MISO	16.83
953881	J848 C	6.01	Queue MISO	6.01
953882	J848 E	32.53	Queue MISO	32.53
954411	J912	14.81	Queue MISO	14.81
954721	J750 C	3.98	Queue MISO	3.98

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
954722	J750 E	21.54	Queue MISO	21.54
954821	J955	187.12	Queue MISO	187.12
955031	J979 C	4.81	Queue MISO	4.81
955032	J979 E	26.02	Queue MISO	26.02
955401	J1022 C	4.74	Queue MISO	4.74
955402	J1022 E	25.64	Queue MISO	25.64
955711	J1055 C	2.37	Queue MISO	2.37
955712	J1055 E	12.84	Queue MISO	12.84
956151	J1102	12.11	Queue MISO	12.11
956281	J1115 C	7.66	Queue MISO	7.66
956282	J1115 E	41.46	Queue MISO	41.46
956451	J1139	17.91	Queue MISO	17.91
990056	J1201	5.18	Queue MISO	5.18
990121	J1216	26.23	Queue MISO	26.23
990641	J1354	30.76	Queue MISO	30.76
990671	J1360 C	9.12	Queue MISO	9.12
990672	J1360 E	49.35	Queue MISO	49.35
990856	J1408	16.3	Queue MISO	16.3
991001	J1453 C	3.67	Queue MISO	3.67
991002	J1453 E	19.85	Queue MISO	19.85
991006	J1454 C	1.22	Queue MISO	1.22
991007	J1454 E	6.61	Queue MISO	6.61
991036	J1464	74.79	Queue MISO	74.79
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.8114	Confirmed LTF	0.8114
LTFEXP_CBM-N	LTFEXP_CBM-N->LTFIMP_CBM-N	0.9256	LTF/CBM	0.9256
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	1.3887	LTF/CBM	1.3887
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	21.7447	LTF/CBM	21.7447
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	49.4763	LTF/CBM	49.4763
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	1.2196	Confirmed LTF	1.2196
LTFEXP_G-007A	LTFEXP_G-007A->LTFIMP_G-007A	1.861	LTF/CMTX	1.861
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	7.2908	Confirmed LTF	7.2908
LTFEXP_LGE-0012019	LTFEXP_LGE-0012019->LTFIMP_LGE-0012019	0.072	Confirmed LTF	0.072
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	1.6099	Confirmed LTF	1.6099
LTFEXP_MEC	LTFEXP_MEC->LTFIMP_MEC	3.2482	Confirmed LTF	3.2482
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.4395	Confirmed LTF	0.4395
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	5.4556	Confirmed LTF	5.4556
LTFEXP_VFT	LTFEXP_VFT->LTFIMP_VFT	4.9968	Confirmed LTF	4.9968

11.6.9 Index 9

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
170018416	964580	AG1-321 TAP	CE	935000	AD1-133 TAP	CE	1	COMED_P1-2_345-L11212_B-S-B	single	1656.0	109.67	111.55	AC	31.26

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
274650	KINCAID ;1U	16.13	80 50	16.13
274651	KINCAID ;2U	16.13	80 50	16.13
274853	TWINGROVE;U1	2.14	80 50	2.14
274854	TWINGROVE;U2	2.2	80 50	2.2
274863	CAYUGA RI;1U	1.72	80 50	1.72
274864	CAYUGA RI;2U	1.72	80 50	1.72
274880	RADFORD R;1U	1.93	80 50	1.93
274889	BRIGHTSTK;1U	1.73	80 50	1.73
904211	W3-135	-0.97	Adder	-1.14
924041	AB2-047 C O1	2.17	80 50	2.17
924261	AB2-070 C O1	6.34	80 50	6.34
925771	AC1-053 C	6.12	80 50	6.12
930461	AB1-087 CT1	15.37	80 50	15.37
930462	AB1-087 ST1	12.22	80 50	12.22
930471	AB1-088 CT1	15.37	80 50	15.37
930472	AB1-088 ST1	12.22	80 50	12.22
930761	AB1-122 CT1	-51.45	Adder	-60.53
933446	AC2-157 1C	1.91	80 50	1.91
933447	AC2-157 2C	1.91	80 50	1.91
935141	AD1-148	10.62	80 50	10.62
936771	AD2-100 C	21.28	80 50	21.28
936971	AD2-131 C	1.4	80 50	1.4
937211	AD2-159 C	8.53	80 50	8.53
939401	AE1-172 C O1	20.86	80 50	20.86
939741	AE1-205 C O1	34.1	80 50	34.1
940101	AE1-252 C O1	41.91	80 50	41.91
941731	AE2-173 O1	20.3	80 50	20.3
942111	AE2-223 C	7.92	80 50	7.92
942481	AE2-261 C	31.34	80 50	31.34
942601	AE2-276	2.51	80 50	2.51
944201	AF1-088 FTIR	50.16	80 50	50.16
944221	AF1-090 C O1	5.35	80 50	5.35
945391	AF1-204 C O1	3.85	80 50	3.85
945871	AF1-252 O1	9.49	80 50	9.49
945881	AF1-253	6.57	80 50	6.57
957141	AF2-008 FTIR	25.08	80 50	25.08
957381	AF2-032 C	2.4	80 50	2.4
959341	AF2-225 C	25.58	80 50	25.58
959611	AF2-252 C	7.5	80 50	7.5
960141	AF2-305	2.24	80 50	2.24
960261	AF2-317	3.4	80 50	3.4

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
960611	AF2-352 C	7.5	80 50	7.5
963831	AG1-236 C	6.12	80 50	6.12
964581	AG1-321 C O1	67.67	80 50	67.67
965091	AG1-374 C	67.48	80 50	67.48
965331	AG1-398	1.79	80 50	1.79
965341	AG1-399 C	16.51	80 50	16.51
965351	AG1-400	46.89	80 50	46.89
965361	AG1-401 C	16.51	80 50	16.51
965371	AG1-402	46.89	80 50	46.89
965381	AG1-403 C	11.0	80 50	11.0
965391	AG1-404	31.26	80 50	31.26
965911	AG1-460 C	2.1	80 50	2.1
951741	J474 C	4.91	Queue MISO	4.91
952651	J756 C	3.89	Queue MISO	3.89
952871	J757 C	4.78	Queue MISO	4.78
953401	J811	10.28	Queue MISO	10.28
953651	J815	35.48	Queue MISO	35.48
953741	J826 C	2.96	Queue MISO	2.96
953851	J845 C	2.95	Queue MISO	2.95
953881	J848 C	5.48	Queue MISO	5.48
954411	J912	13.52	Queue MISO	13.52
954721	J750 C	3.43	Queue MISO	3.43
954821	J955	168.03	Queue MISO	168.03
955031	J979 C	4.38	Queue MISO	4.38
955401	J1022 C	4.44	Queue MISO	4.44
956151	J1102	10.19	Queue MISO	10.19
956281	J1115 C	7.11	Queue MISO	7.11
956451	J1139	17.36	Queue MISO	17.36
990056	J1201	4.75	Queue MISO	4.75
990641	J1354	28.27	Queue MISO	28.27
990671	J1360 C	8.58	Queue MISO	8.58
990856	J1408	14.28	Queue MISO	14.28
991006	J1454 C	0.92	Queue MISO	0.92
991036	J1464	59.78	Queue MISO	59.78
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.7143	Confirmed LTF	0.7143
LTFEXP_CBM-N	LTFEXP_CBM-N->LTFIMP_CBM-N	1.0198	LTF/CBM	1.0198
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	1.1057	LTF/CBM	1.1057
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	18.5397	LTF/CBM	18.5397
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	38.0111	LTF/CBM	38.0111
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	1.0721	Confirmed LTF	1.0721
LTFEXP_G-007A	LTFEXP_G-007A->LTFIMP_G-007A	2.0462	LTF/CMTX	2.0462
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	5.2112	Confirmed LTF	5.2112
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	1.4737	Confirmed LTF	1.4737

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.3866	Confirmed LTF	0.3866
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	4.249	Confirmed LTF	4.249
LTFEXP_VFT	LTFEXP_VFT->LTFIMP_VFT	5.4977	Confirmed LTF	5.4977
274650	KINCAID ;1U	16.14	80 50	16.14
274651	KINCAID ;2U	16.13	80 50	16.13
274853	TWINGROVE;U1	2.14	80 50	2.14
274854	TWINGROVE;U2	2.2	80 50	2.2
274863	CAYUGA RI;1U	1.72	80 50	1.72
274864	CAYUGA RI;2U	1.72	80 50	1.72
274880	RADFORD R;1U	1.93	80 50	1.93
274889	BRIGHTSTK;1U	1.73	80 50	1.73
904211	W3-135	-0.97	Adder	-1.14
924041	AB2-047 C O1	2.17	80 50	2.17
924261	AB2-070 C O1	6.34	80 50	6.34
925771	AC1-053 C	6.12	80 50	6.12
930461	AB1-087 CT1	15.37	80 50	15.37
930462	AB1-087 ST1	12.22	80 50	12.22
930471	AB1-088 CT1	15.37	80 50	15.37
930472	AB1-088 ST1	12.22	80 50	12.22
930761	AB1-122 CT1	-51.45	Adder	-60.53
933446	AC2-157 1C	1.91	80 50	1.91
933447	AC2-157 2C	1.91	80 50	1.91
935141	AD1-148	10.62	80 50	10.62
936771	AD2-100 C	21.28	80 50	21.28
936971	AD2-131 C	1.4	80 50	1.4
937211	AD2-159 C	8.53	80 50	8.53
939401	AE1-172 C O1	20.86	80 50	20.86
939741	AE1-205 C O1	34.1	80 50	34.1
940101	AE1-252 C O1	41.91	80 50	41.91
941731	AE2-173 O1	20.3	80 50	20.3
942111	AE2-223 C	7.92	80 50	7.92
942481	AE2-261 C	31.34	80 50	31.34
942601	AE2-276	2.51	80 50	2.51
944201	AF1-088 FTIR	50.16	80 50	50.16
944221	AF1-090 C O1	5.35	80 50	5.35
945391	AF1-204 C O1	3.85	80 50	3.85
945871	AF1-252 O1	9.49	80 50	9.49
945881	AF1-253	6.57	80 50	6.57
957141	AF2-008 FTIR	25.08	80 50	25.08
957381	AF2-032 C	2.4	80 50	2.4
959341	AF2-225 C	25.58	80 50	25.58
959611	AF2-252 C	7.5	80 50	7.5
960141	AF2-305	2.24	80 50	2.24
960261	AF2-317	3.4	80 50	3.4
960611	AF2-352 C	7.5	80 50	7.5
963831	AG1-236 C	6.12	80 50	6.12
964581	AG1-321 C O1	67.67	80 50	67.67
965091	AG1-374 C	67.48	80 50	67.48
965331	AG1-398	1.79	80 50	1.79
965341	AG1-399 C	16.51	80 50	16.51
965351	AG1-400	46.89	80 50	46.89

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
965361	AG1-401 C	16.51	80 50	16.51
965371	AG1-402	46.89	80 50	46.89
965381	AG1-403 C	11.0	80 50	11.0
965391	AG1-404	31.26	80 50	31.26
965911	AG1-460 C	2.1	80 50	2.1
951741	J474 C	4.91	Queue MISO	4.91
952651	J756 C	3.89	Queue MISO	3.89
952871	J757 C	4.78	Queue MISO	4.78
953401	J811	10.28	Queue MISO	10.28
953651	J815	35.48	Queue MISO	35.48
953741	J826 C	2.96	Queue MISO	2.96
953851	J845 C	2.95	Queue MISO	2.95
953881	J848 C	5.48	Queue MISO	5.48
954411	J912	13.52	Queue MISO	13.52
954721	J750 C	3.43	Queue MISO	3.43
954821	J955	168.03	Queue MISO	168.03
955031	J979 C	4.38	Queue MISO	4.38
955401	J1022 C	4.44	Queue MISO	4.44
956151	J1102	10.19	Queue MISO	10.19
956281	J1115 C	7.11	Queue MISO	7.11
956451	J1139	17.36	Queue MISO	17.36
990056	J1201	4.75	Queue MISO	4.75
990641	J1354	28.27	Queue MISO	28.27
990671	J1360 C	8.58	Queue MISO	8.58
990856	J1408	14.28	Queue MISO	14.28
991006	J1454 C	0.92	Queue MISO	0.92
991036	J1464	59.78	Queue MISO	59.78
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.7143	Confirmed LTF	0.7143
LTFEXP_CBM-N	LTFEXP_CBM-N->LTFIMP_CBM-N	1.0198	LTF/CBM	1.0198
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	1.1057	LTF/CBM	1.1057
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	18.5397	LTF/CBM	18.5397
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	38.0111	LTF/CBM	38.0111
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	1.0721	Confirmed LTF	1.0721
LTFEXP_G-007A	LTFEXP_G-007A->LTFIMP_G-007A	2.0462	LTF/CMTX	2.0462
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	5.2112	Confirmed LTF	5.2112
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	1.4737	Confirmed LTF	1.4737
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.3866	Confirmed LTF	0.3866
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	4.249	Confirmed LTF	4.249
LTFEXP_VFT	LTFEXP_VFT->LTFIMP_VFT	5.4977	Confirmed LTF	5.4977

11.6.10 Index 10

ID	FROM BUS#	FROM BUS	FROM BUS AREA	TO BUS#	TO BUS	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
180200007	965340	AG1-399 TAP	CE	270668	BLUEMOUND; B	CE	1	COMED_P4_BRO-45-BT2-3__	breaker	1829.0	128.0	130.31	AC	43.07

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
274650	KINCAID ;1U	15.15	80 50	15.15
274651	KINCAID ;2U	15.17	80 50	15.17
274880	RADFORD R;1U	2.32	80 50	2.32
274889	BRIGHTSTK;1U	0.69	80 50	0.69
276615	W2-048 GEN	8.07	80 50	8.07
276621	X2-022 GEN	30.26	80 50	30.26
293798	W4-005 E	80.83	80 50	80.83
917502	Z2-087 E	28.03	80 50	28.03
924041	AB2-047 C O1	0.86	80 50	0.86
924042	AB2-047 E O1	35.03	80 50	35.03
924261	AB2-070 C O1	4.23	80 50	4.23
924262	AB2-070 E O1	25.6	80 50	25.6
925771	AC1-053 C	4.24	80 50	4.24
925772	AC1-053 E	28.34	80 50	28.34
935141	AD1-148	8.02	80 50	8.02
936771	AD2-100 C	19.94	80 50	19.94
936772	AD2-100 E	13.29	80 50	13.29
936971	AD2-131 C	1.31	80 50	1.31
936972	AD2-131 E	6.6	80 50	6.6
937211	AD2-159 C	10.24	80 50	10.24
937212	AD2-159 E	47.96	80 50	47.96
939741	AE1-205 C O1	13.53	80 50	13.53
939742	AE1-205 E O1	18.68	80 50	18.68
941731	AE2-173 O1	8.05	80 50	8.05
942111	AE2-223 C	3.14	80 50	3.14
942112	AE2-223 E	21.02	80 50	21.02
942481	AE2-261 C	29.41	80 50	29.41
942482	AE2-261 E	19.61	80 50	19.61
944221	AF1-090 C O1	4.98	80 50	4.98
944222	AF1-090 E O1	23.34	80 50	23.34
945871	AF1-252 O1	8.84	80 50	8.84
945881	AF1-253	6.12	80 50	6.12
957381	AF2-032 C	2.26	80 50	2.26
957382	AF2-032 E	1.06	80 50	1.06
958023	AF2-096 BAT	5.63	Adder	6.62
959341	AF2-225 C	10.15	80 50	10.15
959342	AF2-225 E	14.01	80 50	14.01
959613	AF2-252 BAT	21.56	80 50	21.56
960141	AF2-305	1.5	80 50	1.5
960261	AF2-317	2.57	80 50	2.57
960613	AF2-352 BAT	21.56	80 50	21.56

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
963831	AG1-236 C	4.24	80 50	4.24
963832	AG1-236 E	28.34	80 50	28.34
965331	AG1-398	1.19	80 50	1.19
965341	AG1-399 C	22.74	80 50	22.74
965342	AG1-399 E	106.48	80 50	106.48
965351	AG1-400	64.61	80 50	64.61
965361	AG1-401 C	22.74	80 50	22.74
965362	AG1-401 E	106.48	80 50	106.48
965371	AG1-402	64.61	80 50	64.61
965381	AG1-403 C	15.16	80 50	15.16
965382	AG1-403 E	70.98	80 50	70.98
965391	AG1-404	43.07	80 50	43.07
965911	AG1-460 C	1.97	80 50	1.97
965912	AG1-460 E	2.95	80 50	2.95
951741	J474 C	3.42	Queue MISO	3.42
951742	J474 E	18.49	Queue MISO	18.49
952651	J756 C	3.89	Queue MISO	3.89
952652	J756 E	21.04	Queue MISO	21.04
952871	J757 C	4.56	Queue MISO	4.56
952872	J757 E	24.69	Queue MISO	24.69
953401	J811	9.02	Queue MISO	9.02
953651	J815	32.09	Queue MISO	32.09
953741	J826 C	1.83	Queue MISO	1.83
953742	J826 E	9.9	Queue MISO	9.9
953851	J845 C	1.82	Queue MISO	1.82
953852	J845 E	9.84	Queue MISO	9.84
953881	J848 C	4.93	Queue MISO	4.93
953882	J848 E	26.67	Queue MISO	26.67
954411	J912	12.12	Queue MISO	12.12
954721	J750 C	3.11	Queue MISO	3.11
954722	J750 E	16.83	Queue MISO	16.83
954821	J955	154.2	Queue MISO	154.2
955031	J979 C	3.94	Queue MISO	3.94
955032	J979 E	21.34	Queue MISO	21.34
955401	J1022 C	2.75	Queue MISO	2.75
955402	J1022 E	14.86	Queue MISO	14.86
956151	J1102	10.09	Queue MISO	10.09
956281	J1115 C	6.94	Queue MISO	6.94
956282	J1115 E	37.57	Queue MISO	37.57
956451	J1139	13.05	Queue MISO	13.05
990056	J1201	4.21	Queue MISO	4.21
990121	J1216	19.01	Queue MISO	19.01
990181	J1232	7.45	Queue MISO	7.45
990641	J1354	25.15	Queue MISO	25.15
990671	J1360 C	6.72	Queue MISO	6.72
990672	J1360 E	36.37	Queue MISO	36.37
990856	J1408	13.14	Queue MISO	13.14
991001	J1453 C	2.6	Queue MISO	2.6
991002	J1453 E	14.07	Queue MISO	14.07
991006	J1454 C	0.93	Queue MISO	0.93
991007	J1454 E	5.04	Queue MISO	5.04
991036	J1464	57.12	Queue MISO	57.12

Bus #	Bus	Gendeliv MW Impact	Type	Full MW Impact
LTFEXP_AA2-074	LTFEXP_AA2-074->LTFIMP_AA2-074	0.6328	Confirmed LTF	0.6328
LTFEXP_CBM-N	LTFEXP_CBM-N->LTFIMP_CBM-N	0.8295	LTF/CBM	0.8295
LTFEXP_CBM-S1	LTFEXP_CBM-S1->LTFIMP_CBM-S1	1.0223	LTF/CBM	1.0223
LTFEXP_CBM-S2	LTFEXP_CBM-S2->LTFIMP_CBM-S2	16.6612	LTF/CBM	16.6612
LTFEXP_CBM-W2	LTFEXP_CBM-W2->LTFIMP_CBM-W2	35.0887	LTF/CBM	35.0887
LTFEXP_CPLE	LTFEXP_CPLE->LTFIMP_CPLE	0.9506	Confirmed LTF	0.9506
LTFEXP_G-007A	LTFEXP_G-007A->LTFIMP_G-007A	1.6655	LTF/CMTX	1.6655
LTFEXP_LAGN	LTFEXP_LAGN->LTFIMP_LAGN	5.1312	Confirmed LTF	5.1312
LTFEXP_LGE-0012019	LTFEXP_LGE-0012019->LTFIMP_LGE-0012019	0.0342	Confirmed LTF	0.0342
LTFEXP_LGEE	LTFEXP_LGEE->LTFIMP_LGEE	1.247	Confirmed LTF	1.247
LTFEXP_MEC	LTFEXP_MEC->LTFIMP_MEC	0.8975	Confirmed LTF	0.8975
LTFEXP_SIGE	LTFEXP_SIGE->LTFIMP_SIGE	0.3315	Confirmed LTF	0.3315
LTFEXP_TVA	LTFEXP_TVA->LTFIMP_TVA	3.9857	Confirmed LTF	3.9857
LTFEXP_VFT	LTFEXP_VFT->LTFIMP_VFT	4.4738	Confirmed LTF	4.4738

11.7 Queue Dependencies

The Queue Projects below are listed in one or more indices for the overloads identified in your report. These projects contribute to the loading of the overloaded facilities identified in your report. The percent overload of a facility and cost allocation you may have towards a particular reinforcement could vary depending on the action of these earlier projects. The status of each project at the time of the analysis is presented in the table. This list may change as earlier projects withdraw or modify their requests.

Queue Number	Project Name	Status
AA2-074	CPL-PJM	Confirmed
AB1-087	Sullivan 345kV #1	Active
AB1-088	Sullivan 345kV #2	Active
AB1-091	Davis Creek 345kV	Active
AB1-122	Kendall-Tazewell & Dresden-Mole Creek	Under Construction
AB2-047	Brokaw-Pontiac Midpoint	In Service
AB2-070	Mt. Pulaski-Brokaw	Engineering and Procurement
AC1-053	Lanesville-Brokaw	Active
AC1-056	PJM-AMIL	Confirmed
AC2-154	Davis Creek 138kV	Active
AC2-157	Sullivan 345 kV	Active
AD1-100	Loretto-Wilton 345 kV & Braidwood-Davis Creek 345 kV	Active
AD1-133	Pontiac MidPoint-Dresden	Active
AD1-148	Brokaw-Lanesville	Active
AD2-047	Davis Creek 138 kV	Active
AD2-060	Davis Creek 138kV	Active
AD2-100	Kincaid-Pana	Active
AD2-131	Kincaid-Pana 345kV	Active
AD2-159	Chestnut 345kV	Active
AE1-143	Marion County 161 kV	Engineering and Procurement
AE1-166	Loretto-Wilton & Braidwood-Davis Creek	Active
AE1-172	Loretto-Wilton Center	Active
AE1-205	McLean 345 kV	Active
AE1-252	Loretto-Wilton Center	Active
AE2-152	Loretto-Wilton & Braidwood-Davis Creek	Active
AE2-153	Braidwood-Davis Creek	Active
AE2-173	McLean 345 kV	Active
AE2-223	McLean 345 kV	Active
AE2-254	Garrard County-Tommy-Gooch 69 kV	Engineering and Procurement
AE2-261	Kincaid-Pana	Active
AE2-276	Sullivan 345kV	Active
AF1-088	Sullivan 345 kV	Active
AF1-090	Kincaid-Pana	Active
AF1-156	Braidwood-Davis Creek	Active
AF1-204	Eugene 345 kV	Active
AF1-252	Kincaid-Pana	Active
AF1-253	Kincaid-Pana	Active
AF2-008	Sullivan 345 kV	Active

Queue Number	Project Name	Status
AF2-032	Kincaid	Active
AF2-095	Davis Creek 138 kV	Active
AF2-096	Braidwood-East Frankfort 345 kV	Active
AF2-225	McLean 345 kV	Active
AF2-252	Blue Mound 345 kV	Active
AF2-305	Brokaw-Lanesville 345 kV	Active
AF2-317	Hill Topper 345 kV	Active
AF2-350	Kensington 138 kV	Active
AF2-351	Kensington 138 kV	Active
AF2-352	Blue Mound 345 kV	Active
AG1-236	Lanesville-Brokaw 345 kV	Active
AG1-321	Dresden-Pontiac Midpoint 345 kV	Active
AG1-374	Blue Mound 345 kV	Active
AG1-398	Brokaw-Lanesville 345 kV	Active
AG1-399	Blue Mound-Chestnut 345 kV	Active
AG1-400	Blue Mound-Chestnut 345 kV	Active
AG1-401	Blue Mound-Chestnut 345 kV	Active
AG1-402	Blue Mound-Chestnut 345 kV	Active
AG1-403	Clinton-Brokaw 345 kV	Active
AG1-404	Clinton-Brokaw 345 kV	Active
AG1-460	Kincaid-Pana 345 kV	Active
W2-048	Brokaw-Lanesville	In Service
W3-135	Goose Lake 34.5kV	Engineering and Procurement
W4-005	Blue Mound-Latham	In Service
X2-022	Brokaw-Lanesville	In Service
Z2-081	Streator 34.5kV	In Service
Z2-087	Pontiac MidPoint-Brokaw 345kV	In Service
J1022	MISO	MISO
J1055	MISO	MISO
J1102	MISO	MISO
J1115	MISO	MISO
J1139	MISO	MISO
J1201	MISO	MISO
J1216	MISO	MISO
J1232	MISO	MISO
J1354	MISO	MISO
J1360	MISO	MISO
J1408	MISO	MISO
J1453	MISO	MISO
J1454	MISO	MISO
J1464	MISO	MISO
J474	MISO	MISO
J750	MISO	MISO
J756	MISO	MISO
J757	MISO	MISO
J811	MISO	MISO
J815	MISO	MISO
J826	MISO	MISO
J845	MISO	MISO
J848	MISO	MISO
J912	MISO	MISO
J949	MISO	MISO

Queue Number	Project Name	Status
J955	MISO	MISO
J979	MISO	MISO

11.8 Contingency Descriptions

Contingency Name	Contingency Definition
COMED_P1-2_345-L11212_B-S-C	CONTINGENCY 'COMED_P1-2_345-L11212_B-S-C' / CONTINGENCY # 198 TRIP BRANCH FROM BUS 939400 TO BUS 270704 CKT 1 / AE1-172 TAP 345 LORETTO ; B 345 END
COMED_P4_BRO-45-BT2-3__	CONTINGENCY 'COMED_P4_BRO-45-BT2-3__' / CONTINGENCY # 849 TRIP BRANCH FROM BUS 270853 TO BUS 270819 CKT 1 / PONTIAC ; R 345 MCLEAN ; R 345 TRIP BRANCH FROM BUS 348847 TO BUS 348848 CKT 2 / 7BROKAW T1 345 4BROKAW 138 END
COMED_P1-2_345-L8002____-S	CONTINGENCY 'COMED_P1-2_345-L8002____-S' / CONTINGENCY # 543 TRIP BRANCH FROM BUS 270852 TO BUS 270668 CKT 1 / PONTIAC ; B 345 BLUEMOUND; B 345 END
COMED_P1-2_345-L2105____-S-D	CONTINGENCY 'COMED_P1-2_345-L2105____-S-D' / CONTINGENCY # 441 TRIP BRANCH FROM BUS 944220 TO BUS 347945 CKT 1 / AF1-090 TAP ; R 345 7PANA 345 END
COMED_P1-2_345-L11212_B-S-B	CONTINGENCY 'COMED_P1-2_345-L11212_B-S-B' / CONTINGENCY # 198 TRIP BRANCH FROM BUS 934720 TO BUS 939400 CKT 1 / AD1-100 TAP 345 AE1-172 TAP 345 END
COMED_P4_012-45-BT14-15	CONTINGENCY 'COMED_P4_012-45-BT14-15' / CONTINGENCY # 79 TRIP BRANCH FROM BUS 935000 TO BUS 270717 CKT 1 / AD1-133 TAP 345 DRESDEN ; R 345 TRIP BRANCH FROM BUS 270697 TO BUS 270717 CKT 1 / COLLINS ; R 345 DRESDEN ; R 345 END
COMED_P4_012-45-BT12-14	CONTINGENCY 'COMED_P4_012-45-BT12-14' / CONTINGENCY # 78 TRIP BRANCH FROM BUS 270717 TO BUS 930760 CKT 1 / DRESDEN ; R 345 AB1-122 345 TRIP BRANCH FROM BUS 935000 TO BUS 270717 CKT 1 / AD1-133 TAP 345 DRESDEN ; R 345 END
934725 AD1-100 JNT 345 934730 AD1-100 TAP 345 1	

Contingency Name	Contingency Definition
COMED_P1-2_345-L8001__-S	CONTINGENCY 'COMED_P1-2_345-L8001__-S' / CONTINGENCY # 542 TRIP BRANCH FROM BUS 270853 TO BUS 270819 CKT 1 / PONTIAC ; R 345 MCLEAN ; R 345 END
Base Case	
COMED_P1-2_345-L8014__R-S-B	CONTINGENCY 'COMED_P1-2_345-L8014__R-S-B' / CONTINGENCY # 545 TRIP BRANCH FROM BUS 964580 TO BUS 935000 CKT 1 / AG1-321 TAP TAP 345 AD1- 133 TAP 345 END
COMED_P1-2_345-L8014__R-S-C	CONTINGENCY 'COMED_P1-2_345-L8014__R-S-C' / CONTINGENCY # 545 TRIP BRANCH FROM BUS 935000 TO BUS 270717 CKT 1 / AD1-133 TAP 345 DRESDEN ; R 345 END
EXT_P12:345:AMIL::AUSTIN:PANA: 1	CONTINGENCY 'EXT_P12:345:AMIL::AUSTIN:PANA:1' / 10111 OPEN BRANCH FROM BUS 347945 TO BUS 347955 CKT 1 / 347945 7PANA 345 347955 7AUSTIN 345 1 END

12 Short Circuit Analysis – Primary POI

No breakers were identified as over-dutied as part of this analysis.

13 Summer Peak - Load Flow Analysis - Secondary POI

The Queue Project AG1-404 was evaluated as a 100.0 MW (Capacity 100.00 MW) injection tapping the Bluemond to Chestnut 345 kV line in the ComEd area. Project AG1-404 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AG1-404 was studied with a commercial probability of 53.0 %. Potential network impacts were as follows:

13.1 Generation Deliverability

(Single or N-1 contingencies)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
	270704	LORETTO ; B	345.0	CE	270852	PONTIAC ; B	345.0	CE	1	AEP_P1-2_#363_1682	single	1528.0	99.24	100.59	DC	20.57

13.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies)

None.

13.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADING %	POST PROJECT LOADING %	AC DC	MW IMPACT
179431600	270668	BLUEMOUN D; B	345.0	CE	270852	PONTIAC ; B	345.0	CE	1	COMED_P4_BR O-45-BT2-3	breaker	1528.0	176.19	177.24	AC	16.16
168506637	270704	LORETTO ; B	345.0	CE	939400	AE1-172 TAP	345.0	CE	1	COMED_P1-2_345-L8014_R-S-C	single	1528.0	130.61	132.48	AC	28.60
168506638	270704	LORETTO ; B	345.0	CE	939400	AE1-172 TAP	345.0	CE	1	COMED_P1-2_345-L8014_R-S-B	single	1528.0	124.8	126.67	AC	28.60
174291179	270704	LORETTO ; B	345.0	CE	939400	AE1-172 TAP	345.0	CE	1	COMED_P4_01 2-45-BT12-14	breaker	1528.0	242.51	244.49	AC	29.19
179431273	270704	LORETTO ; B	345.0	CE	939400	AE1-172 TAP	345.0	CE	1	COMED_P4_01 2-45-BT14-15	breaker	1528.0	232.34	234.28	AC	28.68
168506763	270819	MCLEAN ; R	345.0	CE	270853	PONTIAC ; R	345.0	CE	1	COMED_P1-2_345-L8002_-S	single	1819.0	101.54	103.42	AC	33.78
168506647	270852	PONTIAC ; B	345.0	CE	270704	LORETT O ; B	345.0	CE	1	COMED_P1-2_345-L8014_R-S-C	single	1528.0	130.14	132.01	AC	28.62

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC/D C	MW IMPACT
168506648	270852	PONTIAC ; B	345.0	CE	270704	LORETT O ; B	345.0	CE	1	COMED_P1-2_345-L8014_R-S-B	single	1528.0	124.32	126.19	AC	28.62
179431360	270852	PONTIAC ; B	345.0	CE	270704	LORETT O ; B	345.0	CE	1	COMED_P4_012-45-BT12-14	breaker	1528.0	230.27	232.23	AC	29.21
179431361	270852	PONTIAC ; B	345.0	CE	270704	LORETT O ; B	345.0	CE	1	COMED_P4_012-45-BT14-15	breaker	1528.0	221.74	223.66	AC	28.69
168506684	270853	PONTIAC ; R	345.0	CE	964580	AG1-321 TAP	345.0	CE	1	COMED_P1-2_345-L11212_B-S-B	single	1656.0	106.10	107.68	AC	26.09
168506685	270853	PONTIAC ; R	345.0	CE	964580	AG1-321 TAP	345.0	CE	1	COMED_P1-2_345-L11212_B-S-C	single	1656.0	103.14	104.98	AC	26.09
169733844	935000	AD1-133 TAP	345.0	CE	270717	DRESDE N ; R	345.0	CE	1	COMED_P1-2_345-L11212_B-S-B	single	1656.0	116.76	118.34	AC	26.09
169733845	935000	AD1-133 TAP	345.0	CE	270717	DRESDE N ; R	345.0	CE	1	COMED_P1-2_345-L11212_B-S-C	single	1656.0	113.49	115.06	AC	26.09
169733808	939400	AE1-172 TAP	345.0	CE	934720	AD1-100 TAP	345.0	CE	1	COMED_P1-2_345-L8014_R-S-C	single	1528.0	136.22	138.08	AC	28.60
169733809	939400	AE1-172 TAP	345.0	CE	934720	AD1-100 TAP	345.0	CE	1	COMED_P1-2_345-L8014_R-S-B	single	1528.0	130.39	132.25	AC	28.60
174291175	939400	AE1-172 TAP	345.0	CE	934720	AD1-100 TAP	345.0	CE	1	COMED_P4_012-45-BT12-14	breaker	1528.0	259.60	261.58	AC	29.19
179431151	939400	AE1-172 TAP	345.0	CE	934720	AD1-100 TAP	345.0	CE	1	COMED_P4_012-45-BT14-15	breaker	1528.0	249.42	251.36	AC	28.67
170018416	964580	AG1-321 TAP	345.0	CE	935000	AD1-133 TAP	345.0	CE	1	COMED_P1-2_345-L11212_B-S-B	single	1656.0	110.14	111.71	AC	26.09
170018417	964580	AG1-321 TAP	345.0	CE	935000	AD1-133 TAP	345.0	CE	1	COMED_P1-2_345-L11212_B-S-C	single	1656.0	107.22	109.00	AC	26.09
	348847	7BROKAW	345.0	AMI L	965380	AG1-403 TAP	345.0	CE	1	COMED_P4_LA T-45-BT11	breaker	1327.0	138.17	141.32	AC	67.55
	348847	7BROKAW	345.0	AMI L	965380	AG1-403 TAP	345.0	CE	1	COMED_P4_LA T-45-BT15	breaker	1327.0	136.34	143.13	AC	67.80
	924260	AB2-070 TAP	345.0	CE	925770	AC1-053 TAP	345.0	CE	1	COMED_P4_LA T-45-BT11	breaker	1327.0	120.29	122.66	AC	32.45
	924260	AB2-070 TAP	345.0	CE	925770	AC1-053 TAP	345.0	CE	1	COMED_P4_LA T-45-BT15	breaker	1327.0	117.88	120.23	AC	32.2
	924260	AB2-070 TAP	345.0	CE	965380	AG1-403 TAP	345.0	CE	1	COMED_P4_LA T-45-BT11	breaker	1327.0	129.26	131.63	AC	32.45
	924260	AB2-070 TAP	345.0	CE	965380	AG1-403 TAP	345.0	CE	1	COMED_P4_LA T-45-BT15	breaker	1327.0	127.14	129.49	AC	32.2
	270823	MTPULASKI ;	345.0	CE	925770	AC1-053 TAP	345.0	CE	1	COMED_P4_LA T-45-BT11	breaker	1327.0	104.65	107.04	AC	32.45
	270823	MTPULASKI ;	345.0	CE	925770	AC1-053 TAP	345.0	CE	1	COMED_P4_LA T-45-BT15	breaker	1327.0	102.23	104.61	AC	32.2

13.4 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection

Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CKT ID	CONT NAME	Type	Rating MVA	PRE PROJECTIONS LOADING %	POST PROJECTIONS LOADING %	AC/D C	MW IMPACT
	270819	MCLEAN ; R	345.0	CE	348847	7BROKAW	345.0	AMIL	1	COMED_P1-2_345-L8002___-S	operation	1793.0	144.0	145.89	AC	33.81
	270796	KINCAID ; B	345.0	CE	347955	7AUSTIN	345.0	AMIL	1	COMED_P1-2_345-L2105___-S-D	operation	1319.0	145.87	147.57	AC	23.16
	270796	KINCAID ; B	345.0	CE	349700	7LANSVLAM	345.0	AMIL	1	COMED_P1-2_345-L2102___-S	operation	1528.0	98.73	100.42	AC	26.77
	270796	KINCAID ; B	345.0	CE	942480	AE2-261TAP	345.0	CE	1	EXT_P12:345:AMIL::AUSTIN:PANA:1	operation	1201.0	112.79	113.94	AC	14.36

14 Affected Systems

14.1 MISO

MISO Impacts to be determined during later study phases (as applicable).