

#U4-028 West End Fostoria-Chadwick 138kV **Generation Interconnection**

This analysis was completed to assess the reliability impact for the new generation interconnecting to the PJM system as a capacity resource.

Local and Network Impacts

The impact of the proposed generating facility on the AEP System was assessed for adherence with applicable reliability criteria. AEP planning criteria require that the transmission system meet single contingency performance criteria in accordance with the AEP FERC Form 715. Therefore, this criterion was used to assess the impact of the proposed facility on the AEP System. The project was studied as a 100 MW net capacity consistent with the interconnection application. The results, which apply to both Options 1 and 2 are summarized below.

Normal System (2012 Summer Conditions)

- No problems identified.

Single Contingency (2012 Summer Conditions)

- No problems identified.

Multiple Contingency (2012 Summer Conditions)

- No problems identified.

Short Circuit Analysis

- No problems identified.

Stability Analysis

- Stability analysis was not performed as part of this Feasibility Study. The stability assessments are part of the System Impact Study. Based upon the results of this future System Impact Study, the extent of system upgrades could change and the associated costs could be significantly different.

Local Upgrades

- None required.

Network Impacts

Option #1

The queue project U4-028 was studied as a 100MW (13 MW capacity) injection into the AEP system at the 3 point tap of the tapping Howard-Fostoria Central- Greenlawn 138kV line. U4-028 was evaluated for compliance with reliability criteria for summer peak conditions in 2013. Potential network impacts were as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

No problems identified.

Multiple Facility Contingency

(Double Circuit Tower Line, Line with Failed Breaker and Bus Fault contingencies for the full energy output)

No problems identified

Short Circuit

(Summary form of Cost allocation for breakers will be inserted here if any)

No problems identified.

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

No problems identified except for the local network problems identified above.

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

None

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

(Summary form of Cost allocation for transmission lines and transformers will be inserted here if any)

None

Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed that shall study all overload conditions associated with the overloaded element(s) identified.

There is the potential that the U4-028 project could have a cost allocation toward the network upgrades that alleviate the overloads listed below.

1. **(APS)** The Sammis-Wylie Ridge 345kV line (from bus 239092 to bus 20709 ckt 1) loads from 101.3% to 101.4% (DC power flow) of its emergency rating (1483MVA) for the single line contingency outage ('APS-SB-682'). This project contributes approximately 10.6MW to the thermal congestion.

The mitigation for this overload is to install 6.9 miles of high temperature conductor on the empty side of the Sammis-Wylie Ridge 345kV circuit. The cost of this upgrade as estimated by PJM is **\$10.5 million**.

Option #2

The queue project U4-028 was studied as a 100MW (13 MW capacity) injection into the AEP system at the Howard-West End Fostoria Central 138kV line. U4-028 was evaluated for compliance with reliability criteria for summer peak conditions in 2013. Potential network impacts were as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

No problems identified.

Multiple Facility Contingency

(Double Circuit Tower Line, Line with Failed Breaker and Bus Fault contingencies for the full energy output)

No problems identified

Short Circuit

(Summary form of Cost allocation for breakers will be inserted here if any)

No problems identified.

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

No problems identified except for the local network problems identified above.

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

None

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

(Summary form of Cost allocation for transmission lines and transformers will be inserted here if any)

None

Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed that shall study all overload conditions associated with the overloaded element(s) identified.

There is the potential that the U4-028 project could have a cost allocation toward the network upgrades that alleviate the overloads listed below.

1. **(APS)** The Sammis-Wylie Ridge 345kV line (from bus 239092 to bus 20709 ckt 1) loads from 101.3% to 101.4% (DC power flow) of its emergency rating (1483MVA) for the

single line contingency outage ('APS-SB-682'). This project contributes approximately 10.6MW to the thermal congestion.

The mitigation for this overload is to install 6.9 miles of high temperature conductor on the empty side of the Sammis-Wylie Ridge 345kV circuit. The cost of this upgrade as estimated by PJM is **\$10.5 million**.

MISO Impacts

Any impacts on the MISO transmission system will be identified in the Impact Study.