

***Generation Interconnection
Feasibility Study Report***

For

***PJM Generation Interconnection Request
Queue Position Z1-109***

Tosco-VFT 230 kV

March 2014

Preface

The intent of the feasibility study is to determine a plan, with ballpark cost and construction time estimates, to connect the subject generation to the PJM network at a location specified by the Interconnection Customer. The Interconnection Customer may request the interconnection of generation as a capacity resource or as an energy-only resource. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: (1) Direct Connections, which are new facilities and/or facilities upgrades needed to connect the generator to the PJM network, and (2) Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system.

In some instances a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

General

The Interconnection Customer (IC), has proposed a natural gas generating facility located in Linden, New Jersey. The installed facilities will have a total capability of 208 MW with 208 MW of this output being recognized by PJM as capacity. The proposed in-service date for this project is June 30, 2016. **This study does not imply a PSE&G commitment to this in-service date.**

Point of Interconnection

Z1-109 will interconnect with the PSE&G transmission system at one of the two following points of interconnection:

Option 1 will connect via a new three breaker ring bus that connects on the S-2271 230 kV line between the Tosco and VFT substations. **Please note that this option was studied prior to the approval of the conversion of the 138 kV system to 345 kV in the PSE&G zone. As a result, the new topology was not included in the model.** If this option is selected, it will be studied with the new topology in the System Impact Study.

Option 2 will connect via a new three breaker ring bus that connects on the X-1324 345 kV line between the Linden and Bayway substations.

Cost Summary

The Z1-109 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$ 0

Description	Total Cost
Direct Connection Network Upgrades	\$ 16,600,000
Non Direct Connection Network Upgrades	\$ 0
Total Costs	\$ 16,600,000

In addition, the Z1-109 project may be responsible for a contribution to the following costs:

Description	Total Cost
New System Upgrades	\$ 969,800,000
Previously Identified Upgrades	\$ 0
Total Costs	\$ 969,800,000

Cost allocations for these upgrades will be provided in the System Impact Study Report.

Attachment Facilities

The Interconnection Customer will construct the attachment lines into the proposed Point of Interconnection as depicted in the one-line diagram.

Direct Connection Cost Estimate

The total preliminary cost estimate for Direct Connection work is given in the table below:

Description	Total Cost
Construct new 3 breaker 230 kV ring bus substation that breaks the S-2271 230 kV line between Tosco and VFT substations.	\$ 16,600,000
Total	\$ 16,600,000

Estimate Assumptions:

- Single breaker station for the point of interconnection station includes all breaker controls
- Breaker connects to PSE&G
- This is a planning level estimate with 30% confidence level
- No escalation is included
- Expected cost of the project is stated above
- Property is available

Revenue Metering and SCADA Requirements

PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

Public Service Electric and Gas Requirements

The Interconnection Customer will be required to comply with all PSE&G Revenue Metering Requirements for Generation Interconnection Customers. The Revenue Metering Requirements may be found within the "Information and Requirements for Electric Service" document located at the following links:

http://www.pseg.com/business/builders/new_service/before/
<http://www.pjm.com/planning/design-engineering/to-tech-standards.aspx>

Option 1

Network Impacts

The Queue Project #Z1-109 was studied as a 208.0 MW (Capacity 208.0 MW) injection as a tap of the G22_MTX – Tosco 230 kV line in the PSEG area. Project #Z1-109 was evaluated for compliance with reliability criteria for summer peak conditions in 2017. Potential network impacts were as follows:

Contingency Descriptions

The following contingencies resulted in overloads:

Contingency Name	Description
H-2286 + G-2207	CONTINGENCY 'H-2286 + G-2207' DISCONNECT BUS 218357 DISCONNECT BUS 218355 MOVE 100 PERCENT LOAD FROM BUS 218381 TO BUS 218380 MOVE 100 PERCENT LOAD FROM BUS 218398 TO BUS 218399 DISCONNECT BRANCH FROM BUS 218320 TO BUS 218524 CKT 2 DISCONNECT BRANCH FROM BUS 218354 TO BUS 218306 CKT 2 /* PRSN AVG DEANS 230 230 DISCONNECT BRANCH FROM BUS 218354 TO BUS 218300 CKT 1 /* MINUESTG LINDEN 230 230 MOVE 52 PERCENT LOAD FROM BUS 218396 TO BUS 218397 /* MINUESTR T2 T1 MOVE 24 PERCENT LOAD FROM BUS 218396 TO BUS 218410 /* MINUESTR T2 WARINAN T1 MOVE 24 PERCENT LOAD FROM BUS 218396 TO BUS 218414 /* MINUESTR T2 WDBRDG T1 END
PS51B	CONTINGENCY 'PS51B' /* METUCHEN - FANWOOD 230 (NEW O-1315) DISCONNECT BRANCH FROM BUS 218469 TO BUS 218357 CKT 1 /* METUCHEN PRSN AVG 230 230 DISCONNECT BRANCH FROM BUS 218357 TO BUS 218355 CKT 1 /* PRSN AVG NEW DOVER 230 230 DISCONNECT BRANCH FROM BUS 218355 TO BUS 218320 CKT 1 /* NEW DOVER FANWOOD 230 230 MOVE 49 PERCENT LOAD FROM BUS 218401 TO BUS 218402 /* PRSN AVG T1 T2 MOVE 17 PERCENT LOAD FROM BUS 218401 TO BUS 218384 /* PRSN AVG T1 KILMER T2 MOVE 17 PERCENT LOAD FROM BUS 218401 TO BUS 218399 /* PRSN AVG T1 NEWDVR T2 MOVE 17 PERCENT LOAD FROM BUS 218401 TO BUS 218390 /* PRSN AVG T1 LAFAYET T2 END

Contingency Name	Description
PS61	CONTINGENCY 'PS61' /* WARINANCO BUS BREAKER TO ALDENE DISCONNECT BRANCH FROM BUS 218307 TO BUS 217122 CKT 1 /* ALDENE ALDENE 230 230 DISCONNECT BRANCH FROM BUS 217122 TO BUS 218376 CKT 1 /* ALDENE1 ALDENEAB 230 26 DISCONNECT BRANCH FROM BUS 217122 TO BUS 218316 CKT 1 /* ALDENE1 WARINANC 230 230 DISCONNECT BRANCH FROM BUS 218316 TO BUS 218441 CKT 1 /* WARINANC VFT 230 230 DISCONNECT BRANCH FROM BUS 218316 TO BUS 218410 CKT 1 /* WARINANC T1 DISCONNECT BRANCH FROM BUS 218316 TO BUS 218411 CKT 1 /* WARINANC T2 MOVE 13 MW LOAD FROM BUS 218410 TO BUS 218374 /* WARINANC T1 ALDENE T1 MOVE 5 MW LOAD FROM BUS 218410 TO BUS 218375 /* WARINANC T1 ALDENE T2 MOVE 5 MW LOAD FROM BUS 218410 TO BUS 218413 /* WARINANC T1 WOODBRDG T3 MOVE 8 MW LOAD FROM BUS 218411 TO BUS 216924 /* WARINANC T2 NORTHAV T1 MOVE 5 MW LOAD FROM BUS 218411 TO BUS 216925 /* WARINANC T2 NORTHAV T2 MOVE 8 MW LOAD FROM BUS 218411 TO BUS 218397 /* WARINANC T2 MINUEST T1 END
PS8C_B	CONTINGENCY 'PS8C_B' DISCONNECT BRANCH FROM BUS 916600 TO BUS 218441 CKT 1 /* TOSCO G22 230 230 END

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

#	Contingency		Affected Area	Facility Description	Bus			Power Flow	Loading %		Rating		MW Contribution	Ref
	Type	Name			From	To	Circuit		Initial	Final	Type	MVA		
1	N-1	PS8C_B	PSEG - PSEG	LINDEN-MINUESTR 230 kV line	218300	218353	1	DC	90.14	104.66	ER	740	107.44	1
2	Non	Non	PSEG - PSEG	SPRINGRD-W.ORANGE 230 kV line	216911	216914	1	DC	88.47	100.75	NR	512	62.89	2
3	Non	Non	PSEG - PSEG	WARINANC-ALDENE1 230 kV line	218316	217122	1	DC	97.59	111	NR	732	98.21	4
4	N-1	PS8C_B	PSEG - PSEG	NEWDOVRO-FANWOODO 230 kV line	218355	218320	1	DC	99.28	105.34	ER	870	52.72	7

Multiple Facility Contingency

(Double Circuit Tower Line contingencies were studied for the full energy output. The contingencies of Line with Failed Breaker and Bus Fault will be performed for the Impact Study.)

None.

Short Circuit

(Summary of impacted circuit breakers)

New circuit breakers found to be over-duty:

Due to the changes to the PSE&G topology regarding the conversion of multiple 138 kV facilities to 345 kV, the short circuit analysis will be run during the System Impact Study.

Contributions to previously identified circuit breakers found to be over-duty:

Due to the changes to the PSE&G topology regarding the conversion of multiple 138 kV facilities to 345 kV, the short circuit analysis will be run during the System Impact Study.

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

#	Contingency		Affected Area	Facility Description	Bus		Circuit	Power Flow	Loading %		Rating		MW Contrib.	Ref
	Type	Name			From	To			Initial	Final	Type	MVA		
5	Non	Non	PSEG - PSEG	ALDENE2-SPRINGRD 230 kV line	218345	216911	1	DC	102.16	114.44	NR	512	62.89	3
6	DCTL	H-2286 + G-2207	PSEG - PSEG	SPRINGRD-W.ORANGE 230 kV line	216911	216914	1	DC	111.15	121.02	ER	789	77.87	5
7	LFFB	PS61	PSEG - PSEG	LINDEN-MINUESTR 230 kV line	218300	218353	1	DC	117.01	131.62	ER	740	108.11	6
8	Non	Non	PSEG - PSEG	Z1-109 TAP-G22_MTX5 230 kV line	916600	218441	1	DC	115.01	125.5	NR	936	98.21	8
9	N-1	PS51B	PSEG - PSEG	WARINANC-ALDENE1 230 kV line	218316	217122	1	DC	104.44	116.53	ER	887	107.24	9
10	N-1	PS8C_B	PSEG - PSEG	PRSN AVG-NEWDVRO 230 kV line	218357	218355	1	DC	102.97	109.03	ER	870	52.72	10
11	DCTL	H-2286 + G-2207	PSEG - PSEG	ALDENE2-SPRINGRD 230 kV line	218345	216911	1	DC	120.04	129.91	ER	789	77.87	11
12	N-1	PS51B	PSEG - PSEG	Z1-109 TAP-G22_MTX5 230 kV line	916600	218441	1	DC	115.6	125.2	ER	1120	107.53	12
13	N-1	PS8C_B	PSEG - PSEG	METUCHEN-PRSN AVG 230 kV line	218469	218357	1	DC	107.15	113.21	ER	870	52.72	13
14	Non	Non	PSEG - PSEG	G22_MTX5-WARINANC 230 kV line	218441	218316	1	DC	112.66	127.38	NR	667	98.21	14
15	N-1	PS51B	PSEG - PSEG	G22_MTX5-WARINANC 230 kV line	218441	218316	1	DC	117.36	130.42	ER	821	107.24	15
16	DCTL	H-2286 + G-2207	PSEG - PSEG	WARINANC-ALDENE1 230 kV line	218316	217122	1	DC	152.55	166.59	ER	887	125.17	16
17	DCTL	H-2286 + G-2207	PSEG - PSEG	G22_MTX5-WARINANC 230 kV line	218441	218316	1	DC	170.16	185.33	ER	821	125.17	17

Steady-State Voltage Requirements

(Summary of the VAR requirements based upon the results of the steady-state voltage studies)

To be determined.

Stability and Reactive Power Requirement for Low Voltage Ride Through

(Summary of the VAR requirements based upon the results of the dynamic studies)

To be determined.

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

Violation #	Overloaded Facility	Upgrade Description	Network Upgrade Number	Upgrade Cost
#1, 4	LINDEN-MINUESTR 230 kV line	New 230 kV Tosco – Aldene overhead circuit parallel to S-2271, U-2273 and N-2240. Estimated Cost: \$126.6M; Estimated Time: 48 months	Pending	\$ 126,600,000
#2, 3	SPRINGRD-W.ORANGE 230 kV line	1. Re-conductor the Warinanco – VFT (U-2273) 230 kV overhead line. Estimated Cost: \$35.8M; Estimated Time: 38 months 2. Re-conductor the Aldene – Warinanco (N-2240) 230 kV overhead line. Estimated Cost: \$64M; Estimated Time: 42 months 3. Re-conductor the Linden – Tosco (B-2254) 230 kV overhead line. Estimated Cost: \$15.8M; Estimated Time: 35 months 4. New 230 kV Tosco – Aldene overhead circuit parallel to S-2271, U-2273 and N-2240. Estimated Cost: \$126.6M; Estimated Time: 48 months (included above) 5. New 230 kV Aldene – Springfield Rd. underground cable parallel to G-2285. Estimated Cost: \$237.6M; Estimated Time: 48 months 6. New 230 kV Springfield Rd. – W. Orange underground cable parallel to N-2292. Estimated Cost: \$490M; Estimated Time: 48 months	Pending	\$ 843,200,000
Total New Network Upgrades				\$ 969,800,000

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

Violation #	Overloaded Facility	Upgrade Description	Network Upgrade Number	Upgrade Cost
#5, 6, 9, 11, 12, 15, 16, 17	Multiple Facilities	Same reinforcement identified above: New 230 kV Tosco – Aldene overhead circuit parallel to S-2271, U-2273 and N-2240. Estimated Cost: \$126.6M; Estimated Time: 48 months	Pending	\$ 0
#7, 8, 10, 13, 14	Multiple Facilities	Same reinforcement identified above: <ol style="list-style-type: none"> 1. Re-conductor the Warinanco – VFT (U-2273) 230 kV overhead line. Estimated Cost: \$35.8M; Estimated Time: 38 months 2. Re-conductor the Aldene – Warinanco (N-2240) 230 kV overhead line. Estimated Cost: \$64M; Estimated Time: 42 months 3. Re-conductor the Linden – Tosco (B-2254) 230 kV overhead line. Estimated Cost: \$15.8M; Estimated Time: 35 months 4. New 230 kV Tosco – Aldene overhead circuit parallel to S-2271, U-2273 and N-2240. Estimated Cost: \$126.6M; Estimated Time: 48 months 5. New 230 kV Aldene – Springfield Rd. underground cable parallel to G-2285. Estimated Cost: \$237.6M; Estimated Time: 48 months New 230 kV Springfield Rd. – W. Orange underground cable parallel to N-2292. Estimated Cost: \$490M; Estimated Time: 48 months	Pending	\$ 0
Total New Network Upgrades				\$ 0

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None.

Option 2

Network Impacts

The Queue Project #Z1-109 was studied as a 208.0 MW (Capacity 208.0 MW) injection as a tap of the Bayway – Linden 345 kV line in the PSEG area. Project #Z1-109 was evaluated for compliance with reliability criteria for summer peak conditions in 2018. Potential network impacts were as follows:

Contingency Descriptions

The following contingencies resulted in overloads:

None.

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None.

Multiple Facility Contingency

(Double Circuit Tower Line contingencies were studied for the full energy output. The contingencies of Line with Failed Breaker and Bus Fault will be performed for the Impact Study.)

None.

Short Circuit

(Summary of impacted circuit breakers)

New circuit breakers found to be over-duty:

Due to the changes to the PSE&G topology regarding the conversion of multiple 138 kV facilities to 345 kV, the short circuit analysis will be run during the System Impact Study.

Contributions to previously identified circuit breakers found to be over-duty:

Due to the changes to the PSE&G topology regarding the conversion of multiple 138 kV facilities to 345 kV, the short circuit analysis will be run during the System Impact Study.

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None.

Steady-State Voltage Requirements

(Summary of the VAR requirements based upon the results of the steady-state voltage studies)

To be determined.

Stability and Reactive Power Requirement for Low Voltage Ride Through

(Summary of the VAR requirements based upon the results of the dynamic studies)

To be determined.

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

None.

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

None.

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

Not applicable.

Attachment 1

Option 1 System Configuration

Option 1 Appendices

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact.

It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Appendix 1

(PSEG - PSEG) The LINDEN-MINUESTR 230 kV line (from bus 218300 to bus 218353 ckt 1) loads from 90.14% to 104.66% (**DC power flow**) of its emergency rating (740 MVA) for the single line contingency outage of 'PS8C_B'. This project contributes approximately 107.44 MW to the thermal violation.

CONTINGENCY 'PS8C_B'

DISCONNECT BRANCH FROM BUS 916600 TO BUS 218441 CKT 1 /* TOSCO

G22 230 230

END

Bus Number	Bus Name	Full Contribution
218423	LINDNCT1	2.93
218424	LINDNCT2	2.93
218425	LINDNCT3	2.93
218426	LINDNST1	5.73
290745	S-061	0.38
218344	TOSCONUG	2.25
292094	V1-030 C1	0.02
900801	W1-001	1.4
913101	Y1-026	82.91
915271	Y3-051 C	3.17
915272	Y3-051 E1	40.11
916191	Z1-059 C	9.5
916601	Z1-109	107.44

Appendix 2

(PSEG - PSEG) The SPRINGRD-W.ORANGE 230 kV line (from bus 216911 to bus 216914 ckt 1) loads from 88.47% to 100.75% (**DC power flow**) of its normal rating (512 MVA) for non-contingency condition. This project contributes approximately 62.89 MW to the thermal violation.

Bus Number	Bus Name	Full Contribution
218307	ALDENE	0.02
218376	ALDENEAB	12.14
218326	EDISON 1	15.72
218327	EDISON 2	15.73
218328	EDISON 3	15.72
218423	LINDNCT1	1.52
218424	LINDNCT2	1.52
218425	LINDNCT3	1.52
218426	LINDNST1	2.97
290745	S-061	0.22
218360	SEWAREN1	15.75
218361	SEWAREN2	17.87
218362	SEWAREN3	16.2
218363	SEWAREN4	18.78
218364	SEWAREN6	16.79
218344	TOSCONUG	1.3
292094	V1-030 C1	< 0.01
292078	V1-034	0.35
900801	W1-001	4.6
902251	W2-023	94.65
912221	X4-044 C	4.46
913101	Y1-026	47.7
915271	Y3-051 C	1.64
915272	Y3-051 E1	20.81
916251	Z1-033	47.32
916191	Z1-059 C	4.93
916601	Z1-109	62.89

Appendix 3

(PSEG - PSEG) The ALDENE2-SPRINGRD 230 kV line (from bus 218345 to bus 216911 ckt 1) loads from 102.16% to 114.44% (**DC power flow**) of its normal rating (512 MVA) for non-contingency condition. This project contributes approximately 62.89 MW to the thermal violation.

Bus Number	Bus Name	Full Contribution
218307	ALDENE	0.02
218376	ALDENEAB	12.14
218326	EDISON 1	15.72
218327	EDISON 2	15.73
218328	EDISON 3	15.72
218423	LINDNCT1	1.52
218424	LINDNCT2	1.52
218425	LINDNCT3	1.52
218426	LINDNST1	2.97
290745	S-061	0.22
218360	SEWAREN1	15.75
218361	SEWAREN2	17.87
218362	SEWAREN3	16.2
218363	SEWAREN4	18.78
218364	SEWAREN6	16.79
218344	TOSCONUG	1.3
292094	V1-030 C1	< 0.01
292078	V1-034	0.35
900801	W1-001	4.6
902251	W2-023	94.65
912221	X4-044 C	4.46
913101	Y1-026	47.7
915271	Y3-051 C	1.64
915272	Y3-051 E1	20.81
916251	Z1-033	47.32
916191	Z1-059 C	4.93
916601	Z1-109	62.89

Appendix 4

(PSEG - PSEG) The WARINANC-ALDENE1 230 kV line (from bus 218316 to bus 217122 ckt 1) loads from 97.59% to 111.0% (**DC power flow**) of its normal rating (732 MVA) for non-contingency condition. This project contributes approximately 98.21 MW to the thermal violation.

Bus Number	Bus Name	Full Contribution
218326	EDISON 1	18.84
218327	EDISON 2	18.83
218328	EDISON 3	18.84
218423	LINDNCT1	2.34
218424	LINDNCT2	2.34
218425	LINDNCT3	2.34
218426	LINDNST1	4.58
290745	S-061	0.34
218360	SEWAREN1	23.85
218361	SEWAREN2	27.06
218362	SEWAREN3	24.54
218363	SEWAREN4	28.44
218364	SEWAREN6	25.44
218344	TOSCONUG	2.02
292094	V1-030 C1	0.01
292096	V1-030 C2	< 0.01
292078	V1-034	0.23
292680	V3-069 C	< 0.01
900801	W1-001	7.19
902251	W2-023	143.35
902651	W2-052 C	< 0.01
905641	W4-080 C	0.05
909461	X2-089 C	< 0.01
913101	Y1-026	74.35
915251	Y3-049 1	0.02
915253	Y3-049 3	0.02
915271	Y3-051 C	2.53
915272	Y3-051 E1	32.07
916251	Z1-033	31.82
916191	Z1-059 C	7.6
916601	Z1-109	98.21

Appendix 5

(PSEG - PSEG) The SPRINGRD-W.ORANGE 230 kV line (from bus 216911 to bus 216914 ckt 1) loads from 111.15% to 121.02% (**DC power flow**) of its emergency rating (789 MVA) for the tower line contingency outage of 'H-2286 + G-2207'. This project contributes approximately 77.87 MW to the thermal violation.

CONTINGENCY 'H-2286 + G-2207'

DISCONNECT BUS 218357

DISCONNECT BUS 218355

MOVE 100 PERCENT LOAD FROM BUS 218381 TO BUS 218380

MOVE 100 PERCENT LOAD FROM BUS 218398 TO BUS 218399

DISCONNECT BRANCH FROM BUS 218320 TO BUS 218524 CKT 2

DISCONNECT BRANCH FROM BUS 218354 TO BUS 218306 CKT 2 /* PRSN AVG

DEANS 230 230

DISCONNECT BRANCH FROM BUS 218354 TO BUS 218300 CKT 1 /*

MINUESTG LINDEN 230 230

MOVE 52 PERCENT LOAD FROM BUS 218396 TO BUS 218397 /* MINUESTR

T2 T1

MOVE 24 PERCENT LOAD FROM BUS 218396 TO BUS 218410 /* MINUESTR

T2 WARINAN T1

MOVE 24 PERCENT LOAD FROM BUS 218396 TO BUS 218414 /* MINUESTR

T2 WDBRDG T1

END

Bus Number	Bus Name	Full Contribution
218307	ALDENE	0.02
218376	ALDENEAB	12.8
218326	EDISON 1	26.88
218327	EDISON 2	26.87
218328	EDISON 3	26.88
218423	LINDNCT1	1.97
218424	LINDNCT2	1.97
218425	LINDNCT3	1.97
218426	LINDNST1	3.86
206679	M&M S721	-0.82
94130	O66_NONFIRM	49.21
206638	PEAPACK	-0.32
290745	S-061	0.27
218360	SEWAREN1	26.85
218361	SEWAREN2	30.47
218362	SEWAREN3	27.63
218363	SEWAREN4	32.02
218364	SEWAREN6	28.63
218344	TOSCONUG	1.62
293093	U2-077	237.68

299906	U3-032 E	-0.87
292094	V1-030 C1	0.01
292095	V1-030 E1	0.51
292185	V1-030 E2	0.61
292101	V1-030 E4	0.06
292103	V1-030 E5	0.14
292107	V1-030 E7	0.09
292111	V1-030 E9	-0.13
292189	V1-030 EA	0.48
292191	V1-030 EC	-0.64
292092	V1-030 ED	-0.37
292078	V1-034	0.42
297021	V2-009 E1	0.18
297023	V2-009 E2	0.36
297025	V2-009 E3	0.3
297027	V2-009 E4	0.24
297069	V2-025 E	-0.34
293378	V3-024 E	0.72
292666	V3-058 E	0.18
292668	V3-059 E	0.18
293444	V3-065 E	-0.05
293440	V3-066 E	-0.04
293434	V3-067 E	-0.07
293429	V3-068 E	-0.04
292681	V3-069 E	0.3
904002	V4-001 E	-0.11
900801	W1-001	5.66
901802	W1-101 E	-0.12
902002	W1-121 E	0.26
901512	W1-122 E	-0.29
902251	W2-023	161.37
902652	W2-052 E	0.11
903042	W2-091 E	-0.56
903502	W3-032 E	-0.27
903952	W3-076 E	-0.65
903962	W3-077 E	-0.52
904142	W3-095 E	-0.52
903672	W3-106 E	-0.56
903682	W3-110 E	-0.42
904452	W3-126 E	-0.94
904582	W3-139 E	-0.56
904592	W3-140 E	-0.45
904642	W3-145 E	-0.94
904652	W3-146 E	-0.48
904732	W3-154 E	-0.06

905142	W4-014 E	-0.57
905442	W4-046 E	-0.38
905492	W4-059 E	-0.07
905542	W4-064 E	-0.17
905552	W4-065 E	-0.35
905582	W4-068 E	-0.31
905642	W4-080 E	2.86
907002	X1-005 E	-0.39
907012	X1-012 E	-0.55
907132	X1-046 E	-0.44
907402	X1-072 E	-0.09
907462	X1-082 E	-0.46
907302	X1-094 E	-0.91
907522	X1-114 E	-0.11
907412	X1-116 E	-0.38
909442	X2-087 E	-0.09
909452	X2-088 E	0.17
910582	X3-011 E	-0.18
910612	X3-029 E	-0.7
910712	X3-052 E	-0.42
910722	X3-054 E	-0.27
910852	X3-083 E	-0.48
912221	X4-044 C	4.7
912222	X4-044 E	3.8
913101	Y1-026	59.44
913322	Y1-072 E	-0.07
914042	Y2-018 E	-0.08
915271	Y3-051 C	2.13
915272	Y3-051 E1	26.99
916251	Z1-033	57.15
916191	Z1-059 C	6.39
916192	Z1-059 E	1.78
916471	Z1-096 C	0.18
916472	Z1-096 E	0.3
916601	Z1-109	77.87

Appendix 6

(PSEG - PSEG) The LINDEN-MINUESTR 230 kV line (from bus 218300 to bus 218353 ckt 1) loads from 117.01% to 131.62% (**DC power flow**) of its emergency rating (740 MVA) for the line fault with failed breaker contingency outage of 'PS61'. This project contributes approximately 108.11 MW to the thermal violation.

CONTINGENCY 'PS61' /* WARINANCO BUS BREAKER TO
ALDENE
DISCONNECT BRANCH FROM BUS 218307 TO BUS 217122 CKT 1 /* ALDENE
ALDENE 230 230
DISCONNECT BRANCH FROM BUS 217122 TO BUS 218376 CKT 1 /* ALDENE1
ALDENEAB 230 26
DISCONNECT BRANCH FROM BUS 217122 TO BUS 218316 CKT 1 /* ALDENE1
WARINANC 230 230
DISCONNECT BRANCH FROM BUS 218316 TO BUS 218441 CKT 1 /*
WARINANC VFT 230 230
DISCONNECT BRANCH FROM BUS 218316 TO BUS 218410 CKT 1 /*
WARINANC T1
DISCONNECT BRANCH FROM BUS 218316 TO BUS 218411 CKT 1 /*
WARINANC T2
MOVE 13 MW LOAD FROM BUS 218410 TO BUS 218374 /* WARINANC T1
ALDENE T1
MOVE 5 MW LOAD FROM BUS 218410 TO BUS 218375 /* WARINANC T1
ALDENE T2
MOVE 5 MW LOAD FROM BUS 218410 TO BUS 218413 /* WARINANC T1
WOODBDRG T3
MOVE 8 MW LOAD FROM BUS 218411 TO BUS 216924 /* WARINANC T2
NORTHAV T1
MOVE 5 MW LOAD FROM BUS 218411 TO BUS 216925 /* WARINANC T2
NORTHAV T2
MOVE 8 MW LOAD FROM BUS 218411 TO BUS 218397 /* WARINANC T2
MINUEST T1
END

Bus Number	Bus Name	Full Contribution
218423	LINDNCT1	2.95
218424	LINDNCT2	2.95
218425	LINDNCT3	2.95
218426	LINDNST1	5.76
290745	S-061	0.38
218344	TOSCONUG	2.27
293093	U2-077	326.43
292094	V1-030 C1	0.02
292095	V1-030 E1	0.76
292185	V1-030 E2	-0.37
292681	V3-069 E	-0.27

900801	W1-001	7.77
902652	W2-052 E	-0.09
905642	W4-080 E	-2.37
909462	X2-089 E	-0.32
913101	Y1-026	83.42
915271	Y3-051 C	3.18
915272	Y3-051 E1	40.33
916191	Z1-059 C	9.55
916192	Z1-059 E	2.65
916601	Z1-109	108.11

Appendix 7

(PSEG - PSEG) The NEWDOVRO-FANWOODO 230 kV line (from bus 218355 to bus 218320 ckt 1) loads from 99.28% to 105.34% (**DC power flow**) of its emergency rating (870 MVA) for the single line contingency outage of 'PS8C_B'. This project contributes approximately 52.72 MW to the thermal violation.

CONTINGENCY 'PS8C_B'

DISCONNECT BRANCH FROM BUS 916600 TO BUS 218441 CKT 1

/* TOSCO

G22 230 230

END

Bus Number	Bus Name	Full Contribution
218326	EDISON 1	39.03
218327	EDISON 2	39.02
218328	EDISON 3	39.03
218423	LINDNCT1	1.45
218424	LINDNCT2	1.45
218425	LINDNCT3	1.45
218426	LINDNST1	2.83
290745	S-061	0.19
218360	SEWAREN1	36.2
218361	SEWAREN2	41.08
218362	SEWAREN3	37.25
218363	SEWAREN4	43.17
218364	SEWAREN6	38.61
218344	TOSCONUG	1.11
292094	V1-030 C1	< 0.01
292096	V1-030 C2	0.02
292078	V1-034	0.39
292680	V3-069 C	0.01
902251	W2-023	217.57
902651	W2-052 C	< 0.01
905641	W4-080 C	0.1
909461	X2-089 C	0.01
913101	Y1-026	40.73
915251	Y3-049 1	0.03
915253	Y3-049 3	0.03
915271	Y3-051 C	1.57
915272	Y3-051 E1	19.83
916251	Z1-033	53.31
916191	Z1-059 C	4.7
916471	Z1-096 C	0.22
916601	Z1-109	52.72

Appendix 8

(PSEG - PSEG) The Z1-109 TAP-G22_MTX5 230 kV line (from bus 916600 to bus 218441 ckt 1) loads from 115.01% to 125.5% (**DC power flow**) of its normal rating (936 MVA) for non-contingency condition. This project contributes approximately 98.21 MW to the thermal violation.

Bus Number	Bus Name	Full Contribution
218326	EDISON 1	18.84
218327	EDISON 2	18.83
218328	EDISON 3	18.84
218423	LINDNCT1	2.34
218424	LINDNCT2	2.34
218425	LINDNCT3	2.34
218426	LINDNST1	4.58
290745	S-061	0.34
218360	SEWAREN1	23.85
218361	SEWAREN2	27.06
218362	SEWAREN3	24.54
218363	SEWAREN4	28.44
218364	SEWAREN6	25.44
218344	TOSCONUG	2.02
292094	V1-030 C1	0.01
292096	V1-030 C2	< 0.01
292078	V1-034	0.23
292680	V3-069 C	< 0.01
902251	W2-023	143.35
902651	W2-052 C	< 0.01
905641	W4-080 C	0.05
909461	X2-089 C	< 0.01
913101	Y1-026	74.35
915251	Y3-049 1	0.02
915253	Y3-049 3	0.02
915271	Y3-051 C	2.53
915272	Y3-051 E1	32.07
916251	Z1-033	31.82
916191	Z1-059 C	7.6
916601	Z1-109	98.21

Appendix 9

(PSEG - PSEG) The WARINANC-ALDENE1 230 kV line (from bus 218316 to bus 217122 ckt 1) loads from 104.44% to 116.53% (**DC power flow**) of its emergency rating (887 MVA) for the single line contingency outage of 'PS51B'. This project contributes approximately 107.24 MW to the thermal violation.

CONTINGENCY 'PS51B'
(NEW O-1315)

/* METUCHEN - FANWOOD 230

DISCONNECT BRANCH FROM BUS 218469 TO BUS 218357 CKT 1 /*
METUCHEN PRSN AVG 230 230

DISCONNECT BRANCH FROM BUS 218357 TO BUS 218355 CKT 1 /* PRSN AVG
NEW DOVER 230 230

DISCONNECT BRANCH FROM BUS 218355 TO BUS 218320 CKT 1 /* NEW
DOVER FANWOOD 230 230

MOVE 49 PERCENT LOAD FROM BUS 218401 TO BUS 218402 /* PRSN AVG
T1 T2

MOVE 17 PERCENT LOAD FROM BUS 218401 TO BUS 218384 /* PRSN AVG
T1 KILMER T2

MOVE 17 PERCENT LOAD FROM BUS 218401 TO BUS 218399 /* PRSN AVG
T1 NEWDVR T2

MOVE 17 PERCENT LOAD FROM BUS 218401 TO BUS 218390 /* PRSN AVG
T1 LAFAYET T2

END

Bus Number	Bus Name	Full Contribution
218326	EDISON 1	30.47
218327	EDISON 2	30.46
218328	EDISON 3	30.47
218423	LINDNCT1	2.62
218424	LINDNCT2	2.62
218425	LINDNCT3	2.62
218426	LINDNST1	5.13
290745	S-061	0.37
218360	SEWAREN1	34.05
218361	SEWAREN2	38.64
218362	SEWAREN3	35.04
218363	SEWAREN4	40.6
218364	SEWAREN6	36.31
218344	TOSCONUG	2.21
292094	V1-030 C1	0.02
292096	V1-030 C2	0.02
292078	V1-034	0.35
292680	V3-069 C	0.01
900801	W1-001	7.83
902251	W2-023	204.66

902651	W2-052 C	< 0.01
905641	W4-080 C	0.08
913101	Y1-026	81.47
915251	Y3-049 1	0.03
915253	Y3-049 3	0.03
915271	Y3-051 C	2.84
915272	Y3-051 E1	35.92
916251	Z1-033	47.15
916191	Z1-059 C	8.51
916471	Z1-096 C	0.17
916601	Z1-109	107.24

Appendix 10

(PSEG - PSEG) The PRSN AVG-NEWDOR 230 kV line (from bus 218357 to bus 218355 ckt 1) loads from 102.97% to 109.03% (**DC power flow**) of its emergency rating (870 MVA) for the single line contingency outage of 'PS8C_B'. This project contributes approximately 52.72 MW to the thermal violation.

CONTINGENCY 'PS8C_B'

DISCONNECT BRANCH FROM BUS 916600 TO BUS 218441 CKT 1

/* TOSCO

G22 230 230

END

Bus Number	Bus Name	Full Contribution
218326	EDISON 1	39.03
218327	EDISON 2	39.02
218328	EDISON 3	39.03
218423	LINDNCT1	1.45
218424	LINDNCT2	1.45
218425	LINDNCT3	1.45
218426	LINDNST1	2.83
290745	S-061	0.19
218360	SEWAREN1	36.2
218361	SEWAREN2	41.08
218362	SEWAREN3	37.25
218363	SEWAREN4	43.17
218364	SEWAREN6	38.61
218344	TOSCONUG	1.11
292094	V1-030 C1	< 0.01
292096	V1-030 C2	0.02
292078	V1-034	0.39
292680	V3-069 C	0.01
902251	W2-023	217.57
902651	W2-052 C	< 0.01
905641	W4-080 C	0.1
909461	X2-089 C	0.01
913101	Y1-026	40.73
915251	Y3-049 1	0.03
915253	Y3-049 3	0.03
915271	Y3-051 C	1.57
915272	Y3-051 E1	19.83
916251	Z1-033	53.31
916191	Z1-059 C	4.7
916471	Z1-096 C	0.22
916601	Z1-109	52.72

Appendix 11

(PSEG - PSEG) The ALDENE2-SPRINGRD 230 kV line (from bus 218345 to bus 216911 ckt 1) loads from 120.04% to 129.91% (**DC power flow**) of its emergency rating (789 MVA) for the tower line contingency outage of 'H-2286 + G-2207'. This project contributes approximately 77.87 MW to the thermal violation.

CONTINGENCY 'H-2286 + G-2207'

DISCONNECT BUS 218357

DISCONNECT BUS 218355

MOVE 100 PERCENT LOAD FROM BUS 218381 TO BUS 218380

MOVE 100 PERCENT LOAD FROM BUS 218398 TO BUS 218399

DISCONNECT BRANCH FROM BUS 218320 TO BUS 218524 CKT 2

DISCONNECT BRANCH FROM BUS 218354 TO BUS 218306 CKT 2 /* PRSN AVG

DEANS 230 230

DISCONNECT BRANCH FROM BUS 218354 TO BUS 218300 CKT 1 /*

MINUESTG LINDEN 230 230

MOVE 52 PERCENT LOAD FROM BUS 218396 TO BUS 218397 /* MINUESTR

T2 T1

MOVE 24 PERCENT LOAD FROM BUS 218396 TO BUS 218410 /* MINUESTR

T2 WARINAN T1

MOVE 24 PERCENT LOAD FROM BUS 218396 TO BUS 218414 /* MINUESTR

T2 WDBRDG T1

END

Bus Number	Bus Name	Full Contribution
218307	ALDENE	0.02
218376	ALDENEAB	12.8
218326	EDISON 1	26.88
218327	EDISON 2	26.87
218328	EDISON 3	26.88
218423	LINDNCT1	1.97
218424	LINDNCT2	1.97
218425	LINDNCT3	1.97
218426	LINDNST1	3.86
206679	M&M S721	-0.82
94130	O66_NONFIRM	49.21
206638	PEAPACK	-0.32
290745	S-061	0.27
218360	SEWAREN1	26.85
218361	SEWAREN2	30.47
218362	SEWAREN3	27.63
218363	SEWAREN4	32.02
218364	SEWAREN6	28.63
218344	TOSCONUG	1.62
293093	U2-077	237.68

299906	U3-032 E	-0.87
292094	V1-030 C1	0.01
292095	V1-030 E1	0.51
292185	V1-030 E2	0.61
292101	V1-030 E4	0.06
292103	V1-030 E5	0.14
292107	V1-030 E7	0.09
292111	V1-030 E9	-0.13
292189	V1-030 EA	0.48
292191	V1-030 EC	-0.64
292092	V1-030 ED	-0.37
292078	V1-034	0.42
297021	V2-009 E1	0.18
297023	V2-009 E2	0.36
297025	V2-009 E3	0.3
297027	V2-009 E4	0.24
297069	V2-025 E	-0.34
293378	V3-024 E	0.72
292666	V3-058 E	0.18
292668	V3-059 E	0.18
293444	V3-065 E	-0.05
293440	V3-066 E	-0.04
293434	V3-067 E	-0.07
293429	V3-068 E	-0.04
292681	V3-069 E	0.3
904002	V4-001 E	-0.11
900801	W1-001	5.66
901802	W1-101 E	-0.12
902002	W1-121 E	0.26
901512	W1-122 E	-0.29
902251	W2-023	161.37
902652	W2-052 E	0.11
903042	W2-091 E	-0.56
903502	W3-032 E	-0.27
903952	W3-076 E	-0.65
903962	W3-077 E	-0.52
904142	W3-095 E	-0.52
903672	W3-106 E	-0.56
903682	W3-110 E	-0.42
904452	W3-126 E	-0.94
904582	W3-139 E	-0.56
904592	W3-140 E	-0.45
904642	W3-145 E	-0.94
904652	W3-146 E	-0.48
904732	W3-154 E	-0.06

905142	W4-014 E	-0.57
905442	W4-046 E	-0.38
905492	W4-059 E	-0.07
905542	W4-064 E	-0.17
905552	W4-065 E	-0.35
905582	W4-068 E	-0.31
905642	W4-080 E	2.86
907002	X1-005 E	-0.39
907012	X1-012 E	-0.55
907132	X1-046 E	-0.44
907402	X1-072 E	-0.09
907462	X1-082 E	-0.46
907302	X1-094 E	-0.91
907522	X1-114 E	-0.11
907412	X1-116 E	-0.38
909442	X2-087 E	-0.09
909452	X2-088 E	0.17
910582	X3-011 E	-0.18
910612	X3-029 E	-0.7
910712	X3-052 E	-0.42
910722	X3-054 E	-0.27
910852	X3-083 E	-0.48
912221	X4-044 C	4.7
912222	X4-044 E	3.8
913101	Y1-026	59.44
913322	Y1-072 E	-0.07
914042	Y2-018 E	-0.08
915271	Y3-051 C	2.13
915272	Y3-051 E1	26.99
916251	Z1-033	57.15
916191	Z1-059 C	6.39
916192	Z1-059 E	1.78
916471	Z1-096 C	0.18
916472	Z1-096 E	0.3
916601	Z1-109	77.87

Appendix 12

(PSEG - PSEG) The Z1-109 TAP-G22_MTX5 230 kV line (from bus 916600 to bus 218441 ckt 1) loads from 115.6% to 125.2% (**DC power flow**) of its emergency rating (1120 MVA) for the single line contingency outage of 'PS51B'. This project contributes approximately 107.53 MW to the thermal violation.

CONTINGENCY 'PS51B'
(NEW O-1315)

/* METUCHEN - FANWOOD 230

DISCONNECT BRANCH FROM BUS 218469 TO BUS 218357 CKT 1 /*
METUCHEN PRSN AVG 230 230

DISCONNECT BRANCH FROM BUS 218357 TO BUS 218355 CKT 1 /* PRSN AVG
NEW DOVER 230 230

DISCONNECT BRANCH FROM BUS 218355 TO BUS 218320 CKT 1 /* NEW
DOVER FANWOOD 230 230

MOVE 49 PERCENT LOAD FROM BUS 218401 TO BUS 218402 /* PRSN AVG
T1 T2

MOVE 17 PERCENT LOAD FROM BUS 218401 TO BUS 218384 /* PRSN AVG
T1 KILMER T2

MOVE 17 PERCENT LOAD FROM BUS 218401 TO BUS 218399 /* PRSN AVG
T1 NEWDVR T2

MOVE 17 PERCENT LOAD FROM BUS 218401 TO BUS 218390 /* PRSN AVG
T1 LAFAYET T2

END

Bus Number	Bus Name	Full Contribution
218326	EDISON 1	30.83
218327	EDISON 2	30.82
218328	EDISON 3	30.83
218423	LINDNCT1	2.63
218424	LINDNCT2	2.63
218425	LINDNCT3	2.63
218426	LINDNST1	5.15
290745	S-061	0.37
218360	SEWAREN1	34.38
218361	SEWAREN2	39.
218362	SEWAREN3	35.37
218363	SEWAREN4	40.99
218364	SEWAREN6	36.66
218344	TOSCONUG	2.22
292094	V1-030 C1	0.02
292096	V1-030 C2	0.02
292078	V1-034	0.35
292680	V3-069 C	0.01
902251	W2-023	206.59
902651	W2-052 C	< 0.01

905641	W4-080 C	0.08
913101	Y1-026	81.7
915251	Y3-049 1	0.03
915253	Y3-049 3	0.03
915271	Y3-051 C	2.85
915272	Y3-051 E1	36.04
916251	Z1-033	47.63
916191	Z1-059 C	8.54
916471	Z1-096 C	0.18
916601	Z1-109	107.53

Appendix 13

(PSEG - PSEG) The METUCHEN-PRSN AVG 230 kV line (from bus 218469 to bus 218357 ckt 1) loads from 107.15% to 113.21% (**DC power flow**) of its emergency rating (870 MVA) for the single line contingency outage of 'PS8C_B'. This project contributes approximately 52.72 MW to the thermal violation.

CONTINGENCY 'PS8C_B'

DISCONNECT BRANCH FROM BUS 916600 TO BUS 218441 CKT 1

/* TOSCO

G22 230 230

END

Bus Number	Bus Name	Full Contribution
218326	EDISON 1	39.03
218327	EDISON 2	39.02
218328	EDISON 3	39.03
218423	LINDNCT1	1.45
218424	LINDNCT2	1.45
218425	LINDNCT3	1.45
218426	LINDNST1	2.83
290745	S-061	0.19
218360	SEWAREN1	36.2
218361	SEWAREN2	41.08
218362	SEWAREN3	37.25
218363	SEWAREN4	43.17
218364	SEWAREN6	38.61
218344	TOSCONUG	1.11
292094	V1-030 C1	< 0.01
292096	V1-030 C2	0.02
292078	V1-034	0.39
292680	V3-069 C	0.01
902251	W2-023	217.57
902651	W2-052 C	< 0.01
905641	W4-080 C	0.1
913101	Y1-026	40.73
915251	Y3-049 1	0.03
915253	Y3-049 3	0.03
915271	Y3-051 C	1.57
915272	Y3-051 E1	19.83
916251	Z1-033	53.31
916191	Z1-059 C	4.7
916471	Z1-096 C	0.22
916601	Z1-109	52.72

Appendix 14

(PSEG - PSEG) The G22_MTX5-WARINANC 230 kV line (from bus 218441 to bus 218316 ckt 1) loads from 112.66% to 127.38% (**DC power flow**) of its normal rating (667 MVA) for non-contingency condition. This project contributes approximately 98.21 MW to the thermal violation.

Bus Number	Bus Name	Full Contribution
218326	EDISON 1	18.84
218327	EDISON 2	18.83
218328	EDISON 3	18.84
218423	LINDNCT1	2.34
218424	LINDNCT2	2.34
218425	LINDNCT3	2.34
218426	LINDNST1	4.58
290745	S-061	0.34
218360	SEWAREN1	23.85
218361	SEWAREN2	27.06
218362	SEWAREN3	24.54
218363	SEWAREN4	28.44
218364	SEWAREN6	25.44
218344	TOSCONUG	2.02
292094	V1-030 C1	0.01
292096	V1-030 C2	< 0.01
292078	V1-034	0.23
292680	V3-069 C	< 0.01
900801	W1-001	7.19
902251	W2-023	143.35
902651	W2-052 C	< 0.01
905641	W4-080 C	0.05
909461	X2-089 C	< 0.01
913101	Y1-026	74.35
915251	Y3-049 1	0.02
915253	Y3-049 3	0.02
915271	Y3-051 C	2.53
915272	Y3-051 E1	32.07
916251	Z1-033	31.82
916191	Z1-059 C	7.6
916601	Z1-109	98.21

Appendix 15

(PSEG - PSEG) The G22_MTX5-WARINANC 230 kV line (from bus 218441 to bus 218316 ckt 1) loads from 117.36% to 130.42% (**DC power flow**) of its emergency rating (821 MVA) for the single line contingency outage of 'PS51B'. This project contributes approximately 107.24 MW to the thermal violation.

CONTINGENCY 'PS51B'
(NEW O-1315)

/* METUCHEN - FANWOOD 230

DISCONNECT BRANCH FROM BUS 218469 TO BUS 218357 CKT 1 /*
METUCHEN PRSN AVG 230 230

DISCONNECT BRANCH FROM BUS 218357 TO BUS 218355 CKT 1 /* PRSN AVG
NEW DOVER 230 230

DISCONNECT BRANCH FROM BUS 218355 TO BUS 218320 CKT 1 /* NEW
DOVER FANWOOD 230 230

MOVE 49 PERCENT LOAD FROM BUS 218401 TO BUS 218402 /* PRSN AVG
T1 T2

MOVE 17 PERCENT LOAD FROM BUS 218401 TO BUS 218384 /* PRSN AVG
T1 KILMER T2

MOVE 17 PERCENT LOAD FROM BUS 218401 TO BUS 218399 /* PRSN AVG
T1 NEWDVR T2

MOVE 17 PERCENT LOAD FROM BUS 218401 TO BUS 218390 /* PRSN AVG
T1 LAFAYET T2

END

Bus Number	Bus Name	Full Contribution
218326	EDISON 1	30.47
218327	EDISON 2	30.46
218328	EDISON 3	30.47
218423	LINDNCT1	2.62
218424	LINDNCT2	2.62
218425	LINDNCT3	2.62
218426	LINDNST1	5.13
290745	S-061	0.37
218360	SEWAREN1	34.05
218361	SEWAREN2	38.64
218362	SEWAREN3	35.04
218363	SEWAREN4	40.6
218364	SEWAREN6	36.31
218344	TOSCONUG	2.21
292094	V1-030 C1	0.02
292096	V1-030 C2	0.02
292078	V1-034	0.35
292680	V3-069 C	0.01
900801	W1-001	7.83
902251	W2-023	204.66

902651	W2-052 C	< 0.01
905641	W4-080 C	0.08
913101	Y1-026	81.47
915251	Y3-049 1	0.03
915253	Y3-049 3	0.03
915271	Y3-051 C	2.84
915272	Y3-051 E1	35.92
916251	Z1-033	47.15
916191	Z1-059 C	8.51
916471	Z1-096 C	0.17
916601	Z1-109	107.24

Appendix 16

(PSEG - PSEG) The WARINANC-ALDENE1 230 kV line (from bus 218316 to bus 217122 ckt 1) loads from 152.55% to 166.59% (**DC power flow**) of its emergency rating (887 MVA) for the tower line contingency outage of 'H-2286 + G-2207'. This project contributes approximately 125.17 MW to the thermal violation.

CONTINGENCY 'H-2286 + G-2207'

DISCONNECT BUS 218357

DISCONNECT BUS 218355

MOVE 100 PERCENT LOAD FROM BUS 218381 TO BUS 218380

MOVE 100 PERCENT LOAD FROM BUS 218398 TO BUS 218399

DISCONNECT BRANCH FROM BUS 218320 TO BUS 218524 CKT 2

DISCONNECT BRANCH FROM BUS 218354 TO BUS 218306 CKT 2 /* PRSN AVG

DEANS 230 230

DISCONNECT BRANCH FROM BUS 218354 TO BUS 218300 CKT 1 /*

MINUESTG LINDEN 230 230

MOVE 52 PERCENT LOAD FROM BUS 218396 TO BUS 218397 /* MINUESTR

T2 T1

MOVE 24 PERCENT LOAD FROM BUS 218396 TO BUS 218410 /* MINUESTR

T2 WARINAN T1

MOVE 24 PERCENT LOAD FROM BUS 218396 TO BUS 218414 /* MINUESTR

T2 WDBRDG T1

END

Bus Number	Bus Name	Full Contribution
218326	EDISON 1	32.63
218327	EDISON 2	32.62
218328	EDISON 3	32.63
218423	LINDNCT1	3.14
218424	LINDNCT2	3.14
218425	LINDNCT3	3.14
218426	LINDNST1	6.15
206679	M&M S721	-0.55
94130	O66_NONFIRM	32.22
206638	PEAPACK	-0.21
290745	S-061	0.44
218360	SEWAREN1	39.35
218361	SEWAREN2	44.65
218362	SEWAREN3	40.49
218363	SEWAREN4	46.92
218364	SEWAREN6	41.96
218344	TOSCONUG	2.59
293093	U2-077	382.44
292094	V1-030 C1	0.02
292095	V1-030 E1	0.81

292185	V1-030 E2	0.75
292101	V1-030 E4	0.05
292107	V1-030 E7	0.1
292111	V1-030 E9	-0.08
292189	V1-030 EA	0.31
292191	V1-030 EC	-0.42
292092	V1-030 ED	-0.24
292078	V1-034	0.27
297021	V2-009 E1	0.2
297023	V2-009 E2	0.4
297025	V2-009 E3	0.23
297069	V2-025 E	-0.22
293378	V3-024 E	0.82
292666	V3-058 E	0.12
292668	V3-059 E	0.12
293444	V3-065 E	-0.03
293440	V3-066 E	-0.02
293434	V3-067 E	-0.04
293429	V3-068 E	-0.02
292681	V3-069 E	0.43
900801	W1-001	9.11
901802	W1-101 E	-0.08
901512	W1-122 E	-0.19
902251	W2-023	236.48
902652	W2-052 E	0.15
903672	W3-106 E	-0.37
903682	W3-110 E	-0.28
904452	W3-126 E	-0.62
904592	W3-140 E	-0.3
904642	W3-145 E	-0.62
904652	W3-146 E	-0.32
905492	W4-059 E	-0.05
905542	W4-064 E	-0.11
905552	W4-065 E	-0.23
905642	W4-080 E	4.03
907012	X1-012 E	-0.37
907132	X1-046 E	-0.29
907402	X1-072 E	-0.06
907302	X1-094 E	-0.6
907522	X1-114 E	-0.07
907412	X1-116 E	-0.25
909442	X2-087 E	-0.06
909452	X2-088 E	0.19
910712	X3-052 E	-0.27
910722	X3-054 E	-0.18

910852	X3-083 E	-0.32
913101	Y1-026	95.44
915271	Y3-051 C	3.4
915272	Y3-051 E1	43.04
916251	Z1-033	37.42
916191	Z1-059 C	10.19
916192	Z1-059 E	2.83
916471	Z1-096 C	0.16
916472	Z1-096 E	0.26
916601	Z1-109	125.17

Appendix 17

(PSEG - PSEG) The G22_MTX5-WARINANC 230 kV line (from bus 218441 to bus 218316 ckt 1) loads from 170.16% to 185.33% (**DC power flow**) of its emergency rating (821 MVA) for the tower line contingency outage of 'H-2286 + G-2207'. This project contributes approximately 125.17 MW to the thermal violation.

CONTINGENCY 'H-2286 + G-2207'

DISCONNECT BUS 218357

DISCONNECT BUS 218355

MOVE 100 PERCENT LOAD FROM BUS 218381 TO BUS 218380

MOVE 100 PERCENT LOAD FROM BUS 218398 TO BUS 218399

DISCONNECT BRANCH FROM BUS 218320 TO BUS 218524 CKT 2

DISCONNECT BRANCH FROM BUS 218354 TO BUS 218306 CKT 2 /* PRSN AVG

DEANS 230 230

DISCONNECT BRANCH FROM BUS 218354 TO BUS 218300 CKT 1 /*

MINUESTG LINDEN 230 230

MOVE 52 PERCENT LOAD FROM BUS 218396 TO BUS 218397 /* MINUESTR

T2 T1

MOVE 24 PERCENT LOAD FROM BUS 218396 TO BUS 218410 /* MINUESTR

T2 WARINAN T1

MOVE 24 PERCENT LOAD FROM BUS 218396 TO BUS 218414 /* MINUESTR

T2 WDBRDG T1

END

Bus Number	Bus Name	Full Contribution
218326	EDISON 1	32.63
218327	EDISON 2	32.62
218328	EDISON 3	32.63
218423	LINDNCT1	3.14
218424	LINDNCT2	3.14
218425	LINDNCT3	3.14
218426	LINDNST1	6.15
206679	M&M S721	-0.55
94130	O66_NONFIRM	32.22
206638	PEAPACK	-0.21
290745	S-061	0.44
218360	SEWAREN1	39.35
218361	SEWAREN2	44.65
218362	SEWAREN3	40.49
218363	SEWAREN4	46.92
218364	SEWAREN6	41.96
218344	TOSCONUG	2.59
293093	U2-077	382.44
292094	V1-030 C1	0.02
292095	V1-030 E1	0.81

292185	V1-030 E2	0.75
292101	V1-030 E4	0.05
292107	V1-030 E7	0.1
292111	V1-030 E9	-0.08
292189	V1-030 EA	0.31
292191	V1-030 EC	-0.42
292092	V1-030 ED	-0.24
292078	V1-034	0.27
297021	V2-009 E1	0.2
297023	V2-009 E2	0.4
297025	V2-009 E3	0.23
297069	V2-025 E	-0.22
293378	V3-024 E	0.82
292666	V3-058 E	0.12
292668	V3-059 E	0.12
293444	V3-065 E	-0.03
293440	V3-066 E	-0.02
293434	V3-067 E	-0.04
293429	V3-068 E	-0.02
292681	V3-069 E	0.43
900801	W1-001	9.11
901802	W1-101 E	-0.08
901512	W1-122 E	-0.19
902251	W2-023	236.48
902652	W2-052 E	0.15
903672	W3-106 E	-0.37
903682	W3-110 E	-0.28
904452	W3-126 E	-0.62
904592	W3-140 E	-0.3
904642	W3-145 E	-0.62
904652	W3-146 E	-0.32
905492	W4-059 E	-0.05
905542	W4-064 E	-0.11
905552	W4-065 E	-0.23
905642	W4-080 E	4.03
907012	X1-012 E	-0.37
907132	X1-046 E	-0.29
907402	X1-072 E	-0.06
907302	X1-094 E	-0.6
907522	X1-114 E	-0.07
907412	X1-116 E	-0.25
909442	X2-087 E	-0.06
909452	X2-088 E	0.19
910712	X3-052 E	-0.27
910722	X3-054 E	-0.18

910852	X3-083 E	-0.32
913101	Y1-026	95.44
915271	Y3-051 C	3.4
915272	Y3-051 E1	43.04
916251	Z1-033	37.42
916191	Z1-059 C	10.19
916192	Z1-059 E	2.83
916471	Z1-096 C	0.16
916472	Z1-096 E	0.26
916601	Z1-109	125.17