

***Generation Interconnection
System Impact Study Report***

For

***PJM Generation Interconnection Request
Queue Position AA2-173***

Hatfield 500kV

(Revised)

April 2016

Preface

The intent of the System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate Interconnected Transmission Owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation, if any, is included in the System Impact Study.

The Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs associated with them will be addressed when seeking an Interconnection Agreement as outlined below. Developer will also be responsible for providing and installing metering equipment in compliance with applicable PJM and Transmission Owner standards.

General

Hill Top Energy Center LLC (“Interconnection Customer” or “Hill Top Energy”) has proposed a natural gas generating facility located approximately 2 miles north of Nemacolin, Greene County, Pennsylvania. The installed facilities will have a total capability of 515 MW with 515 MW of this output being recognized by PJM as capacity. The proposed in-service date for this project is January 1, 2019. **This study does not imply a West Penn Power Company commitment to this in-service date.**

Point of Interconnection (POI)

For AA2-173 project, the connection from the West Penn Power transmission system to Hill Top Energy’s facilities will be provided by constructing a new 500 kV cross-bus at Hatfield 500 kV Substation. The Point of Interconnection is located outside the Substation as shown in Appendix 2.

Transmission Owner Scope of Work and Costs Estimation

The Potomac attachment facilities and network upgrades as well as related costs estimates required for AB1-173 interconnection project are shown in below table. Please note that these costs do not include CIAC Tax Gross-up:

Project Costs Description	Amount						
Attachment Facilities <u>Metering</u> 500 kV metering package to be installed inside Hill Top Energy's facilities. <u>Inline facilities from tap point to POI:</u> <ul style="list-style-type: none"> - Install attachment line from the POI located outside the substation to the bus. - Install fully rated load break switch in attachment line. 	\$ 450,000						
Direct Connection Network Upgrades None.	\$ 0						
Non-Direct Connection Network Upgrades <table border="1"> <thead> <tr> <th>NUN</th><th>Description</th></tr> </thead> <tbody> <tr> <td>n4942</td><td>Expand 500kV bus and install 2-500kV breakers and associated equipment.</td></tr> <tr> <td>n4943</td><td>Adjust Remote Relay and Metering Settings at Hatfield Substation.</td></tr> </tbody> </table>	NUN	Description	n4942	Expand 500kV bus and install 2-500kV breakers and associated equipment.	n4943	Adjust Remote Relay and Metering Settings at Hatfield Substation.	\$ 6,158,800
NUN	Description						
n4942	Expand 500kV bus and install 2-500kV breakers and associated equipment.						
n4943	Adjust Remote Relay and Metering Settings at Hatfield Substation.						
Allocation for New System Upgrades None.	\$ 0						
Contributions for Previously Identified Upgrades None.	\$ 0						
Total Costs	\$ 6,608,800						

* NUN means Network Upgrade Number.

Interconnection Customer Requirements

Hill Top Energy will be responsible for meeting all criteria as specified in the applicable sections of the First Energy “Requirements for Transmission Connected Facilities” document including:

1. The purchase and installation of fully rated 12.5 kV circuit breaker on the high side of the (AA2-173) step-up transformer.
2. The purchase and installation of the minimum required Interconnected Transmission Owner generation interconnection relaying and control facilities. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition (SCADA) equipment.
4. The establishment of dedicated communication circuits for SCADA.
5. A compliance with the Interconnected Transmission Owner and PJM generator power factor and voltage control requirements.
6. The execution of a back-up service agreement to serve the customer load supplied from the (AA2-173) generation project interconnection point when the units are out-of-service. This

The above requirements are in addition to any metering or other requirements required by PJM.

Schedule of Work

Based on the scope of interconnection attachment facilities, direct and non-direct system upgrades, it is expected to take a minimum of twenty four (24) months from the date of a fully executed Interconnection Construction Service Agreement to complete the installation. This includes a preliminary payment that compensates the Interconnected Transmission Owner for the first three months of the engineering design work that is related to the interconnection facilities of the Project. It also assumes that the Interconnection Customer will provide the property for the Project direct connection facilities and all right-of-way, permits, easements, etc. that will be needed. A further assumption is that there will be no environmental issues with any of the new properties associated with this project, that there will be no delays in acquiring the necessary permits for implementing the defined direct connection facilities and that transmission system outages will be possible when requested.

Revenue Metering and SCADA Requirements

PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

Transmission Owner Requirements

The IC will be required to comply with all Interconnected Transmission Owner revenue metering requirements for generation interconnection customers. The Interconnected Transmission Owner revenue metering requirements may be found in the Interconnected Transmission Owner "Requirements for Transmission Connected Facilities" document located at the following links:

www.firstenergycorp.com/feconnect

www.pjm.com/planning/design-engineering/to-tech-standards.aspx

Network Impacts

The Queue Project AA2-173 was evaluated as a 515.0 MW (Capacity 515.0 MW) injection into the Hatfield 500 kV substation in the APS area. Project AA2-173 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AA2-173 was studied with a commercial probability of 100%. Potential network impacts were as follows:

Summer Peak Analysis - 2019

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

Steady-State Voltage Requirements

(Results of the steady-state voltage studies should be inserted here)

None

Short Circuit

(Summary of impacted circuit breakers)

None

Affected System Analysis & Mitigation

Delivery of Energy Portion of Interconnection Request

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission

Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

Not Applicable

Light Load Analysis - 2019

Light Load Studies to be conducted during later study phases (as required by PJM Manual 14B).

System Reinforcements

Short Circuit

(Summary form of Cost allocation for breakers will be inserted here if any)

None

Stability and Reactive Power Requirement

(Results of the dynamic studies should be inserted here)

No violations are identified, however, requires revision of Interconnection Customer's Operation Guidelines.

Summer Peak Load Flow Analysis Reinforcements

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

None

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

(Summary form of Cost allocation for transmission lines and transformers will be inserted here if any)

Light Load Load Flow Analysis Reinforcements

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

None

Contribution to Previously Identified System Reinforcements


(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

(Summary form of Cost allocation for transmission lines and transformers will be inserted here if any)

None

Appendix 1

Project Location



Appendix 2

System Configuration – Single Line Diagram

