

***Generation Interconnection  
REVISED  
Impact Study Report***

***For***

***PJM Generation Interconnection Request  
Queue Position AD2-020***

***Valley 138kV***

**September 2021**

## Preface

The intent of the System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the System Impact Study is performed.

The System Impact Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

## General

Southwest Michigan Solar Project, LLC proposes to install PJM Project #AD2-020, a 100 MW (61.9 MW Capacity) solar facility in Van Buren County, Michigan (see Figure 2). The primary point of interconnection will be a direct connection to AEP's Valley 138 kV substation (see Figure 1). The secondary point of interconnection is to AEP's Valley – Colby 138 kV section of the Valley – Kenzie Creek 138 kV circuit (see Figure 3).

The requested in service date is December 1, 2020

### **Point of Interconnection**

#### **Primary Point of Interconnection (Valley 138 kV Substation)**

To accommodate the interconnection at the Valley 138 kV substation, the installation of one (1) new 138 kV circuit breakers will be required, associated protection and control equipment, SCADA, and 138 kV revenue metering.

### **Cost Summary**

The AD2-020 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$ 250,000
Direct Connection Network Upgrades	\$ 0
Non Direct Connection Network Upgrades	\$ 2,000,000
Allocation for New System Upgrades	\$ 0
Contribution for Previously Identified Upgrades	\$ 0
<b>Total Costs</b>	<b>\$ 2,250,000</b>

## Attachment Facilities

The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
138 kV Revenue Metering	\$ 250,000
<b>Total Attachment Cost Estimate</b>	<b>\$ 250,000</b>

## Direct Connection Cost Estimate

There are no Direct Connection Facilities required to be constructed by the Transmission Owner.

## Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Install one (1) new 138 kV circuit breaker (see Figure 1). Installation of associated protection and control equipment, SCADA, and 138 kV revenue metering will also be required.	\$ 2,000,000
<b>Total Non-Direct Facilities Cost Estimate</b>	<b>\$ 2,000,000</b>

## Schedule

It is anticipated that the time between receipt of executed agreements and Commercial Operation may range from 12 to 18 months if no line work is required. If line work is required, construction time would be between 24 to 36 months after signing an interconnection agreement.

**Note:** The time provided between anticipated normal completion of the Facilities Study, subsequent execution of ISA and ICSA documents, and the proposed In-Service Date is shorter than usual and may be difficult to achieve.

## **Interconnection Customer Requirements**

It is understood that Southwest Michigan Solar Project, LLC is responsible for all costs associated with this interconnection. The costs above are reimbursable to AEP. The cost of Southwest Michigan Solar Project, LLC's generating plant and the costs for the line connecting the generating plant to either the 138 kV substations are not included in this report; these are assumed to be Southwest Michigan Solar Project, LLC's responsibility.

The Generation Interconnection Agreement does not in or by itself establish a requirement for American Electric Power to provide power for consumption at the developer's facilities. A separate agreement may be reached with the local utility that provides service in the area to ensure that infrastructure is in place to meet this demand and proper metering equipment is installed. It is the responsibility of the developer to contact the local service provider to determine if a local service agreement is required.

Requirement from the PJM Open Access Transmission Tariff:

1. An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.
2. The Interconnection Customer may be required to install and/or pay for metering as necessary to properly track real time output of the facility as well as installing metering which shall be used for billing purposes. See Section 8 of Appendix 2 to the Interconnection Service Agreement as well as Section 4 of PJM Manual 14D for additional information.

## **Revenue Metering and SCADA Requirements**

### **PJM Requirements**

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

### **AEP Requirements**

The Interconnection Customer will be required to comply with all AEP Revenue Metering Requirements for Generation Interconnection Customers. The Revenue Metering Requirements may be found within the "Requirements for Connection of New Facilities or Changes to Existing Facilities Connected to the AEP Transmission System" document located at the following link:

<http://www.pjm.com/~media/planning/plan-standards/private-aep/aep-interconnection-requirements.ashx>

## **Network Impacts**

The Queue Project AD2-020 was evaluated as a 100.0 MW (Capacity 61.9 MW) injection into the Valley 138 kV substation in the AEP area. Project AD2-020 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AD2-020 was studied with a commercial probability of 100%. Potential network impacts were as follows:

### **Summer Peak Analysis - 2021**

#### **Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

None.

#### **Light Load Analysis**

*Light Load Studies to be conducted during later study phases (applicable to wind, coal, nuclear, and pumped storage projects).*

None.

#### **Multiple Facility Contingency**

*(Double Circuit Tower Line contingencies were studied for the full energy output. The contingencies of Line with Failed Breaker and Bus Fault will be performed for the Impact Study.)*

None.

#### **Short Circuit**

*(Summary of impacted circuit breakers)*

None.

#### **Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

None.

#### **Steady-State Voltage Requirements**

*(Summary of the VAR requirements based upon the results of the steady-state voltage studies)*

To be determined during the Facilities Study Phase

#### **Stability and Reactive Power Requirement for Low Voltage Ride Through**

*(Summary of the VAR requirements based upon the results of the dynamic studies)*

To be determined during the Facilities Study Phase

### **New System Reinforcements**

*(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)*

None.

### **Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

None.

### **Potential Congestion due to Local Energy Deliverability**

*PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.*

None.

### **Incremental Capacity Transfer Rights (ICTRs)**

Will be determined at a later study phase

### **Affected System Analysis & Mitigation**

#### **LGEE Impacts:**

None

#### **MISO Impacts:**

None.

#### **Duke, Progress & TVA Impacts:**


None

#### **OVEC Impacts:**

None

**Figure 1: Primary Point of Interconnection (Valley 138 kV)**  
**Single-Line Diagram**

AD2-020 Primary Point of Interconnection





**Figure 2: Primary Point of Interconnection (Valley 138 kV)**

