

***Generation Interconnection
Impact Study Report***

For

***PJM Generation Interconnection Request
Queue Position AD2-138
Olive (AEP) – Reynolds (NIPSCO) 345 kV***

December 2019

Preface

The intent of the System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the System Impact Study is performed.

The System Impact Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

General

Jordan Creek Wind Farm, LLC (Jordan Creek) proposes to install PJM Project #AD2-138, a 200.0 MW (35.2 MW Capacity) wind generating facility in Pulaski County, Indiana (see Figure 2). The primary point of interconnection will be to the Olive (AEP) – Reynolds (NIPSCO) 345 kV circuit #1 (see Figure 1).

The requested in service date is December 31, 2020

Point of Interconnection

Primary Point of Interconnection (Olive – Reynolds (NIPSCO) 345 kV Circuit #1)

To accommodate the interconnection on the Olive – Reynolds (NIPSCO) 345 kV circuit #1, the switching station will have to be expanded requiring the installation of three (3) new 345 kV circuit breakers at the proposed AC2-080 345 kV switching station (see Figure 1). Installation of associated protection and control equipment, 345 kV line risers, SCADA, and 345 kV revenue metering will also be required. AEP reserves the right to specify the final acceptable configuration considering design practices, future expansion, and compliance requirements.

Cost Summary

This project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$ 350,000
Direct Connection Network Upgrades	\$ 4,000,000
Non Direct Connection Network Upgrades	\$ 350,000
Allocation for New System Upgrades	\$ 0
Contribution for Previously Identified Upgrades	\$ 0
Total Costs	\$ 4,700,000

Attachment Facilities

The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Estimated Cost
345 kV Revenue Metering	\$350,000

Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

New Line Tap/Switching Station Work and Cost:

- Expand the switching station requiring the installation of three (3) new 345 kV circuit breakers 345 at the proposed AC2-080 345 kV switching station. Installation of associated protection and control equipment, 345 kV line risers, SCADA, and 345 kV revenue metering will also be required (see Figure 1).
 - **Estimated Station Cost: \$4,000,000**

Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Estimated Cost
Upgrade line protection and controls at the Olive 345 kV substation.	\$350,000
Upgrade line protection and control settings at the Reynolds (NIPSCO) 345 kV substation.	NIPSCO to provide scope and cost estimate
Total	\$350,000

Interconnection Customer Requirements

It is understood that Jordan Creek is responsible for all costs associated with this interconnection. The cost of Jordan Creek's generating plant and the costs for the line connecting the generating plant to the point of interconnection are not included in this report; these are assumed to be Jordan Creek's responsibility.

The Generation Interconnection Agreement does not in or by itself establish a requirement for American Electric Power to provide power for consumption at the developer's facilities. A separate agreement may be reached with the local utility that provides service in the area to ensure that infrastructure is in place to meet this demand and proper metering equipment is installed. It is the responsibility of the developer to contact the local service provider to determine if a local service agreement is required

Requirement from the PJM Open Access Transmission Tariff:

1. An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.
2. The Interconnection Customer may be required to install and/or pay for metering as necessary to properly track real time output of the facility as well as installing metering which shall be used for billing purposes. See Section 8 of Appendix 2 to the Interconnection Service Agreement as well as Section 4 of PJM Manual 14D for additional information.

Revenue Metering and SCADA Requirements

PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Sections 24.1 and 24.2.

AEP Requirements

The Interconnection Customer will be required to comply with all AEP Revenue Metering Requirements for Generation Interconnection Customers. The Revenue Metering Requirements may be found within the "Requirements for Connection of New Facilities or Changes to Existing Facilities Connected to the AEP Transmission System" document located at the following link:

<http://www.pjm.com/~media/planning/plan-standards/private-aep/aep-interconnection-requirements.ashx>

Network Impacts

The Queue Project AD2-138 was evaluated as a 200.0 MW (Capacity 35.2 MW) injection into the AC2-080 substation (which is a tap of the Olive – Reynolds 345 kV line #1) in the AEP area. Project AD2-138 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AD2-138 was studied with a commercial probability of 100%. Potential network impacts were as follows:

Summer Peak Analysis - 2021

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None.

Light Load Analysis

Light Load Studies to be conducted during later study phases (applicable to wind, coal, nuclear, and pumped storage projects).

Multiple Facility Contingency

(Double Circuit Tower Line contingencies were studied for the full energy output. The contingencies of Line with Failed Breaker and Bus Fault will be performed for the Impact Study.)

None.

Short Circuit

(Summary of impacted circuit breakers)

None.

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None.

Steady-State Voltage Requirements

(Summary of the VAR requirements based upon the results of the steady-state voltage studies)

None.

Stability and Reactive Power Requirement for Low Voltage Ride Through

(Summary of the VAR requirements based upon the results of the dynamic studies)

To be determined during the Facilities Study Phase.

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

To be determined during the Facilities Study Phase.

Contribution to Previously Identified System Reinforcements

(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)

None.

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified

None.

Incremental Capacity Transfer Rights (ICTRs)

Will be determined at a later study phase

Affected System Analysis & Mitigation

LGEE Impacts:

None

MISO Impacts:

MISO Impacts to be determined during later study phases (as applicable).


Duke, Progress & TVA Impacts:

None

OVEC Impacts:

None

Figure 1: (Olive (AEP) – Reynolds (NIPSCO) 345 kV Circuit #1)
Single-Line Diagram



**Figure 2: Primary Point of Interconnection (Olive (AEP) – Reynolds (NIPSCO) 345 kV
Circuit #1)**




Figure 3: Customer Facility Location

