



**Generation Interconnection  
System Impact Study Report  
for  
Queue Project AE1-108  
BREMO-SCOTTSVILLE 138 KV  
91.8 MW Capacity / 153 MW Energy**

December 2020

## Table of Contents

1	Introduction.....	4
2	Preface.....	4
3	General .....	5
4	Point of Interconnection.....	6
5	Cost Summary .....	6
6	Transmission Owner Scope of Work .....	8
7	Incremental Capacity Transfer Rights (ICTRs) .....	9
8	Schedule.....	9
9	Transmission Owner Analysis.....	9
10	Interconnection Customer Requirements.....	9
11	Revenue Metering and SCADA Requirements .....	10
11.1	PJM Requirements .....	10
11.2	Meteorological Data Reporting Requirements .....	10
11.3	Interconnected Transmission Owner Requirements.....	10
12	Summer Peak Analysis .....	11
12.1	Generation Deliverability .....	11
12.2	Multiple Facility Contingency .....	11
12.3	Contribution to Previously Identified Overloads.....	11
12.4	Steady-State Voltage Requirements .....	11
12.5	Potential Congestion due to Local Energy Deliverability.....	11
12.6	System Reinforcements.....	13
12.7	Flow Gate Details.....	14
12.8	Queue Dependencies .....	15
12.9	Contingency Descriptions.....	16
13	Light Load Analysis .....	17
14	Short Circuit Analysis.....	17
15	Stability and Reactive Power Assessment.....	17
16	Affected Systems .....	19
16.1	TVA.....	19
16.2	Duke Energy Progress.....	19
16.3	MISO .....	19

16.4	LG&E.....	19
17	Attachment 1: One Line Diagram & Project Location.....	20

## 1 Introduction

This System Impact Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 205, as well as the System Impact Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is AEP.

## 2 Preface

The intent of the System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the System Impact Study is performed.

The System Impact Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

### 3 General

The Interconnection Customer (IC), has proposed a Solar generating facility located in Buckingham County, Virginia. The installed facilities will have a total capability of 153 MW with 91.8 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is August 31, 2021. This study does not imply a TO commitment to this in-service date.

<b>Queue Number</b>	<b>AE1-108</b>
<b>Project Name</b>	BREMO-SCOTTSVILLE 138 KV
<b>State</b>	Virginia
<b>County</b>	Buckingham
<b>Transmission Owner</b>	AEP
<b>MFO</b>	153
<b>MWE</b>	153
<b>MWC</b>	91.8
<b>Fuel</b>	Solar
<b>Basecase Study Year</b>	2022

Any new service customers who can feasibly be commercially operable prior to June 1st of the basecase study year are required to request interim deliverability analysis.

## 4 Point of Interconnection

AE1-108 will interconnect with the AEP transmission system via a new station cut into the (Dominion) Brema – Scottsville (AEP) 138 kV tie line.

To accommodate the interconnection on the (Dominion) Brema - Scottsville (AEP) 138 kV line, a new three (3) circuit breaker 138 kV switching station physically configured in a breaker and half bus arrangement but operated as a ring-bus will be constructed (see Attachment 1). Installation of associated protection and control equipment, 138 kV line risers, SCADA, and 138 kV revenue metering will also be required. AEP reserves the right to specify the final acceptable configuration considering design practices, future expansion, and compliance requirements.

## 5 Cost Summary

The AE1-108 project will be responsible for the following costs:

Description	Total Cost
<b>Total Physical Interconnection Costs</b>	\$9,946,000
<b>Allocation towards System Network Upgrade Costs*</b>	\$0
<b>Total Costs</b>	\$9,946,000

\*As your project progresses through the study process and other projects modify their request or withdraw, then your cost allocation could change.

This cost excludes a Federal Income Tax Gross Up charges. This tax may or may not be charged based on whether this project meets the eligibility requirements of IRS Notice 88-129. If at a future date it is determined that the Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

Note 1: PJM Open Access Transmission Tariff (OATT) section 217.3A outline cost allocation rules. The rules are further clarified in PJM Manual 14A Attachment B. The allocation of costs for a network upgrade will start with the first Queue project to cause the need for the upgrade. Later queue projects will receive cost allocation contingent on their contribution to the violation and are allocated to the queues that have not closed less than 5 years following the execution of the first Interconnection Service Agreement which identifies the need for this upgrade.

Note 2: For customers with System Reinforcements listed: If your present cost allocation to a System Reinforcement indicates \$0, then please be aware that as changes to the interconnection process occur, such as prior queued projects withdrawing from the queue, reducing in size, etc, the cost responsibilities can change and a cost allocation may be assigned to your project. In addition, although your present cost

allocation to a System Reinforcement is presently \$0, your project may need this system reinforcement completed to be deliverable to the PJM system. If your project comes into service prior to completion of the system reinforcement, an interim deliverability study for your project will be required.

## 6 Transmission Owner Scope of Work

The total physical interconnection costs is given in the table below:

Description	Total Cost
Construct a new three (3) circuit breaker 138 kV switching station physically configured in a breaker and half bus arrangement but operated as a ring-bus. Installation of associated protection and control equipment, 138 kV line risers and SCADA will also be required.	\$8,150,000
Bremo - Scottsville 138 kV T-Line Cut In	\$770,000
138kV Revenue Metering	\$376,000
Generator lead first span exiting the POI station, including the first structure outside the fence	\$400,000
Upgrade line protection and controls at the Scottsville 138 kV substation	\$250,000
Upgrade line protection and controls at the Bremo (Dominion) 138 kV substation	TBD by Dominion
<b>Total Physical Interconnection Costs</b>	<b>\$9,946,000</b>

The estimates provided in this report are preliminary in nature, as they were determined without the benefit of detailed engineering studies. Final estimates will require an onsite review and coordination to determine final construction requirements. In addition, Stability analysis will be completed during the Facilities Study stage. It is possible that a need for additional upgrades could be identified by these studies.



## 7 Incremental Capacity Transfer Rights (ICTRs)

None

## 8 Schedule

It is anticipated that the time between receipt of executed Agreements and Commercial Operation may range from 12 to 18 months if no line work is required. If line work is required, construction time would generally be between 24 to 36 months after Agreement execution.

## 9 Transmission Owner Analysis

None

## 10 Interconnection Customer Requirements

It is understood that the Interconnection Customer is responsible for all costs associated with this interconnection. The costs above are reimbursable to the Interconnected Transmission Owner. The cost of the Interconnection Customer's generating plant and the costs for the line connecting the generating plant to the Interconnected Transmission Owner's Transmission circuit are not included in this report; these are assumed to be the Interconnection Customer's responsibility.

The Generation Interconnection Agreement does not in or by itself establish a requirement for the Interconnected Transmission Owner to provide power for consumption at the developer's facilities. A separate agreement may be reached with the local utility that provides service in the area to ensure that infrastructure is in place to meet this demand and proper metering equipment is installed. It is the responsibility of the developer to contact the local service provider to determine if a local service agreement is required.

Requirement from the PJM Open Access Transmission Tariff:

1. An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.
2. The Interconnection Customer may be required to install and/or pay for metering as necessary to properly track real time output of the facility as well as installing metering which shall be used for billing purposes. See Section 8 of Appendix 2 to the Interconnection Service Agreement as well as Section 4 of PJM Manual 14D for additional information.

## **11 Revenue Metering and SCADA Requirements**

### **11.1 PJM Requirements**

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

### **11.2 Meteorological Data Reporting Requirements**

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Back Panel temperature (Fahrenheit)
- Irradiance (Watts/meter<sup>2</sup>)
- Ambient air temperature (Fahrenheit) – (Accepted, not required)
- Wind speed (meters/second) – (Accepted, not required)
- Wind direction (decimal degrees from true north) – (Accepted, not required)

### **11.3 Interconnected Transmission Owner Requirements**

The IC will be required to comply with all Interconnected Transmission Owner's revenue metering requirements for generation interconnection customers located at the following link:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/>

## 12 Summer Peak Analysis

The Queue Project AE1-108 was evaluated as a 153.0 MW (Capacity 91.8 MW) injection into a tap of the Bremono – Scottsville 138 kV line in the AEP area. Project AE1-108 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE1-108 was studied with a commercial probability of 100.0 %. Potential network impacts were as follows:

### 12.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

### 12.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

### 12.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

### 12.4 Steady-State Voltage Requirements

None

### 12.5 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

ID	FROM BUS#	FROM BUS	kV	FROM BUS AREA	TO BUS#	TO BUS	kV	TO BUS AREA	CK T ID	CONT NAME	Type	Rating MVA	PRE PROJECT LOADIN G %	POST PROJECT LOADIN G %	AC/D C	MW IMPACT
61704	313867	6BREMODIST	230.0	DVP	314765	6MTEAGLE	230.0	DVP	1	DVP_P 1-2: LN 2027-B	operation	661.760009766	94.58	102.61	AC	53.4
61661	314747	6BREMO	230.0	DVP	313867	6BREMODIST	230.0	DVP	1	DVP_P 1-2: LN 2027-B	operation	661.760009766	96.8	104.84	AC	53.4



## 12.6 System Reinforcements

None

## 12.7 Flow Gate Details

The following indices contain additional information about each facility presented in the body of the report. For each index, a description of the flowgate and its contingency was included for convenience. The intent of the indices is to provide more details on which projects/generators have contributions to the flowgate in question. All New Service Queue Requests, through the end of the Queue under study, that are contributors to a flowgate will be listed in the indices. Please note that there may be contributors that are subsequently queued after the queue under study that are not listed in the indices. Although this information is not used "as is" for cost allocation purposes, it can be used to gage the impact of other projects/generators. It should be noted the project/generator MW contributions presented in the body of the report are Full MW Impact contributions which are also noted in the indices column named "Full MW Impact", whereas the loading percentages reported in the body of the report, take into consideration the PJM Generator Deliverability Test rules such as commercial probability of each project as well as the ramping impact of "Adder" contributions. The MW Impact found and used in the analysis is shown in the indices column named "Gendeliv MW Impact".

---

## 12.8 Queue Dependencies

None

## 12.9 Contingency Descriptions

Contingency Name	Contingency Definition
<b>DVP_P1-2: LN 2027-B</b>	CONTINGENCY 'DVP_P1-2: LN 2027-B' OPEN BRANCH FROM BUS 933500 TO BUS 314333 CKT 1 /* AC2-165 TAP 230.00 - 6POWHATN 230.00 OPEN BRANCH FROM BUS 314310 TO BUS 314322 CKT 1 /* 6JUDES F 230.00 - 6MDLTHAN 230.00 OPEN BRANCH FROM BUS 314310 TO BUS 314333 CKT 1 /* 6JUDES F 230.00 - 6POWHATN 230.00 OPEN BUS 314310 /* ISLAND: 6JUDES F 230.00 OPEN BUS 314333 /* ISLAND: 6POWHATN 230.00 END



### 13 Light Load Analysis

*Light Load Studies (As applicable).*

Not applicable

### 14 Short Circuit Analysis

The following Breakers are overdutied

None

### 15 Stability and Reactive Power Assessment

*(Summary of the VAR requirements based upon the results of the dynamic studies)*

#### EXECUTIVE SUMMARY

Generator Interconnection Request AE1-108 is for a 153 MW Maximum Facility Output (MFO) solar generating facility. AE1-108 consists of 62 x 2.5256 MW TMEIC PVH-L2700GR solar inverters with a Point of Interconnection (POI) connecting to the transmission line between the Scottsville and BreMO Bluff 138 kV substations in Buckingham County, Virginia, in the American Electric Power (AEP) transmission system.

The power flow scenario for the analysis was based on the RTEP 2022 summer peak case, modified to include applicable queue projects. AE1-108 has been dispatched online at maximum facility output, with approximately unity power factor at the high side of the station transformer.

AE1-108 was tested for compliance with NERC, PJM, Transmission Owner and other applicable criteria. For this study, 68 contingencies were simulated, each with a 20 second simulation time period. Studied faults included:

- Steady-state operation (20 second simulation)
- Three-phase faults with normal clearing time
- Single-phase bus faults with normal clearing time
- Single-phase faults with a stuck breaker
- Single-phase faults placed at 80% of the line with delayed (Zone 2) clearing at remote line end because of primary communications/relaying failure
- Three-phase faults with loss of multiple circuits caused by a common tower contingency

The 68 fault contingencies tested on the 2022 summer peak case met the recovery criteria:

- The AE1-108 generators were able to ride through the faults except for faults where protective actions trip one or more generator(s).

- All generators maintained synchronism and any post-contingency oscillations are positively damped with a damping margin of at least 3%.
- All bus voltages recover to 0.7 p.u. within 2.5 seconds and the final voltage is within the range of 0.92 p.u. to 1.05 p.u. excluding 500 kV buses. The final voltages for 500 kV buses should be within 1.02 p.u. to 1.08 p.u and the final voltages for 69 kV buses should be within 0.893 p.u. to 1.019 p.u.
- No transmission element trips, other than those either directly connected or designated to trip as a consequence of the fault.

The AE1-108 queue project did not meet the 0.95 lagging power factor requirement. An additional 18.64 Mvar would be required for the plant to meet the 0.95 lagging power factor requirement. The plant did meet the 0.95 leading power factor requirement.

## **16 Affected Systems**

### **16.1 TVA**

None

### **16.2 Duke Energy Progress**

None

### **16.3 MISO**

None

### **16.4 LG&E**

None

## 17 Attachment 1: One Line Diagram & Project Location

### AE1-108 Point of Interconnection (Bremo - Scottsville 138 KV)

Remote stations not completely shown.



