

***Generation Interconnection  
System Impact Study Report***

***For***

***PJM Generation Interconnection Request  
Queue Position AE1-117***

***“Bethany 138 kV”***

**Rev 0: August 2019  
Rev 1: November 2019  
Rev 2: July 2021  
Rev 3: May 2022**

## Contents

Preface.....	4
General.....	4
Revision History .....	4
Point of Interconnection .....	5
Transmission Owner Scope of Work .....	5
Substation Interconnection Estimate.....	5
Required Relaying and Communications.....	6
Metering.....	6
Interconnection Customer Scope of Direct Connection Work.....	6
Inverter Requirements .....	7
Special Operating Requirements.....	7
Summer Peak Analysis - 2022 .....	8
Generator Deliverability .....	8
Multiple Facility Contingency .....	8
Contribution to Previously Identified Overloads .....	8
Delivery of Energy Portion of Interconnection Request.....	9
Summer Peak Load Flow Analysis Reinforcements.....	13
Short Circuit.....	14
Stability Analysis.....	14
Light Load Analysis - 2022.....	14
Attachment 1 – Single Line Diagram.....	15
Attachment 2 - Dynamic Simulation Analysis.....	16
Executive Summary .....	16
Introduction .....	17
Description of Project .....	17
Reactive Power Assessment.....	21
MFO Assessment .....	22
Loadflow and Dynamics Case Setup.....	22
Fault Cases .....	23
Evaluation Criteria .....	24
Summary of Results .....	24
Flow Gate Details .....	32

Index 1.....	33
Index 2.....	35
Index 3.....	38

## **Preface**

The intent of the System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the System Impact Study is performed.

The System Impact Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The Interconnection Customer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

## **General**

Skipjack Offshore Energy, LLC, the Interconnection Customer (IC), has proposed a 152.0 MW Energy (41.5 MW Capacity) offshore wind generating facility to be located in the Atlantic Ocean east of Sussex County, Delaware at GPS coordinates Latitude 38.4987110, Longitude -74.6284920. PJM studied the AE1-117 project as an injection into the Delmarva Power & Light Company (DPL) transmission system at the Bethany 138 kV Substation and evaluated it for compliance with reliability criteria for summer peak conditions in 2022. The project was studied at a commercial probability of 100%. The planned in-service date, as requested by the IC, is June 1, 2022. This date may not be attainable due to required PJM studies (Facilities) and the Transmission Owner's construction schedule.

## **Revision History**

The System Impact Study Report was revised in November 2019 to include the stability analysis results. The report was further revised in July 2021 to update the Summer Peak Analysis to reflect the results of PJM's retool study. The report was revised again in May 2022 to reflect PJM's second retool study.

## Point of Interconnection

The Interconnection Customer requested a transmission level Point of Interconnection (POI) be evaluated for the AE1-117 project. As a result, the POI will be located at an Interconnection Customer owned circuit breaker within 500 feet of the Bethany 138 kV Substation where it will connect to a new bus position (see Attachment 1).

## Transmission Owner Scope of Work

### Substation Interconnection Estimate

**Scope:** Expanding DPL's Bethany 138 kV Substation to a six (6) position ring bus by constructing one (1) new 138 kV bus position to facilitate the interconnection of AE1-117.

The project will require the addition of one (1) 138 kV breaker, three (3) 138 kV disconnect switches, three (3) CT/VT combination units, and substation bus.

**Estimate:** \$4,100,000

**Construction Time:** 36-48 months

### **Major Equipment Included in Estimate:**

- Power Circuit Breaker, 138 kV, 3 cycle  
Qty. 1
- Breaker Disconnect, 138 kV  
Qty. 2
- Line Disconnect, 138 kV  
Qty. 1
- Double 1590 ACSR (325')  
Qty. 3
- Insulators, 138 kV  
Qty. 21
- Disconnect Switch Stand, Low, 138 kV, Steel  
Qty. 1
- Relay Panel, Transmission Line, FL/BU (20")  
Qty. 1
- Control Panel, 138 kV Circuit Breaker (10")  
Qty. 1
- Take-off structure, 138 kV  
Qty. 2
- 138 kV Lightning Arresters  
Qty. 3
- 138 kV Lightning Arresters Stands  
Qty. 3

**Estimate Assumptions:**

- Room in Control Enclosure for New Relay Panel.
- Fiber optic cable necessary is 1,000 linear feet.
- Developer to purchase additional land for substation expansion, if necessary.
- Existing AC & DC systems are adequate
- Existing ground grid and storm water management requires southward expansion.

**Required Relaying and Communications**

New protection relays are required for the new terminals.

Front line and back-up line protection will be required. A relay panel for the generator bus will be required with front line and back-up protection.

A breaker control relay on a breaker control panel will be required for the control and operation of each new 138 kV circuit breaker (1 total).

The project will require re-wiring and adjustment of existing relay schemes to accommodate the new 138 kV position at the substation.

**Metering**

A three phase 138 kV revenue metering point will need to be established within the IC facility at the POI.

The IC will purchase and install all metering instrument transformers, as well as construct a metering structure per DPL's specifications. The secondary wiring connections at the instrument transformers will be completed by the IC's contractors and inspected by DPL, while the secondary wiring work at the metering enclosure will be completed by DPL's meter technicians. The metering control cable and meter cabinets will be supplied by DPL and installed by the IC's contractors. DPL's meter technicians will program and install two solid state multi-function meters (Primary & Backup) for each new metering position. Each meter will be equipped with load profile, telemetry, and DNP outputs. The IC will be provided with one (1) meter DNP output.

The IC will be required to make provisions for a POTS (plain old telephone service) line within approximately three (3) feet of each DPL metering position to facilitate remote interrogation and data collection.

**Interconnection Customer Scope of Direct Connection Work**

The IC is responsible for all design and construction related to activities on their side of the Point of Interconnection. Site preparation, including grading and an access road, as necessary, is assumed to be by the IC. Route selection, line design, and right-of-way acquisition of the direct connect facilities is not included in this report, and is the responsibility of the IC. Protective relaying and metering design and installation must comply with DPL's applicable standards. The IC is also required to provide revenue

metering and real-time telemetering data to PJM in conformance with the requirements contained in PJM Manuals M-01 and M-14 and the PJM Tariff.

DPL requires that an IC circuit breaker is located within 500 feet of the DPL substation to facilitate the relay protection scheme between DPL and the IC at the Point of Interconnection (POI).

### **Inverter Requirements**

- The Interconnection Customer shall design is non-synchronous generation facility with the ability to maintain a power factor of at least 0.95 leading to 0.95 lagging measured at the Point of Interconnection.

### **Special Operating Requirements**

1. DPL will require the capability to remotely disconnect the generator from the grid by communication from its System Operations facility. Such disconnection may be facilitated by a generator breaker, or other method depending upon the specific circumstances and the evaluation by DPL.
2. DPL reserves the right to charge the Interconnection Customer operation and maintenance expenses to maintain the Interconnection Customer attachment facilities, including metering and telecommunications facilities, owned by DPL.

## Summer Peak Analysis - 2022

Potential transmission network impacts are as follows:

### **Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

None

### **Multiple Facility Contingency**

*(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)*

1. (DP&L - DP&L) The TODD-PRESTON 69 kV line (from bus 232234 to bus 232233 ckt 1) loads from 100.0% to 110.88% (AC power flow) of its emergency rating (93 MVA) for the line fault with failed breaker contingency outage of 'DPL\_P4-2\_DP11'. This project contributes approximately 12.08 MW to the thermal violation.

```
CONTINGENCY 'DPL_P4-2_DP11'                      /*STEELE BUS
BREAKER TO MILFORD
DISCONNECT BRANCH FROM BUS 232004 TO BUS 232000 CKT 1
/*MILFORD STEELE 230 230
DISCONNECT BRANCH FROM BUS 232000 TO BUS 232005 CKT 1
/*STEELE VIENNA 230 230
END
```

Please refer to Index 1 for a table containing the generators having contribution to this flowgate.

### **Contribution to Previously Identified Overloads**

*(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)*

1. (DP&L - PECO) The CLAY\_230-LINWOOD 230 k V line (from bus 231000 to bus 213750 ckt 1) loads from 126.19% to 128.33% (AC power flow) of its emergency rating (804 MVA) for the line fault with failed breaker contingency outage of 'PECO\_P4\_LINWO225/\* \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK'. This project contributes approximately 22.42 MW to the thermal violation.

```
CONTINGENCY 'PECO_P4_LINWO225/* $ DELCO $ PECO_P4_LINWO225 $
STBK'
TRIP BRANCH FROM BUS 213750 TO BUS 231001 CKT 1          /* LINWOOD
230.00 EDGEMR5 230.00 $ DELCO $ PECO_P4_LINWO225 $ STBK
DISCONNECT BUS 213892                                     /* PHLISL87 230.00 $
DELCO $ PECO_P4_LINWO225 $ STBK
```



DISCONNECT BUS 213888 /\* PHLISCT1 18.00 \$ DELCO  
 \$ PECO\_P4\_LINWO225 \$ STBK  
 DISCONNECT BUS 213889 /\* PHLISCT2 18.00 \$ DELCO  
 \$ PECO\_P4\_LINWO225 \$ STBK  
 END/\* \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK

Please refer to Index 2 for a table containing the generators having contribution to this flowgate.

2. (DP&L - DP&L) The EDGEMR 5-CLAY\_230 230 kV line (from bus 231001 to bus 231000 ckt 1) loads from 122.14% to 124.1% (AC power flow) of its emergency rating (804 MVA) for the line fault with failed breaker contingency outage of 'PECO\_P4\_LINWO225/\* \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK'. This project contributes approximately 19.99 MW to the thermal violation.

CONTINGENCY 'PECO\_P4\_LINWO225/\* \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK'  
 TRIP BRANCH FROM BUS 213750 TO BUS 231001 CKT 1 /\* LINWOOD  
 230.00 EDGEMR5 230.00 \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK  
 DISCONNECT BUS 213892 /\* PHLISL87 230.00 \$  
 DELCO \$ PECO\_P4\_LINWO225 \$ STBK  
 DISCONNECT BUS 213888 /\* PHLISCT1 18.00 \$ DELCO  
 \$ PECO\_P4\_LINWO225 \$ STBK  
 DISCONNECT BUS 213889 /\* PHLISCT2 18.00 \$ DELCO  
 \$ PECO\_P4\_LINWO225 \$ STBK  
 END/\* \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK

Please refer to Index 3 for a table containing the generators having contribution to this flowgate.

### **Delivery of Energy Portion of Interconnection Request**

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Only the most severely overloaded conditions are listed. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed, which will study all overload conditions associated with the overloaded element(s) identified.

1. (PJM500 - PJM500) The PCHBTM1S-CNASTONE 500 kV line (from bus 200064 to bus 200004 ckt 1) loads from 98.17% to 100.17% (AC power flow) of its emergency rating (3525 MVA) for the single line contingency outage of 'PECO\_P1-2\_5007\_S/\* \$ CHESCO \$ PECO\_P1-2\_5007\_S \$ L'. This project contributes approximately 61.92 MW to the thermal violation.

CONTINGENCY 'PECO\_P1-2\_5007\_S/\* \$ CHESCO \$ PECO\_P1-2\_5007\_S \$ L'  
 TRIP BRANCH FROM BUS 200066 TO BUS 270072 CKT 1 /\*  
 PCHBTM1N 500.00 FUR RUN\_500 500.00 \$ CHESCO \$ PECO\_P1-2\_5007\_S \$ L  
 END/\* \$ CHESCO \$ PECO\_P1-2\_5007\_S \$ L

2. (PJM500 - PJM500) The PCHBTM1N-FUR RUN\_500 500 kV line (from bus 200066 to bus 270072 ckt 1) loads from 109.9% to 112.0% (AC power flow) of its emergency rating (2931 MVA) for the single line contingency outage of 'PECO\_P1-2\_5012/\* \$ CHESCO \$ PECO\_P1-2\_5012 \$ L'. This project contributes approximately 53.14 MW to the thermal violation.

CONTINGENCY 'PECO\_P1-2\_5012/\* \$ CHESCO \$ PECO\_P1-2\_5012 \$ L'  
 TRIP BRANCH FROM BUS 200064 TO BUS 200004 CKT 1 /\*  
 PCHBTM1S 500.00 CNASTONE 500.00 \$ CHESCO \$ PECO\_P1-2\_5012 \$ L  
 END/\* \$ CHESCO \$ PECO\_P1-2\_5012 \$ L

3. (PECO - PECO) The LINWOOD-POST 230 kV line (from bus 213750 to bus 214216 ckt 1) loads from 104.63% to 105.52% (AC power flow) of its emergency rating (1593 MVA) for the single line contingency outage of 'PECO\_P1-2\_220-43/\* \$ DELCO \$ PECO\_P1-2\_220-43 \$ L'. This project contributes approximately 23.13 MW to the thermal violation.

CONTINGENCY 'PECO\_P1-2\_220-43/\* \$ DELCO \$ PECO\_P1-2\_220-43 \$ L'  
 TRIP BRANCH FROM BUS 214221 TO BUS 213750 CKT 1 /\*  
 CHIREACT\_43 230.00 LINWOOD 230.00 \$ DELCO \$ PECO\_P1-2\_220-43 \$ L  
 END/\* \$ DELCO \$ PECO\_P1-2\_220-43 \$ L

4. (PECO - PECO) The LINWOOD-CHIREACT\_43 230 kV line (from bus 213750 to bus 214221 ckt 1) loads from 104.99% to 105.89% (AC power flow) of its emergency rating (1593 MVA) for the single line contingency outage of 'PECO\_P1-2\_220-97/\* \$ DELCO \$ PECO\_P1-2\_220-97 \$ L'. This project contributes approximately 23.34 MW to the thermal violation.

CONTINGENCY 'PECO\_P1-2\_220-97/\* \$ DELCO \$ PECO\_P1-2\_220-97 \$ L'  
 TRIP BRANCH FROM BUS 213750 TO BUS 214216 CKT 1 /\* LINWOOD  
 230.00 POST 230.00 \$ DELCO \$ PECO\_P1-2\_220-97 \$ L  
 END/\* \$ DELCO \$ PECO\_P1-2\_220-97 \$ L

5. (PECO - PECO) The POST-CHIREACT\_39 230 kV line (from bus 214216 to bus 214220 ckt 1) loads from 99.83% to 100.72% (AC power flow) of its emergency rating (1593 MVA) for the single line contingency outage of 'PECO\_P1-2\_220-43/\* \$ DELCO \$ PECO\_P1-2\_220-43 \$ L'. This project contributes approximately 23.13 MW to the thermal violation.

CONTINGENCY 'PECO\_P1-2\_220-43/\* \$ DELCO \$ PECO\_P1-2\_220-43 \$ L'  
 TRIP BRANCH FROM BUS 214221 TO BUS 213750 CKT 1 /\*  
 CHIREACT\_43 230.00 LINWOOD 230.00 \$ DELCO \$ PECO\_P1-2\_220-43 \$ L  
 END/\* \$ DELCO \$ PECO\_P1-2\_220-43 \$ L

6. (PECO - PECO) The CHIREACT\_39-CHICHST2 230 kV line (from bus 214220 to bus 213490 ckt 1) loads from 99.83% to 100.72% (AC power flow) of its emergency rating (1593 MVA) for the single line contingency outage of 'PECO\_P1-2\_220-43/\* \$ DELCO \$ PECO\_P1-2\_220-43 \$ L'. This project contributes approximately 23.13 MW to the thermal violation.

CONTINGENCY 'PECO\_P1-2\_220-43/\* \$ DELCO \$ PECO\_P1-2\_220-43 \$ L'  
 TRIP BRANCH FROM BUS 214221 TO BUS 213750 CKT 1 /\*  
 CHIREACT\_43 230.00 LINWOOD 230.00 \$ DELCO \$ PECO\_P1-2\_220-43 \$ L  
 END/\* \$ DELCO \$ PECO\_P1-2\_220-43 \$ L

7. (PECO - PECO) The CHIREACT\_43-CHICHST1 230 kV line (from bus 214221 to bus 213489 ckt 1) loads from 104.99% to 105.89% (AC power flow) of its emergency rating (1593 MVA) for the single line contingency outage of 'PECO\_P1-2\_220-97/\* \$ DELCO \$ PECO\_P1-2\_220-97 \$ L'. This project contributes approximately 23.34 MW to the thermal violation.

CONTINGENCY 'PECO\_P1-2\_220-97/\* \$ DELCO \$ PECO\_P1-2\_220-97 \$ L'  
 TRIP BRANCH FROM BUS 213750 TO BUS 214216 CKT 1 /\* LINWOOD  
 230.00 POST 230.00 \$ DELCO \$ PECO\_P1-2\_220-97 \$ L  
 END/\* \$ DELCO \$ PECO\_P1-2\_220-97 \$ L

8. (DP&L - PECO) The CLAY\_230-LINWOOD 230 kV line (from bus 231000 to bus 213750 ckt 1) loads from 115.04% to 117.37% (AC power flow) of its emergency rating (804 MVA) for the single line contingency outage of 'PECO\_P1-2\_220-85/\* \$ DELCO \$ 220-85 \$ LC'. This project contributes approximately 22.51 MW to the thermal violation.

CONTINGENCY 'PECO\_P1-2\_220-85/\* \$ DELCO \$ 220-85 \$ LC'  
 TRIP BRANCH FROM BUS 213750 TO BUS 231001 CKT 1 /\* LINWOOD  
 230.00 EDGEMR5 230.00 \$ DELCO \$ 220-85 \$ L  
 END/\* \$ DELCO \$ 220-85 \$ L

9. (DP&L - PECO) The EDGEMR 5-LINWOOD 230 kV line (from bus 231001 to bus 213750 ckt 1) loads from 113.39% to 115.71% (AC power flow) of its emergency rating (804 MVA) for the single line contingency outage of 'PECO\_P1-2\_220-84'. This project contributes approximately 21.78 MW to the thermal violation.

CONTINGENCY 'PECO\_P1-2\_220-84' /\* \$ DELCO \$ 220-84 \$  
 LB

TRIP BRANCH FROM BUS 213750 TO BUS 231000 CKT 1 /\* LINWOOD  
230.00 CLAY\_230 230.00 \$ DELCO \$ 220-84 \$ L  
END/\* \$ DELCO \$ 220-84 \$ L

10. (DP&L - DP&L) The EDGEMR 5-CLAY\_230 230 kV line (from bus 231001 to bus 231000 ckt 1) loads from 112.48% to 115.03% (AC power flow) of its emergency rating (804 MVA) for the single line contingency outage of 'PECO\_P1-2\_220-85/\* \$ DELCO \$ 220-85 \$ LC'. This project contributes approximately 20.06 MW to the thermal violation.

CONTINGENCY 'PECO\_P1-2\_220-85/\* \$ DELCO \$ 220-85 \$ LC'  
TRIP BRANCH FROM BUS 213750 TO BUS 231001 CKT 1 /\* LINWOOD  
230.00 EDGEMR5 230.00 \$ DELCO \$ 220-85 \$ L  
END/\* \$ DELCO \$ 220-85 \$ L

## Summer Peak Load Flow Analysis Reinforcements

Index	Facility	Upgrade Description	Cost	Cost Allocated to AE1-117	NUN
2,3	CLAY_230 230.0 kV - LINWOOD 230.0 kV Ckt 1 & EDGEMR 5 230.0 kV - CLAY_230 230.0 kV Ckt 1	<p><b>B2985:</b> Replace the 230 kV CB #225 at Linwood Substation (PECO) with a double circuit breaker (back to back circuit breakers in one device).</p> <p>Projected in service date 6/1/2022.</p> <p>Queue Project AE1-117 presently does not receive cost allocation for this upgrade.</p> <p>Cost: \$1,400,000</p> <p><b>N6926:</b> Increase the emergency rating of the Claymont - Linwood 230 kV line by rebuilding the line with new poles, foundations, insulators and OPGW and replacing terminal equipment at Claymont.</p> <p>Cost: \$7,100,000</p> <p>Queue Project AE1-117 presently does not receive cost allocation for this upgrade.</p> <p><b>N8078.3:</b> Upgrades to affected PECO facilities associated with N6926</p> <p><b>N6927:</b> Increase the emergency rating of the Edge Moor to Claymont 230 kV line by rebuilding the circuit. The rebuild will include the installation of new poles, foundations, insulators, and conductor. In addition, terminal equipment will need to be upgraded at Claymont and Edge Moor Substations.</p> <p>Cost: \$23,000,000</p> <p>Queue Project AE1-117 presently does not receive cost allocation for this upgrade.</p> <p><b>N8078.4:</b> Upgrades to affected PECO facilities associated with N6927</p> <p>Note 1: Although Queue Project AE1-117 may not have cost responsibility for these upgrades, Queue Project AE1-117 may need these upgrades in-service to be deliverable to the PJM system. If Queue Project AE1-117 comes into service prior to completion of the upgrades, Queue Project AE1-117 will need an interim study.</p>	\$31,500,000	\$0	B2985 N6926 N6927 N8078.3 N8078.4

Index	Facility	Upgrade Description	Cost	Cost Allocated to AE1-117	NUN																		
1	TODD 69.0 kV - PRESTON 69.0 kV Ckt 1	<p><b>N5788:</b> To mitigate the (DP&amp;L) TODD-PRESTON 69 kV line (from bus 232234 to bus 232233 ckt 1) overload will require substation reinforcements at Preston Substation and Todd Substation. Replace 600A Disconnect Switch at each substation.</p> <p>Cost: \$100,000</p> <p>Time Estimate: 12 months</p> <p>New Rating: Rate A: 95 Rate B: 130 Rate C: 130</p> <table border="1"> <thead> <tr> <th>Queue</th><th>MW</th><th>Cost %</th><th>Cost \$</th><th>Type</th><th>ContName</th></tr> </thead> <tbody> <tr> <td>AE1-087</td><td>7.65</td><td>38.77%</td><td>38,773</td><td>breaker</td><td>DPL_P4-2_DP11</td></tr> <tr> <td>AE1-117</td><td>12.08</td><td>61.23%</td><td>61,227</td><td>breaker</td><td>DPL_P4-2_DP11</td></tr> </tbody> </table>	Queue	MW	Cost %	Cost \$	Type	ContName	AE1-087	7.65	38.77%	38,773	breaker	DPL_P4-2_DP11	AE1-117	12.08	61.23%	61,227	breaker	DPL_P4-2_DP11	\$100,000	\$61,227	N5788
Queue	MW	Cost %	Cost \$	Type	ContName																		
AE1-087	7.65	38.77%	38,773	breaker	DPL_P4-2_DP11																		
AE1-117	12.08	61.23%	61,227	breaker	DPL_P4-2_DP11																		
<b>Total</b>			<b>\$31,600,000</b>	<b>\$61,227</b>																			

## Short Circuit

No issues identified.

## Stability Analysis


Please see Attachment 2 for results.

## Light Load Analysis - 2022

No Issues identified.

## Attachment 1 – Single Line Diagram

# AE1-117 Bethany 138 kV Bethany Substation



An Interconnection Customer circuit breaker will be required no more than 500 feet from the DPL substation.

**POI** Point of Interconnection

## Attachment 2 - Dynamic Simulation Analysis

### Executive Summary

Generator Interconnection Request AE1-117 is for a 152 MW Maximum Facility Output (MFO)<sup>1</sup> offshore wind generating facility, which consists of 19 Siemens Gamesa SWT42 DD 8MW wind turbines. The AE1-117 offshore wind generating facility will be located in Atlantic Ocean east of Sussex County, Delaware.

Project AE1-117 offshore wind generating facility will directly connect to the existing Bethany 138 kV substation in the Delmarva Power & Light Company (DPL) transmission system via approximately 0.01 miles 138 kV transmission cable. The Point of Interconnection (POI) will be where the Interconnection Customer gen-tie line terminates at a new line terminal in the Bethany substation.

This report describes a dynamic simulation analysis of AE1-117 as part of the overall system impact study. The load flow scenario for the analysis was based on the RTEP 2022 peak load case, modified to include applicable queue projects. AE1-117 has been dispatched online at maximum power output, with unity power factor and approximately 1.01 pu voltage at the generator terminals.

AE1-117 was tested for compliance with NERC, PJM, Transmission Owner, and other applicable criteria. 58 contingencies were studied, each with a 20 second simulation time period (with 1.0 second initial run prior to any events). Studied faults included:

- a) Steady state operation (Category P0);
- b) Three phase faults with normal clearing time on the intact network (Category P1);
- c) Single phase to ground faults with delayed clearing due to a stuck breaker (Category P4);
- d) Single phase faults placed at 80% of the line with delayed (Zone 2) clearing at line end remote from the fault due to primary communications/relay failure (Category P5).

For 58 fault contingencies tested on the 2022 peak load case:

- a) AE1-117 was able to ride through the faults (except for faults where protective action trips a generator(s)).
- b) Post-contingency oscillations were positively damped with a damping margin of at least 3%.
- c) Following fault clearing, all bus voltages recover to a minimum of 0.7 per unit after 2.5 seconds (except where protective action isolates that bus).
- d) No transmission element trips, other than those either directly connected or designed to trip as a consequence of that fault.

Please also note that the project AE1-117 meets the 0.95 leading and lagging reactive power requirement at the high side of facility main transformer.

---

<sup>1</sup> The MFO of the facility is 152 MW according to "Planning Center - Submission Admin - https://queuepoint-internalac2prod/pjmcom.pdf".



## **Introduction**

Generator Interconnection Request AE1-117 is for a 152 MW Maximum Facility Output (MFO)<sup>2</sup> offshore wind generating facility, which consists of 19 Siemens Gamesa SWT42 DD 8MW wind turbines. The AE1-117 offshore wind generating facility will be located in Atlantic Ocean east of Sussex County, Delaware.

Project AE1-117 offshore wind generating facility will directly connect to the existing Bethany 138 kV substation in the Delmarva Power & Light Company (DPL) transmission system via approximately 0.01 miles 138 kV transmission cable. The Point of Interconnection (POI) will be where the Interconnection Customer gen-tie line terminates at a new line terminal in the Bethany substation.

This analysis is effectively a screening study to determine whether the addition of AE1-117 will meet the dynamic requirements of the NERC, PJM, and Transmission Owner reliability standards.

In this report the AE1-117 project and how it is proposed to be connected to the grid are first described, followed by a description of how the project is modeled in this study. The fault cases are then described and analyzed, and lastly a discussion of the results is provided.

## **Description of Project**

Generator Interconnection Request AE1-117 is for a 152 MW Maximum Facility Output (MFO) offshore wind generating facility, which consists of 19 Siemens Gamesa SWT42 DD 8MW wind turbines. The AE1-117 offshore wind generating facility will be located in Atlantic Ocean east of Sussex County, Delaware.

Project AE1-117 offshore wind generating facility will directly connect to the existing Bethany 138 kV substation in the Delmarva Power & Light Company (DPL) transmission system via approximately 0.01 miles 138 kV transmission cable. The Point of Interconnection (POI) will be where the Interconnection Customer gen-tie line terminates at a new line terminal in the Bethany substation

The connection diagram of the AE1-117 offshore wind generating facility is shown in Figure 1. Table 1 lists the parameters given in the impact study data and the corresponding parameters of the AE1-117 loadflow model.

Additional project details are provided in Attachments 1 through 4:

- Attachment 1 contains the Impact Study Data which details the proposed AE1-117 project.
- Attachment 2 shows the one line diagram of the DPL network in the vicinity of AE1-117.
- Attachment 3 provides a diagram of the PSS/E model in the vicinity of AE1-117.
- Attachment 4 gives the PSS/E loadflow and dynamic models of the AE1-117.

---

<sup>2</sup> The MFO of the facility is 152 MW according to “Planning Center - Submission Admin - <https://queuepoint-internalac2prod.pjm.com.pdf>”.




Figure 1: AE1-117 Plant Model

**Table 1: AE1-117 Plant Model**

	<b>Impact Study Data</b>	<b>Model</b>
Wind Turbines	19X8 MW Siemens Gamesa SWT42 DD 8MW, 60 Hz  MVA base = N/A Vt = 0.69 kV Zsource = N/A  $P_{gen}^3 = 8.0$ MW $Q_{max}^4 = 4$ MVA $Q_{min} = -4$ MVA	1 x 152 MW generator  Pgen            152 MW Pmax            152 MW Pmin            0 MW Qgen            0.0 MVA Qmax            76MVA Qmin            -76 MVA Mbase <sup>5</sup> 169.10 MVA Zsorce           j1.0 @ Mbase
Wind Generator Step-up Transformers	19X 66/0.69 kV transformer  Rating = 8.9 MVA  Transformer base = 8.9 MVA  Impedance = $0.0099 + j0.0693$ pu @ MVA base  Number of taps = N/A Tap step size = N/A	1x 66/0.69 kV two winding transformer (DYng)  Rating = 169.1 MVA  Transformer base = 169.1 MVA  Impedance = $0.0099 + j0.0693$ pu @ MVA base  Number of taps = 5 Tap step size = 2.5 %
Main Transformer	1x 138/66 kV transformer  Rating = 200 MVA (ONAN)  Transformer base = 200 MVA  Impedance = $0.001667 + j0.069980$ pu @ MVA base  Number of taps = N/A Tap step size = N/A	1x 138/66 kV transformer (YngD)  Rating = 200 MVA  Transformer base = 200 MVA  Impedance = $0.001667 + j0.069980$ pu @ MVA base  Number of taps = 33 Tap step size = 0.625 %


<sup>3</sup> This information is from the document “Planning Center - Submission Admin - httpsqueuepoint-internalac2prodpjmcom\_.pdf” and its attachments.

<sup>4</sup> The Leading and lagging values are estimated based on “SWT42\_Model\_PQ-Capability\_SWT\_DD\_7.0\_8.0MW\_Ver\_01.pdf”.

<sup>5</sup> Machine base is from the PSSE model (AE1-117.raw) provided with the data package.

Collector System Equivalent (Offshore GL)	66 kV cable Rating = 177.2 MVA MVA base = 100 MVA Impedance = $0.001779 + j0.009519$ pu @ MVA base Charging susceptance = 0.202247 pu @ MVA base	66 kV cable Rating = 177.2 MVA MVA base = 100 MVA Impedance = $0.001779 + j0.009519$ pu @ MVA base Charging susceptance = 0.202247 pu @ MVA base
Collector System Equivalent (Offshore CL)	2X 66 kV offshore cable Rating = 88.6 MVA Length = 30 miles MVA base = 100 MVA Impedance = $0.024982 + j0.13371$ pu @ MVA base Charging susceptance = 0.2775 pu @ MVA base	2X 66 kV offshore cable Rating = 88.6 MVA Length = 30 miles MVA base = 100 MVA Impedance = $0.024982 + j0.13371$ pu @ MVA base Charging susceptance = 0.2775 pu @ MVA base
Collector System Equivalent (Onshore CL)	2X 66 kV onshore cable Rating = 98.3 MVA Length = 10 miles MVA base = 100 MVA Impedance = $0.008715 + j0.047067$ pu @ MVA base Charging susceptance = 0.09104 pu @ MVA base	2X 66 kV onshore cable Rating = 98.3 MVA Length = 10 miles MVA base = 100 MVA Impedance = $0.008715 + j0.047067$ pu @ MVA base Charging susceptance = 0.09104 pu @ MVA base
Transmission Cable	0.01 miles 138 kV transmission cable Rating = 0 MVA MVA base = 100 MVA Impedance = $0.0 + j0.0001$ pu @ MVA base Charging susceptance = 0.0 pu @ MVA base	0.01 miles 138 kV transmission cable Rating = 0 MVA MVA base = 100 MVA Impedance = $0.0 + j0.0001$ pu @ MVA base Charging susceptance = 0.0 pu @ MVA base

Auxiliary load <sup>6</sup>	Active power = 1.9 MW Reactive power = 1.425 MVAR	P = 1.90 MW Q = 1.425 MVAR Vt = 0.69 kV
Station Load	Active power = 0.0 MW Reactive power = 0.0 MVAR	Not modeled
Other	2X25 MVAR offshore fixed reactors 2X25 MVAR onshore switched reactors	2X25 MVAR fixed shunt reactors at high voltage side of GSU 2X25 MVAR switched shunt reactors at onshore 69 kV bus



**Figure 2: AE1-117 Single Line Diagram (PSS/E)**

### **Reactive Power Assessment**

AE1-117 was assessed for compliance with reactive power capability requirements using the supplied capability curves. Please note this is a new facility.

- Generation shall have the ability to maintain a power factor of at least 0.95 leading to 0.95 lagging at the high side of facility transformer or the result of the System Impact Study indicated that, for the safety and reliability of the Transmission System, no power factor requirement is required<sup>7, 8</sup>

Generator	MFO	Required pF Range		Maximum (Lagging)	Minimum (Leading)
		Lagging	Leading		
AE1-117	152	0.95	0.95		
Total MVAR Required				49.96	-49.96
MVAR from Generators				Qmax	Qmin
				76.0	-76.0
Customer Planned Compensation				0	-50.0
Qloss				7.91	7.91
Total Available MVAR at High Side of Facility Transformer				83.9	-118.1

<sup>6</sup> According to the document “Planning Center - Submission Admin - https://queuepoint-internalac2prod/pjmcom.pdf” and its attachments”, the auxiliary load and station load are connected at low voltage side of GSU

<sup>7</sup> As specified in the document “Reactive Power Requirements.doc”, Date: 6/15/2018.

<sup>8</sup> As specified in Attachment O of the document “PJM Open Access Transmission Tariff” Effective Date: 4/23/2018.

Deficiency in MVAR	Meet	Meet
--------------------	------	------

The offshore wind generating facility AE1-117 **meets** the reactive power requirement at the high side of facility transformer.

### **MFO Assessment**

The MFO of AE1-117 was also assessed and found that the MFO at POI is **lower** than the requested MFO.

	Active Power (MW)
Requested Gross MW	152
Requested MFO	152
Aux+SS	1.9
Losses	5.31
MFO at the POI	144.79
<b>Available MFO &lt;= Requested MFO</b>	<b>Yes</b>

The auxiliary load and station service load were switched off when performing the dynamic analysis to ensure the MFO at the POI is close enough to the requested MFO. After the station service load and the auxiliary load were switched off, the MFO at the POI increased from 144.79 MW to 146.69 MW which was close enough to meet MFO requirement.

### **Loadflow and Dynamics Case Setup**

The dynamics simulation analysis was carried out using PSS/E Version 33. The load flow scenario and fault cases for this study are based on DPL planning criteria<sup>9</sup>, PJM's Regional Transmission Planning Process<sup>10</sup> and discussions with PJM.

The selected load flow scenario is the RTEP 2022 peak load case with the following modifications:

- Addition of all applicable queue projects prior to AE1-117.
- Addition of AE1-117 queue project.
- Removal of withdrawn and subsequent queue projects in the vicinity of AE1-117.
- Dispatch of units in the PJM system in order to maintain slack generators within limits.

In the load flow the AE1-117 generator was set to maximum power output, with unity power factor and approximately 1.0 pu voltage at the generator bus.

<sup>9</sup> Exelon – Transmission Planning Criteria, <https://www.pjm.com/-/media/planning/planning-criteria/exelon-planning-criteria.ashx?la=en>.

<sup>10</sup> Manual 14B: PJM Region Transmission Planning Process, Rev 44, February 21, 2019, Attachment G: PJM Stability, Short Circuit, and Special RTEP Practices and Procedures.

Table 2: AE1-117 machine initial conditions

Bus	Name	Unit	PGEN (MW)	QGEN (MVar)	ETERM (pu)	POI Voltage (pu)
938895	AE1-117 GEN	1	152.00	0.47	1.01	1.02

Generation within the vicinity (within five buses) of AE1-117 has been dispatched online at maximum output (P<sub>MAX</sub>). The dispatch within the DPL area is given in Attachment 5.

### **Fault Cases**

The project was tested for compliance with NERC, DPL, PJM, and other applicable criteria. 58 contingencies were studied, each with a 20 second simulation time period (with 1.0 second initial run prior to any events). Contingencies to be studied include:

- Steady state operation (Category P0);
- Three phase faults with normal clearing time on the intact network (Category P1);
- Single phase to ground faults with delayed clearing due to a stuck breaker (Category P4);
- Single phase faults placed at 80% of the line with delayed (Zone 2) clearing at line end remote from the fault due to primary communications/relay failure (Category P5).

No High Speed Reclosing (HSR) contingencies were found in the vicinity of AE1-117<sup>11</sup>. No common tower events (Category P7) in the vicinity of AE1-117 were found to be studied.

Buses at which the faults listed above were applied are:

- AE1-117 POI 138 kV
- Bethany 138/69 kV
- Roxana 138 kV
- 138<sup>th</sup> Street 138 kV

Table 3 gives the details of typical fault clearing time<sup>12</sup> for 138 kV and 69 kV breakers at DPL.

Table 3: AE1-117 breaker details

TO	Circuit Breaker	Three Phase Fault Normal Clearing Time (cycles)	SLG Delayed Clearing Time due to Stuck Breaker (cycles)	SLG Delayed Clearing Time due to Primary Relay Failure (cycles)
DPL	138 kV	9	21	37
DPL	69 kV	9	22	42

<sup>11</sup> PJM\_HighSpeedReclosing\_List.xlsx

<sup>12</sup> Rev. 20 of "2017 Revised Clearing time for each PJM company\_Rev20.xls"

A complete list of the contingencies that were studied is given in Table 6 to Table 9.

### **Evaluation Criteria**

This study is focused on AE1-117, along with the rest of the PJM system, maintaining synchronism and having all states return to an acceptable new condition following the disturbance. The recovery criteria applicable to this study are as per PJM's Regional Transmission Planning Process and Transmission Owner criteria:

- a) AE1-117 is able to ride through the faults (except for faults where protective action trips the generator(s)),
- b) The system with AE1-117 included is transiently stable and post-contingency oscillations should be positively damped with a damping margin of at least 3%.
- c) Following fault clearing, all bus voltages recover to a minimum of 0.7 per unit after 2.5 seconds (except where protective action isolates that bus).
- d) No transmission element trips, other than those either directly connected or designed to trip as a consequence of that fault.

### **Summary of Results**

Plots from the dynamic simulations are provided in Attachment 6, with results summarized in Table 6 through Table 9.

For all 58 fault contingencies tested on the 2022 peak load case:

- a) AE1-117 was able to ride through the faults (except for faults where protective action trips a generator(s)).
- b) Post-contingency oscillations were positively damped with a damping margin of at least 3%.
- c) Following fault clearing, all bus voltages recover to a minimum of 0.7 per unit after 2.5 seconds (except where protective action isolates that bus).
- d) No transmission element trips, other than those either directly connected or designed to trip as a consequence of that fault.

No mitigation was found to be required.

**Table 4: Summary of Machine Tripped by Protective Action**

<b>Contingency</b>	<b>Time [s]</b>	<b>Unit</b>	<b>Bus</b>	<b>Protective Action</b>
None	-	-	-	-

Network non-convergence was also observed as summarized in Table 5.

**Table 5: Summary of Network Non-Convergence**

<b>Contingency</b>	<b>Time [s]</b>	<b>Unit</b>	<b>Bus</b>
P1.01*~P1.05*	1.0~1.1542	AE1-117 GEN	938895
P1.07*~P1.09*	1.1583	AE1-117 GEN	938895
P1.10*	1.0~1.2542	AE1-117 GEN	938895



<b>Contingency</b>	<b>Time [s]</b>	<b>Unit</b>	<b>Bus</b>
P1.11*	1.0~1.9209	AE1-117 GEN	938895
P1.12*	1.0~1.1750	AE1-117 GEN	938895
P1.13*	1.0, 1.1542~1.1958	AE1-117 GEN	938895
P1.14*	1.0, 1.1542~1.2667	AE1-117 GEN	938895
P1.15*	1.0, 1.1542~1.2042	AE1-117 GEN	938895
P1.16*	1.0, 1.1542~1.1833	AE1-117 GEN	938895
P1.17*	1.0, 1.1542~1.1917	AE1-117 GEN	938895
P4_1B1.01*	1.1542~1.3583	AE1-117 GEN	938895
P4_1B1.24*	1.3583~1.3708	AE1-117 GEN	938895
P4_1B1.25*	1.3583, 1.3625	AE1-117 GEN	938895
P5.01*	1.1542~1.3958	AE1-117 GEN	938895

\* Non-convergence during fault that should not be a problem if it recovers back after the fault is removed.

**Table 6: Steady State Operation – Category P0**

<b>Fault ID</b>	<b>Duration</b>	<b>AE1-117 No Mitigation</b>
P0_01	Steady state 20 sec	Stable

**Table 7: Three-phase Faults with Normal Clearing – Category P1**

<b>Fault ID</b>	<b>Fault description</b>	<b>Clearing Time &amp; Reclose (Cycles)</b>	<b>AE1-117 No Mitigation</b>
P1.01	3ph fault @ AE1-117 138 kV POI on AE1-117 circuit. Trips AE1-117	9	Stable
P1.02	3ph fault @ Bethany 138 kV on AE1-117 circuit, trips AE1-117	9	Stable
P1.03	3ph fault @ Bethany 138 kV on Roxana circuit 13739	9	Stable
P1.04	3ph fault @ Bethany 138 kV on 138th Street circuit 13732	9	Stable
P1.05	3ph fault @ Bethany 138 kV on 138/69 kV transformer AT1	9	Stable
P1.06	3ph fault @ Bethany 69kV on 138/69 kV transformer AT1	9	Stable
P1.07	3ph fault @ Bethany 69kV on Cedar Neck circuit 6740	9	Stable
P1.08	3ph fault @ Bethany 69kV on Dirickson	9	Stable
P1.09	3ph fault @ Bethany 69kV on 69/12 kV transformer T2	9	Stable
P1.10	3ph fault @ Roxana 138 kV on Bethany circuit 13739	9	Stable
P1.11	3ph fault @ Roxana 138 kV on Omar - Indian River circuit 13745	9	Stable
P1.12	3ph fault @ Roxana 138 kV on Bayard	9	Stable
P1.13	3ph fault @ 138th Street 138 kV on Bethany circuit 13732	9	Stable
P1.14	3ph fault @ 138th Street 138 kV on Ocean Bay circuit 13731	9	Stable
P1.15	3ph fault @ 138th Street 138 kV on 138/12 kV T1	9	Stable
P1.16	3ph fault @ 138th Street 138 kV on 138/12 kV T2	9	Stable
P1.17	3ph fault @ 138th Street 138 kV on 138/16 kV T3	9	Stable

**Table 8: Single-phase Faults with Stuck Breaker – Category P4**

<b>Fault ID</b>	<b>Fault description</b>	<b>Clearing Time Normal and Delayed (Cycles)</b>	<b>AE1-117 No Mitigation</b>
P4_1B1.01	SLG @ AE1-117 138 kV on Bethany circuit. Breaker stuck at AE1-117 POI. SLG @ AE1-117 138 kV due to breaker failure, fault cleared with loss of AE1-117	9/21	Stable
P4_1B1.02	SLG @ Bethany 138 kV on AE1-117 circuit. Breaker NEW stuck at Bethany. SLG @ Bethany 138 kV due to breaker failure, fault cleared with loss of AE1-117 and Roxana circuit 13739	9/21	Stable
P4_1B1.03	SLG @ Bethany 138 kV on AE1-117 circuit. Breaker 130 stuck at Bethany. SLG @ Bethany 138 kV due to breaker failure, fault cleared with loss of AE1-117 and Bethany 138/69 kV AT1	9/21	Stable
P4_1B1.04	SLG @ Bethany 138 kV on Roxana circuit 13739. Breaker NEW stuck at Bethany. SLG @ Bethany 138 kV due to breaker failure, fault cleared with loss of AE1-117	9/21	Stable
P4_1B1.05	SLG @ Bethany 138 kV on Roxana circuit 13739. Breaker 130 stuck at Bethany. SLG @ Bethany 138 kV due to breaker failure, fault cleared with loss of Bethany 138 kV capacitor banks	9/21	Stable
P4_1B1.06	SLG @ Bethany 138 kV on 138/12 kV TR#1. Breaker 133 stuck at Bethany. SLG @ Bethany 138 kV due to breaker failure, fault cleared with loss of Bethany 138 kV capacitor banks	9/21	Stable
P4_1B1.07	SLG @ Bethany 138 kV on 138/12 kV TR#1. Breaker 132 stuck at Bethany. SLG @ Bethany 138 kV due to breaker failure, fault cleared with loss of 138th Street circuit 13732	9/21	Stable
P4_1B1.08	SLG @ Bethany 138 kV on 138th Street circuit 13732. Breaker 132 stuck at Bethany. SLG @ Bethany 138 kV due to breaker failure, fault cleared with loss of Bethany 138/12 kV TR#1	9/21	Stable

<b>Fault ID</b>	<b>Fault description</b>	<b>Clearing Time Normal and Delayed (Cycles)</b>	<b>AE1-117 No Mitigation</b>
P4_1B1.09	SLG @ Bethany 138 kV on 138th Street circuit 13732. Breaker 134 stuck at Bethany. SLG @ Bethany 138 kV due to breaker failure, fault cleared with loss of Bethany 138/69 kV AT1	9/21	Stable
P4_1B1.10	SLG @ Bethany 138 kV on 138/69 kV AT1. Breaker 134 stuck at Bethany. SLG @ Bethany 138 kV due to breaker failure, fault cleared with loss of 138th Street circuit 13732	9/21	Stable
P4_1B1.11	SLG @ Bethany 138 kV on 138/69 kV AT1. Breaker 130 stuck at Bethany. SLG @ Bethany 138 kV due to breaker failure, fault cleared with loss of AE1-117 circuit	9/21	Stable
P4_1B1.12	SLG @ Bethany 69 kV on 138/69 kV AT1, Breaker 7560 stuck at Bethany. SLG @ Bethany 69 kV due to breaker failure, fault cleared with loss Dirickson circuit	9/22	Stable
P4_1B1.13	SLG @ Bethany 69 kV on 138/69 kV AT1, Breaker 7510 stuck at Bethany. SLG @ Bethany 69 kV due to breaker failure, fault cleared with loss Bethany 69/12 kV TR#2	9/22	Stable
P4_1B1.14	SLG @ Bethany 69 kV on Dirickson circuit, Breaker 7560 stuck at Bethany. SLG @ Bethany 69 kV due to breaker failure, fault cleared with loss Bethany 138/69 kV AT1	9/22	Stable
P4_1B1.15	SLG @ Bethany 69 kV on Dirickson circuit, Breaker 7530 stuck at Bethany. SLG @ Bethany 69 kV due to breaker failure, fault cleared with loss Cedar Neck circuit 6740	9/22	Stable
P4_1B1.16	SLG @ Bethany 69 kV on Cedar Neck circuit 6740, Breaker 7530 stuck at Bethany. SLG @ Bethany 69 kV due to breaker failure, fault cleared with loss Dirickson circuit	9/22	Stable
P4_1B1.17	SLG @ Bethany 69 kV on Cedar Neck circuit 6740, Breaker 7540 stuck at Bethany. SLG @ Bethany 69 kV due to breaker failure, fault cleared with no additional element loss	9/22	Stable

<b>Fault ID</b>	<b>Fault description</b>	<b>Clearing Time Normal and Delayed (Cycles)</b>	<b>AE1-117 No Mitigation</b>
P4_1B1.18	SLG @ Bethany 69 kV on 69/12 kV TR#2, Breaker 7510 stuck at Bethany. SLG @ Bethany 69 kV due to breaker failure, fault cleared with Bethany 138/69 kV AT1	9/22	Stable
P4_1B1.19	SLG @ Bethany 69 kV on 69/12 kV TR#2, Breaker 7550 stuck at Bethany. SLG @ Bethany 69 kV due to breaker failure, fault cleared with Bethany 69 kV capacitor banks	9/22	Stable
P4_1B1.20	SLG @ Roxana 138 kV on Bethany circuit 13739, Breaker 131 stuck at Roxana. SLG @ Roxana 138 kV due to breaker failure, fault cleared with loss Omar-Indian River circuit 13745	9/21	Stable
P4_1B1.21	SLG @ Roxana 138 kV on Bethany circuit 13739, Breaker 132 stuck at Roxana. SLG @ Roxana 138 kV due to breaker failure, fault cleared with loss Bayard circuit	9/21	Stable
P4_1B1.22	SLG @ Roxana 138 kV on Omar - Indian River circuit 13745, Breaker 131 stuck at Roxana. SLG @ Roxana 138 kV due to breaker failure, fault cleared with loss Bethany circuit 13739	9/21	Stable
P4_1B1.23	SLG @ Roxana 138 kV on Omar - Indian River circuit 13745, Breaker 130 stuck at Roxana. SLG @ Roxana 138 kV due to breaker failure, fault cleared with loss Bayard circuit	9/21	Stable
P4_1B1.24	SLG @ Roxana 138 kV on Bayard circuit, Breaker 130 stuck at Roxana. SLG @ Roxana 138 kV due to breaker failure, fault cleared with loss Omar - Indian River circuit 13745	9/21	Stable
P4_1B1.25	SLG @ Roxana 138 kV on Bayard circuit, Breaker 132 stuck at Roxana. SLG @ Roxana 138 kV due to breaker failure, fault cleared with loss Bethany circuit 13739	9/21	Stable
P4_1B1.26	SLG @ 138th Street 138 kV on Bethany circuit 13732, Breaker 130 stuck at 138th Street. SLG @ 138th Street 138 kV due to breaker failure, fault cleared with loss 138th Street 138/12 kV TR#1	9/21	Stable

<b>Fault ID</b>	<b>Fault description</b>	<b>Clearing Time Normal and Delayed (Cycles)</b>	<b>AE1-117 No Mitigation</b>
P4_1B1.27	SLG @ 138th Street 138 kV on 138th Street 138/12 kV TR#1, Breaker 130 stuck at 138th Street. SLG @ 138th Street 138 kV due to breaker failure, fault cleared with loss Bethany circuit 13732	9/21	Stable
P4_1B1.28	SLG @ 138th Street 138 kV on 138th Street 138/12 kV TR#1, Breaker 131 stuck at 138th Street. SLG @ 138th Street 138 kV due to breaker failure, fault cleared with loss Bethany circuit 13732, T3, T2, and Ocean Bay circuit 13731	9/21	Stable
P4_1B1.29	SLG @ 138th Street 138 kV on Ocean Bay circuit 13731, Breaker 132 stuck at 138th Street. SLG @ 138th Street 138 kV due to breaker failure, fault cleared with loss T3, T2	9/21	Stable

**Table 9: Single-phase Faults with Delayed (Zone 2) Clearing due to Primary Communication/Relay Failure – Category P5**

<b>Fault ID</b>	<b>Fault description</b>	<b>Clearing Time (Cycles)</b>	<b>AE1-117 No Mitigation</b>
P5.01	SLG @ 80% of 138 kV circuit from AE1-117 POI to Bethany	9/37	Stable
P5.02	SLG @ 80% of 138 kV circuit from Bethany to AE1-117	9/37	Stable
P5.03	SLG @ 80% of 138 kV circuit 13732 from Bethany to 138th Street	9/37	Stable
P5.04	SLG @ 80% of 138 kV circuit 13739 from Bethany to Roxana	9/37	Stable
P5.05	SLG @ 80% of 69 kV circuit 6740 from Bethany to Cedar Neck	9/42	Stable
P5.06	SLG @ 80% of 69 kV circuit 6735 from Bethany to Dirickson	9/42	Stable
P5.07	SLG @ 80% of 138 kV circuit 13739 from Roxana to Bethany	9/37	Stable
P5.08	SLG @ 80% of 138 kV circuit 13745 from Roxana to Omar - Indian River	9/37	Stable
P5.09	SLG @ 80% of 138 kV circuit from Roxana to Bayard	9/37	Stable
P5.10	SLG @ 80% of 138 kV circuit 13732 from 138th Street to Bethany	9/37	Stable
P5.11	SLG @ 80% of 138 kV circuit 13731 from 138th Street to Ocean Bay	9/37	Stable

## **Flow Gate Details**

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.



## Index 1

DP&L - DP&L) The TODD-PRESTON 69 kV line (from bus 232234 to bus 232233 ckt 1) loads from 100.0% to 110.88% (AC power flow) of its emergency rating (93 MVA) for the line fault with failed breaker contingency outage of 'DPL\_P4-2\_DP11'. This project contributes approximately 12.08 MW to the thermal violation.

CONTINGENCY 'DPL\_P4-2\_DP11' /\*STEELE BUS BREAKER TO MILFORD

DISCONNECT BRANCH FROM BUS 232004 TO BUS 232000 CKT 1 /\*MILFORD STEELE 230 230

DISCONNECT BRANCH FROM BUS 232000 TO BUS 232005 CKT 1 /\*STEELE VIENNA 230 230  
END

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
932161	AC2-023 C	4.39
932162	AC2-023 E	3.2
938651	AE1-087 C	6.12
938652	AE1-087 E	1.53
938891	AE1-117 C O1	3.3
938892	AE1-117 E O1	8.78
939151	AE1-145 C1	2.21
232905	BAYVIEW1	0.2
LTF	BLUEG	0.38
LTF	CALDERWOOD	0.04
LTF	CANNELTON	0.02
LTF	CARR	0.02
LTF	CATAWBA	0.03
LTF	CHEOAH	0.04
LTF	CHILHOWEE	0.01
LTF	COFFEEN	0.04
LTF	COTTONWOOD	0.16
232926	CRISFLD1	0.17
LTF	DUCKCREEK	0.09
LTF	EDWARDS	0.04
LTF	FARMERCITY	0.03
LTF	G-007	0.05
LTF	GIBSON	0.02
LTF	HAMLET	0.04
LTF	NEWTON	0.11
293670	O-025 C	0.11
LTF	O-066	0.34
232912	OH NUG1	0.5
232914	OH NUG3	0.5

232915	OH NUG4	0.5
232916	OH NUG5	0.5
LTF	PRAIRIE	0.2
LTF	RENSSELAER	0.02
LTF	SANTEETLA	0.01
LTF	SMITHLAND	0.02
232921	TASLEY2G	0.34
LTF	TATANKA	0.05
LTF	TILTON	0.05
LTF	TRIMBLE	0.04
LTF	TVA	0.13
LTF	UNIONPOWER	0.06
232919	VN10	0.31
232907	VN8	3.26
901003	W1-003 C	0.25
901004	W1-003 E	0.5
901013	W1-004 C	0.25
901014	W1-004 E	0.5
901023	W1-005 C	0.25
901024	W1-005 E	0.5
901033	W1-006 C	0.25
901034	W1-006 E	0.5
907052	X1-032 E	0.46
910571	X3-008 C	0.42
910572	X3-008 E	4.75
913411	Y1-080 C	0.05
913412	Y1-080 E	0.57
915541	Y3-058 C	0.13
915542	Y3-058 E	1.41
917081	Z2-012 C	0.12
917082	Z2-012 E	1.37
917432	Z2-076 E	0.18
917442	Z2-077 E	0.18
918831	AA1-102 C	0.99
918832	AA1-102 E	10.93
930202	AB1-056 E OI	13.54
924831	AB2-136 C	7.74
924832	AB2-136 E	8.21
925151	AB2-172 C	7.27
925152	AB2-172 E	11.86
925261	AB2-180 C	2.12
925262	AB2-180 E	0.91
927031	AC1-190 C	12.81
927032	AC1-190 E	5.49

## Index 2

(DP&L - PECO) The CLAY\_230-LINWOOD 230 kV line (from bus 231000 to bus 213750 ckt 1) loads from 126.19% to 128.33% (AC power flow) of its emergency rating (804 MVA) for the line fault with failed breaker contingency outage of 'PECO\_P4\_LINWO225/\* \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK'. This project contributes approximately 22.42 MW to the thermal violation.

CONTINGENCY 'PECO\_P4\_LINWO225/\* \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK'  
 TRIP BRANCH FROM BUS 213750 TO BUS 231001 CKT 1 /\* LINWOOD 230.00  
 EDGEMR5 230.00 \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK  
 DISCONNECT BUS 213892 /\* PHLISL87 230.00 \$ DELCO \$  
 PECO\_P4\_LINWO225 \$ STBK  
 DISCONNECT BUS 213888 /\* PHLISCT1 18.00 \$ DELCO \$  
 PECO\_P4\_LINWO225 \$ STBK  
 DISCONNECT BUS 213889 /\* PHLISCT2 18.00 \$ DELCO \$  
 PECO\_P4\_LINWO225 \$ STBK  
 END/\* \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
932161	AC2-023 C	4.03
932162	AC2-023 E	2.94
933631	AC2-185 C	2.01
933632	AC2-185 E	3.27
933641	AC2-186 C	2.77
933642	AC2-186 E	4.51
934681	AD1-097 3	-2.73
934691	AD1-097 4	-1.62
936452	AD2-059 E	0.18
936611	AD2-076 C O1	3.1
936612	AD2-076 E O1	5.06
938651	AE1-087 C	2.5
938652	AE1-087 E	0.63
938811	AE1-107 C	5.64
938812	AE1-107 E	4.02
938891	AE1-117 C O1	6.12
938892	AE1-117 E O1	16.3
939151	AE1-145 C1	3.01
LTF	BLUEG	0.38
LTF	CALDERWOOD	0.02
LTF	CANNELTON	0.02
LTF	CARR	0.61
LTF	CATAWBA	< 0.01
LTF	CHEOAH	0.02

<i>LTF</i>	<i>CHILHOWEE</i>	<i>&lt; 0.01</i>
<i>231708</i>	<i>CHRIST3</i>	<i>3.57</i>
<i>LTF</i>	<i>COFFEEN</i>	<i>0.04</i>
<i>LTF</i>	<i>COTTONWOOD</i>	<i>0.11</i>
<i>LTF</i>	<i>CPL</i>	<i>&lt; 0.01</i>
<i>LTF</i>	<i>DUCKCREEK</i>	<i>0.09</i>
<i>LTF</i>	<i>EDWARDS</i>	<i>0.04</i>
<i>231917</i>	<i>EM10</i>	<i>0.76</i>
<i>231916</i>	<i>EM3</i>	<i>4.56</i>
<i>231901</i>	<i>EM4</i>	<i>9.06</i>
<i>231900</i>	<i>EM5</i>	<i>32.42</i>
<i>LTF</i>	<i>FARMERCITY</i>	<i>0.02</i>
<i>LTF</i>	<i>G-007</i>	<i>2.21</i>
<i>LTF</i>	<i>GIBSON</i>	<i>0.02</i>
<i>231908</i>	<i>HR1</i>	<i>6.51</i>
<i>231909</i>	<i>HR2</i>	<i>6.63</i>
<i>231910</i>	<i>HR3</i>	<i>6.51</i>
<i>231505</i>	<i>HR4</i>	<i>13.33</i>
<i>LTF</i>	<i>NEWTON</i>	<i>0.1</i>
<i>LTF</i>	<i>O-066</i>	<i>14.44</i>
<i>LTF</i>	<i>PRAIRIE</i>	<i>0.18</i>
<i>LTF</i>	<i>RENSSELAER</i>	<i>0.49</i>
<i>LTF</i>	<i>SANTEETLA</i>	<i>&lt; 0.01</i>
<i>LTF</i>	<i>SMITHLAND</i>	<i>0.01</i>
<i>LTF</i>	<i>TATANKA</i>	<i>0.05</i>
<i>LTF</i>	<i>TILTON</i>	<i>0.05</i>
<i>LTF</i>	<i>TRIMBLE</i>	<i>0.04</i>
<i>LTF</i>	<i>TVA</i>	<i>0.09</i>
<i>LTF</i>	<i>UNIONPOWER</i>	<i>0.04</i>
<i>901004</i>	<i>W1-003 E</i>	<i>0.68</i>
<i>901014</i>	<i>W1-004 E</i>	<i>0.68</i>
<i>901024</i>	<i>W1-005 E</i>	<i>0.68</i>
<i>901034</i>	<i>W1-006 E</i>	<i>0.68</i>
<i>907052</i>	<i>X1-032 E</i>	<i>0.6</i>
<i>910572</i>	<i>X3-008 E</i>	<i>1.94</i>
<i>910822</i>	<i>X3-066 E</i>	<i>0.62</i>
<i>913362</i>	<i>Y1-079 E</i>	<i>1.02</i>
<i>913412</i>	<i>Y1-080 E</i>	<i>0.33</i>
<i>915542</i>	<i>Y3-058 E</i>	<i>1.41</i>
<i>917082</i>	<i>Z2-012 E</i>	<i>1.87</i>
<i>917432</i>	<i>Z2-076 E</i>	<i>0.3</i>
<i>917442</i>	<i>Z2-077 E</i>	<i>0.3</i>
<i>918832</i>	<i>AA1-102 E</i>	<i>14.06</i>
<i>919831</i>	<i>AA2-069</i>	<i>60.58</i>
<i>930202</i>	<i>AB1-056 E O1</i>	<i>26.98</i>

930921	AB1-141 C	2.26
930922	AB1-141 E	1.05
930931	AB1-142 C	2.26
930932	AB1-142 E	1.05
931262	AB1-176 E	0.93
923921	AB2-032 C	2.27
923922	AB2-032 E	1.07
923951	AB2-036 C	5.75
923952	AB2-036 E	9.41
923961	AB2-037 C	12.64
923962	AB2-037 E	20.65
924801	AB2-133 C O1	4.09
924802	AB2-133 E O1	5.18
924821	AB2-135 C	4.83
924822	AB2-135 E	5.5
924831	AB2-136 C	3.85
924832	AB2-136 E	4.08
924971	AB2-153 C	1.27
924972	AB2-153 E	2.07
925151	AB2-172 C	2.97
925152	AB2-172 E	4.84
925251	AB2-179 C	6.63
925252	AB2-179 E	2.19
925261	AB2-180 C	2.12
925262	AB2-180 E	0.91
926131	AC1-091 C	0.99
926132	AC1-091 E	1.62
926141	AC1-092 C	0.99
926142	AC1-092 E	1.62
926151	AC1-093 C	0.94
926152	AC1-093 E	1.54
926161	AC1-094 C	0.79
926162	AC1-094 E	1.31
927031	AC1-190 C	5.46
927032	AC1-190 E	2.34

### Index 3

(DP&L - DP&L) The EDGEMR 5-CLAY\_230 230 kV line (from bus 231001 to bus 231000 ckt 1) loads from 122.14% to 124.1% (AC power flow) of its emergency rating (804 MVA) for the line fault with failed breaker contingency outage of 'PECO\_P4\_LINWO225/\* \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK'. This project contributes approximately 19.99 MW to the thermal violation.

CONTINGENCY 'PECO\_P4\_LINWO225/\* \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK'  
 TRIP BRANCH FROM BUS 213750 TO BUS 231001 CKT 1 /\* LINWOOD 230.00  
 EDGEMR5 230.00 \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK  
 DISCONNECT BUS 213892 /\* PHLISL87 230.00 \$ DELCO \$  
 PECO\_P4\_LINWO225 \$ STBK  
 DISCONNECT BUS 213888 /\* PHLISCT1 18.00 \$ DELCO \$  
 PECO\_P4\_LINWO225 \$ STBK  
 DISCONNECT BUS 213889 /\* PHLISCT2 18.00 \$ DELCO \$  
 PECO\_P4\_LINWO225 \$ STBK  
 END/\* \$ DELCO \$ PECO\_P4\_LINWO225 \$ STBK

<i>Bus Number</i>	<i>Bus Name</i>	<i>Full Contribution</i>
932161	AC2-023 C	3.6
932162	AC2-023 E	2.62
933631	AC2-185 C	1.78
933632	AC2-185 E	2.91
933641	AC2-186 C	2.46
933642	AC2-186 E	4.01
934681	AD1-097 3	-2.44
934691	AD1-097 4	-1.44
936452	AD2-059 E	0.15
936611	AD2-076 C O1	2.71
936612	AD2-076 E O1	4.42
938651	AE1-087 C	2.23
938652	AE1-087 E	0.56
938811	AE1-107 C	4.71
938812	AE1-107 E	3.36
938891	AE1-117 C O1	5.46
938892	AE1-117 E O1	14.53
939151	AE1-145 C1	2.68
LTF	BLUEG	0.28
LTF	CALDERWOOD	0.01
LTF	CANNELTON	0.02
LTF	CARR	0.54
LTF	CBM-S2	0.01
LTF	CHEOAH	0.01
LTF	CHILHOWEE	< 0.01

231919	CHRIST1	0.83
231920	CHRIST2	0.82
231708	CHRIST3	2.72
LTF	COFFEEN	0.03
LTF	COTTONWOOD	0.07
LTF	CPL	0.02
LTF	DUCKCREEK	0.07
LTF	EDWARDS	0.03
231901	EM4	6.82
231900	EM5	32.36
LTF	FARMERCITY	0.02
LTF	G-007	1.96
LTF	GIBSON	0.01
231908	HR1	4.9
231910	HR3	4.9
231505	HR4	13.3
LTF	NEWTON	0.07
LTF	O-066	12.79
LTF	PRAIRIE	0.13
LTF	RENSSELAER	0.43
LTF	SANTEETLA	< 0.01
LTF	SMITHLAND	< 0.01
LTF	TATANKA	0.03
LTF	TILTON	0.04
LTF	TRIMBLE	0.03
LTF	TVA	0.06
LTF	UNIONPOWER	0.02
901004	W1-003 E	0.61
901014	W1-004 E	0.61
901024	W1-005 E	0.61
901034	W1-006 E	0.61
907052	X1-032 E	0.54
909411	X2-083	0.09
910572	X3-008 E	1.72
910822	X3-066 E	0.54
913362	Y1-079 E	0.9
913412	Y1-080 E	0.29
915542	Y3-058 E	1.26
917082	Z2-012 E	1.66
917432	Z2-076 E	0.27
917442	Z2-077 E	0.27
918832	AA1-102 E	12.54
919831	AA2-069	53.96
930202	AB1-056 E O1	24.05
930921	AB1-141 C	1.97

930922	<i>AB1-141 E</i>	<i>0.92</i>
930931	<i>AB1-142 C</i>	<i>1.97</i>
930932	<i>AB1-142 E</i>	<i>0.92</i>
931262	<i>AB1-176 E</i>	<i>0.81</i>
923921	<i>AB2-032 C</i>	<i>1.98</i>
923922	<i>AB2-032 E</i>	<i>0.93</i>
923951	<i>AB2-036 C</i>	<i>5.07</i>
923952	<i>AB2-036 E</i>	<i>8.3</i>
923961	<i>AB2-037 C</i>	<i>11.32</i>
923962	<i>AB2-037 E</i>	<i>18.5</i>
924801	<i>AB2-133 C OI</i>	<i>3.55</i>
924802	<i>AB2-133 E OI</i>	<i>4.51</i>
924821	<i>AB2-135 C</i>	<i>4.21</i>
924822	<i>AB2-135 E</i>	<i>4.8</i>
924831	<i>AB2-136 C</i>	<i>3.43</i>
924832	<i>AB2-136 E</i>	<i>3.64</i>
924971	<i>AB2-153 C</i>	<i>1.11</i>
924972	<i>AB2-153 E</i>	<i>1.81</i>
925151	<i>AB2-172 C</i>	<i>2.64</i>
925152	<i>AB2-172 E</i>	<i>4.31</i>
925251	<i>AB2-179 C</i>	<i>5.62</i>
925252	<i>AB2-179 E</i>	<i>1.85</i>
925261	<i>AB2-180 C</i>	<i>1.89</i>
925262	<i>AB2-180 E</i>	<i>0.81</i>
926131	<i>AC1-091 C</i>	<i>0.88</i>
926132	<i>AC1-091 E</i>	<i>1.44</i>
926141	<i>AC1-092 C</i>	<i>0.88</i>
926142	<i>AC1-092 E</i>	<i>1.44</i>
926151	<i>AC1-093 C</i>	<i>0.83</i>
926152	<i>AC1-093 E</i>	<i>1.37</i>
926161	<i>AC1-094 C</i>	<i>0.7</i>
926162	<i>AC1-094 E</i>	<i>1.16</i>
927031	<i>AC1-190 C</i>	<i>4.86</i>
927032	<i>AC1-190 E</i>	<i>2.08</i>