



**Generation Interconnection
System Impact Study Report
for
Queue Project AE1-147
BELLEFONTE 46 KV
12 MW Capacity / 20 MW Energy**

August, 2019

Table of Contents

1	Introduction.....	4
2	Preface.....	4
3	General	5
3.1	Point of Interconnection	6
3.2	Cost Summary.....	6
4	Transmission Owner Scope of Work	7
4.1	Attachment Facilities.....	7
4.2	Direct Connection Cost Estimate.....	7
4.3	Non-Direct Connection Cost Estimate.....	7
5	Schedule.....	8
6	Transmission Owner Analysis.....	9
7	Interconnection Customer Requirements.....	10
7.1	System Protection.....	10
7.2	Compliance Issues and Interconnection Customer Requirements	10
7.3	Power Factor Requirements.....	11
8	Revenue Metering and SCADA Requirements	12
8.1	PJM Requirements	12
8.1.1	Meteorological Data Reporting Requirement.....	12
8.2	FE Requirements	12
9	Network Impacts	13
10	Generation Deliverability	15
11	Multiple Facility Contingency	15
12	Contribution to Previously Identified Overloads	15
13	Potential Congestion due to Local Energy Deliverability.....	15
14	System Reinforcements:	16
15	Affected Systems	18
15.1	LG&E.....	18
15.2	MISO	18
15.3	TVA.....	18
15.4	Duke Energy Progress.....	18
15.5	NYISO	18

16	Short Circuit.....	20
17	Stability Analysis.....	22
18	Light Load Analysis.....	24
19	Attachment 1- One Line.....	25
20	Attachment 2: Site Plan	26

1 Introduction

This System Impact Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 205, as well as the System Impact Study Agreement between **Keystone State Renewables, LLC**, the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is West Penn Power (WPP)- Part of Allegheny Power System (APS).

2 Preface

The intent of the System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the System Impact Study is performed.

The System Impact Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

3 General

Keystone State Renewables, LLC (Interconnection Customer) has proposed a new solar generating facility located in Centre County, Pennsylvania. The installed facilities will have a total capability of 20 MW with 12 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is December 31, 2021. **This study does not imply a West Penn Power Company (Transmission Owner or WPP) commitment to this in-service date.**

Queue Number	AE1-147
Project Name	BELLEFONTE 46 KV
Interconnection Customer	Keystone State Renewables, LLC
State	Pennsylvania
County	Centre
Transmission Owner	APS
MFO	20
MWE	20
MWC	12
Fuel	Solar
Basecase Study Year	2022

3.1 Point of Interconnection

The interconnection of the project will be accomplished by tapping the Bellefonte – Milesburg #2 46 kV line and constructing a one span tap. The transmission line tap will be located approximately 1.5 miles from Brush Junction. The IC will be responsible for acquiring all easements, properties, and permits that may be required to construct both the new interconnection line tap and the associated attachment facilities.

Attachment 1 shows a one-line diagram of the proposed primary Direct Connection facilities for the AE1-147 generation project to connect to the FirstEnergy (“FE”) transmission system. Attachment 2 provides the proposed location for the point of interconnection. The IC will be responsible for constructing the facilities on its side of the POI.

3.2 Cost Summary

The AE1-147 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$34,000
Direct Connection Network Upgrade	\$0
Non Direct Connection Network Upgrades	\$16,000
New System Upgrades	\$0
Contribution to Previously Identified Upgrades	\$0
Total Costs	\$50,000

The costs provided above exclude the Contribution in Aid of Construction (“CIAC”) Federal Income Tax Gross Up charge. If, at a future date, it is determined that the CIAC Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

The required Attachment Facilities and Direct and Non-Direct Connection work for the interconnection of the AE1-147 generation project to the FE Transmission System is detailed in the following sections. The associated one-line with the generation project Attachment Facilities and the Primary Direct and Non-Direct Connection facilities are shown in Attachment 1.

4 Transmission Owner Scope of Work

4.1 Attachment Facilities

The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Construct one span of 46 kV line to customer's substation and install one 46 kV switch.	\$8,000
Install 46 kV meter package.	\$26,000
Total Direct Connection Facility Costs	\$34,000

4.2 Direct Connection Cost Estimate

There is no Direct Connection work required for this project.

4.3 Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
<ul style="list-style-type: none">Install 46 kV tap structure and two 46 kV switches at the tap point.	\$16,000
Total Direct Connection Facility Costs	\$16,000

5 Schedule

Based on the scope of work for the Attachment Facilities and the Direct and/or Non-Direct Connection facilities, it is expected to take a minimum of **12 months** after the signing of an Interconnection Construction Service Agreement to complete the installation. This includes the requirement for the IC to make a preliminary payment that compensates FE for the first three months of the engineering design work that is related to the construction of the Attachment Facilities. Full initial deposit is required for the Non-Direct Connection work. This assumes that there will be no environmental issues with any of the new properties associated with this project, that there will be no delays in acquiring the necessary permits for implementing the defined interconnection work, and that all transmission system outages will be allowed when requested.

6 Transmission Owner Analysis

FE performed an analysis of its underlying transmission <100 kV system. The AE1-147 project did not contribute to any overloads on the FE transmission <100 kV system.

7 Interconnection Customer Requirements

7.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in FE's "Requirements for Transmission Connected Facilities" document located at:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>.

Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

The IC's GSU transformers shall be designed with a delta winding on the high (utility) side. Transformer with other configurations must be studied by FE to determine if they would be acceptable for installation on the FE transmission system. Furthermore, other transformer winding configurations may result in additional upgrades to the transmission system.

7.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with FE's "Requirements for Transmission Connected Facilities" document located at: <http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated 46 kV circuit breaker to protect the AE1-147 generator lead line. A single circuit breaker must be used to protect this line; if the project has several GSU transformers, the individual GSU transformer breakers cannot be used to protect this line.
2. The purchase and installation of the minimum required FE generation interconnection relaying and control facilities. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition ("SCADA") equipment to provide information in a compatible format to the FE Transmission System Control Center.
4. Compliance with the FE and PJM generator power factor and voltage control requirements.
5. The execution of a back-up service agreement to serve the customer load supplied from the AE1-147 generation project metering point when the units are out-of-service. This assumes the intent of the IC is to net the generation with the load.

The IC will also be required to meet all PJM, ReliabilityFirst, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and ReliabilityFirst audits.

Failure to comply with these requirements may result in a disconnection of service if the violation is found to compromise the reliability of the FE system.

7.3 Power Factor Requirements

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the FE transmission system.

8 Revenue Metering and SCADA Requirements

8.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

8.1.1 Meteorological Data Reporting Requirement

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Temperature (degrees Fahrenheit)
- Atmospheric pressure (hectopascals)
- Irradiance
- Forced outage data

8.2 FE Requirements

Interconnection Customer will be required to comply with all FirstEnergy revenue metering requirements for generation interconnection customers. The FirstEnergy revenue metering requirements may be found in the FirstEnergy "Requirements for Transmission Connected Facilities" document located at the following link:

<http://www.pjm.com/planning/design-engineering/to-tech-standards/private-firstenergy.aspx>

9 Network Impacts

The Queue Project AE1-147 was evaluated as a 20.0 MW (Capacity 12.0 MW) injection at the National Gypsum to Bush Junction 46 kV line in the APS (WPP) area. Project AE1-147 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE1-147 was studied with a commercial probability of 100%. Potential network impacts were as follows:

Summer Peak Load Flow

10 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

11 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

12 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

13 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

14 System Reinforcements:

None

Affected Systems

15 Affected Systems

15.1 LG&E

None.

15.2 MISO

None.

15.3 TVA

None.

15.4 Duke Energy Progress

None.

15.5 NYISO

None.

Short Circuit

16 Short Circuit

The following Breakers are overduty:

None

Stability

17 Stability Analysis


To be finalized in the Facilities Study phase.

Light Load

18 Light Load Analysis

No violations.

19 Attachment 1- One Line



20 Attachment 2: Site Plan

