



**Generation Interconnection
System Impact Study Report
for
Queue Project AE1-227
SOUTH CUMBERLAND 69 KV
30.69 MW Capacity / 49.5 MW Energy**

November 2019

Table of Contents

Preface 4

General..... 5

Point of Interconnection..... 6

Cost Summary..... 6

Transmission Owner Scope of Work..... 7

 Attachment Facilities 7

 Direct Connection Cost Estimate..... 7

 Non-Direct Connection Cost Estimate 7

Incremental Capacity Transfer Rights (ICTRs)..... 8

Schedule 8

Interconnection Customer Requirements 8

Revenue Metering and SCADA Requirements..... 9

 PJM Requirements..... 9

 AEP Requirements 9

Network Impacts.....10

 Generation Deliverability.....12

 Multiple Facility Contingency.....12

 Contribution to Previously Identified Overloads12

 Potential Congestion due to Local Energy Deliverability12

 Light Load Analysis.....12

 Steady-State Voltage Requirements12

 Stability and Reactive Power Requirements for Low Voltage Ride Through.....12

 System Reinforcements12

 Affected Systems.....13

 LG&E14

 MISO14

 TVA14

 Duke Energy Progress14

 NYISO.....14

 Short Circuit.....16

Figure 1: AE1-227 Point of Interconnection (South Cumberland 69 kV) Single-Line Diagram17

Figure 2: AE1-227 Point of Interconnection (South Cumberland 69 kV)18

Preface

The intent of the System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances, a generator interconnection may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection, may also contribute to the need for the same network reinforcement. Cost allocation rules for network upgrades can be found in PJM Manual 14A, Attachment B. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Interconnection Customer seeking to interconnect a wind generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

PJM utilizes manufacturer models to ensure the performance of turbines is properly captured during the simulations performed for stability verification and, where applicable, for compliance with low voltage ride through requirements. Turbine manufacturers provide such models to their customers. The list of manufacturer models PJM has already validated is contained in Attachment B of Manual 14G. Manufacturer models may be updated from time to time, for various reasons such as to reflect changes to the control systems or to more accurately represent the capabilities turbines and controls which are currently available in the field. Additionally, as new turbine models are developed, turbine manufacturers provide such new models which must be used in the conduct of these studies. PJM needs adequate time to evaluate the new models in order to reduce delays to the System Impact Study process timeline for the Interconnection Customer as well as other Interconnection Customers in the study group. Therefore, PJM will require that any Interconnection Customer with a new manufacturer model must supply that model to PJM, along with a \$10,000 fully refundable deposit, no later than three (3) months prior to the starting date of the System Impact Study (See Section 4.3 for starting dates) for the Interconnection Request which shall specify the use of the new model. The Interconnection Customer will be required to submit a completed dynamic model study request form (Attachment B-1 of Manual 14G) in order to document the request for the study.

General

BQ Energy, LLC, has proposed to install PJM project # AE1-227, a Solar generating facility located in Guernsey County, Ohio (See Figure 2). The installed facilities will have a total capability of 49.5 MW with 30.69 MW of this output being recognized by PJM as Capacity. The Point of Interconnection will be a direct connection to the South Cumberland 69 kV substation (See Figure 1).

The proposed in-service date for this project is September 30, 2021. This study does not imply a TO commitment to this in-service date.

The objective of this System Impact Study is to determine budgetary cost estimates and approximate construction timelines for identified transmission facilities required to connect the proposed generating facilities to the AEP transmission system. These reinforcements include the Attachment Facilities, Local Upgrades, and Network Upgrades required for maintaining the reliability of the AEP transmission system.

Queue Number	AE1-227
Project Name	SOUTH CUMBERLAND 69 KV
Interconnection Customer	BQ Energy, LLC.
State	Ohio
County	Guernsey
Transmission Owner	AEP
MFO	49.5
MWE	49.5
MWC	30.69
Fuel	Solar
Basecase Study Year	2022

Point of Interconnection

AE1-227 will interconnect with the AEP transmission system at the South Cumberland 69 kV substation.

To accommodate the interconnection at the South Cumberland 69 kV substation, the substation will have to be expanded requiring the installation of one (1) 69 kV circuit breaker (see Figure 1). Installation of associated protection and control equipment, 69 kV line risers, SCADA, and 69 kV revenue metering will also be required. AEP reserves the right to specify the final acceptable configuration considering design practices, future expansion, and compliance requirements.

Note: The Interconnection Customer may be required to go offline for routine circuit breaker maintenance.

Cost Summary

The AE1-227 project will be responsible for the following costs:

Description	Total Cost
Attachment Facilities	\$200,000
Direct Connection Network Upgrade	\$800,000
Non Direct Connection Network Upgrades	\$200,000
Allocation for New System Upgrades	\$0
Contribution for Previously Identified Upgrades	\$0
Total Costs	\$1,200,000

The estimates are preliminary in nature, as they were determined without the benefit of detailed engineering studies. Final estimates will require an on-site review and coordination to determine final construction requirements.

Transmission Owner Scope of Work

Attachment Facilities

The total preliminary cost estimate for the Attachment work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
69 kV Revenue Metering	\$200,000
Total Attachment Facility Costs	\$200,000

Direct Connection Cost Estimate

The total preliminary cost estimate for the Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Expand South Cumberland 69 kV Substation	\$800,000
Total Direct Connection Facility Costs	\$800,000

Non-Direct Connection Cost Estimate

The total preliminary cost estimate for the Non-Direct Connection work is given in the table below. These costs do not include CIAC Tax Gross-up.

Description	Total Cost
Upgrade line protection and controls at the South Cumberland 69 kV substation.	\$200,000
Total Non-Direct Connection Facility Costs	\$200,000

Incremental Capacity Transfer Rights (ICTRs)

None

Schedule

It is anticipated that the time between receipt of executed Agreements and Commercial Operation may range from 12 to 18 months if no line work is required. If line work is required, construction time would generally be between 24 to 36 months after signing Agreement execution.

Interconnection Customer Requirements

It is understood that BQ Energy is responsible for all costs associated with this interconnection. The costs above are reimbursable to AEP. The cost of BQ Energy's generating plant and the costs for the line connecting the generating plant to the South Cumberland 69 kV substation are not included in this report; these are assumed to be BQ Energy's responsibility.

The Generation Interconnection Agreement does not in or by itself establish a requirement for American Electric Power to provide power for consumption at the developer's facilities. A separate agreement may be reached with the local utility that provides service in the area to ensure that infrastructure is in place to meet this demand and proper metering equipment is installed. It is the responsibility of the developer to contact the local service provider to determine if a local service agreement is required.

Requirement from the PJM Open Access Transmission Tariff:

1. An Interconnection Customer entering the New Services Queue on or after October 1, 2012 with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.
2. The Interconnection Customer may be required to install and/or pay for metering as necessary to properly track real time output of the facility as well as installing metering which shall be used for billing purposes. See Section 8 of Appendix 2 to the Interconnection Service Agreement as well as Section 4 of PJM Manual 14D for additional information.

Revenue Metering and SCADA Requirements

PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

AEP Requirements

The Interconnection Customer will be required to comply with all AEP Revenue Metering Requirements for Generation Interconnection Customers. The Revenue Metering Requirements may be found within the "Requirements for Connection of New Facilities or Changes to Existing Facilities Connected to the AEP Transmission System" document located at the following link:

<http://www.pjm.com/~media/planning/plan-standards/private-aep/aep-interconnection-requirements.ashx>

Network Impacts

The Queue Project AE1-227 was evaluated as a 49.5 MW (Capacity 30.7 MW) injection into the S Cumberland 69 kV substation in the AEP area. Project AE1-227 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE1-227 was studied with a commercial probability of 1.00. Potential network impacts were as follows:

Summer Peak Load Flow

Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

Light Load Analysis

Not required

Steady-State Voltage Requirements

(Summary of the VAR requirements based upon the results of the steady-state voltage studies)

To be evaluated during the Facilities Study Phase

Stability and Reactive Power Requirements for Low Voltage Ride Through

(Summary of the VAR requirements based upon the results of the dynamic studies)

To be evaluated during the Facilities Study Phase

System Reinforcements

None

Affected Systems

LG&E

None

MISO

MISO Impacts to be evaluated during the Facilities Study Phase

TVA

None

Duke Energy Progress

None

NYISO

None

Short Circuit

Short Circuit

The following Breakers are over duty

None

© PJM Interconnection 2019. All rights reserved



Figure 2: AE1-227 Point of Interconnection (South Cumberland 69 kV)

