



**Generation Interconnection
Impact Study Report
for
Queue Project AE2-227
IRON BRIDGE 34 KV
12 MW Capacity / 20 MW Energy**

February, 2020

Table of Contents

| | | |
|-------|---|----|
| 1 | Introduction..... | 4 |
| 2 | Preface..... | 4 |
| 3 | General | 4 |
| 3.1 | Point of Interconnection | 5 |
| 3.2 | Cost Summary..... | 5 |
| 4 | Transmission Owner Scope of Work | 5 |
| 5 | Transmission Owner Analysis..... | 6 |
| 5.1 | Power Flow Analysis | 6 |
| 5.2 | Short Circuit Analysis | 7 |
| 5.3 | Stability Analysis | 7 |
| 6 | Interconnection Customer Requirements..... | 7 |
| 6.1 | System Protection..... | 7 |
| 6.2 | Compliance Issues and Interconnection Customer Requirements | 7 |
| 6.3 | Power Factor Requirements..... | 8 |
| 7 | Revenue Metering and SCADA Requirements | 8 |
| 7.1 | PJM Requirements | 8 |
| 7.1.1 | Meteorological Data Reporting Requirement..... | 8 |
| 7.2 | Dominion Requirements..... | 8 |
| 8 | Network Impacts | 8 |
| 9 | Generation Deliverability | 10 |
| 10 | Multiple Facility Contingency | 10 |
| 11 | Contribution to Previously Identified Overloads | 10 |
| 12 | Potential Congestion due to Local Energy Deliverability..... | 10 |
| 13 | System Reinforcements..... | 11 |
| 14 | Flow Gate Details | 11 |
| 14.1 | Contingency Descriptions..... | 11 |
| 14.2 | Index 1 | 13 |
| 14.3 | Queue Dependencies | 17 |
| 15 | Affected Systems | 20 |
| 15.1 | Duke Energy Progress..... | 20 |
| 16 | Short Circuit..... | 22 |

Attachment 1.....23

1 Introduction

This System Impact Study (SIS) has been prepared in accordance with the PJM Open Access Transmission Tariff, 205, as well as the Impact Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is Virginia Electric and Power Company (VEPCO).

2 Preface

The intent of the System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the System Impact Study is performed.

The System Impact Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

3 General

The Interconnection Customer (IC) has proposed a solar generating facility located in Chesterfield County, Virginia. The installed facilities will have a total capability of 20 MW with 12 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is 10/31/2022. This study does not imply a Transmission Owner (TO) commitment to this in-service date.

Attachment facilities and local upgrades (if required) along with terms and conditions to interconnect AE2-227 will be specified in a separate two party Interconnection Agreement (IA) between ITO and the IC as this project is considered FERC non-jurisdictional per the PJM Open Access Transmission Tariff (OATT).

| | |
|---------------------------------|-------------------------------|
| Queue Number | AE2-227 |
| Project Name | IRON BRIDGE 34 KV |
| Interconnection Customer | TCE Virginia Development, LLC |
| State | Virginia |
| County | Chesterfield |
| Transmission Owner | Dominion |
| MFO | 20 |
| MWE | 20 |
| MWC | 12 |
| Fuel | Solar |
| Basecase Study Year | 2022 |

3.1 Point of Interconnection

AE2-227 will interconnect with the Dominion distribution system at the Iron Bridge 34kV substation.

3.2 Cost Summary

The AE2-227 project will be responsible for the following costs:

| Description | Total Cost |
|---|-------------------------|
| Attachment Facilities | \$ To be provided in IA |
| Direct Connection Network Upgrade | \$ To be provided in IA |
| Non Direct Connection Network Upgrades | \$ To be provided in IA |
| Total Costs | \$ To be provided in IA |

In addition, the AE2-227 project may be responsible for a contribution to the following costs

| Description | Total Cost |
|------------------------|-------------------|
| System Upgrades | \$ 0 |

4 Transmission Owner Scope of Work

Attachment facilities and local upgrades (if required) along with terms and conditions to interconnect AE2-227 will be specified in a separate two party Interconnection Agreement (IA) between ITO and the IC as this project is considered FERC non-jurisdictional per the PJM Open Access Transmission Tariff (OATT). From the transmission system perspective, no network reinforcements are required as shown in the Network Impact Section below. The single line is shown below in Attachment 1.

Dominion assessed the impact of the proposed Queue Project AE2-227 was evaluated as a 12.0 MW Capacity (20.0 MW Energy) injection at the Iron Bridge 34.5 kV substation bus in the Dominion Transmission System, for compliance with NERC Reliability Criteria on Dominion Transmission System. The system was assessed

using the summer 2022 AE2 case provided to Dominion by PJM. When performing a generation analysis, Dominion's main analysis will be load flow study results under single contingency (both normal and stressed system conditions). Dominion Criteria considers a transmission facility overloaded if it exceeds 94% of its emergency rating under normal and stressed system conditions. A full listing of Dominion's Planning Criteria and interconnection requirements can be found in the Company's Facility Connection Requirements which are publicly available at: <http://www.dominionenergy.com>.

The results of these studies evaluate the system under a limited set of operating conditions and do not guarantee the full delivery of the capacity and associated energy of this proposed generation facility under all operating conditions. NERC Planning and Operating Reliability Criteria allow for the re-dispatch of generating units to resolve projected and actual deficiencies in real time and planning studies. Specifically in Planning Studies NERC Category C Contingency Conditions (Bus Fault, Tower Line, N-1-1, and Stuck Breaker scenarios) allow for re-dispatch of generating units to resolve potential reliability deficiencies. For Dominion Planning Criteria the re-dispatch of generating units for these contingency conditions is allowed as long as the projected loading does not exceed 100% of a facility Load Dump Rating.

The required Attachment Facilities, Direct Connection and Non-Direct Connection work for the interconnection of the AE2-227 generation project to the Dominion Transmission System is detailed in the following sections. The associated one-line with the generation project attachment facilities and primary direct and non-direct connection are shown in Attachment 1.

Note that the ITO findings were made from a conceptual review of this project. A more detailed review of the connection facilities and their cost will be identified in a future study phases. Further note that the cost estimate data contained in this document should be considered high level estimates since it was produced without a detailed engineering review. The applicant will be responsible for the actual cost of construction. ITO herein reserves the right to return to any issues in this document and, upon appropriate justification, request additional monies to complete any reinforcements to the transmission systems.

5 Transmission Owner Analysis

5.1 Power Flow Analysis

PJM performed a power flow analysis of the transmission system using a 2022 summer peak load flow model and the results were verified by Dominion. Additionally, Dominion performed an analysis of its transmission system. The AE2-227 project contributes to overloads on the Dominion transmission system as shown in the "Network Impact" section of the report. The estimated cost of system reinforcements necessary to mitigate these overloads is also provided.

5.2 Short Circuit Analysis

PJM performed a short circuit analysis and the results were verified by Dominion. The connection of AE2-227 project to the system does not result in any newly overdutied circuit breakers on the Dominion transmission system and does not have a significant fault current contribution to existing overdutied circuit breakers

5.3 Stability Analysis

No transmission system stability analysis was required for this project.

6 Interconnection Customer Requirements

6.1 System Protection

The IC must design its Customer Facilities in accordance with all applicable standards, including the standards in Dominion's "Dominion Energy Electric Transmission Generator Interconnection Requirements" documented in Dominion's Facility Interconnection Requirements "Exhibit C" located at:

<https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. Preliminary Protection requirements will be provided as part of the Facilities Study. Detailed Protection Requirements will be provided once the project enters the construction phase.

6.2 Compliance Issues and Interconnection Customer Requirements

The proposed Customer Facilities must be designed in accordance with Dominion's "Dominion's Facility Interconnection Requirements" document located at: <https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>. In particular, the IC is responsible for the following:

1. The purchase and installation of a fully rated protection device (circuit breaker, circuit switcher, fuse) to protect the IC's GSU transformer(s).
2. The purchase and installation of the minimum required Dominion generation interconnection relaying and control facilities as described in the System Protection noted above. This includes over/under voltage protection, over/under frequency protection, and zero sequence voltage protection relays.
3. The purchase and installation of supervisory control and data acquisition ("SCADA") equipment to provide information in a compatible format to the Dominion Transmission System Control Center.
4. Compliance with the Dominion and PJM generator power factor and voltage control requirements.

The GSU(s) associated with the IC queue request shall meet the grounding requirements as noted in Dominion's "Dominion's Facility Interconnection Requirements" document located at:

<https://www.dominionenergy.com/company/moving-energy/electric-transmission-access>.

The IC will also be required to meet all PJM, SERC, and NERC reliability criteria and operating procedures for standards compliance. For example, the IC will need to properly locate and report the over and under voltage and over and under frequency system protection elements for its units as well as the submission of the generator model and protection data required to satisfy the PJM and SERC audits. Failure to comply with these requirements

may result in a disconnection of service if the violation is found to compromise the reliability of the Dominion system.

6.3 Power Factor Requirements

The IC shall design its non-synchronous Customer Facility with the ability to maintain a power factor of at least 0.95 leading (absorbing VARs) to 0.95 lagging (supplying VARs) measured at the high-side of the facility substation transformer(s) connected to the Dominion transmission system.

7 Revenue Metering and SCADA Requirements

7.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

7.1.1 Meteorological Data Reporting Requirement

The solar generation facility shall provide the Transmission Provider with site-specific meteorological data including:

- Temperature (degrees Fahrenheit)
- Atmospheric pressure (hectopascals)
- Irradiance
- Forced outage data

7.2 Dominion Requirements

See Section 3.4.6 “Metering and Telecommunications” of Dominion’s “Dominion’s Facility Interconnection Requirements” document located at: <https://www.dominionenergy.com/company/moving-energy/electrictransmission-access>.

8 Network Impacts

The Queue Project AE2-227 was evaluated as a 20.0 MW (Capacity 12.0 MW) injection at the Iron Bridge 34 kV substation in the Dominion area. Project AE2-227 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AE2-227 was studied with a commercial probability of 100%. Potential network impacts were as follows:

Summer Peak Load Flow

9 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

| ID | FROM BUS# | FROM BUS | kV | FROM BUS AREA | TO BUS# | TO BUS | kV | TO BUS AREA | CK T ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADIN G % | POST PROJECT LOADIN G % | AC/D C | MW IMPACT |
|----------|-----------|----------|-------|---------------|---------|---------|-------|-------------|---------|------------------|--------|------------|------------------------|-------------------------|--------|-----------|
| 18167102 | 314218 | 6ELMONT | 230.0 | DVP | 314908 | 8ELMONT | 500.0 | DVP | 1 | DVP_P1-2: LN 557 | single | 920.92 | 99.77 | 100.0 | AC | 2.1 |

10 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

11 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

12 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

| ID | FROM BUS# | FROM BUS | kV | FROM BUS AREA | TO BUS# | TO BUS | kV | TO BUS AREA | CK T ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADIN G % | POST PROJECT LOADIN G % | AC/D C | MW IMPACT |
|----------|-----------|----------|-------|---------------|---------|----------|-------|-------------|---------|-----------------------------|-----------|------------|------------------------|-------------------------|--------|-----------|
| 39796469 | 314309 | 6IRON208 | 230.0 | DVP | 314338 | 6SOUWEST | 230.0 | DVP | 1 | 314903(8CHCKAHM)-314908()_1 | operation | 663.64 | 132.58 | 134.02 | AC | 9.37 |

13 System Reinforcements

| ID | Index | Facility | Upgrade Description | Cost | Cost Allocated to AE1-252 | NUN |
|----------|-------|--|--|--------------|---------------------------|-------|
| 18167102 | 1 | 6ELMONT 230.0 kV - 8ELMONT 500 kV Ckt 1 | <p>To resolve the Elmont 500/230 kV overload:</p> <p>n6127: Elmont 500 – 230 kV Tx#1: replace the 500-230 kV transformer #1 increase its line rating to 1134 MVA (normal), 1203 MVA (emergency), and 1365 MVA (load dump).</p> <p>Project Type : CON</p> <p>Cost : \$22 million</p> <p>Time Estimate : 24-30 months</p> <p>Queue Project AE2-227 presently does not receive cost allocation for this upgrade.</p> <p>Note 1: as changes to the interconnection process occur, such as prior queued projects withdrawing from the queue, reducing in size, etc, Queue Project AE2-227 could receive cost allocation.</p> <p>Note 2: Although Queue Project AE2-227 may not have cost responsibility for this upgrade, Queue Project AE2-227 may need this upgrade in-service to be deliverable to the PJM system. If Queue Project AE2-227 comes into service prior to completion of the upgrade, Queue Project AE2-227 will need an interim study.</p> | \$22,000,000 | \$0 | n6127 |
| | | | Total Cost: | \$22,000,000 | \$0 | |

14 Flow Gate Details

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact. It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

14.1 Contingency Descriptions

| Contingency Name | Contingency Definition |
|------------------|---|
| DVP_P1-2: LN 557 | <p>CONTINGENCY 'DVP_P1-2: LN 557'</p> <p>OPEN BRANCH FROM BUS 314214 TO BUS 314903 CKT 1 /* 6CHCKAHM 230.00 - 8CHCKAHM 500.00</p> <p>OPEN BRANCH FROM BUS 314903 TO BUS 314908 CKT 1 /* 8CHCKAHM 500.00 - 8ELMONT 500.00</p> <p>END</p> |

| Contingency Name | Contingency Definition |
|-----------------------------|---|
| 314903(8CHCKAHM)-314908()_1 | CONTINGENCY '314903(8CHCKAHM)-314908()_1' OPEN BRANCH FROM BUS 314903 TO BUS 314908 CKT 1 END |

14.2 Index 1

| ID | FROM BUS# | FROM BUS | FROM BUS AREA | TO BUS# | TO BUS | TO BUS AREA | CKT ID | CONT NAME | Type | Rating MVA | PRE PROJECT LOADING % | POST PROJECT LOADING % | AC DC | MW IMPACT |
|----------|-----------|----------|---------------|---------|---------|-------------|--------|------------------|--------|------------|-----------------------|------------------------|-------|-----------|
| 18167102 | 314218 | 6ELMONT | DVP | 314908 | 8ELMONT | DVP | 1 | DVP_P1-2: LN 557 | single | 920.92 | 99.77 | 100.0 | AC | 2.1 |

| Bus # | Bus | MW Impact |
|--------|-----------------------------------|-----------|
| 314229 | 6MT RD221 | 0.1199 |
| 314236 | 6NRTHEST | 0.1589 |
| 314243 | 3PROV 92 | 0.2918 |
| 314250 | 6ROCKVILLE | 0.2697 |
| 314309 | 6IRON208 | 0.3461 |
| 315043 | 1FOUR RIVERA | 2.9688 |
| 315044 | 1FOUR RIVERB | 2.2998 |
| 315045 | 1FOUR RIVERC | 2.9688 |
| 315046 | 1FOUR RIVERD | 2.2998 |
| 315047 | 1FOUR RIVERE | 2.2998 |
| 315048 | 1FOUR RIVERF | 2.9663 |
| 315050 | 1FOURRIVERG | 3.7284 |
| 315053 | 1BELMED1 (Deativation : 04/16/18) | 16.2723 |
| 315054 | 1BELMED2 (Deativation : 04/16/18) | 16.2723 |
| 315055 | 1BELMED3 (Deativation : 04/16/18) | 13.5058 |
| 315058 | 1CHESTF3 (Deativation : 12/13/18) | 17.2790 |
| 315059 | 1CHESTF4 (Deativation : 12/13/18) | 28.0093 |
| 315060 | 1CHESTF5 | 7.4886 |
| 315061 | 1CHESTG7 | 2.9350 |
| 315062 | 1CHESTS7 | 1.3341 |
| 315063 | 1CHESTG8 | 2.8794 |
| 315064 | 1CHESTS8 | 1.4830 |
| 315065 | 1CHESTF6 | 14.5913 |
| 315067 | 1DARBY 1 | 2.1513 |
| 315068 | 1DARBY 2 | 2.1538 |
| 315069 | 1DARBY 3 | 2.1614 |
| 315070 | 1DARBY 4 | 2.1639 |
| 315074 | 1HOPCGN1 (Deativation : 06/25/19) | 6.1303 |
| 315075 | 1HOPCGN2 (Deativation : 06/25/19) | 6.0509 |
| 315077 | 1HOPHCF1 | 1.7122 |
| 315078 | 1HOPHCF2 | 1.7122 |
| 315079 | 1HOPHCF3 | 1.7122 |
| 315080 | 1HOPHCF4 | 2.5993 |
| 315083 | 1SPRUNCA (Deativation : 01/12/19) | 9.5161 |
| 315084 | 1SPRUNCB (Deativation : 01/12/19) | 9.5161 |
| 315090 | 1YORKTN1 (Deativation : 09/09/18) | 16.7829 |
| 315091 | 1YORKTN2 (Deativation : 09/09/18) | 17.4162 |
| 919211 | AA1-145 | 8.5832 |
| 923831 | AB2-022 C | 1.1412 |
| 924061 | AB2-050 | 0.5049 |
| 924241 | AB2-068 O1 | 96.4791 |

| Bus # | Bus | MW Impact |
|--------|--------------|-----------|
| 925051 | AB2-160 C O1 | 3.8752 |
| 925061 | AB2-161 C O1 | 1.9635 |
| 925331 | AB2-190 C | 13.4441 |
| 925811 | AC1-060 | 0.0529 |
| 925861 | AC1-065 C | 2.3718 |
| 926291 | AC1-107 O1 | 145.6288 |
| 926411 | AC1-112 C | 0.2923 |
| 926551 | AC1-134 | 1.2622 |
| 926661 | AC1-147 C | 1.1536 |
| 926751 | AC1-161 C O1 | 14.7202 |
| 926781 | AC1-164 C | 37.3130 |
| 927041 | AC1-191 C O1 | 11.2177 |
| 927221 | AC1-216 C O1 | 6.4756 |
| 930121 | AB1-027 C | 0.3754 |
| 932041 | AC2-012 C | 5.2185 |
| 932501 | AC2-070 C | 1.8629 |
| 932581 | AC2-078 C O1 | 2.5700 |
| 932591 | AC2-079 C O1 | 3.1507 |
| 932831 | AC2-110 C | 0.9487 |
| 933061 | AC2-130 | 0.2927 |
| 933261 | AC2-137 C | 2.0168 |
| 933271 | AC2-138 C | 0.4714 |
| 933291 | AC2-141 C | 14.7202 |
| 933731 | AC2-196 C | 0.8989 |
| 934011 | AD1-025 C | 11.1313 |
| 934061 | AD1-033 C | 3.7799 |
| 934141 | AD1-041 C | 3.6799 |
| 934571 | AD1-082 C | 4.4748 |
| 934781 | AD1-105 C | 7.3674 |
| 935111 | AD1-144 C | 0.9106 |
| 935161 | AD1-151 C O1 | 10.8033 |
| 935211 | AD1-156 C | 1.3794 |
| 936041 | AD2-007 | 1.1817 |
| 936051 | AD2-008 C | 1.9379 |
| 936151 | AD2-021 | 0.2300 |
| 936301 | AD2-039 C | 0.9487 |
| 936341 | AD2-044 C | 0.1473 |
| 936581 | AD2-073 C | 1.2168 |
| 936591 | AD2-074 C | 3.4653 |
| 936661 | AD2-085 C | 1.8970 |
| 936761 | AD2-097 C | 1.8048 |
| 937221 | AD2-160 C O1 | 2.9294 |
| 937251 | AD2-164 | 2.7867 |
| 937541 | AD2-215 C | 0.9200 |
| 938031 | AE1-004 C | 0.9487 |
| 938181 | AE1-027 C | 1.1749 |
| 938191 | AE1-028 C | 0.6816 |
| 938531 | AE1-072 C O1 | 8.7590 |
| 938551 | AE1-074 C | 1.6981 |
| 938631 | AE1-085 C O1 | 5.5781 |
| 938771 | AE1-103 C O1 | 1.7991 |
| 939191 | AE1-149 C O1 | 6.8774 |

| Bus # | Bus | MW Impact |
|--------|--------------|-----------|
| 939241 | AE1-155 C | 7.9447 |
| 939281 | AE1-159 C O1 | 6.5840 |
| 939311 | AE1-162 C | 1.2184 |
| 939421 | AE1-174 C | 0.2359 |
| 939431 | AE1-175 C | 1.5689 |
| 939611 | AE1-191 C | 7.3598 |
| 939751 | AE1-206 C O1 | 34.6737 |
| 940061 | AE1-248 C O1 | 9.3009 |
| 940071 | AE1-249 C | 5.1117 |
| 940231 | AE2-005 C | 0.9487 |
| 940251 | AE2-007 O1 | 88.3404 |
| 940431 | AE2-027 C O1 | 11.4422 |
| 940481 | AE2-033 C | 8.3260 |
| 940541 | AE2-040 O1 | 1.6747 |
| 940551 | AE2-041 | 5.0463 |
| 940651 | AE2-052 | 2.2924 |
| 940891 | AE2-078 C | 1.4181 |
| 940901 | AE2-079 C | 1.4181 |
| 940911 | AE2-080 C | 1.4181 |
| 941101 | AE2-104 C O1 | 1.8003 |
| 941141 | AE2-108 C | 1.3622 |
| 941151 | AE2-109 C | 0.4768 |
| 941281 | AE2-122 C O1 | 14.3966 |
| 941291 | AE2-123 C O1 | 14.7952 |
| 941301 | AE2-124 C O1 | 13.4392 |
| 941501 | AE2-147 C | 7.8129 |
| 941531 | AE2-150 | 0.1116 |
| 941581 | AE2-155 C | 0.7087 |
| 941591 | AE2-156 O1 | 9.1469 |
| 941601 | AE2-157 C | 6.3857 |
| 942001 | AE2-212 C | 1.5425 |
| 942131 | AE2-225 C | 1.0800 |
| 942151 | AE2-227 C | 2.1048 |
| 942161 | AE2-228 C | 1.9150 |
| 942171 | AE2-229 C | 0.8100 |
| 942191 | AE2-231 C O1 | 2.9187 |
| 942341 | AE2-247 C | 0.8222 |
| 942371 | AE2-250 C O1 | 6.8836 |
| 942401 | AE2-253 C | 3.0812 |
| 942471 | AE2-260 C O1 | 7.0738 |
| 942551 | AE2-270 S C | 10.6802 |
| 942552 | AE2-270 B C | 7.1201 |
| 942851 | AE2-304 C | 0.3083 |
| LGEE | LGEE | 0.0506 |
| CIN | CIN | 0.1715 |
| CPLE | CPLE | 3.0667 |
| IPL | IPL | 0.0646 |
| CBM-W2 | CBM-W2 | 15.1148 |
| CBM-W1 | CBM-W1 | 0.0811 |
| WEC | WEC | 0.0419 |
| CBM-S2 | CBM-S2 | 5.4628 |
| CARR | CARR | 0.4866 |

| Bus # | Bus | MW Impact |
|-------------------|------------|------------------|
| CBM-S1 | CBM-S1 | 2.7177 |
| AA2-074 | AA2-074 | 2.0862 |
| MEC | MEC | 1.3075 |
| RENSSELAER | RENSSELAER | 0.3849 |

14.3 Queue Dependencies

| Queue Number | Project Name | Status |
|--------------|------------------------------------|-----------------------------|
| AE2-079 | Poolesville 34.5 kV | Active |
| AE2-124 | Landstown 230 kV | Active |
| AE1-072 | Shawboro-Sligo 230 kV | Active |
| AE2-250 | Purdy Sw.-Reams 115 kV | Active |
| AE2-007 | Chesapeake 230 kV | Active |
| AE1-103 | Holland-Union Camp 115 kV | Active |
| AE1-149 | Disputanta-Poe 115 kV | Active |
| AE2-033 | Clubhouse-Sappony 230 kV | Active |
| AE2-155 | Old Church 34.5 kV | Active |
| AE2-122 | Birdneck-Landstown 230 kV | Active |
| AB2-161 | Waverly #2 DP 115kV | Engineering and Procurement |
| AC2-141 | Septa 500kV | Active |
| AC1-134 | Four Rivers 230kV | In Service |
| AD1-144 | Kings Fork 34.5 kV | Engineering and Procurement |
| AE2-027 | Harrowgate-Locks 115kV | Active |
| AE1-085 | Bakers Pond-Bell Ave 115 kV | Active |
| AE2-229 | Suffolk 34 kV | Active |
| AE1-248 | Bell Avenue 115 kV | Active |
| AB1-027 | Old Church 34.5 KV | Under Construction |
| AC1-164 | Chickahominy 230kV | Active |
| AC1-107 | Chickahominy 500kV | Engineering and Procurement |
| AD1-025 | Hopewell-Surry 230 kV | Active |
| AD2-039 | Harmony Village-Shackleford 115 kV | Engineering and Procurement |
| AD2-085 | Myrtle-Windsor DP 115kV | Active |
| AD2-044 | Northern Neck 34.5 kV | Engineering and Procurement |
| AC2-078 | Disputanta-Waverly 115kV | Active |
| AE1-028 | Hickory 34.5 kV | Engineering and Procurement |
| AC2-012 | Grassfield-Great Bridge 115kV | Active |
| AE2-123 | Birdneck-Landstown 230 kV | Active |
| AC1-065 | Harmony Village-Shackleford 115kV | Engineering and Procurement |
| AD2-160 | Hickory-Moyock 230kV | Active |
| AE1-159 | Fredericksburg-Pinewood 115 kV | Active |
| AC2-079 | Ivor-Oakridge 115kV | Active |
| AD1-082 | Bakers Pond-Ivor 115kV | Active |
| AB2-050 | Four Rivers 230kV | In Service |
| AE2-156 | Yadkin 115 kV | Active |
| AE2-304 | South Hertford 34 kV | Engineering and Procurement |
| AD1-156 | Poe 34.5 kV | Engineering and Procurement |
| AB2-160 | Reams 115kV | Engineering and Procurement |
| AE2-005 | Harmony Village-Shackleford 115 kV | Active |
| AE2-104 | Suffolk 115 kV | Active |
| AC2-130 | Chesterfield 230kV 5 | In Service |
| AE2-078 | Poolesville 34.5 kV | Active |
| AE1-174 | Light Foot 34.5 kV | Active |
| AD2-215 | Kings Fork 34.5 kV | Engineering and Procurement |
| AC1-216 | Hopewell-Surry 230kV | Active |
| AE2-040 | Sapony 34.5 kV | Active |
| AB2-022 | Elizabeth City 34.5kV | Engineering and Procurement |
| AE1-074 | Winterpock 34.5 kV | Engineering and Procurement |

| Queue Number | Project Name | Status |
|--------------|------------------------------------|-----------------------------|
| AE1-191 | Harmony Village-Shackleford 115 kV | Active |
| AD2-074 | Garner DP-Lancaster 115 kV | Active |
| AD2-164 | Peninsula 34.5kV | Engineering and Procurement |
| AE2-247 | Myrtle-Windsor 115 kV | Active |
| AB2-068 | Chickahominy 500kV | Suspended |
| AE2-270 | Hopewell-Surry 230 kV | Active |
| AD2-007 | Hopewell-Surry 230 kV | Active |
| AC2-138 | Northern Neck 34.5kV | Engineering and Procurement |
| AE2-225 | Suffolk 34 kV | Active |
| AD1-041 | Harmony Village-Shackleford 115 kV | Active |
| AC1-060 | Providence Forge 34.5kV | In Service |
| AE1-206 | Four Rivers-Hanover 230 kV | Active |
| AD2-008 | Hopewell-Surry 230 kV | Active |
| AD1-033 | Fentress-Landstown 230 kV | Active |
| AE1-155 | Garner-Northern Neck 115 kV | Active |
| AE2-052 | Disputanta-Poe 115 kV | Active |
| AE1-027 | Hickory 34.5 kV | Engineering and Procurement |
| AC1-191 | Elmont 115kV | Active |
| AE1-004 | Harmony Village-Shackleford 115 kV | Active |
| AC2-196 | Fentress 34.5kV | Engineering and Procurement |
| AE2-212 | Harrowgate 34 kV | Active |
| AC1-112 | Old Church 34.5kV | In Service |
| AE2-260 | Clubhouse 230 kV | Active |
| AE2-253 | Hickory-Moyock 230 kV | Active |
| AC1-161 | Septa 500kV | Active |
| AD1-105 | Kings Dominion DP 115 kV | Active |
| AE1-249 | Reams 115 kV | Active |
| AD1-151 | Hopewell-Surry 230 kV | Active |
| AB2-190 | Hopewell-Surry 230kV | Engineering and Procurement |
| AE1-162 | Smithfield 34.5 kV | Engineering and Procurement |
| AE2-147 | Swamp 230 kV | Active |
| AE2-231 | St. Johns 115 kV | Active |
| AE2-041 | Harmony Village 230 kV | Active |
| AE2-108 | Kings Dominion DP 115kV | Active |
| AD2-021 | Elko 34.5 kV | Engineering and Procurement |
| AD2-073 | Sanders DP 230 kV | Active |
| AE2-227 | Iron Bridge 34 kV | Active |
| AE2-157 | Wakefield-Waverly 115 kV | Active |
| AE2-109 | Kings Dominion DP 115 kV | Active |
| AD2-097 | Spruance NUG 230kV | Engineering and Procurement |
| AC2-110 | Harmony Village-Shackleford 115kV | Engineering and Procurement |
| AE2-080 | Poolesville 34.5 kV | Active |
| AE2-270 | Hopewell-Surry 230 kV | Active |
| AA1-145 | Four Rivers 230kV | In Service |
| AC1-147 | Grassfield 34.5kV | Engineering and Procurement |
| AC2-070 | Old Church 34.5kV | Engineering and Procurement |
| AA2-074 | CPL-PJM | Confirmed |
| AE2-150 | Bakers Pond-Bell Ave 115 kV | Active |
| AC2-137 | Elko 34.5kV | Engineering and Procurement |
| AE1-175 | Light Foot 34.5 kV | Active |
| AE2-228 | Tyler 34 kV | Active |

Affected Systems

15 Affected Systems

15.1 Duke Energy Progress

No Duke Energy Progress impacts were identified as part of this study.

Short Circuit

16 Short Circuit

The following Breakers are overdutied:

None

Attachment 1

System Configuration

