



**Generation Interconnection
System Impact Study Report
for
Queue Project AF2-305
BROKAW-LANESVILLE 345 KV
9.2 MW Capacity / 0 MW Energy**

Revision 1: January 2022

Revision 0: February 2021

Table of Contents

1	Introduction.....	3
2	Preface.....	3
3	Revision History.....	3
4	General.....	4
5	Point of Interconnection.....	4
6	Cost Summary	4
7	Transmission Owner Scope of Work.....	5
8	Schedule.....	5
9	Interconnection Customer Requirements.....	5
10	Revenue Metering and SCADA Requirements	5
10.1	PJM Requirements	5
10.2	Interconnected Transmission Owner Requirements.....	6
11	Summer Peak Analysis	6
11.1	Generation Deliverability	6
11.2	Multiple Facility Contingency	6
11.3	Contribution to Previously Identified Overloads.....	6
11.4	Steady-State Voltage Requirements.....	6
11.5	Potential Congestion due to Local Energy Deliverability.....	6
11.6	System Reinforcements.....	7
12	Short Circuit Analysis.....	7
13	Stability and Reactive Power	7
14	Affected Systems	7
14.1	MISO	7
	Attachment 1: One Line Diagram.....	8

1 Introduction

This System Impact Study has been prepared in accordance with the PJM Open Access Transmission Tariff, 205, as well as the System Impact Study Agreement between the Interconnection Customer (IC), and PJM Interconnection, LLC (PJM), Transmission Provider (TP). The Interconnected Transmission Owner (ITO) is ComEd.

2 Preface

The intent of the System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on PJM web site) for the appropriate transmission owner.

In some instances an Interconnection Customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the System Impact Study is performed.

The System Impact Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

The Interconnection Customer seeking to interconnect a wind or solar generation facility shall maintain meteorological data facilities as well as provide that meteorological data which is required per Schedule H to the Interconnection Service Agreement and Section 8 of Manual 14D.

An Interconnection Customer with a proposed new Customer Facility that has a Maximum Facility Output equal to or greater than 100 MW shall install and maintain, at its expense, phasor measurement units (PMUs). See Section 8.5.3 of Appendix 2 to the Interconnection Service Agreement as well as section 4.3 of PJM Manual 14D for additional information.

3 Revision History

This January 2022 revisions updates the stability analysis and MISO Affected System Study sections of the report. Stability Analysis is not required for this project. There are no MISO impacts.

4 General

The Interconnection Customer (IC) has proposed a 9.2 MW Capacity only (0 MW energy) upgrade to prior queue project AB2-070, a wind generating facility located in DeWitt County, Illinois. The AF2-305 and AB2-070 will have a combined total capability of 200 MW with 35.2 MW of this output being recognized by PJM as Capacity. The proposed in-service date for this project is September 1, 2021. This study does not imply a TO commitment to this in-service date.

Queue Number	AF2-305
Project Name	BROKAW-LANESVILLE 345 KV
State	Illinois
County	DeWitt
Transmission Owner	ComEd
MFO	200
MWE	0
MWC	9.2
Fuel	Wind
Basecase Study Year	2023

Any new service customers who can feasibly be commercially operable prior to June 1st of the basecase study year are required to request interim deliverability analysis.

5 Point of Interconnection

AF2-305 will interconnect with the ComEd transmission system at the same Point of Interconnection as prior queue project AB2-070 at ComEd's to be constructed TSS 909 Tabor 345 kV Substation.

6 Cost Summary

The AF2-305 project will be responsible for the following costs:

Description	Cost
Total Physical Interconnection Costs	\$ 0
Allocation towards System Network Upgrade Costs*	\$ 0
Total Costs	\$ 0

*As your project progresses through the study process and other projects modify their request or withdraw, then your cost allocation could change.

This cost excludes a Federal Income Tax Gross Up charges. This tax may or may not be charged based on whether this project meets the eligibility requirements of IRS Notice 88-129. If at a future date it is determined that the Federal Income Tax Gross charge is required, the Transmission Owner shall be reimbursed by the Interconnection Customer for such taxes.

Note 1: PJM Open Access Transmission Tariff (OATT) section 217.3A outline cost allocation rules. The rules are further clarified in PJM Manual 14A Attachment B. The allocation of costs for a network upgrade will start with the first Queue project to cause the need for the upgrade. Later queue projects will receive cost allocation contingent on their contribution to the violation and are allocated to the queues that have not closed less than 5 years following the execution of the first Interconnection Service Agreement which identifies the need for this upgrade.

Note 2: For customers with System Reinforcements listed: If your present cost allocation to a System Reinforcement indicates \$0, then please be aware that as changes to the interconnection process occur, such as prior queued projects withdrawing from the queue, reducing in size, etc, the cost responsibilities can change and a cost allocation may be assigned to your project. In addition, although your present cost allocation to a System Reinforcement is presently \$0, your project may need this system reinforcement completed to be deliverable to the PJM system. If your project comes into service prior to completion of the system reinforcement, an interim deliverability study for your project will be required.

7 Transmission Owner Scope of Work

There is no Transmission Owner scope of work.

8 Schedule

ComEd would take approximately 24-months to construct the AB2-070 substation after the ISA / ICSA are signed.

9 Interconnection Customer Requirements

The Interconnection Customer is responsible for all design and construction related activities on the Interconnection Customer's side of the Point of Interconnection.

10 Revenue Metering and SCADA Requirements

10.1 PJM Requirements

The Interconnection Customer will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See PJM Manuals M-01 and M-14D, and PJM Tariff Section 8 of Attachment O.

10.2 Interconnected Transmission Owner Requirements

The IC will be required to comply with all Interconnected Transmission Owner's revenue metering requirements for generation interconnection customers located at the following link:

ComEd interconnection requirements can be found at <https://www.pjm.com/planning/design-engineering/to-tech-standards/private-comed.aspx>

To the extent that these Applicable Technical Requirements and Standards may conflict with the terms and conditions of the Tariff, the Tariff shall control.

11 Summer Peak Analysis

The Queue Project AF2-305 was evaluated as a 0 MW (Capacity 9.2 MW) injection as an uprate to AB2-070 tapping the Brokaw to Lanesville 345kV line in the ComEd area. Project AF2-305 was evaluated for compliance with applicable reliability planning criteria (PJM, NERC, NERC Regional Reliability Councils, and Transmission Owners). Project AF2-305 was studied with a commercial probability of 100.0 %. Potential network impacts were as follows:

11.1 Generation Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

11.2 Multiple Facility Contingency

(Double Circuit Tower Line, Fault with a Stuck Breaker, and Bus Fault contingencies for the full energy output)

None

11.3 Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

11.4 Steady-State Voltage Requirements

None

11.5 Potential Congestion due to Local Energy Deliverability

PJM also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The developer can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

None

11.6 System Reinforcements

None

12 Short Circuit Analysis

No breakers were identified as overdutied as part of this study.

13 Stability and Reactive Power

Stability Analysis is not required.

14 Affected Systems

14.1 MISO

An Affected System analysis is not required for this project.

Attachment 1: One Line Diagram

AF2-305
PRIMARY POI

